

ENVIRONMENTAL LABWORKS, INC.

July 22, 2025

Saugerties CSD
310 Washington Ave Ext
Saugerties, NY 12477

Dear James,


The following are results of the analyses performed on water samples from **GD Morse Elementary School** received at the laboratory on 06/26/25.

Date/Time Collected: 06/26/25 7:24-7:28am First Draw
Collected By: SCSD
Project ID: 06262529
Secondary ID: ME252440-42

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Cafeteria Bottle Filler 06262529-1	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Main Office Bottle Filler 06262529-2	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Upstairs Bottle Filler 06262529-3	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director