

**ENVIRONMENTAL LABWORKS, INC.**

---

July 22, 2025

Saugerties CSD  
310 Washington Ave Ext  
Saugerties, NY 12477

Dear James,

The following are results of the analyses performed on water samples from **Saugerties High School** received at the laboratory on 06/26/25.

Date/Time Collected: 06/26/25 6:14-7:02am First Draw  
Collected By: SCSD  
Project ID: 06262526  
Secondary ID: HS252400-423

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
HS Right Kettle 06262526-1	EPA 200.8 Lead	0.000449 mg/L		0.005 mg/L	07/15/25
HS Kitchen Ice 06262526-2	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Kitchen Coffee 06262526-3	EPA 200.8 Lead	0.000885 mg/L		0.005 mg/L	07/15/25
JH Cafeteria Bottle Filler 06262526-4	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Cafeteria Bottle Filler 06262526-5	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
JH Gym Bottle Filler 06262526-6	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
JH Office Bottle Filler 06262526-7	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Rm 500 Bottle Filler 06262526-8	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Rm 514 Bottle Filler 06262526-9	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Rm 601C Bottle Filler 06262526-10	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25

**ENVIRONMENTAL LABWORKS, INC.**

**Saugerties High School - 06262526**

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
HS Sports Ice Machine 06262526-11	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Sports Water Jug 06262526-12	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Bottle Filler by 423 06262526-13	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Main Office Bottle Filler 06262526-14	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS 300 Wing Bottle Filler 06262526-15	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Bottle Filler by Rm 14 06262526-16	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS 100 Wing Bottle Filler 06262526-17	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS R.O. 17A 06262526-18	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Weight Rm Bottle Filler 06262526-19	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS Left Kettle 06262526-20	EPA 200.8 Lead	0.00682 mg/L	X	0.005 mg/L	07/15/25
HS Rm 600 Bottle Filler 06262526-21	EPA 200.8 Lead	0.000492 mg/L		0.005 mg/L	07/15/25
HS Rm 614 Bottle Filler 06262526-22	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS 614 R.O. 06262526-23	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25
HS 616 R.O. 06262526-24	EPA 200.8 Lead	<0.00040 mg/L		0.005 mg/L	07/15/25

Qualifier(Q) :

X - Value exceeds Maximum Contaminant Level or Regulatory Level.

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824


**ENVIRONMENTAL LABWORKS, INC.**

---

**Saugerties High School - 06262526**

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director