

ENVIRONMENTAL LABWORKS, INC.

July 22, 2025

Saugerties CSD
310 Washington Ave Ext
Saugerties, NY 12477

Dear James,

The following are results of the analyses performed on water samples from **Cahill Elementary School** received at the laboratory on 06/26/25.

Date/Time Collected: 06/26/25 6:00-6:22am First Draw
Collected By: SCSD
Project ID: 06262527
Secondary ID: CE252424-34

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Nurse Bottle Filler 06262527-1	EPA 200.8 Lead	<0.00080 mg/L	0.005 mg/L	07/15/25
Basement Men Rm Bottle Fill 06262527-2	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Rm 203 Bottle Filler 06262527-3	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Basement Cust. Bottle Filler 06262527-4	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Rm 214 Bottle Filler 06262527-5	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Library Bottle Filler 06262527-6	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Cafeteria Bottle Fill Right 06262527-7	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Cafeteria Bottle Fill Left 06262527-8	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
3 rd Fl Bottle Filler Right 06262527-9	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
3 rd Fl Bottle Filler Left 06262527-10	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25
Rm 108 Bottle Filler 06262527-11	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/15/25


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Cahill Elementary School - 06262527

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director