

**ENVIRONMENTAL LABWORKS, INC.**

July 22, 2025

Saugerties CSD  
310 Washington Ave Ext  
Saugerties, NY 12477

Dear James,


The following are results of the analyses performed on water samples from **Riccardi Elementary School** received at the laboratory on 06/26/25.

Date/Time Collected: 06/26/25 6:30-7:22am First Draw  
Collected By: SCSD  
Project ID: 06262528  
Secondary ID: RE252435-39

| LOCATION/<br>SAMPLE ID                | PARAMETER         | RESULTS       | ACTION LEVEL | ANALYZED |
|---------------------------------------|-------------------|---------------|--------------|----------|
| Rm 128 Bottle Filler<br>06262528-1    | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 07/15/25 |
| Rm 224 Bottle Filler<br>06262528-2    | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 07/15/25 |
| Rm 205 Bottle Filler<br>06262528-3    | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 07/15/25 |
| Rm 124 Bottle Filler<br>06262528-4    | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 07/15/25 |
| Cafeteria Bottle Filler<br>06262528-5 | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 07/15/25 |

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director