Hunterdon Central Regional High School

84 Route 31, Flemington, New Jersey 08822-1239
(908) 782-5727

Jessica Cangelosi-Hade, Superintendent
Edward C. Brandt, Principal

August 2025

Dear Hunterdon Central Regional High School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Hunterdon Central Regional High School tested our schools' drinking water for lead back in May 2025. At that time, one drinking water outlet in the lower level girls locker room tested above the 15 µg/l for lead. That water outlet was immediately shut off and disconnected.

A follow-up sample from that girls locker room water fountain was taken on July 8, 2025. Results found that the water fountain is now below 15 µg/l. Sample results are attached. The fountain is now back in use.

For more information about water quality in our schools, contact Matthew O'Brien at the Hunterdon Central Regional High School Operations Department at 908-284-7170.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at **www.epa.gov/lead**, call the National Lead Information Center at 800-424-LEAD, or contact your healthcare provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Jessica Cangelosi-Hade
Superintendent

ENVIRONMENTAL SERVICES
A Mainline Company

181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:
Hunterdon Central Regional High School

84 Route 31, Flemington, NJ, 08822

Performed For:
Hunterdon Central Regional High School
Matt O'Brien
84 Route 31, Flemington, Nj, 08822

Prepared By:
LEW Environmental Services, LLC.
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website http://www.LEWCorp.com

Inspection Date: 07/08/2025
Project Number: 3492

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Hunterdon Central	7/8/2025	7/17/2025	1	WATER COOL GIRLS LOCKER RM	7.5
Hunterdon Central	7/8/2025	7/17/2025	SR	SUNROOM	<1.00