

Lead in School Drinking Water Report

Martha Lake Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-06-05

Date(s) analyzed: 2025-06-25

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	410929	Unit A - Main Building	Fountain/Tap Combo	Music Room	1 of 1	Tap	center	9
2	410934	Unit A - Main Building	Sink	Library Office/Workroom.	1 of 1	Tap	center	7
3	410953	Unit A - Main Building	Fountain/Tap Combo	Room 103	1 of 1	Tap	center	7
4	410959	Unit A - Main Building	Fountain/Tap Combo	Room 113	1 of 1	Tap	center	6
5	410364	Unit A - Main Building	Fountain/Tap Combo	Room 211	1 of 1	Water Fountain	right	5
6	410926	Unit A - Main Building	Sink - Multi-Compartment	Kitchen	1 of 1. Vegetable/fruit prep	Tap	left	5
7	410943	Unit A - Main Building	Fountain/Tap Combo	Room 108	1 of 1	Tap	center	5
8	410937	Unit A - Main Building	Fountain/Tap Combo	Room 111	1 of 1	Tap	center	4
9	410941	Unit A - Main Building	Fountain/Tap Combo	Room 109	1 of 1	Tap	center	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
10	410365	Unit A - Main Building	Fountain/Tap Combo	Room 210	1 of 1	Tap	center	3
11	410381	Unit A - Main Building	Fountain/Tap Combo	Room 202	1 of 1	Tap	center	3
12	410935	Unit A - Main Building	Fountain/Tap Combo	Room 112	1 of 1	Tap	center	3
13	410939	Unit A - Main Building	Fountain/Tap Combo	Room 110	1 of 1	Tap	center	3
14	410945	Unit A - Main Building	Fountain/Tap Combo	Room 107	1 of 1	Tap	center	3
15	410361	Unit A - Main Building	Fountain/Tap Combo	Room 212	1 of 1	Tap	center	2
16	410363	Unit A - Main Building	Fountain/Tap Combo	Room 211	1 of 1	Tap	center	2
17	410367	Unit A - Main Building	Fountain/Tap Combo	Room 207	1 of 1	Tap	center	2
18	410369	Unit A - Main Building	Fountain/Tap Combo	Room 208	1 of 1	Tap	center	2
19	410371	Unit A - Main Building	Fountain/Tap Combo	Room 209	1 of 1	Tap	center	2
20	410373	Unit A - Main Building	Fountain/Tap Combo	Room 206	1 of 1	Tap	center	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
21	410375	Unit A - Main Building	Fountain/Tap Combo	Room 205	1 of 1	Tap	center	2
22	410377	Unit A - Main Building	Fountain/Tap Combo	Room 204	1 of 1	Tap	center	2
23	410383	Unit A - Main Building	Fountain/Tap Combo	Room 201	1 of 1	Tap	center	2
24	410932	Unit A - Main Building	Sink	Work Room	1 of 1	Tap	center	2
25	410951	Unit A - Main Building	Fountain/Tap Combo	Room 104	1 of 1	Tap	center	2
26	410384	Unit A - Main Building	Fountain/Tap Combo	Room 201	1 of 1	Water Fountain	right	1
27	410930	Unit A - Main Building	Fountain/Tap Combo	Music Room	1 of 1	Water Fountain	right	1
28	410931	Unit A - Main Building	Sink	Nurses Office	1 of 1	Tap	center	1
29	410947	Unit A - Main Building	Fountain/Tap Combo	Room 106	1 of 1	Tap	center	1
30	410955	Unit A - Main Building	Fountain/Tap Combo	Room 102	1 of 1	Tap	center	1
31	410957	Unit A - Main Building	Fountain/Tap Combo	Room 101	1 of 1	Tap	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
32	410360	Unit A - Main Building	Fountain/Tap Combo	Room 113	1 of 1	Water Fountain	right	<1
33	410362	Unit A - Main Building	Fountain/Tap Combo	Room 212	1 of 1	Water Fountain	right	<1
34	410366	Unit A - Main Building	Fountain/Tap Combo	Room 210	1 of 1	Water Fountain	right	<1
35	410368	Unit A - Main Building	Fountain/Tap Combo	Room 207	1 of 1	Water Fountain	right	<1
36	410370	Unit A - Main Building	Fountain/Tap Combo	Room 208	1 of 1	Water Fountain	right	<1
37	410372	Unit A - Main Building	Fountain/Tap Combo	Room 209	1 of 1	Water Fountain	right	<1
38	410374	Unit A - Main Building	Fountain/Tap Combo	Room 206	1 of 1	Water Fountain	right	<1
39	410376	Unit A - Main Building	Fountain/Tap Combo	Room 205	1 of 1	Water Fountain	right	<1
40	410378	Unit A - Main Building	Fountain/Tap Combo	Room 204	1 of 1	Water Fountain	right	<1
41	410379	Unit A - Main Building	Fountain/Tap Combo	Room 203	1 of 1	Tap	center	<1
42	410380	Unit A - Main Building	Fountain/Tap Combo	Room 203	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
43	410382	Unit A - Main Building	Fountain/Tap Combo	Room 202	1 of 1	Water Fountain	right	<1
44	410927	Unit A - Main Building	Fountain with Bottle Filler	Front Entrance Fountain	1 of 1	Water Bottle Filler	center	<1
45	410928	Unit A - Main Building	Fountain with Bottle Filler	Front Entrance Fountain	1 of 1	Water Fountain	right	<1
46	410933	Unit A - Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
47	410936	Unit A - Main Building	Fountain/Tap Combo	Room 112	1 of 1	Water Fountain	right	<1
48	410938	Unit A - Main Building	Fountain/Tap Combo	Room 111	1 of 1	Water Fountain	right	<1
49	410940	Unit A - Main Building	Fountain/Tap Combo	Room 110	1 of 1	Water Fountain	right	<1
50	410942	Unit A - Main Building	Fountain/Tap Combo	Room 109	1 of 1	Water Fountain	right	<1
51	410944	Unit A - Main Building	Fountain/Tap Combo	Room 108	1 of 1	Water Fountain	right	<1
52	410946	Unit A - Main Building	Fountain/Tap Combo	Room 107	1 of 1	Water Fountain	right	<1
53	410948	Unit A - Main Building	Fountain/Tap Combo	Room 106	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
54	410949	Unit A - Main Building	Fountain/Tap Combo	Room 105	1 of 1	Tap	center	<1
55	410950	Unit A - Main Building	Fountain/Tap Combo	Room 105	1 of 1	Water Fountain	right	<1
56	410952	Unit A - Main Building	Fountain/Tap Combo	Room 104	1 of 1	Water Fountain	right	<1
57	410954	Unit A - Main Building	Fountain/Tap Combo	Room 103	1 of 1	Water Fountain	right	<1
58	410956	Unit A - Main Building	Fountain/Tap Combo	Room 102	1 of 1	Water Fountain	right	<1
59	410958	Unit A - Main Building	Fountain/Tap Combo	Room 101	1 of 1	Water Fountain	right	<1