

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-001/Main Office Lav Sink Lims Reference ID: AD27005-01 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-002/Principle Lav Sink Lims Reference ID: AD27005-02 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-003/Nurs Sink Lims Reference ID: AD27005-03 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	1.66		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-004/Nurse Lav Sink Lims Reference ID: AD27005-04 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	1.14		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-005/Media Work Rm 401 Sink Lims Reference ID: AD27005-05 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-006/110 Sink Lims Reference ID: AD27005-06 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	12.9		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-007/112 Sink Lims Reference ID: AD27005-07 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	1.76		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-008/112 Lav Sink Lims Reference ID: AD27005-08 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-009/113 Sink Lims Reference ID: AD27005-09 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-009/113 Sink (Continued) Lims Reference ID: AD27005-09 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals (Continued)									
Lead	1.36		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-010/113 Lav Sink Lims Reference ID: AD27005-10 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	4.81		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-011/114 Sink Lims Reference ID: AD27005-11 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	2.16		1	1.00	µg/L	07/10/25 15:21	07/14/25 13:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-012/114 Lav Sink Lims Reference ID: AD27005-12 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	1.23		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-013/115 Sink Lims Reference ID: AD27005-13 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	3.75		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-014/115 Lav Sink Lims Reference ID: AD27005-14 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	3.60		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-015/116 Sink Lims Reference ID: AD27005-15 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	6.24		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-016/116 Lav Sink Lims Reference ID: AD27005-16 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	1.19		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-017/117 Sink Lims Reference ID: AD27005-17 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-017/117 Sink (Continued) Lims Reference ID: AD27005-17 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals (Continued)									
Lead	13.4		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-018/117 Lav Sink Lims Reference ID: AD27005-18 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	5.35		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-019/118 Sink Lims Reference ID: AD27005-19 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	3.37		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-020/118 Lav Sink Lims Reference ID: AD27005-20 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	1.80		1	1.00	µg/L	07/10/25 15:21	07/14/25 14:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-021/119 Sink Lims Reference ID: AD27005-21 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	3.19		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-022/119 Lav Sink Lims Reference ID: AD27005-22 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	3.14		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-023/201 Sink Lims Reference ID: AD27005-23 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	10.1		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-024/Corridor Bottle Filler by 202 Lims Reference ID: AD27005-24 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-025/202 Sink Lims Reference ID: AD27005-25 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: HH-025/202 Sink (Continued)

Lims Reference ID: AD27005-25 Matrix: Drinking Water

Sampled: 06/18/25 07:00:00

Metals (Continued)

Lead	1.78		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:47	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-026/202 Lav Sink

Lims Reference ID: AD27005-26 Matrix: Drinking Water

Sampled: 06/18/25 07:00:00

Metals

Lead	1.09		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:53	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-027/204 Sink

Lims Reference ID: AD27005-27 Matrix: Drinking Water

Sampled: 06/18/25 07:00:00

Metals

Lead	2.52		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:55	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-028/Girls Gang Lav Sink #1 Left

Lims Reference ID: AD27005-28 Matrix: Drinking Water

Sampled: 06/18/25 07:00:00

Metals

Lead	1.18		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:57	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-029/Girls Gang Lav Sink #2

Lims Reference ID: AD27005-29 Matrix: Drinking Water

Sampled: 06/18/25 07:00:00

Metals

Lead	ND		1	1.00	µg/L	07/10/25 15:16	07/14/25 14:59	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-030/Girls Gang Lav Sink #3

Lims Reference ID: AD27005-30 Matrix: Drinking Water

Sampled: 06/18/25 07:00:00

Metals

Lead	ND		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:01	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-031/Girls Gang Lav Sink #4 Right

Lims Reference ID: AD27005-31 Matrix: Drinking Water

Sampled: 06/18/25 07:30:00

Metals

Lead	ND		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:03	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-032/Boys Gang Lav Sink #1 Left

Lims Reference ID: AD27005-32 Matrix: Drinking Water

Sampled: 06/18/25 07:30:00

Metals

Lead	ND		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:08	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: HH-033/Boys Gang Lav Sink #2

Lims Reference ID: AD27005-33 Matrix: Drinking Water

Sampled: 06/18/25 07:30:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-033/Boys Gang Lav Sink #2 (Continued) Lims Reference ID: AD27005-33 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-034/Boys Gang Lav Sink #3 Lims Reference ID: AD27005-34 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-035/Boys Gang Lav Sink #4 Lims Reference ID: AD27005-35 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	2.40		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-036/205 Sink Lims Reference ID: AD27005-36 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	2.02		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-037/205 Sink Lims Reference ID: AD27005-37 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	1.96		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-038/206 Sink Lims Reference ID: AD27005-38 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	3.55		1	1.00	µg/L	07/10/25 15:40	07/11/25 16:00	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: HH-039/208 Sink Lims Reference ID: AD27005-39 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	5.55		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-040/210 Sink Lims Reference ID: AD27005-40 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	1.44		1	1.00	µg/L	07/10/25 15:16	07/14/25 15:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-041/207 Sink Lims Reference ID: AD27005-41 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-041/207 Sink (Continued) Lims Reference ID: AD27005-41 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals (Continued)									
Lead	3.23		1	1.00	µg/L	07/11/25 11:28	07/14/25 15:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-042/209 Sink Lims Reference ID: AD27005-42 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									
Lead	1.70		1	1.00	µg/L	07/11/25 11:28	07/14/25 15:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-043/212 Sink Lims Reference ID: AD27005-43 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									
Lead	2.23		1	1.00	µg/L	07/11/25 11:28	07/14/25 15:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-044/214 Sink Lims Reference ID: AD27005-44 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									
Lead	4.39		1	1.00	µg/L	07/11/25 11:28	07/14/25 15:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-045/216 Sink Lims Reference ID: AD27005-45 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									
Lead	87.3	D	5	5.00	µg/L	07/15/25 16:46	07/16/25 15:15	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: HH-046/218 Sink Lims Reference ID: AD27005-46 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									
Lead	2.73		1	1.00	µg/L	07/11/25 11:28	07/14/25 15:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-047/213 Sink Lims Reference ID: AD27005-47 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-048/Woman Gang Lav Sink Left Lims Reference ID: AD27005-48 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-049/Woman Gang Lav Sink Right Lims Reference ID: AD27005-49 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-049/Woman Gang Lav Sink Right (Continued) Lims Reference ID: AD27005-49 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-050/Mens Gang Lav Sink Left Lims Reference ID: AD27005-50 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-051/Mens Gang Lav Sink Right Lims Reference ID: AD27005-51 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	3.64		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-052/315 Sink Left Lims Reference ID: AD27005-52 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	6.44		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-053/315 Sink Right Lims Reference ID: AD27005-53 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	26.6		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-054/314 Sink Left Lims Reference ID: AD27005-54 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	7.21		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-055/314 Sink Right Lims Reference ID: AD27005-55 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	3.15		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-056/313 Sink Left Lims Reference ID: AD27005-56 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	83.1		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-057/313 Sink Right Lims Reference ID: AD27005-57 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-057/313 Sink Right (Continued) Lims Reference ID: AD27005-57 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	4.21		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-058/312 Sink Left Lims Reference ID: AD27005-58 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	5.54		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-059/312 Sink Right Lims Reference ID: AD27005-59 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	16.5		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-060/311 Sink Left Lims Reference ID: AD27005-60 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	8.80		1	1.00	µg/L	07/11/25 11:28	07/14/25 16:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-061/311 Sink right Lims Reference ID: AD27005-61 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	11.3		1	1.00	µg/L	07/10/25 17:36	07/14/25 16:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-062/310 Sink Left Lims Reference ID: AD27005-62 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	4.60		1	1.00	µg/L	07/10/25 17:36	07/14/25 16:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-063/310 Sink Right Lims Reference ID: AD27005-63 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	7.65		1	1.00	µg/L	07/10/25 17:36	07/14/25 16:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-064/309 Sink Left Lims Reference ID: AD27005-64 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	8.96		1	1.00	µg/L	07/10/25 17:36	07/14/25 16:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-065/309 Sink Right Lims Reference ID: AD27005-65 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-065/309 Sink Right (Continued) Lims Reference ID: AD27005-65 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals (Continued)									
Lead	57.0		1	1.00	µg/L	07/10/25 17:36	07/14/25 16:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-066/308 Sink Left Lims Reference ID: AD27005-66 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	9.84		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-067/308 Sink Right Lims Reference ID: AD27005-67 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	6.08		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-068/307 Sink Left Lims Reference ID: AD27005-68 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	6.72		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-069/307 Sink Right Lims Reference ID: AD27005-69 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	2.30		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-070/306 Sink Left Lims Reference ID: AD27005-70 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	4.01		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-071/306 Sink Right Lims Reference ID: AD27005-71 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	15.2		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-072/305 Sink Lims Reference ID: AD27005-72 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	21.6		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-073/Staff Women Lav Sink (Single) Lims Reference ID: AD27005-73 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-073/Staff Women Lav Sink (Single) (Continued) Lims Reference ID: AD27005-73 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals (Continued)									
Lead	3.04		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-074/Staff Men Lav Sink (Single) Lims Reference ID: AD27005-74 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	7.26		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-075/Boys Gang Lav Sink #1 Left (by 303) Lims Reference ID: AD27005-75 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.05		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-076/Boys Gang Lav Sink #2 M (by 303) Lims Reference ID: AD27005-76 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.30		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-077/Boys Gang Lav Sink #3 Right (by 303) Lims Reference ID: AD27005-77 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.03		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-078/Girls Gang Lav Sink #1 Left (by 303) Lims Reference ID: AD27005-78 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.56		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-079/Girls Gang Lav Sink #2 M (by 303) Lims Reference ID: AD27005-79 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.72		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-080/Girls Gang Lav Sink #3 Right (by 303) Lims Reference ID: AD27005-80 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	2.00		1	1.00	µg/L	07/10/25 17:36	07/14/25 17:35	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:**

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-081/Bottle Filler by 301 Faculty Break Rm Lims Reference ID: AD27005-81 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-082/Faculty Break Rm Sink Lims Reference ID: AD27005-82 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-083/Boys Gym Locker Sink #1 Lims Reference ID: AD27005-83 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	5.98		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-084/Boys Gym Locker Sink #2 Lims Reference ID: AD27005-84 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	5.91		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-085/Girls Gym Locker Sink #1 Lims Reference ID: AD27005-85 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	3.60		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-086/Girls Gym Locker Sink #2 Lims Reference ID: AD27005-86 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	5.27		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-087/Kitchen Hand Sink by Dishwasher Lims Reference ID: AD27005-87 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	9.51		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-088/Kitchen Lav Sink Lims Reference ID: AD27005-88 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	20.7		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-089/Triple Sink Lims Reference ID: AD27005-89 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Harris Hill Elementary (HH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:35**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HH-089/Triple Sink (Continued) Lims Reference ID: AD27005-89 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-090/Serve Line Sink Lims Reference ID: AD27005-90 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	6.74		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-091/Hand Sink by Serve Line Lims Reference ID: AD27005-91 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.65		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HH-092/Bottle Filler in Cafeteria Lims Reference ID: AD27005-92 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:37	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005

LIMS Reference ID: AD27005

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name:

Clarence CSD - Harris Hill Elementary (HH)

Project ID:

_Master Project-CLCS25

Customer PO:**Sales Rep:**

David Prince

Received:

07/07/2025 09:35

Reported:**Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012527005**LIMS Reference ID:** AD27005**EMSL Customer ID:** CLCS25**Attention:** Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name:

Clarence CSD - Harris Hill Elementary (HH)

Project ID:

_Master Project-CLCS25

Customer PO:**Sales Rep:**

David Prince

Received:

07/07/2025 09:35

Reported:

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AD27005

Customer Information		Billing Information	
Customer ID:		Billing ID:	
Company Name: Clarence Central School District		Company Name: Same as Left	
Contact Name: Brian Logel		Billing Contact:	
Street Address: 9625 main Street		Street Address:	
City, State, Zip: Clarence, NY 14031 Country: USA		City, State, Zip: Country:	
Phone: 716-407-9131		Phone:	
Email(s) for Report: Blogel@clarenceschools.org		Email(s) for Invoice:	
Project Information			
Project Name/No: Clarence CSD - Harris Hill Elementary (HH)		Purchase Order:	
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected: NY State of Connecticut (CT) must select project location:	
Sampled By Name: Brian Logel		☐ Commercial (Taxable) ☐ Residential (Non-Taxable)	
Sampled By Signature: [Signature]		No. of Samples in Shipment:	
Turn-Around-Time (TAT)			
☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☒ 2 Week			
Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.			
MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm ²	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)
Reporting Limit based on a minimum 0.25g sample weight.	SW 846-6010D	ICP-OES	0.0004% (4ppm)
**Not appropriate for Ceramic Tiles - XRF is recommended	NIOSH 7082	Flame Atomic Absorption	4µg/filter
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe
If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D	ICP-OES	1.0µg/wipe
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
Unpreserved ☐	EPA 200.7	ICP-OES	0.020 mg/L (ppm)
Preserved with HNO ₃ ☐ PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)
Drinking Water	EPA 200.8	ICP-MS	0.001 mg/L (ppm)
Unpreserved ☐			
Preserved with HNO ₃ ☒ PH<2			
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter
Other:			
Sample Number	Sample Location	Volume / Area	Date / Time Sampled
HH-001 Up To	See Attached Sheets		6/18/25
HH-092	See Attached Sheets		
Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by: Brian Logel	Date/Time: 7/01/25, 5pm	Relinquished by: [Signature]	Date/Time: 7/01/25 0935
Relinquished by:	Date/Time:	Received by:	Date/Time:

UPS# 1Z 55A V35 03 9388 5983

UPS# 1Z 55A V35 03 9457 1345
UPS# 1Z 55A V35 03 9480 1959

Box #1

*6010C Available Upon Request

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 1 of 2

AD27005

Clare, Central

Building: Harris Hill		FIRST DRAW										
SAMPLE NUMBER	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
HH-001 1	6/18/25	6:00am	Main Office Lav Sink				✓					
HH-002 2	6/18/25		Principal Lav Sink				✓					
HH-003 3	6/18/25		Nurs Sink				✓					
HH-004 4	6/18/25		Nurse Lav Sink				✓					
HH-005 5	6/18/25		Media Work Rm 401 Sink				✓					
HH-006 6 LAV	6/18/25		110 Sink				✓					
HH-007 7	6/18/25		112 Sink				✓					
HH-008 8	6/18/25		112 Lav Sink				✓					
HH-009 9	6/18/25		113 Sink				✓					
HH-010 10	6/18/25		113 Lav Sink				✓					
HH-011 11	6/18/25	6:30am	114 sink				✓					
HH-012 12	6/18/25		114 Lav Sink				✓					
HH-013 13	6/18/25		115 Sink				✓					
HH-014 14	6/18/25		115 Lav Sink				✓					
HH-015 15	6/18/25		116 Sink				✓					
HH-016 16	6/18/25		116 Lav Sink				✓					
HH-017 17	6/18/25		117 Sink				✓					
HH-018 18	6/18/25		117 Lav Sink				✓					

COMPLIANCE YEAR: 2016

A127005

Clare, Central

Building		FIRST											
DRAW		DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
SAMPLE NUMBER													
HH-019	14	6/18/25		118 Sink				✓					
HH-020	20	6/18/25		118 Lav Sink				✓					
HH-021	21	6/18/25	7:00am	119 Sink				✓					
HH-022	21	6/18/25		119 Lav Sink				✓					
HH-023	23	6/18/25		201 Sink				✓					
HH-024	24	6/18/25		Corridor Bottle Filler by 202		✓							
HH-025	25	6/18/25		202 Sink				✓					
HH-026	26	6/18/25		202 Lav Sink				✓					
HH-027	27	6/18/25		204 Sink				✓					
HH-028	28	6/18/25		Girls Gang Lav Sink #1 Left				✓					
HH-029	29	6/18/25		Girls Gang Lav Sink #2				✓					
HH-030	30	6/18/25		Girls Gang Lav Sink #3				✓					
HH-031	31	6/18/25	7:30am	Girls Gang Lav Sink #4 Right				✓					
HH-032	22	6/18/25		Boys Gang Lav Sink #1 Left				✓					
HH-033	33	6/18/25		Boys Gang Lav Sink #2				✓					
HH-034	34	6/18/25		Boys Gang Lav Sink #3				✓					
HH-035	35	6/18/25		Boys Gang Lav Sink #4 Right				✓					
HH-036	36	6/18/25		203 Sink				✓					

COMPLIANCE YEAR: 2016

AD27005

Clare, Central

Building	FIRST											
	DRAW	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)
SAMPLE NUMBER												RESULT ppb
HH-037	37	6/18/25		205 Sink				✓				
HH-038	38	6/18/25		206 Sink				✓				
HH-039	39	6/18/25		208 Sink				✓				
HH-040	40	6/18/25		210 Sink								
HH-041	41	6/18/25	8:00am	207 Sink								
HH-042	42	6/18/25		209 Sink								
HH-043	43	6/18/25		212 Sink								
HH-044	44	6/18/25		214 Sink								
HH-045	45	6/18/25		216 Sink								
HH-046	46	6/18/25		218 Sink								
HH-047	47	6/18/25		213 Sink								
HH-048	48	6/18/25		Women Gang Lav Sink Left								
HH-049	49	6/18/25		Women Gang Lav Sink Right								
HH-050	50	6/18/25	8:30am	Mens Gang Lav Sink Left								
HH-051	51	6/18/25		Mens Gang Lav Sink Right								
HH-052	52	6/18/25		315 Sink Left								
HH-053	53	6/18/25		315 Sink Right								
HH-054	54	6/18/25		314 Sink Left								

COMPLIANCE YEAR: 2016

AD27005

Claren, Central

Building		FIRST												
DRAW		DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb	
SAMPLE NUMBER														
HH-055	55	6/18/25		314 Sink Right				X						
HH-056	56	6/18/25		313 Sink Left				X						
HH-057	57	6/18/25		313 Sink Right				X						
HH-058	58	6/18/25		312 Sink Left				X						
HH-059	59	6/18/25		312 Sink Right				X						
HH-060	60	6/18/25		311 Sink Left				X						
HH-061	61	6/18/25		311 Sink Right				X						
HH-062	62	6/18/25		310 Sink Left				X						
HH-063	63	6/18/25		310 Sink Right				X						
HH-064	64	6/18/25		309 Sink Left				X						
HH-065	65	6/18/25		309 Sink Right				X						
HH-066	66	6/18/25		308 Sink Left				X						
HH-067	67	6/18/25		308 Sink Right				X						
HH-068	68	6/18/25		307 Sink Left				X						
HH-069	69	6/18/25		307 Sink Right				X						
HH-070	70	6/18/25		306 Sink Left				X						
HH-071	71	6/18/25		306 Sink Right				X						
HH-072	72	6/18/25		305 Sink				X						

COMPLIANCE YEAR: 2016

11/27/05

Clare, Central

Building		FIRST DRAW										
SAMPLE NUMBER	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
HH-073	73	6/18/25	Staff Women Lav Sink (Single)				X					
HH-074	74	6/18/25	Staff Men Lav Sink (Single)				X					
HH-075	75	6/18/25	Boys Gang Lav Sink #1 Left (by 303)				X					
HH-076	76	6/18/25	Boys Gang Lav Sink #2 M (by 303)				X					
HH-077	77	6/18/25	Boys Gang Lav Sink #3 K. (by 303)				X					
HH-078	78	6/18/25	Girls Gang Lav Sink #1 Left (by 303)				X					
HH-079	79	6/18/25	Girls Gang Lav Sink #2 M (by 303)				X					
HH-080	80	6/18/25	Girls Gang Lav Sink #3 K (by 303)				X					
HH-081	81	6/18/25	Bottle Filler by 301 Faculty Break Rm		X		X					
HH-082	82	6/18/25	Faculty Break Room Sink				X					
HH-083	83	6/18/25	Boys Gym Locker Sink #1				X					
HH-084	84	6/18/25	Boys Gym Locker Sink #2				X					
HH-085	85	6/18/25	Girls Gym Locker Sink #1				X					
HH-086	86	6/18/25	Girls Gym Locker Sink #2				X					
HH-087	87	6/18/25	Kitchen Hand Sink by Dishwasher				X					
HH-088	88	6/18/25	Kitchen Lav Sink				X					
HH-089	89	6/18/25	Triple Sink				X					
HH-090	90	6/18/25	Serve Line sink				X					

COMPLIANCE YEAR: 2016

Clare, Central

[illegible]