

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-001/Tech Bathroom Lims Reference ID: AD26962-01 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-002/Sink Near Print Shop Lims Reference ID: AD26962-02 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	5.82		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-003/Womens Lav by Sink by Print Shop Lims Reference ID: AD26962-03 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	1.06		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-004/Mens Lav by Sink by Print Shop Lims Reference ID: AD26962-04 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-005/Bottle Filler by Print Shop Lims Reference ID: AD26962-05 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-006/Bottle Filler by 508 Lims Reference ID: AD26962-06 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-007/503 Sink Lims Reference ID: AD26962-07 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-008/Girls 500 Lav Left Sink Lims Reference ID: AD26962-08 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 17:03	07/15/25 08:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-009/Girls Lav Center Sink Lims Reference ID: AD26962-09 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-009/Girls Lav Center Sink (Continued) Lims Reference ID: AD26962-09 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-010/Girls Lav Right Sink Lims Reference ID: AD26962-10 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-011/Boys 500 Lav Left Sink Lims Reference ID: AD26962-11 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	1.13		1	1.00	µg/L	07/15/25 16:46	07/16/25 14:36	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: HS-012/Boys Lav Center Sink Lims Reference ID: AD26962-12 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/15/25 16:46	07/16/25 14:39	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: HS-013/Boys Lav Right Sink Lims Reference ID: AD26962-13 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-014/Faculty Womens Sink Lims Reference ID: AD26962-14 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/15/25 16:46	07/16/25 14:45	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: HS-015/Handicap Sink Lims Reference ID: AD26962-15 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-016/Womens Faculty by 411 Left Sink Lims Reference ID: AD26962-16 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	9.40		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-017/Womens Faculty by 411 Center Sink Lims Reference ID: AD26962-17 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-017/Womens Faculty by 411 Center Sink (Continued) Lims Reference ID: AD26962-17 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals (Continued)									
Lead	18.6		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-018/Womens Faculty by 411 Right Sink Lims Reference ID: AD26962-18 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	13.9		1	1.00	µg/L	07/15/25 16:46	07/16/25 14:54	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: HS-019/Mens Faculty by 411 Left Sink Lims Reference ID: AD26962-19 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	6.99		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-020/Mens Faculty by 411 Left Center Sink Lims Reference ID: AD26962-20 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	7.93		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-021/Mens Faculty by 411 Right Center Sink Lims Reference ID: AD26962-21 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-022/Mens Faculty by 411 Right Sink Lims Reference ID: AD26962-22 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	14.1		1	1.00	µg/L	07/14/25 15:42	07/15/25 10:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-023/Unisex Single by 404 sink Lims Reference ID: AD26962-23 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	11.9		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-024/Unisex Single by 401 sink Lims Reference ID: AD26962-24 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	8.32		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:22	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-025/Superintendent Lav Sink Lims Reference ID: AD26962-25 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-026/Dist Office Kitchen Sink Lims Reference ID: AD26962-26 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-027/District Office Mens Sink Left Lims Reference ID: AD26962-27 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	6.50		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-028/District Office Mens Sink Right Lims Reference ID: AD26962-28 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	13.7		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-029/District Office Womens Sink Left Lims Reference ID: AD26962-29 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	3.50		1	1.00	µg/L	07/11/25 12:35	07/14/25 17:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-030/District Office Womens Sink Right Lims Reference ID: AD26962-30 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	1.21		1	1.00	µg/L	07/11/25 12:35	07/14/25 17:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-031/Dist. Offc. Basemnt Bottle Filler Lims Reference ID: AD26962-31 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-032/2nd Flr Bottle Filler by boys gang lav Lims Reference ID: AD26962-32 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-034/2nd Flr Girls Lav Sink #1 (left most) Lims Reference ID: AD26962-34 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-034/2nd Flr Girls Lav Sink #1 (left most) (Continued) Lims Reference ID: AD26962-34 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	9.10		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-035/2nd Flr Girls Lav Sink #2 Lims Reference ID: AD26962-35 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	2.99		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-036/2nd Flr Girls Lav Sink #3 Lims Reference ID: AD26962-36 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	2.61		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-037/2nd Flr Girls Lav Sink #4 Lims Reference ID: AD26962-37 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	4.03		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-038/2nd Flr Girls Lav Sink #5 Lims Reference ID: AD26962-38 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	5.06		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-040/2nd flr Bottle Filler by Scaff gang lav Lims Reference ID: AD26962-39 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-041/2nd flr Men Staff Gang Lav Sink Left Lims Reference ID: AD26962-40 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-042/2nd flr Men Staff Gang Lav Sink Right Lims Reference ID: AD26962-41 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-043/2nd Flr Women Staff Lav Sink Left Lims Reference ID: AD26962-42 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-043/2nd Flr Women Staff Lav Sink Left (Continued) Lims Reference ID: AD26962-42 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-044/2nd Flr Women Staff Lav Sink Right Lims Reference ID: AD26962-43 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-051/Boys Team Rm Sink Lims Reference ID: AD26962-50 Matrix: Drinking Water Sampled: 06/13/25 08:30:00									
Metals									
Lead	1.64		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-052/Boys Gym Locker Sink Left Lims Reference ID: AD26962-51 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-053/Boys Gym Locker Sink Right Lims Reference ID: AD26962-52 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-054/Gym Office Lav Sink Lims Reference ID: AD26962-53 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-055/Girls Team Room Sink Left Lims Reference ID: AD26962-54 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	1.59		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-056/Girls Team Room Sink Right Lims Reference ID: AD26962-55 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 12:35	07/14/25 18:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-057/Trainer Rm Sink Lims Reference ID: AD26962-56 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-057/Trainer Rm Sink (Continued) Lims Reference ID: AD26962-56 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 18:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-058/Girls Gym Locker Sink Left Lims Reference ID: AD26962-57 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-059/Girls Gym Locker Sink Center Lims Reference ID: AD26962-58 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-060/Girls Gym Locker Sink Right Lims Reference ID: AD26962-59 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-061/Gym Girls Office Lav Sink Lims Reference ID: AD26962-60 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-069/Rm 330 Fountain Lims Reference ID: AD26962-61 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-070/Unisex Lav Sink by 332 Lims Reference ID: AD26962-62 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-071/Unisex Lav Sink by 326 Lims Reference ID: AD26962-63 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-076/Rm 326 Boys Lav Sink Lims Reference ID: AD26962-64 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-076/Rm 326 Boys Lav Sink (Continued) Lims Reference ID: AD26962-64 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-077/Rm 326 Girls Lav Sink Lims Reference ID: AD26962-65 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-078/Rm 326 Utility Sink Lims Reference ID: AD26962-66 Matrix: Drinking Water Sampled: 06/13/25 07:00:00									
Metals									
Lead	8.15		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-081/Mens Faculty by Big Stair Lav Sink Left Lims Reference ID: AD26962-67 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-082/Mens Faculty by Big Stair Lav Sink Right Lims Reference ID: AD26962-68 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-083/Womens by Big Stair Lav Sink Left Lims Reference ID: AD26962-69 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-084/Womens by Big Stair Lav Sink Right Lims Reference ID: AD26962-70 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-089/Back Stage Utility Sink Lims Reference ID: AD26962-71 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	7.65		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-090/Back Stage Lav Sink Lims Reference ID: AD26962-72 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-090/Back Stage Lav Sink (Continued) Lims Reference ID: AD26962-72 Matrix: Drinking Water Sampled: 06/13/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-095/Fountain by Gym Lims Reference ID: AD26962-73 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-096/Rm 325 Sink Lims Reference ID: AD26962-74 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-078A/326 Fountain Lims Reference ID: AD26962-78 Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 14:24	07/14/25 19:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-100/Wood Shop Lav Sink Lims Reference ID: AD26962-79 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	10.3		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-101/Wood Shop Utility Sink Lims Reference ID: AD26962-80 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-102/138 lab Sink Lims Reference ID: AD26962-81 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	7.10		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-103/Basement Art Rm 140 Sink Left Lims Reference ID: AD26962-82 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	5.84		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-104/Basement Art Rm 140 Sink Right Lims Reference ID: AD26962-83 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-104/Basement Art Rm 140 Sink Right (Continued)									
		Lims Reference ID:		AD26962-83		Matrix: Drinking Water		Sampled: 06/13/25 06:00:00	
Metals (Continued)									
Lead	4.17		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-105/Rm 125 Office Sink									
		Lims Reference ID:		AD26962-84		Matrix: Drinking Water		Sampled: 06/13/25 06:00:00	
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-106/Rm 132 Art Front Left Sink									
		Lims Reference ID:		AD26962-85		Matrix: Drinking Water		Sampled: 06/13/25 06:00:00	
Metals									
Lead	3.29		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-107/Rm 132 Art Front Right Sink									
		Lims Reference ID:		AD26962-86		Matrix: Drinking Water		Sampled: 06/13/25 06:00:00	
Metals									
Lead	1.56		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-109/Rm 130 Art Front Left Sink									
		Lims Reference ID:		AD26962-88		Matrix: Drinking Water		Sampled: 06/13/25 06:00:00	
Metals									
Lead	7.44		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-110/Rm 130 Art Front Right Sink									
		Lims Reference ID:		AD26962-89		Matrix: Drinking Water		Sampled: 06/13/25 06:30:00	
Metals									
Lead	2.96		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-111/Rm 130 Art Rear Left Sink									
		Lims Reference ID:		AD26962-90		Matrix: Drinking Water		Sampled: 06/13/25 06:30:00	
Metals									
Lead	3.69		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-112/Rm 130 Art Rear Right Sink									
		Lims Reference ID:		AD26962-91		Matrix: Drinking Water		Sampled: 06/13/25 06:30:00	
Metals									
Lead	309	D	5	5.00	µg/L	07/11/25 16:04	07/15/25 07:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-115/Bottle Filler by Elevator 1st Flr									
		Lims Reference ID:		AD26962-94		Matrix: Drinking Water		Sampled: 06/13/25 06:30:00	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-115/Bottle Filler by Elevator 1st Flr (Continued) Lims Reference ID: AD26962-94 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	5.82		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-116/Guidance Break Room Sink Lims Reference ID: AD26962-95 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-117/Men Faculty Sink Left Lims Reference ID: AD26962-96 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-118/Men Faculty Sink Right Lims Reference ID: AD26962-97 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-119/Women Faculty Sink Left Lims Reference ID: AD26962-98 Matrix: Drinking Water Sampled: 06/13/25 06:30:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-120/Women Faculty Sink Right Lims Reference ID: AD26962-99 Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-121/Girls Gang Lav by Nurse Sink #1 (left) Lims Reference ID: AD26962-AA Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	4.86		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-122/Girls Gang Lav by Nurse Sink #2 Lims Reference ID: AD26962-AB Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	3.60		1	1.00	µg/L	07/11/25 16:04	07/14/25 20:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-123/Girls Gang Lav by Nurse Sink #3 Lims Reference ID: AD26962-AC Matrix: Drinking Water Sampled: 06/13/25 06:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-123/Girls Gang Lav by Nurse Sink #3 (Continued) Lims Reference ID: AD26962-AC Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	2.81		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-124/Girls Gang Lav by Nurse Sink #4 Lims Reference ID: AD26962-AD Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	15.1		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-125/Bottle Filler by Nurse 1st Fir Lims Reference ID: AD26962-AE Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-126/Nurse Office Sink Lims Reference ID: AD26962-AF Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-127/Nurse Lav Sink Lims Reference ID: AD26962-AG Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-128/Principal Office Sink Lims Reference ID: AD26962-AH Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	17.0		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-129/Faculty Brk Room Sink Lims Reference ID: AD26962-AI Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-130/Food Court Sink East Side Lims Reference ID: AD26962-AJ Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	2.43		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-131/Food Court Center Sink Hand Sink Lims Reference ID: AD26962-AK Matrix: Drinking Water Sampled: 06/13/25 06:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-131/Food Court Center Sink Hand Sink (Continued) Lims Reference ID: AD26962-AK Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	2.99		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-133/Kitchen Triple Sink Lims Reference ID: AD26962-AL Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	1.08		1	1.00	µg/L	07/15/25 16:46	07/16/25 14:47	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: HS-134/Kitchen Hand Sink Lims Reference ID: AD26962-AM Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	4.44		1	1.00	µg/L	07/14/25 15:43	07/15/25 10:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-135/Kitchen Prep Sink North Lims Reference ID: AD26962-AN Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-137/Kitchen Prep Sink Island Lims Reference ID: AD26962-AO Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	1.16		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-138/Kitchen Prep Sink Small near line Lims Reference ID: AD26962-AP Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-139/Kitchen Mens Lav Sink Lims Reference ID: AD26962-AQ Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-140/Kitchen Womens Lav Sink Lims Reference ID: AD26962-AR Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-141/Cafeteria Bottle Filler Lims Reference ID: AD26962-AS Matrix: Drinking Water Sampled: 06/13/25 06:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS-141/Cafeteria Bottle Filler (Continued) Lims Reference ID: AD26962-AS Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-142/Kitchen Ice Machine Lims Reference ID: AD26962-AT Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-149/Wood Shop Drink Fountain Lims Reference ID: AD26962-BA Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-150/Drink Fountain by 128 Lims Reference ID: AD26962-BB Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	56.4		1	1.00	µg/L	07/14/25 15:43	07/15/25 11:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: HS-151/Rm 124 Sink Lims Reference ID: AD26962-BC Matrix: Drinking Water Sampled: 06/13/25 08:00:00									
Metals									
Lead	24.2		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CC-001/Hand Sink Lims Reference ID: AD26962-BD Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	4.33		1	1.00	µg/L	07/15/25 10:16	07/15/25 14:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CC-002/Island Sink Lims Reference ID: AD26962-BE Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	2.61		1	1.00	µg/L	07/15/25 10:16	07/15/25 14:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CC-003/Triple Sink Left Lims Reference ID: AD26962-BF Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	91.2		1	1.00	µg/L	07/15/25 10:16	07/15/25 14:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CC-004/Triple Sink Right Lims Reference ID: AD26962-BG Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962**LIMS Reference ID:** AD26962**EMSL Customer ID:** CLCS25**Attention:** Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:**

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-004/Tribble Sink Right (Continued) Lims Reference ID: AD26962-BG Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals (Continued)									
Lead	28.3		1	1.00	µg/L	07/14/25 15:42	07/15/25 09:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: CC-005/Ice Maker Lims Reference ID: AD26962-BH Matrix: Drinking Water Sampled: 06/13/25 06:00:00									
Metals									
Lead	ND		1	1.00	µg/L	07/15/25 16:46	07/16/25 14:50	SE	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962

LIMS Reference ID: AD26962

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - High School (HS)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 07/07/2025 09:25**Reported:****Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012526962**LIMS Reference ID:** AD26962**EMSL Customer ID:** CLCS25**Attention:** Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name:

Clarence CSD - High School (HS)

Project ID:

_Master Project-CLCS25

Customer PO:**Sales Rep:**

David Prince

Received:

07/07/2025 09:25

Reported:

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AD26962

Customer Information		Billing Information	
Customer ID:		Billing ID:	
Company Name:	Clarence Central School District	Company Name:	Same as Left
Contact Name:	Brian Logel	Billing Contact:	
Street Address:	9625 main Street	Street Address:	
City, State, Zip:	Clarence, NY 14031	City, State, Zip:	
Country:	USA	Country:	
Phone:	716-407-9131	Phone:	
Email(s) for Report:	Blogel@clarenceschools.org	Email(s) for Invoice:	
Project Information			
Project Name/No:		Purchase Order:	
Clarence CSD - High School (HS)			
EMSL LIMS Project ID:		US State where samples collected:	
(If applicable, EMSL will provide)		NY	
State of Connecticut (CT) must select project location:		☐ Commercial (Taxable) ☐ Residential (Non-Taxable)	
Sampled By Name:		Sampled By Signature:	
Brian Logel			
No. of Samples in Shipment			
Turn-Around-Time (TAT)			
☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☒ 2 Week			
Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.			
MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm ²	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)
Reporting Limit based on a minimum 0.25g sample weight.	SW 846-6010D	ICP-OES	0.0004% (4ppm)
**Not appropriate for Ceramic Tiles - XRF is recommended	NIOSH 7082	Flame Atomic Absorption	4µg/filter
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe
If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D	ICP-OES	1.0µg/wipe
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)
TTLIC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)
SM 3111B / SW 846-7000B	Flame Atomic Absorption		0.4 mg/L (ppm)
Wastewater	EPA 200.7	ICP-OES	0.020 mg/L (ppm)
Unpreserved ☐	EPA 200.5	ICP-OES	0.003 mg/L (ppm)
Preserved with HNO ₃ ☐ PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)
Drinking Water			
Unpreserved ☐			
Preserved with HNO ₃ ☒ PH<2			
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter
Other:			
Sample Number	Sample Location	Volume / Area	Date / Time Sampled
HS-001 Up To	See Attached Sheets		6/13/25
HH-151	See Attached Sheets		
			Rec'd PMS.
CC-001 up To	See Attached Sheet		
CC-005			
Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by: Brian Logel		Received by:	
Date/Time: 7/01/25, 5pm		Date/Time: 7/01/25 0935	
Relinquished by:		Received by:	
Date/Time:		Date/Time:	

Controlled Document - COC-26 Lead-017 05/09/2022

*6010C Available Upon Request

☒ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Building	FIRST DRAW											
	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
HS-001	9/13/25	6:00am	Tech Bathroom									
HS-002	9/13/25		Sink near Print Shop									
HS-003	9/13/25		Womens Lav by Sink by Print Shop									
HS-004	9/13/25		Mens Lav Sink by Print Shop									
HS-005	9/13/25		Bottle Fillery by Print Shop									
HS-006	9/13/25		Bottle Fillery by 508									
HS-007	9/13/25		503 Sink									
HS-008	9/13/25		Girls 500 Lav Left Sink									
HS-009	9/13/25		Girls Lav Center Sink									
HS-010	9/13/25		Girls Lav Right Sink									
HS-011	9/13/25	6:30am	Boys 500 Lav Left Sink									
HS-012	9/13/25		Boys Lav Center Sink									
HS-013	9/13/25		Boys Lav Right Sink									
HS-014	9/13/25		Faculty Women Sink									
HS-015	9/13/25		Handicap Sink									
HS-016	9/13/25		Womens Faculty by 411 Left Sink									
HS-017	9/13/25		Womens Faculty by 411 Center Sink									
HS-018	9/13/25		Womens Faculty by 411 Right Sink									

Building	FIRST DRAW											
	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
HS-019	9/13/25		Mens Faculty by 411 Left Sink									
HS-020	9/13/25		Mens Faculty by 411 Left Center Sink									
HS-021	9/13/25	7:00am	Mens Faculty by 411 Right Center Sink									
HS-022	9/13/25		Mens Faculty by 411 Right Sink									
HS-023	9/13/25		Unisex Single by 404 sink									
HS-024	9/13/25		Unisex Single by 401 sink									
HS-025	9/13/25		Superintendent Lav Sink									
HS-026	9/13/25		Dist Office Kitchen Sink									
HS-027	9/13/25		District Office Mens Sink Left									
HS-028	9/13/25		District Office Mens Sink Right									
HS-029	9/13/25		District Office Womens Sink Left									
HS-030	9/13/25		District Office Womens Sink Right									
HS-031	9/13/25	7:30am	Dist. Offc. Basemnt Bottle Filler									
Blank												
Blank												
HS-032	9/13/25		2nd Flr Bottle Filler by boys gang lav									
HS-033 -	9/13/25		2nd Flr Boys Gang Lav Sink	Fix Sink								
HS-034	9/13/25		2nd Flr Girls Lav Sink #1 (left most)									

Building	FIRST DRAW											
SAMPLE NUMBER	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
35 HS-035	9/13/25		2nd Flr Girls Lav Sink #2									
36 HS-036	9/13/25		2nd Flr Girls Lav Sink #3									
37 HS-037	9/13/25		2nd Flr Girls Lav Sink #4									
38 HS-038	9/13/25		2nd Flr Girls Lav Sink #5									
39 HS-039 ONE	9/13/25		2nd Flr Girls Lav Sink #2		Error		No	Sample				
40 HS-040	9/13/25		2nd Flr Bottle Filler by Staff gang lav									
41 HS-041	9/13/25	8:00am	2nd Flr Men Staff Gang Lav Sink Left									
42 HS-042	9/13/25		2nd Flr Men Staff Gang Lav Sink Right									
43 HS-043	9/13/25		2nd Flr Women Staff Lav Sink Left									
44 HS-044	9/13/25		2nd Flr Women Staff Lav Sink Right									
45 HS-045	9/13/25											
46 HS-046	9/13/25											
47 HS-047	9/13/25											
48 HS-048	9/13/25											
49 HS-049	9/13/25											
50 HS-050	9/13/25	8:30am										

Building	FIRST DRAW											
	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
HS-051	9/13/25	6:00am	Boys Team Rm Sink				/					
HS-052	9/13/25		Boys Gym Locker Sink Left				/					
HS-053	9/13/25		Boys Gym Locker Sink Right				/					
HS-054	9/13/25		Gym Office Lav Sink				/					
HS-055	9/13/25		Girls Team Room Sink Left				/					
HS-056	9/13/25		Girls Team Room Sink Right				/					
HS-057	9/13/25		Trainer Rm Sink				/					
HS-058	9/13/25		Girls Gym Locker Sink Left				/					
HS-059	9/13/25		Girls Gym Locker Sink Center				/					
HS-060	9/13/25		Girls Gym Locker Sink Right				/					
HS-061	9/13/25	6:30am	Gym Girls Office Lav Sink				/					
HS-062 No Sample	9/13/25		Boys Gang Lav by Gym Sink Left	Mixing Faucet			/					
HS-063 No Sample	9/13/25		Boys Gang Lav by Gym Sink Center				/					
HS-064 No Sample	9/13/25		Boys Gang Lav by Gym Sink Right				/					
HS-065 No Sample	9/13/25		Girls Gang Lav by Gym Sink #1 (left)				/					
HS-066 No Sample	9/13/25		Girls Gang Lav by Gym Sink #2				/					
HS-067 No Sample	9/13/25		Girls Gang Lav by Gym Sink #3	Mixing Faucet			/					
HS-068 No Sample	9/13/25		Girls Gang Lav by Gym Sink #4				/					

Building	FIRST DRAW											
	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
65 HS-069	9/13/25		Rm 330 Fountain		/							
63 HS-070	9/13/25		Unisex Lav Sink by 332				/					
64 HS-071	9/13/25	7:00am	Unisex Lav sink by 326				/					
HS-072 No Sample	9/13/25		Pool Girls Lav Sink Left	Mixing Faucet			/					
HS-073 No Sample	9/13/25		Pool Girls Lav Sink Right	↓		↓	✓					
HS-074 No Sample	9/13/25		Pool Boys Lav Sink Left	↓		↓	✓					
HS-075 No Sample	9/13/25		Pool Boys Lav Sink Right	Mixing Faucet			✓					
65 HS-076	9/13/25		Rm 326 Boys Lav Sink				/					
66 HS-077	9/13/25		Rm 326 Girls Lav Sink				/					
67 HS-078	9/13/25		Rm 326 Utility Sink				/					
HS-079 ONE	9/13/25	?	Rm 326 Back Lav Sink Left		No Sample							
HS-080 ONE	9/13/25	?	Rm 326 Back Lav Sink Right		No Sample							
68 HS-081	9/13/25	7:30am	Mens Faculty by Big Stair Lav Sink Left				/					
69 HS-082			Mens Faculty by Big Stair Lav Sink Right				/					
70 HS-083			Womens by Big Stair Lav Sink Left				/					
71 HS-084	9/13/25		Womens by Big Stair Lav Sink Right				/					
HS-085 No Sample	9/13/25		Ramp Boys Lav Sink Left	Mixing Faucet			/					
HS-086 No Sample	9/13/25		Ramp Boys Lav Sink Right	Mixing Faucet			/					

Building		FIRST DRAW										
SAMPLE NUMBER	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
HS-087 No Sample	9/13/25		Ramp Girls Lav Sink Left	Mixing Faucet			✓					
HS-088 No Sample	9/13/25		Ramp Girls Lav Sink Right	Mixing Faucet			✓					
10 HS-089	9/13/25		Back Stage Utility Sink				✓					
13 HS-090	9/13/25		Back Stage Lav Sink				✓					
HS-091 No Sample	9/13/25		Library Boys Lav Sink Left	Mixing Faucet			✓					
HS-092 No Sample	9/13/25		Library Boys Lav Sink Right	↓		↓	✓					
HS-093 No Sample	9/13/25	8:00am	Library Girls Lav Sink Left	↓		↓	✓					
HS-094 No Sample	9/13/25		Library Girls Lav Sink Right	Mixing Faucet			✓					
14 HS-095	9/13/25		Fountain BY Gym									
15 HS-096	9/13/25		Rm 325 sink									
16 HS-097 -	9/13/25											
17 HS-098 -	9/13/25											
18 HS-099 -	9/13/25											
19 HS-078 A			326 Fountain		✓							

Building	FIRST DRAW											
	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
90 HS-100	9/13/25	6:00am	Wood Shop Lav Sink									
91 HS-101	9/13/25		Wood Shop Utility Sink									
92 HS-102	9/13/25		138 135 Computer lab Sink									
93 HS-103	9/13/25		Basement Art Rm 140 Sink Left									
94 HS-104	9/13/25		Basement Art Rm 140 Sink Right									
95 HS-105	9/13/25		Basement Rm 138 Office Sink 125									
96 HS-106	9/13/25		Rm 132 Art Front Left Sink									
97 HS-107	9/13/25		Rm 132 Art Front Right Sink									
98 HS-108 -	9/13/25		Rm 132 Art Back Single Sink	OFF SW - OFF								
99 HS-109	9/13/25		Rm 130 Art Front Left Sink									
100 HS-110	9/13/25	6:30am	Rm 130 Art Front Right Sink									
101 HS-111	9/13/25		Rm 130 Art Rear Left Sink									
102 HS-112	9/13/25		Rm 130 Art Rear Right Sink									
103 HS-113 ~	9/13/25		Boys Gang Lav by 120 Sink Left	Mixing Faucet								
104 HS-114 ~	9/13/25		Boys Gang Lav by 120 Sink Right	Mixing Faucet								
105 HS-115	9/13/25		Bottle Filler by Elevator 1st Flr									
106 HS-116	9/13/25		Guidance Break Room Sink									
107 HS-117	9/13/25		Men Faculty Sink Left									

Clarence Central

Building	FIRST DRAW											
	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
008 HS-118	9/13/25		Men Faculty Sink Right									
009 HS-119	9/13/25		Women Faculty Sink Left									
100 HS-120	9/13/25	7:00am	Women Faculty Sink Right									
101 HS-121	9/13/25		Girls Gang Lav by Nurse Sink #1 (left)									
102 HS-122	9/13/25		Girls Gang Lav by Nurse Sink #2									
103 HS-123	9/13/25		Girls Gang Lav by Nurse Sink #3									
104 HS-124	9/13/25		Girls Gang Lav by Nurse Sink #4									
105 HS-125	9/13/25		Bottle Filler by Nurse 1st Flr									
106 HS-126	9/13/25		Nurse Office Sink									
107 HS-127	9/13/25		Nurse Lav Sink									
108 HS-128	9/13/25		Principal Office Sink									
109 HS-129	9/13/25		Faculty Brk Room Sink									
110 HS-130	9/13/25	7:30am	Food Court Sink East Side									
111 HS-131			Food Court Center Sink Left									
HS-132 DNE			Food Court Center Sink Right									
118 HS-133	9/13/25		Kitchen Triple Sink									
113 HS-134	9/13/25		Kitchen Hand Sink									
114 HS-135	9/13/25		Kitchen Prep Sink North Left									

Building		FIRST DRAW										
SAMPLE NUMBER	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
HS-136 ONE	9/13/25		Kitchen Prep Sink North Right									
15 HS-137	9/13/25		Kitchen Prep Sink Island									
16 HS-138	9/13/25		Kitchen Prep Sink Small near line									
17 HS-139	9/13/25		Kitchen Mens Lav Sink									
18 HS-140	9/13/25		Kitchen Womens Lav Sink									
19 HS-141	9/13/25		Cafeteria Bottle Filler									
20 HS-142	9/13/25	8:00am	Kitchen Ice Machine									
21 HS-143 -	9/13/25											
22 HS-144 -	9/13/25											
23 HS-145 -	9/13/25											
24 HS-146 -	9/13/25											
25 HS-147 -	9/13/25											
26 HS-148 -	9/13/25											
27 HS-149	9/17		Wood shop Drink fountain									
28 HS-150			Drink fountain 5/12/18									
29 HS-151	9/17		Rm 124 Sink									

Clarence Central

[illegible]