

August – January 2024

Facilities Summary

Boyd Anderson High School

3050 NW 41 Street

Lauderdale Lakes, FL 33309

October 18, 2022

- Broken Seats in the Cafeteria (over 8)
- Cafeteria tables missing seats is safety hazard, sharp metal edges
- Unusable equipment drink stations in cafeteria since 2009
- Outdoor seating and usable area
- Bldg. 5 top floor roof has been leaking for two years
- No somatic in the cafeteria for student trays
- At least nine seats or more in the cafeteria are broken
- Furniture sharp edges sharp edges cafeteria
- Cafeteria outdoor seating and unused unusable area
- Building 2 expansion joints so deteriorating due to ongoing roofing repairs from West construction
- Building 1 second floor boy's bathroom area rooms 172, 171 and 173 and a storage area 239 inoperable due to flood was created by construction. Boy's bathroom and part of the hallway area has been closed for more than 30 days
- Building 1 second floor storage area closet 239 has leaking and rust
- Building 1 staircase 5 there is a security camera blind spot bottommost staircase A
- Outside of building 5 sinking hazard walkway to grass area deep drops deep inclines walkway to grassy area concrete elevated tripping hazard
- Boy's locker room missing part of the ceiling old football locker room being held up by a construction jack, locker room still has hole in the ceiling from AC maintenance contractors never fixed hole
- Old boys football locker room inoperable for a year and a half-student still access part of that locker room
- Boy's locker room has exposed electrical outlets boy's locker home building 2

- Gym floor for resurfacing (told every 7 years) paint job was complete but baseboards are still missing leaving gaping holes between the gym floor and the walls
- Jumbo-trons are not working due to electrical permit issues waiting for clearance 2 years
- 15 broken seats in the gymnasium
- Flooding is still an issue
- Auditorium carpet not replaced since 1975
- Construction materials and garbage left outside the front and perimeter of the auditorium and the field by construction vender West Construction
- Roof construction and delay causing additional damage to all buildings
- West Construction possibly liable
- Visitor's dugout on boy's baseball field has no roof for the past 8 years
- Visitor's baseball field/auditorium driveway/entryway need repaving -concrete/gravel not level
- Behind gym area basketball poles without hoops and poles without padding back of bldg. 2
- Girl's softball field not maintained, overgrown grass
- Science classes moved to the auditorium due to repairs, repairs causing student displacement
- Track under construction



2





4






Lauderdale Lakes Middle
November 1, 2023

- 4 open work orders
- Work orders were closed when work was not completed from the district side
- Broken tile in hallway floor near rooms 110A and 110
- Broken floor tiles throughout the building with multiple open work orders
- Corridor 004C cracks in the flooring
- Only 14 work orders open in the school, but multiple issues were cited
- Corridor 004, broken emergency exit sign
- Strong urine odor coming from bathroom upon entering the building
- Corridor 007 B dents in the wall (sheetrock) throughout the building
- Mixed-matched paint throughout the building
- Boys' restroom 138 needs custodial attention-no toilet paper
- Termite issue throughout the campus
- Mixed-matched floor tiles
- Security not using standard approved monitors
- Several cameras are not functioning
- Girls' restroom 136 needs custodial maintenance, no toilet paper

- Ceiling tiles throughout the school, buckling from humidity and AC throughout the campus
- Corridor 006 B broken exit sign
- Corridor 006 multiple areas with broken tiles
- The front area 101 & 104 boys' and girls' restroom strong odor
- Broken seats (4) in the cafeteria, injury hazard
- Electrical boxes not properly fixed to the wall
- Rusted freezer units in the cafeteria food preparation area
- Cracked tiles in the cafeteria serving area work order in for a year
- Tray conveyer not working
- Random furniture outside of classroom portables, tripping hazard, injury hazard
- The tree roots up-ending asphalt in play area in the back of the gym
- Is there a collaborative agreement between the school and the city for use of the tennis court? Presumed to belong to the city Lauderdale Lakes
- Gymnasium floor tiles chipped and broken
- Bleachers broken, completely coming off the risers
- Gym filthy
- Ripped and torn wall padding in the gymnasium
- Home games unattainable. The school is using Boyd Anderson for games
- General cleanliness unacceptable (trash)
- Broken bleachers (injury hazard) not adequately secured
- The scoreboard is not functioning at all
- Termite problem in the gym
- Large number of B-stock items stored in gym equipment room
- Wood flooring broken and baseboards completely separated from the wall
- Wood baseboard disintegrating
- Scoreboards in a gymnasium do not work
- School received a scoreboard two years ago. Cannot be hooked up electronically because of permit issues
- Gymnasium paint peeling all over. Gym on schedule to be painted in November
- Gym equipment storage area excessive amounts of electronics for B- stock pickup
- Ceiling tiles buckling over the Kiva area













Marjory Stoneman Douglas High School

5901 Pine Island Road

Parkland, FL 33076

11/15/2023

- Include, Building numbers/Locations and details of concerns/questions
- Corridor on the side of building 700 lift with equipment on it caution tape barrier/ injury hazard
- Girls rest room holes in the tile due to sink replacement room 713
- AP science class large amount of B-stock technology/old computers
- Gymnasium roof leaks onto basketball floor near bleachers
- Two separate roof leaks in the gymnasium
- Peeling paint outside gymnasium
- Roof leaks in auditorium in the backstage area
- Roof leaks in girl's locker room
- Outside basketball and volleyball court need resurfacing.

- Elevator 500 blg. Inoperable/elevator issues or 4 years/issues with fire alarm connections/outside vendor
- Cracks in concrete 2nd floor 500blg. rainwater not draining/outside vendor
- Blg. 9 roof leaks causing mold and mildew issues inside classrooms/set to be repaired
- First year of having IS teacher. Never had IS. Students sat in the front office
- Issue with sound in the auditorium
- Lift onsite
- Head custodian calls and repairs in auditorium for seating is done immediately
- Leaks in auditorium rest rooms
- Outside vendor contracts not being turned over to BCPS
- Elevators not ADA compliant
- Cafeteria has 20 broken tables
- School qualifies for and has requested swing space and has not received it
- School in need of overall painting and updating. 400bldg. girls locker room feminine hygiene dispenser taped to the wall
- Freezer in need of repair in the cafe













Blanche Ely High School


1201 NW 6th Ave

Pompano Beach, FL 33960

Date: November 29, 2023

- Hazardous roof leak-corridor 001
- Bldg. 100 bathrooms (girls) no paper towels, no female hygiene receptacles, peeling paint, low toilet water pressure, graffiti (boys) graffiti mirror needs to be replaced, peeling paint
- Shared cafeteria with Marcom Elementary-vacant serving stations possible electrical hazard
- Auditorium roof leaking in areas around security cameras
- No bus loop cameras
- No speakers on football field (Sound system)

- 70 cameras/10 inoperable
- 800bldg roof leaking (brand new)
- Lightning weather warning alarm needs to be installed-ordered two years ago
- Paint peeling in stadium around fans
- Bldg. 26-bathroom hand dryer inoperable
- Cafeteria no tray collection machine



- Include, Building numbers/Locations and details of concerns/questions:
- Culinary room no designated safe space
- Ceiling busted in the digital design room
- Auditorium flooded-floods every heavy rain/carpets have been replaced twice
- All auditorium chairs need to be replaced
- Observed up to 6 blind spots no cameras
- No safe space designated in the mini-gym
- No padding on basketball poles
- Basketball poles missing hoops
- Football field has flooding issue
- Chopped paint on AC duct in the gym (set to be repainted)
- Track needs some maintenance.

Collins Elementary School

Date: December 13, 2023

- **Include, Building numbers/Locations and details of concerns/questions:**
- Fencing around the perimeter of the school is not secure
- Playground in need of new equipment (in poor condition/not current standard)
- Playground project was cancelled for the new office and bus loop
- School currently has no bus loop
- Area where students are dropped off from the buses there is no fencing or protection barrier for students
- The bus loop project was canceled due to flooding.
- Group bathroom project. Has been put on hold for three years/ project started up to 10 years ago
- The group bathroom is unfinished. With exposed
- Construction material gated off for the last three years/students using a modular portable
- The cafeteria has exposed pipe material. On the main food steamer system
- Cafeteria is only 47% complete
- AC for kitchen 3 to 4 years not completed/ portable AC unit
- AC in Kitchen cannot be connected until fire alarm is properly connected


- AECOM/SMART Bond transition of project managers issues are ongoing projects under construction for years-multiple expired permits and PMs with no progress or follow-up
- New Bus loop, front office and cafeteria construction cancelled in 2010
- Communication issues between district Bond program, projects are being done, PPO is pulled in to fix work already done by Bond project managers
- No Speakers in the back of the school (code red etc.)
- Bldg. 7 and 8 have no bathroom access (using portable)
- Bldg. 800 and Bldg. 500 corner camera has water spots
- No sound system stage/auditorium
- Stage not ADA compliant













Collins Elementary
Date: December 13, 2023















Westglades Middle School

11000 Holmberg RD

Parkland, FL 33076

Date: December 20, 2023

- Only one working elevator
- Inadequate lighting in the “fake front” (security concerns)
- Tennis courts need resurfacing
- Cafeteria partition broken for 3-4 years (vendor)
- Gym floors need to be resurfaced
- Sound system does not work
- Bldg.1 Hall 124 water fountain not working
- Not enough desks
- Request to vendor for bleacher replacement over a year
- Vendor warranty issues
- Bldg.1 pillars rusting (repairing) SMART Bond









005
INSIDE
CIRCULATION





- ADMINISTRATION
- GYMN/AUDI.
- MEDIA
- 100 BUILDING
- 200 BUILDING
- MUSIC

100 BUILDING



















Oriole Elementary School

3081 NW 39th St.

Lauderdale Lakes, FL 33309

Date: January 18, 2024

- SMART Bond states all work is complete at this site
- Roof is not complete due to vendors
- Media Center under construction
- AC in front office not working no follow-up from AECOM
- Leaking faucet in kitchen area
- Multiple blind spots/2 cameras not working
- Fire/sprinkler system not connected for 2 years (Media Center)
- Mold smell overwhelming in Bldg. 7
- Construction containers sitting outside of Bldg. 7
- Media Center need new carpet
- Playgrounds still have sand/unmaintained
- Playgrounds need inspections and renovations
- Tennis court poles unpadded
- Rm. 763 poor air quality mold smell
- Restrooms 150-151 inoperable due to construction
- Ceiling tiles in multiple rooms in Bldg. 7 need to be replaced
- Ceiling paint peeling building 6
- No grounds keeper
- SMART Bond construction issues ongoing
- Vendor for AC not responsive
- Bld. 7 AC drip pans causing issues with air quality in entire building

















See Something. Say Something
Be a Broward Buddy. Report a Tip!

In an emergency, call 911 immediately. To submit a safety or security concern that is not an emergency, please use one of the tip reporting methods provided below. Please remember you can choose to remain anonymous.

Anonymous Tip Submission Box
 Submit a tip directly via our Anonymous Tip Submission Box (see Broward County Tip Reports for more details) or provide a written report to your school principal, principal's assistant, school nurse, social media handles, etc.

Call Us Anytime (Even on Holidays)
 Call our District Security Operations Center (DSOC) 24 hours a day, 7 days a week, including holidays. One of our District Security Specialists will take your tip over the phone or email. Submit it immediately to our investigators. Please let the DSOC Specialist know if you wish to remain anonymous.

Send Us an Email
 Submit a tip using the email address below. Although your email address is displayed using this tip reporting method, you can choose to remain anonymous by simply mentioning it in your message.


FortifyFL
 Submit a tip via FortifyFL online (no download required) or download the app for easier use. Immediately reach law enforcement and Broward Schools investigators.

SecurityTips@BrowardSchools.com
GetFortifyFL.com



This project was supported by Grant No. 2019-15-BE-0211 awarded by the Bureau of Justice Assistance, the Bureau of Justice Assistance is a component of the Department of Justice's Office of Justice Programs, which includes the Bureau of Justice Statistics, the National Institute of Justice, the Office of Juvenile Justice and Delinquency Prevention, the Office for Science and Crime, and the SMART Center of the Department of Justice.




Our Morning Procedures

1. Enter the classroom ready to learn.

2. Place your agenda and homework in

Our Afternoon Procedures

1. Make sure that your desk and surrounding area is clean.

2. Make sure that your agenda and homework are in your backpack.










le

Question?

S

SIT UP STRAIGHT WITH
YOUR FEET ON THE FLOOR
UNDER YOUR DESK

L

LISTEN AND LEAN
FORWARD. KEEP YOUR
HEAD OFF OF YOUR DESK

A

ACTIVATE YOUR
THINKING AND ASK &
ANSWER QUESTIONS

N

NOD YOUR HEAD TO
INDICATE YOU ARE
PAYING ATTENTION

T

TRACK THE SPEAKER
WITH YOUR EYES

RHYMING
They have it

NGS
open here

E ELEMENTARY
VES...

MISSION...

VISION...

IN MOTTO...

Administrative Form



PHONICS/ WORD WORK CENTER

Consonants

Bb	Cc	Dd
Ff	Gg	Hh
Ii	Jj	Kk
Ll	Mm	Nn
Oo	Pp	Qq
Rr	Ss	Tt
Vv	Ww	Xx
Yy	Zz	

Digraphs

Consonant			
ch	ck	ng	ph
sh	th	wr	wh

Vowel			
ai	ay	ea	ee
ei	ew	ie	oo
oe	oo	ue	ui

Vowels

Short	Long
a	ā
e	ē
i	ī
o	ō
u	ū

Beginning Blends

bl	br	cl	cr	dr
fl	fr	gl	gr	pl
pr	sk	sl	sm	sn
sp	st	sw	tr	tw

Ending

ct	ld	lp	nd	pt	rm	rt
----	----	----	----	----	----	----











William Dandy Middle School

2400 NW 26th St.

Fort Lauderdale, FL 33311

January 24, 2024

- Score board need to be replaced in the gym
- Gym seats need to be replaced
- Basketball court needs resurfacing
- Lockers in girl locker rooms are in poor condition
- Media Center carpet need to be replaced
- Shortage of facilities staff
- Issues with sound system in cafe/auditorium
- Have had 5 project managers
- Bathroom has been under construction for 4 years
- Portable on list to be removed for over a year
- Track is inoperable
- Perimeter fencing issues
- Vendor issues with construction in girl's bathroom Bldg.14
- Dilapidated soccer nets directly on track need to be removed (safety issue)
- Bldg. 18 girl's bathroom toilet not anchored to the floor
- Cafeteria new floor has wholes and cracks
- 3 rotting portables on site
- Exposed nails in areas with new roofing
- Girls rest room 709 open access panels exposed in ceiling (vendors)
- Fire Alarm replacement issues

