

502 Oltendorf Rd, Streamwood, IL 60107

BUILDING S	SUMMARY		
Gross SF	60,065	Number of Levels	2
Year Built	1965	Number of Additions	2




LEVEL 2



LEVEL 1

ENROLLMENT METRICS






Occupancy: the maximum number of people that can be housed in a space in accordance with the building/ fire code

**NOTE: Occupancy is NOT the recommended number of students for a space, it is the maximum allowed by code.

Effective Capacity: the amount of

students a school can effectively support based on the District's current practices and future vision for teaching and learning. This is calculated based on ISBE's square footage per student guideline.

Enrollment: current number of students attending the facility.




* This comparison notes the difference between Oakhill Elementary School area per student in comparison to the current National average as noted in the 2015 School Construction Report. The master planning process will produce outcomes pertinent to the District as a whole. This is just one metric to compare space.

square feet • 15 square feet

Oakhill Elementary School

2015 National Low **Ouartile Number**



TRAVEL

Furthest approximate travel time from one location to another for an average Kindergarten Student.



Furthest approximate travel time from one location to another for an average **Fourth Grade Student.**



Performance Venue Performing Arts Classroom Resources Science Lab

Special Education Stem / Hands-On Learning Restrooms

Student Support ☐ Visual Arts

Under-sized space Room Capacity based on ISBE 10 Guidelines

Omo Travel Path

Room Capacity Guidelines (not included







Spatial Educational Adequacy(2	25%)	С
(Data collected through Staff Survey)	6.5/	10
Physical Features	8.1/	10
Environment Supports Variety	6.3/	10
Visual Stimulation	5.6/	10
Future Readiness	6.0/	10
Puilding Allocation (25%)		_

	, -	
Building Allocation(25%)	С	
Gross SF/student	137	
Site Acreage/Guideline	67%	
Mobiles in Use/Basement Used	No/No	


Facility Condition(35%)	С
FCI	.27
Water Usage(5%)	Α
Gallons/SF	4.7
Energy Heage(10%)	D

Energy Usage(10%)		
Total EUI	42.5kBTU/SF/yr	
Electric	15.0kBTU/SF/yr	
Gas	27.5kBTU/SF/yr	

AGGREGATED FACILITY GRADE

Educational Adequacy grades were determined by a survey issued to staff. Square Foot/Student grades were determined by building area and enrollment. Facility grades are determined building assessments. Water grades were determined by comparing utility data to the Commercial Buildings Energy Consumption Survey. Energy grades were deteremined by comparing utility data to the US Dept of Energy's Building Performance Database. Percent in parenthesis indicates weight of category in aggregate facility grade.

Activity mapping is based on survey data (Week in the Life) collected by teachers throughout the district over the course of one week. The teachers provided the learning activity and amount of time spent in that activity. Data was aggregated for the school and is represented by the average percent of time spent in the activity.




What's a Listening Tour?

Staff surveys (Listening Tours) were sent to each school where faculty gave input about the strengths and weaknesses of the building. The following comments highlight common themes and concerns.

Listening Tour Comments

- There are smells throughout the lower floor due to the flooding.
- Room temperatures are inconsistent.
- The size of the classrooms is good.
- Teachers who responded feel the classrooms are some of the best spaces at this school but could also use improvement to technology, thermal comfort and lighting.
- More parking on site would be desirable.



(EUI)

ENERGY USAGE

COS


+ WATER

USAGE


'ATER

4

This chart indicates the approximate cost of deferred and anticipated maintenance (in dollars) of items assessed by building system. Highlighted items indicate those items in immediate need, code requirement, poor and fair condition.



This chart indicates the approximate cost of deferred and anticipated maintenance (in dollars) based on condition of assessed items.




This chart indicates the approximate cost of deferred and anticipated maintenance (in dollars) based on condition of assessed items in relation to the entire cohort of buildings.




FACILITY





Energy Use Intensity (EUI) is a key metric that expresses a building's energy use as a function of its size. Generally, a low EUI signifies good energy performance



WATER USAGE/SF FOR ELEMENTARY SCHOOLS IN U-46 Water usage is a key metric that expresses a school's water use and total cost of water in comparison to the other middle schools in the district.

How is this information collected?

The goal of the DLR Group integrated design team is to **collect multiple qualitative and quantitative data points** around the same set of items - for example energy use, air quality, or learning behavior - in order to **form a holistic picture**. The team collects these data points through the use of sensors (in the space for 1-7 days), spot measurement equipment, expert walkthroughs, focus groups, surveys, and ethnographic observation techniques. The results are validated by cross-checking data points, such as a survey answer and a spot measurement, that should relate to one another.