



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

July 21, 2025

Andy Chasteen  
Medford School District  
900 Kenyon St  
Medford, OR 97501  
TEL: 541-842-3646  
FAX 541-842-1160

RE: Washington Elem Lead Testing- AMENDED                      Order No.: 25050768

Dear Andy Chasteen:

Neilson Research Corporation received 25 sample(s) on 5/15/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Director of Project Management  
245 S Grape St  
Medford, OR 97501



Revision v1



Neilson Research Corporation

245 S Grape St

Medford, OR 97501

TEL: (541) 770-5678 FAX: (541) 770-2901

Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 25050768

Date: 7/21/2025

---

---

**CLIENT:** Medford School District

**Project:** Washington Elem Lead Testing-AMENDED

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

---

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768  
 Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-01      Client Sample ID: Health Rm-Sink  
 Collection Date: 5/15/2025 5:37:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Health Rm-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.30		0.515	ppb	1	6/12/2025	15.0	A	

**Lab ID:** 25050768-02      Client Sample ID: Health Rm Unisex RR-Sink  
 Collection Date: 5/15/2025 5:38:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Health Rm Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A	

**Lab ID:** 25050768-03      Client Sample ID: 1st Flr Boy's RR across Rm 3-Sink (L)  
 Collection Date: 5/15/2025 5:40:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Boy's RR across Rm 3-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768  
 Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-04      Client Sample ID: 1st Flr Boy's RR across Rm 3-Sink (C)  
 Collection Date: 5/15/2025 5:40:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Boy's RR across Rm 3-Sink (C)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.20		0.515	ppb	1	6/12/2025	15.0	A	

**Lab ID:** 25050768-05      Client Sample ID: 1st Flr Boy's RR across Rm 3-Sink (R)  
 Collection Date: 5/15/2025 5:41:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Boy's RR across Rm 3-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A	

**Lab ID:** 25050768-06      Client Sample ID: 1st Flr O/S Boy's RR-DF (L)  
 Collection Date: 5/15/2025 5:41:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr O/S Boy's RR-DF (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768  
 Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-07      Client Sample ID: 1st Flr O/S Boy's RR-DF (R)  
 Collection Date: 5/15/2025 5:42:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr O/S Boy's RR-DF (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-08      Client Sample ID: 1st Flr Girl's RR across Ofc-Sink (L)  
 Collection Date: 5/15/2025 5:47:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Girl's RR across Ofc-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.06		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-09      Client Sample ID: 1st Flr Girl's RR across Ofc-Sink (C)  
 Collection Date: 5/15/2025 5:47:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Girl's RR across Ofc-Sink (C)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.57		0.515	ppb	1	6/12/2025	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768  
 Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-10      Client Sample ID: 1st Flr Girl's RR across Ofc-Sink (R)  
 Collection Date: 5/15/2025 5:47:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Girl's RR across Ofc-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-11      Client Sample ID: 1st Flr by Ofc/Trophy Case-Elkay BF(Up)  
 Collection Date: 5/15/2025 5:48:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr by Ofc/Trophy Case-Elkay BF(Up)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-12      Client Sample ID: 1st Flr by Ofc/Trophy Case-Elkay BF(Low)  
 Collection Date: 5/15/2025 5:48:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr by Ofc/Trophy Case-Elkay BF(Low)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768  
 Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-13      Client Sample ID: 1st Flr Staff Men's Unisex RR by Ofc- Sink L  
 Collection Date: 5/15/2025 5:54:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Staff Men's Unisex RR by Ofc- Sink L

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-14      Client Sample ID: 1st Flr Staff Women's Unisex RR by Ofc-Sink  
 Collection Date: 5/15/2025 5:54:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: 1st Flr Staff Women's Unisex RR by Ofc-Sink R

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.25		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-15      Client Sample ID: Kitchen-Sink (Food Prep-S Wall)  
 Collection Date: 5/15/2025 5:27:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Kitchen-Sink (Food Prep-S Wall)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768

Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-16      Client Sample ID: Kitchen-Sink (Hand/Eye Wash-S Wall)  
 Collection Date: 5/15/2025 5:29:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Kitchen-Sink (Hand/Eye Wash-S Wall)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.621		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-17      Client Sample ID: Kitchen-Sink (Triple Sink-S Wall)  
 Collection Date: 5/15/2025 5:29:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Kitchen-Sink (Triple Sink-S Wall)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-18      Client Sample ID: Kitchen-Sink (Pre Rinse/DW-Sprayer)  
 Collection Date: 5/15/2025 5:30:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Kitchen-Sink (Pre Rinse/DW-Sprayer)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.17		0.515	ppb	1	6/12/2025	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768

Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-19      Client Sample ID: Kitchen-Sink (Hand Wash/Serving Ln)  
 Collection Date: 5/15/2025 5:31:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Kitchen-Sink (Hand Wash/Serving Ln)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.851		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-20      Client Sample ID: Kitchen Unisex RR-Sink  
 Collection Date: 5/15/2025 5:31:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Kitchen Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.754		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-21      Client Sample ID: Playground-DF (O/S Cafeteria)-Upper  
 Collection Date: 5/15/2025 5:57:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: Playground-DF (O/S Cafeteria)-Upper

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768  
 Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-22      Client Sample ID: La Clinica-Exam Rm #1-DF  
 Collection Date: 5/15/2025 6:04:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: La Clinica-Exam Rm #1-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-23      Client Sample ID: La Clinica-Exam Rm #1-Sink  
 Collection Date: 5/15/2025 6:05:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: La Clinica-Exam Rm #1-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.584		0.515	ppb	1	6/12/2025	15.0	A

**Lab ID:** 25050768-24      Client Sample ID: La Clinica-Exam Rm #2-DF  
 Collection Date: 5/15/2025 6:05:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: La Clinica-Exam Rm #2-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.29		0.515	ppb	1	6/12/2025	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

# Analytical Report

WO#: 25050768  
 Date Reported: 7/21/2025

Medford School District  
 900 Kenyon St  
 Medford, OR 97501

**Lab Order:** 25050768  
**Received Date:** 5/15/2025 8:46:00 AM  
**Reported Date:** 7/21/2025 1:52:01 PM

Sample Information:

**Lab ID:** 25050768-25      Client Sample ID: La Clinica-Handwash by O/S RR-Sink  
 Collection Date: 5/15/2025 6:06:00 AM      Collected By: Mike Medel  
 Matrix: Drinking Water      Sample Location: La Clinica-Handwash by O/S RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 25050768  
 21-Jul-25

**Client:** Medford School District  
**Project:** Washington Elem Lead Testing-AMENDED  
**TestCode:** LEAD\_SCHOOLS

Sample ID: MB-31681	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: PBW	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986833						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31681	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: LCSW	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986834						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0	103	85	115				

Sample ID: 25050768-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Health Rm-Sink	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986836						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	106	0.520	100	3.30	103	70	130				

Sample ID: 25050768-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Health Rm-Sink	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986837						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.520	100	3.30	101	70	130	106	1.26		20

**Qualifiers:** CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 DF Dilution Factor  
 ND Not Detected at the Reporting Limit  
 H Holding times for preparation or analysis exceed  
 RL Reporting Limit

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 25050768  
 21-Jul-25

**Client:** Medford School District  
**Project:** Washington Elem Lead Testing-AMENDED  
**TestCode:** LEAD\_SCHOOLS

Sample ID:	MB-31685	SampType:	MBLK	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/12/2025	RunNo:	60228
Client ID:	PBW	Batch ID:	31685	TestNo:	E200.8	Units:	E200.8	Analysis Date:	6/12/2025	SeqNo:	986861
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID:	LCS-31685	SampType:	LCS	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/12/2025	RunNo:	60228
Client ID:	LCSW	Batch ID:	31685	TestNo:	E200.8	Units:	E200.8	Analysis Date:	6/12/2025	SeqNo:	986862
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0	102	85	115				

Sample ID:	25050768-21AMS	SampType:	MS	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/12/2025	RunNo:	60228
Client ID:	Playground-DF (O/S	Batch ID:	31685	TestNo:	E200.8	Units:	E200.8	Analysis Date:	6/12/2025	SeqNo:	986864
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0.453	102	70	130				

Sample ID:	25050768-21AMSD	SampType:	MSD	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/12/2025	RunNo:	60228
Client ID:	Playground-DF (O/S	Batch ID:	31685	TestNo:	E200.8	Units:	E200.8	Analysis Date:	6/12/2025	SeqNo:	986865
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0.453	102	70	130	103	0.0385	20	

**Qualifiers:** CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 DF Dilution Factor  
 ND Not Detected at the Reporting Limit  
 H Holding times for preparation or analysis exceed  
 RL Reporting Limit

Revision v1



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: [www.nrclabs.com](http://www.nrclabs.com)

## Sample Log-In Check List

Client Name: MedfordSchoolDist      Work Order Number: 25050768      RcptNo: 1

Logged by:	Ashley Spiegelberg	5/15/2025 8:46:00 AM	
Completed By:	Dorie Evans	6/16/2025 10:40:29 AM	
Reviewed By:	Dorie Evans	6/16/2025 10:40:34 AM	

### Chain of Custody

1. Is Chain of Custody complete?      Yes       No       Not Present   
 2. How was the sample delivered?      Client

### Log In

3. Coolers are present?      Yes       No       NA   
 4. Shipping container/cooler in good condition?      Yes       No   
    Custody seals intact on shipping container/cooler?      Yes       No       Not Present       NA   
    No.      Seal Date:      Signed By:  
 5. Was an attempt made to cool the samples?      Yes       No       NA   
 6. Were all samples received at a temperature of >0° C to 6.0°C      Yes       No       NA   
 7. Sample(s) in proper container(s)?      Yes       No   
 8. Sufficient sample volume for indicated test(s)?      Yes       No   
 9. Are samples (except VOA and ONG) properly preserved?      Yes       No   
 10. Was preservative added to bottles?      Yes       No       NA   
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm?      Yes       No       No VOA Vials   
 12. Were any sample containers received broken?      Yes       No   
 13. Does paperwork match bottle labels?      Yes       No   
    (Note discrepancies on chain of custody)  
 14. Are matrices correctly identified on Chain of Custody?      Yes       No   
 15. Is it clear what analyses were requested?      Yes       No   
 16. Were all holding times able to be met?      Yes       No   
    (If no, notify customer for authorization.)

### Special Handling (if applicable)

17. Was client notified of all discrepancies with this order?      Yes       No       NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

### Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b>		<b>Section B</b>		<b>Section C</b>		<b>Section D</b>	
<b>Required Client Information</b>		<b>Required Project Information</b>		<b>Invoice Information</b>		<b>Rush Status (Subject to Scheduling)</b>	
Company: MSD 549C	Project Name: Washington	Attention: Accounting	Standard 10-14 Days		5 Business Days (50% surcharge)		
Address: 900 Kenyon Medford, OR 97501	Project Number: Report andy.chasteen@medford.k12.or.us	Company Name: Medford School District	3 Business Days (75% surcharge)		24 - 48 hours (100% surcharge)		
Email: andy.chasteen@medford.k12.or.us	Copy T Seth.barry@medford.k12.or.us	Address: 900 Kenyon Medford, OR 97501	Other		Other		
Phone: 541-840-4315 Fax:		P.O. #	Authorized		Yes ___ No ___		
Collected By (Print): <i>Walter Medel</i>							
Collected By (Sign): <i>[Signature]</i>							
Email Report: Yes ___ No ___	Mail Report: Yes ___ No ___						
Fax Report: Yes ___ No ___							

Sample ID	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Health Room - Sink	DW	5/15/2025	5:37	1			01
Health Room Unisex Restroom - Sink	DW	5/15/2025	5:38	1			02
1st Floor Boy's Restroom Across From Room 3 - Sink (Left)	DW	5/15/2025	5:40	1			03
1st Floor Boy's Restroom Across From Room 3 - Sink (Center)	DW	5/15/2025	5:40	1			04
1st Floor Boy's Restroom Across From Room 3 - Sink (Right)	DW	5/15/2025	5:41	1			05
1st Floor Outside Boy's Restroom - Drinking Fountain (Left)	DW	5/15/2025	5:41	1			06
1st Floor Outside Boy's Restroom - Drinking Fountain (Right)	DW	5/15/2025	5:42	1			07
1st Floor Girl's Restroom Across From Office - Sink (Left)	DW	5/15/2025	5:47	1			08
1st Floor Girl's Restroom Across From Office - Sink (Center)	DW	5/15/2025	5:47	1			09
1st Floor Girl's Restroom Across From Office - Sink (Right)	DW	5/15/2025	5:47	1			10
1st Floor By Office/Trophy Case - Elkay Bottle Filler (Upper)	DW	5/15/2025	5:48	1			11
1st Floor By Office/Trophy Case - Elkay Bottle Filler (Lower)	DW	5/15/2025	5:48	1			12
1st Floor Staff Men's Restroom Near Office - Sink <i>Water, left</i>	DW	5/15/2025	5:54	1			13
1st Floor Staff Women's Restroom Near Office - Sink <i>Water, right</i>	DW	5/15/2025	5:54	1			14
Kitchen - Sink (Food Prep - South Wall)	DW	5/15/2025	5:57	1			15
Kitchen - Sink (Hand/Eye Wash - South Wall)	DW	5/15/2025	5:59	1			16
Kitchen - Sink (Triple Sink - South Wall)	DW	5/15/2025	5:59	1			17
Kitchen - Sink (Pre-rinse/Dishwasher - Sprayer Only)	DW	5/15/2025	5:59	1			18
Kitchen - Sink (Hand Wash/Serving Line)	DW	5/15/2025	5:59	1			19
Kitchen Unisex Restroom - Sink	DW	5/15/2025	5:59	1			20
Playground - Drinking Fountain (Outside Cafeteria) - Upper	DW	5/15/2025	N/A	1			21
Playground - Drinking Fountain (Outside Cafeteria) - Lower <i>at of the table</i>	DW	5/15/2025	5:57	1			22
La Clinica - Exam Room # 1 - Drinking Fountain	DW	5/15/2025	6:04	1			22

