

Lead Tests - Washington Elementary School - Main Building - # 20481200											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results (PPB)	Filter For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20481200-001NS	20481200-001NS26A	Health Room - Sink	05/15/25	3.3						None.
2	20481200-002BF	20481200-002BF26A	Health Room Unisex Restroom - Sink	05/15/25	ND						None.
3	20481200-003BF	20481200-003BF26A	1st Floor Boy's Restroom Across From Room 3 - Sink (Left)	05/20/25	1.7						None.
4	20481200-004BF	20481200-004BF26A	1st Floor Boy's Restroom Across From Room 3 - Sink (Center)	05/20/25	1.3						None.
5	20481200-005BF	20481200-005BF26A	1st Floor Boy's Restroom Across From Room 3 - Sink (Right)	05/20/25	1.4						None.
6	20481200-006DW	20481200-006DW26A	1st Floor Outside Boy's Restroom - Drinking Fountain (Left)	05/15/25	ND						None.
7	20481200-007DW	20481200-007DW26A	1st Floor Outside Boy's Restroom - Drinking Fountain (Right)	05/15/25	ND						None.
8	20481200-008BF	20481200-008BF26A	1st Floor Girl's Restroom Across From Office - Sink (Left)	05/20/25	0.9						None.
9	20481200-009BF	20481200-009BF26A	1st Floor Girl's Restroom Across From Office - Sink (Center)	05/20/25	1.5						None.
10	20481200-010BF	20481200-010BF26A	1st Floor Girl's Restroom Across From Office - Sink (Right)	05/20/25	0.7						None.
11	20481200-011DW	20481200-011DW26A	1st Floor By Office/Trophy Case - Bottle Filler (Upper)	05/15/25	ND	Sediment	05/01/23	04/24/25	Elkay	Ferguson	
12	20481200-012DW	20481200-012DW26A	1st Floor By Office/Trophy Case - Drinking Fountain (Lower)	05/15/25	ND	Sediment	05/01/23	04/24/25	Elkay	Ferguson	
13	20481200-013BF	20481200-013BF26A	1st Floor Left Staff Restroom Near Office - Sink	05/20/25	0.5						None.
14	20481200-014BF	20481200-014BF26A	1st Floor Right Staff Restroom Near Office - Sink	05/20/25	0.6						None.
15	20481200-015KF	20481200-015KF26A	Kitchen - Sink (Food Prep - South Wall)	05/15/25	ND						None.
16	20481200-016KF	20481200-016KF26A	Kitchen - Sink (Hand/Eye Wash - South Wall)	05/15/25	0.6						None.
17	20481200-017KF	20481200-017KF26A	Kitchen - Sink (Triple Sink - South Wall)	05/15/25	ND						None.
18	20481200-018KF	20481200-018KF26A	Kitchen - Sink (Pre-rinse/Dishwasher - Sprayer Only)	05/15/25	7.2						None.
19	20481200-019KF	20481200-019KF26A	Kitchen - Sink (Hand Wash/Serving Line)	05/15/25	0.9						None.
20	20481200-020BF	20481200-020BF26A	Kitchen Unisex Restroom - Sink	05/20/25	1.6						None.
21	20481200-021DW	20481200-021DW26A	Playground - Drinking Fountain (Outside Cafeteria) - Upper	05/15/25	ND						None.
22	20481200-022DW	20481200-022DW26A	Playground - Drinking Fountain (Outside Cafeteria) - Lower	05/05/20	0.6						Taken out of service as per custodian.
N/A	N/A	N/A	Outside Portable - Drinking Fountain (Fixture 1)	07/11/18	NA						Removed.
N/A	N/A	N/A	Outside Portable - Drinking Fountain (Fixture 2)	07/11/18	NA						Removed.
N/A	N/A	N/A	Outside Portable - Drinking Fountain (Fixture 3)	07/11/18	NA						Removed.
N/A	N/A	N/A	Outside Portable - Drinking Fountain (Fixture 4)	07/11/18	NA						Removed.
N/A	N/A	N/A	Outside Portable - Drinking Fountain (Fixture 5)	07/11/18	NA						Removed.
N/A	N/A	N/A	Outside Portable - Drinking Fountain (Fixture 6)	07/11/18	NA						Removed.
23	20481200-023DW	20481200-023DW26A	La Clinica - Exam Room # 1 - Drinking Fountain	05/15/25	ND						None.
24	20481200-024NS	20481200-024NS26A	La Clinica - Exam Room # 1 - Sink	05/15/25	0.6						None.
25	20481200-025NS	20481200-025NS26A	La Clinica - Exam Room # 2 - Sink	05/15/25	1.3						None.
26	20481200-026NS	20481200-026NS26A	La Clinica - Hand Wash Near Restroom - Sink	05/20/25	0.8						None.
27	20481200-027DW	20481200-027DW26A	Room 1 - Drinking Fountain	05/15/25	2.5						None.
28	20481200-028CF	20481200-028CF26A	Room 1 - Sink	05/15/25	8.5						None.
N/A	N/A	N/A	Room 2 - Drinking Fountain	04/09/08	NA						Removed.
29	20481200-029CF	20481200-029CF26A	Room 2 - Sink	05/15/25	1.5						None.
30	20481200-030DW	20481200-030DW26A	Room 3 - Drinking Fountain	05/15/25	2.0						None.
31	20481200-031CF	20481200-031CF26A	Room 3 - Sink	05/15/25	1.8						None.
32	20481200-032DW	20481200-032DW26A	Room 5 - Drinking Fountain	05/15/25	0.8						None.
33	20481200-033CF	20481200-033CF26A	Room 5 - Sink	05/15/25	1.4						None.
34	20481200-034DW	20481200-034DW26A	Room 6 - Drinking Fountain	05/15/25	2.8						None.
35	20481200-035CF	20481200-035CF26A	Room 6 - Sink	05/15/25	4.3						None.
36	20481200-036DW	20481200-036DW26A	Room 7 - Drinking Fountain	05/15/25	3.0	Lead	07/26/16	08/05/25	APIL3R	Amazon	
37	20481200-037CF	20481200-037CF26A	Room 7 - Sink	05/15/25	0.7						
38	20481200-038DW	20481200-038DW26A	Room 8 - Drinking Fountain	05/15/25	1.1	Lead	07/26/16	08/05/25	APIL3R	Amazon	
39	20481200-039CF	20481200-039CF26A	Room 8 - Sink	05/15/25	ND						None.
40	20481200-040SF	20481200-040SF26A	Media Center Work Room - Sink	05/15/25	ND						None.
41	20481200-041BF	20481200-041BF26A	Media Center Staff Only Unisex Restroom - Sink	05/20/25	1.0						None.
42	20481200-042DW	20481200-042DW26A	Room 9 - Drinking Fountain	05/15/25	ND						None.
43	20481200-043CF	20481200-043CF26A	Room 9 - Sink	05/15/25	ND						None.
44	20481200-044BF	20481200-044BF26A	Room 9 Unisex Restroom (Left) - Sink	05/20/25	4.4						None.
45	20481200-045BF	20481200-045BF26A	Room 9 Unisex Restroom (Right) - Sink	05/20/25	9.2						None.
46	20481200-046BF	20481200-046BF26A	Boy's Restroom Outside Room 9 - Sink (Left)	05/20/25	4.6						None.
47	20481200-047BF	20481200-047BF26A	Boy's Restroom Outside Room 9 - Sink (Center)	05/20/25	3.9						None.
48	20481200-048BF	20481200-048BF26A	Boy's Restroom Outside Room 9 - Sink (Right)	05/20/25	7.6						None.
49	20481200-049DW	20481200-049DW26A	Room 10 - Drinking Fountain	05/15/25	ND						None.
50	20481200-050CF	20481200-050CF26A	Room 10 - Sink	05/15/25	ND						None.
51	20481200-051BF	20481200-051BF26A	Room 10 Unisex Restroom - Sink	05/20/25	ND						None.
52	20481200-052DW	20481200-052DW26A	1st Floor Outside Room 11 - Drinking Fountain (Left)	05/15/25	ND						None.
53	20481200-053DW	20481200-053DW26A	1st Floor Outside Room 11 - Drinking Fountain (Right)	05/15/25	ND						None.
54	20481200-054DW	20481200-054DW26A	Room 11 - Drinking Fountain	05/15/25	ND						None.
55	20481200-055CF	20481200-055CF26A	Room 11 - Sink	05/15/25	ND						None.
56	20481200-056BF	20481200-056BF26A	Room 11 Unisex Restroom - Sink	05/20/25	0.6						None.

57	20481200-057DW	20481200-057DW26A	Room 12 - Drinking Fountain	05/15/25	8.9							None.
58	20481200-058CF	20481200-058CF26A	Room 12 - Sink	05/15/25	5.9							None.
59	20481200-059DW	20481200-059DW26A	Staff Break Room (Room 13) - Drinking Fountain	05/15/25	2.9							None.
60	20481200-060SF	20481200-060SF26A	Staff Break Room (Room 13) - Sink	05/15/25	1.1							None.
61	20481200-061CF	20481200-061CF26A	Room 14 - Sink	05/15/25	1.3							None.
62	20481200-062DW	20481200-062DW26A	Room 20 - Drinking Fountain	05/15/25	0.9							None.
63	20481200-063CF	20481200-063CF26A	Room 20 - Sink	05/15/25	3.2							None.
64	20481200-064DW	20481200-064DW26A	Room 21 - Drinking Fountain	05/15/25	0.8							None.
65	20481200-065CF	20481200-065CF26A	Room 21 - Sink	05/15/25	2.9							None.
N/A	N/A	N/A	Room 21A - Sink (Left - Faucet) (Hot)	NA	N/A							Do not test hot.
66	20481200-066CF	20481200-066CF26A	Room 21A - Sink (Right - Faucet) (Cold)	08/05/25	3.0	Lead	08/04/25			Percola		None.
67	20481200-067DW	20481200-067DW26A	Room 22 - Drinking Fountain	05/15/25	0.6							None.
68	20481200-068CF	20481200-068CF26A	Room 22 - Sink	05/15/25	3.0							None.
69	20481200-069DW	20481200-069DW26A	2nd Floor Outside Boy's Restroom/22 - Drinking Fountain (Left)	08/05/25	1.7	Lead	08/04/25			Percola		Share filter.
70	20481200-070DW	20481200-070DW26A	2nd Floor Outside Boy's Restroom/22 - Drinking Fountain (Right)	05/15/25	4.1	Lead	08/04/25			Percola		Share filter.
71	20481200-071BF	20481200-071BF26A	2nd Floor Boy's Restroom Across From Room 22 - Sink (Left)	05/20/25	5.3							None.
72	20481200-072BF	20481200-072BF26A	2nd Floor Boy's Restroom Across From Room 22 - Sink (Center)	05/20/25	ND							None.
73	20481200-073BF	20481200-073BF26A	2nd Floor Boy's Restroom Across From Room 22 - Sink (Right)	05/20/25	1.1							None.
74	20481200-074DW	20481200-074DW26A	Room 23 - Drinking Fountain	05/15/25	0.7							None.
75	20481200-075CF	20481200-075CF26A	Room 23 - Sink	05/15/25	ND							None.
76	20481200-076BF	20481200-076BF26A	2nd Floor Girl's Restroom Across From Room 23 - Sink (Left)	05/20/25	3.6							None.
77	20481200-077BF	20481200-077BF26A	2nd Floor Girl's Restroom Across From Room 23 - Sink (Center)	05/20/25	1.6							None.
78	20481200-078BF	20481200-078BF26A	2nd Floor Girl's Restroom Across From Room 23 - Sink (Right)	05/20/25	1.4							None.
79	20481200-079DW	20481200-079DW26A	2nd Floor Outside Room 23-A - Bottle Filler (Upper)	05/15/25	ND	Sediment	05/01/23	04/24/25		Elkay	Ferguson	
80	20481200-080DW	20481200-080DW26A	2nd Floor Outside Room 23-A - Fountain (Lower)	05/15/25	ND	Sediment	05/01/23	04/24/25		Elkay	Ferguson	
81	20481200-081DW	20481200-081DW26A	Room 24 - Drinking Fountain	05/15/25	0.7							None.
82	20481200-082CF	20481200-082CF26A	Room 24 - Sink	05/15/25	1.2							None.
83	20481200-083DW	20481200-083DW26A	Room 25 - Drinking Fountain	05/15/25	0.6							None.
84	20481200-084CF	20481200-084CF26A	Room 25 - Sink	05/15/25	1.1							None.
85	20481200-085DW	20481200-085DW26A	Room 26 - Drinking Fountain	05/15/25	1.4	Lead	07/26/16	08/05/25		APIL3R	Amazon	
86	20481200-086CF	20481200-086CF26A	Room 26 - Sink	05/15/25	3.0							None.
87	20481200-087DW	20481200-087DW26A	Room 27 - Drinking Fountain	05/15/25	8.6							None.
88	20481200-088CF	20481200-088CF26A	Room 27 - Sink	05/15/25	3.8							None.
89	20481200-089DW	20481200-089DW26A	2nd Floor Hallway Outside Room 27 - Drinking Fountain (Left)	05/15/25	1.2	Lead	07/27/17	08/05/25		3US-MAX-F01H	Lowes	
90	20481200-090DW	20481200-090DW26A	2nd Floor Hallway Outside Room 27 - Drinking Fountain (Right)	05/15/25	4.8	Lead	07/27/17	08/05/25		3US-MAX-F01H	Lowes	
91	20481200-091DW	20481200-091DW26A	Room 28 - Drinking Fountain	05/15/25	2.2							None.
92	20481200-092CF	20481200-092CF26A	Room 28 - Sink	05/15/25	2.8							None.
93	20481200-093DW	20481200-093DW26A	Room 29 - Drinking Fountain	05/15/25	0.8	Lead	05/08/08	05/15/18		3US-MAX-F01H	Lowes	
94	20481200-094CF	20481200-094CF26A	Room 29 - Sink	05/15/25	7.0							None.
95	20481200-095BF	20481200-095BF26A	Girl's Restroom Across From Room 29 - Sink (Left)	05/20/25	9.0							None.
96	20481200-096BF	20481200-096BF26A	Girl's Restroom Across From Room 29 - Sink (Center)	05/20/25	8.3							None.
97	20481200-097BF	20481200-097BF26A	Girl's Restroom Across From Room 29 - Sink (Right)	05/20/25	13.8							None.
98	20481200-098DW	20481200-098DW26A	Room 30 - Drinking Fountain	05/15/25	2.0							None.
99	20481200-099CF	20481200-099CF26A	Room 30 - Sink	05/15/25	3.6							None.
100	20481200-100DW	20481200-100DW26A	Room 31 - Drinking Fountain	05/15/25	9.6							None.
101	20481200-101CF	20481200-101CF26A	Room 31 - Sink	05/15/25	10.5							None.

*None Detected (ND) = 0.515 Or Less PPB

= Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)

*The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.