



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 21, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Washington Elem Lead Testing-~~AMENDED~~ Order No.: 25050760

Dear Andy Chasteen:

Neilson Research Corporation received 25 sample(s) on 5/15/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation

245 S Grape St

Medford, OR 97501

TEL: (541) 770-5678 FAX: (541) 770-2901

Website: www.nrclabs.com

Case Narrative

WO#: 25050760

Date: 7/21/2025

CLIENT: Medford School District

Project: Washington Elem Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-01 Client Sample ID: Rm 1-DF
 Collection Date: 5/15/2025 5:23:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 1-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.50		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-02 Client Sample ID: Rm 1-Sink
 Collection Date: 5/15/2025 5:24:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 1-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.54		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-03 Client Sample ID: Rm 2-Sink
 Collection Date: 5/15/2025 5:25:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 2-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.49		0.500	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-04 Client Sample ID: Rm 3-DF
 Collection Date: 5/15/2025 5:26:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 3-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.96		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-05 Client Sample ID: Rm 3-Sink
 Collection Date: 5/15/2025 5:27:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 3-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.84		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-06 Client Sample ID: Rm 5-DF
 Collection Date: 5/15/2025 5:28:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 5-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.839		0.500	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-07 Client Sample ID: Rm 5-Sink
 Collection Date: 5/15/2025 5:29:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 5-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.37		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-08 Client Sample ID: Rm 6-DF
 Collection Date: 5/15/2025 5:30:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 6-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.77		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-09 Client Sample ID: Rm 6-Sink
 Collection Date: 5/15/2025 5:31:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 6-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.27		0.500	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760

Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-10 Client Sample ID: Rm 7-DF
 Collection Date: 5/15/2025 5:32:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 7-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.02		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-11 Client Sample ID: Rm 7-Sink
 Collection Date: 5/15/2025 5:33:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 7-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.658		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-12 Client Sample ID: Rm 8-DF
 Collection Date: 5/15/2025 5:34:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 8-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.09		0.500	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-13 Client Sample ID: Rm 8-Sink
 Collection Date: 5/15/2025 5:35:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 8-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-14 Client Sample ID: Media Ctr Work Rm-Sink
 Collection Date: 5/15/2025 5:38:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Media Ctr Work Rm-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-15 Client Sample ID: Media Ctr Staff Unisex RR-Sink
 Collection Date: 5/15/2025 5:39:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Media Ctr Staff Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.34		0.500	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-16 Client Sample ID: Rm 9-DF
 Collection Date: 5/15/2025 5:40:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-17 Client Sample ID: Rm 9-Sink
 Collection Date: 5/15/2025 5:41:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-18 Client Sample ID: Rm 9 Unisex RR-Sink (L)
 Collection Date: 5/15/2025 5:43:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9 Unisex RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	7.80		0.500	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760

Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-19 Client Sample ID: Rm 9 Unisex RR-Sink (R)
 Collection Date: 5/15/2025 5:45:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9 Unisex RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-20 Client Sample ID: Boy's RR O/S Rm 9-Sink (L)
 Collection Date: 5/15/2025 5:47:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.59		0.515	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-21 Client Sample ID: Boy's RR O/S Rm 9-Sink (C)
 Collection Date: 5/15/2025 5:48:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Sink (C)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.42		0.515	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-22 Client Sample ID: Boy's RR O/S Rm 9-Sink (R)
 Collection Date: 5/15/2025 5:49:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.40		0.515	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-23 Client Sample ID: Rm 10-DF
 Collection Date: 5/15/2025 5:50:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 10-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/11/2025	15.0	A	

Lab ID: 25050760-24 Client Sample ID: Rm 10-Sink
 Collection Date: 5/15/2025 5:51:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 10-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/11/2025	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 7/21/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 7/21/2025 1:48:57 PM

Sample Information:

Lab ID: 25050760-25 Client Sample ID: Rm 10 Unisex RR-Sink
 Collection Date: 5/15/2025 5:52:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 10 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	A

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- DF Dilution Factor
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- R RPD outside accepted recovery limits
- C1 Sample container temperature is out of limit as specified at testcode
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050760
 21-Jul-25

Client: Medford School District
Project: Washington Elem Lead Testing-AMENDED
TestCode: LEAD_SCHOOLS

Sample ID:	MB-31655	SampType:	MBLK	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/11/2025	RunNo:	60207
Client ID:	PBW	Batch ID:	31655	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986322
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID:	LCS-31655	SampType:	LCS	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/11/2025	RunNo:	60207
Client ID:	LCSW	Batch ID:	31655	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986323
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.520	100	0	105	85	115				

Sample ID:	MB-31631	SampType:	MBLK	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/10/2025	RunNo:	60207
Client ID:	PBW	Batch ID:	31631	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986340
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID:	LCS-31631	SampType:	LCS	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/10/2025	RunNo:	60207
Client ID:	LCSW	Batch ID:	31631	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986342
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	108	0.500	100	0	108	85	115				

Qualifiers: CI Sample container temperature is out of limit as specified at testcode
 MI Recovery outside control limits due to Matrix Interference
 DF Dilution Factor
 ND Not Detected at the Reporting Limit
 H Holding times for preparation or analysis exceed
 RL Reporting Limit

Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050760
 21-Jul-25

Client: Medford School District
Project: Washington Elem Lead Testing-AMENDED
TestCode: LEAD_SCHOOLS

Sample ID:	25050758-23AMS	SampType:	MS	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/10/2025	RunNo:	60207
Client ID:	BatchQC	Batch ID:	31631	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986344
Analyte	Result	PQL	0.500	SPK value	100	0.742	104	%REC	104	RPD Ref Val	130
Lead								LowLimit	70	%RPD	RPDLimit
								HighLimit			Qual

Sample ID:	25050758-23AMS	SampType:	MSD	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/10/2025	RunNo:	60207
Client ID:	BatchQC	Batch ID:	31631	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986345
Analyte	Result	PQL	0.500	SPK value	100	0.742	102	%REC	102	RPD Ref Val	105
Lead								LowLimit	70	%RPD	RPDLimit
								HighLimit			Qual

Sample ID:	25050719-51AMS	SampType:	MS	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/11/2025	RunNo:	60207
Client ID:	BatchQC	Batch ID:	31655	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986356
Analyte	Result	PQL	0.520	SPK value	100	0.769	105	%REC	105	RPD Ref Val	130
Lead								LowLimit	70	%RPD	RPDLimit
								HighLimit			Qual

Sample ID:	25050719-51AMS	SampType:	MSD	TestCode:	LEAD_SCHO	Units:	ppb	Prep Date:	6/11/2025	RunNo:	60207
Client ID:	BatchQC	Batch ID:	31655	TestNo:	E200.8	E200.8		Analysis Date:	6/11/2025	SeqNo:	986357
Analyte	Result	PQL	0.520	SPK value	100	0.769	105	%REC	105	RPD Ref Val	106
Lead								LowLimit	70	%RPD	RPDLimit
								HighLimit			Qual

Qualifiers: CI Sample container temperature is out of limit as specified at testcode
 MI Recovery outside control limits due to Matrix Interference
 DF Dilution Factor
 ND Not Detected at the Reporting Limit
 H Holding times for preparation or analysis exceed
 RL Reporting Limit




Revision v1



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 25050760 RcptNo: 1

Logged by:	Ashley Spiegelberg	5/15/2025 8:46:00 AM	
Completed By:	Coni Boyko	5/16/2025 2:33:59 PM	
Reviewed By:	Ashley Spiegelberg	6/13/2025 10:39:49 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present NA
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
- HNO3 pH<2
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels?
 (Note discrepancies on chain of custody) Yes No
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met?
 (If no, notify customer for authorization.) Yes No

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: MSD 549C	Address: 902 Kenyon Medford, OR 97501	Project Name: Washington	Project Number:	Attention: Accounting	Company Name: Medford School District	Standard 10-14 Days	
Email: andy.chasteen@medford.k12.or.us	Phone: 541-840-4315	Report To: andy.chasteen@medford.k12.or.us	Copy To: seth.barry@medford.k12.or.us	Address: 900 Kenyon Medford, OR 97501	5 Business Days (50% surcharge)		3 Business Days (75% surcharge)
Fax Report: Yes ___ No ___		Fax: _____		P.O. # _____	24 - 48 hours (100% surcharge)		Other _____
Collected By (Print): <u>Cody Fleming</u>		Mail Report: Yes ___ No ___		Authorized: Yes ___ No ___			
Collected By (Sign): <u>Cody Fleming</u>		Fax Report: Yes ___ No ___					

Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers	* Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Room 1 - Drinking Fountain	DW	5/15/2025	5:23	1			01
Room 1 - Sink	DW	5/15/2025	5:24	1			02
Room 2 - Sink	DW	5/15/2025	5:25	1			03
Room 3 - Drinking Fountain	DW	5/15/2025	5:26	1			04
Room 3 - Sink	DW	5/15/2025	5:27	1			05
Room 5 - Drinking Fountain	DW	5/15/2025	5:28	1			06
Room 5 - Sink	DW	5/15/2025	5:29	1			07
Room 6 - Drinking Fountain	DW	5/15/2025	5:30	1			08
Room 6 - Sink	DW	5/15/2025	5:31	1			09
Room 7 - Drinking Fountain	DW	5/15/2025	5:32	1			10
Room 7 - Sink	DW	5/15/2025	5:33	1			11
Room 8 - Drinking Fountain	DW	5/15/2025	5:34	1			12
Room 8 - Sink	DW	5/15/2025	5:35	1			13
Media Center Work Room - Sink	DW	5/15/2025	5:38	1			14
Media Center Staff Only Unisex Restroom - Sink	DW	5/15/2025	5:39	1			15
Room 9 - Drinking Fountain	DW	5/15/2025	5:40	1			16
Room 9 - Sink	DW	5/15/2025	5:41	1			17
Room 9 Unisex Restroom (Left) - Sink	DW	5/15/2025	5:43	1			18
Room 9 Unisex Restroom (Right) - Sink	DW	5/15/2025	5:45	1			19
Boy's Restroom Outside Room 9 - Sink (Left)	DW	5/15/2025	5:47	1			20
Boy's Restroom Outside Room 9 - Sink (Center)	DW	5/15/2025	5:48	1			21
Boy's Restroom Outside Room 9 - Sink (Right)	DW	5/15/2025	5:49	1			22
Room 10 - Drinking Fountain	DW	5/15/2025	5:50	1			23

