

Lead Tests - Griffin Creek Elementary School- Main Building - # 20480100											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results (PPB)	Filtering For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20480100-001DW	20480100-001DW26A	Health Room - Drinking Fountain	05/13/25	ND						None.
2	20480100-002NS	20480100-002NS26A	Health Room - Sink	05/13/25	ND						None.
3	20480100-003BF	20480100-003BF26A	Health Room Restroom - Sink	05/20/25	ND						None.
4	20480100-004SF	20480100-004SF26A	Staff Break Room - Sink (Main Fixture)	05/13/25	ND						None.
5	20480100-005WB	20480100-005WB26A	Staff Break Room - Sink (Bottle Filler)	05/13/25	ND						None.
6	20480100-006BF	20480100-006BF26A	Unisex Restroom Outside Staff Break Room - Sink	05/13/25	3.3						None.
7	20480100-007DW	20480100-007DW26A	Room 9 - Drinking Fountain	05/13/25	0.6						None.
8	20480100-008CF	20480100-008CF26A	Room 9 - Sink	05/13/25	0.6						None.
9	20480100-009DW	20480100-009DW26A	Room 10 - Drinking Fountain	05/13/25	0.9						None.
10	20480100-010CF	20480100-010CF26A	Room 10 - Sink	05/13/25	ND						None.
11	20480100-011DW	20480100-011DW26A	Room 11 - Drinking Fountain	05/13/25	0.5						None.
12	20480100-012CF	20480100-012CF26A	Room 11 - Sink	05/13/25	0.7						None.
13	20480100-013BF	20480100-013BF26A	Staff Men's Restroom In-between Rooms 11/12 - Sink	05/20/25	0.7						None.
14	20480100-014BF	20480100-014BF26A	Staff Women's Restroom In-between Rooms 11/12 - Sink	05/20/25	ND						None.
15	20480100-015BF	20480100-015BF26A	Girl's Restroom Adjacent To Room 12 - Sink (Left)	05/20/25	ND						None.
16	20480100-016BF	20480100-016BF26A	Girl's Restroom Adjacent To Room 12 - Sink (Right)	05/20/25	ND						None.
17	20480100-017BF	20480100-017BF26A	Boy's Restroom Adjacent To Room 12 - Sink (Left)	05/20/25	ND						None.
18	20480100-018BF	20480100-018BF26A	Boy's Restroom Adjacent To Room 12 - Sink (Right)	05/20/25	0.6						None.
19	20480100-019DW	20480100-019DW26A	Room 12 - Drinking Fountain	05/13/25	0.6						None.
20	20480100-020CF	20480100-020CF26A	Room 12 - Sink	05/13/25	ND						None.
21	20480100-021DW	20480100-021DW26A	Room 13 - Drinking Fountain	05/13/25	0.6						None.
22	20480100-022CF	20480100-022CF26A	Room 13 - Sink	05/13/25	ND						None.
23	20480100-023DW	20480100-023DW26A	Room 14 - Drinking Fountain	05/13/25	ND						None.
24	20480100-024CF	20480100-024CF26A	Room 14 - Sink	05/13/25	ND						None.
25	20480100-025DW	20480100-025DW26A	Room 15 - Drinking Fountain	05/13/25	ND						None.
26	20480100-026CF	20480100-026CF26A	Room 15 - Sink	05/13/25	ND						None.
27	20480100-027DW	20480100-027DW26A	Room 16 - Drinking Fountain	05/13/25	ND						None.
28	20480100-028CF	20480100-028CF26A	Room 16 - Sink	05/13/25	ND						None.
29	20480100-029DW	20480100-029DW26A	Room 17 - Drinking Fountain	05/13/25	ND						None.
30	20480100-030CF	20480100-030CF26A	Room 17 - Sink	05/13/25	ND						None.
31	20480100-031DW	20480100-031DW26A	Room 18 - Drinking Fountain	05/13/25	ND						None.
32	20480100-032CF	20480100-032CF26A	Room 18 - Sink	05/13/25	ND						None.
33	20480100-033DW	20480100-033DW26A	Room 19 - Drinking Fountain	05/13/25	1.8						None.
34	20480100-034CF	20480100-034CF26A	Room 19 - Sink	05/13/25	ND						None.
35	20480100-035DW	20480100-035DW26A	Room 20 - Drinking Fountain	05/13/25	ND						None.
36	20480100-036CF	20480100-036CF26A	Room 20 - Sink	05/13/25	ND						None.
37	20480100-037BF	20480100-037BF26A	Men's Restroom Outside Cafeteria - Sink (Left)	05/20/25	ND						None.
38	20480100-038BF	20480100-038BF26A	Men's Restroom Outside Cafeteria - Sink (Right)	05/20/25	0.6						None.
39	20480100-039BF	20480100-039BF26A	Women's Restroom Outside Cafeteria - Sink (Left)	05/20/25	ND						None.
40	20480100-040BF	20480100-040BF26A	Women's Restroom Outside Cafeteria - Sink (Right)	05/20/25	ND						None.
Lead Tests - Griffin Creek Elementary School- Rooms 1-8 Building - # 20480101											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Filtering For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20480101-001DW	20480101-001DW26A	Room 1 - Drinking Fountain	05/13/25	ND						None.
2	20480101-002CF	20480101-002CF26A	Room 1 - Sink	05/13/25	1.1						None.
3	20480101-003BF	20480101-003BF26A	Room 1 Unisex Restroom - Sink	05/20/25	0.9						None.
4	20480101-004DW	20480101-004DW26A	Room 2 - Drinking Fountain	05/13/25	ND						None.
5	20480101-005CF	20480101-005CF26A	Room 2 - Sink	05/13/25	0.9						None.
6	20480101-006BF	20480101-006BF26A	Room 2 Unisex Restroom - Sink	05/20/25	1.1						None.
7	20480101-007DW	20480101-007DW26A	Room 3 - Drinking Fountain	05/13/25	0.7						None.
8	20480101-008CF	20480101-008CF26A	Room 3 - Sink	05/13/25	ND						None.
9	20480101-009DW	20480101-009DW26A	Room 4 - Drinking Fountain	05/13/25	ND						None.
10	20480101-010CF	20480101-010CF26A	Room 4 - Sink	05/13/25	0.8						None.
11	20480101-011BF	20480101-011BF26A	Boy's Restroom Next to Room 4 (Old - Adjacent To The Custodian Office) - Sink (Left)	05/20/25	1.1						None.
12	20480101-012BF	20480101-012BF26A	Boy's Restroom Next to Room 4 (Adjacent To The Custodian Office) - Sink (Right)	05/13/25	0.6						None.
13	20480101-013BF	20480101-013BF26A	Girl's Restroom Next to Room 4 (Adjacent To The Custodian Office) - Sink (Left)	05/20/25	0.9						None.
14	20480101-014BF	20480101-014BF26A	Girl's Restroom Next to Room 4 (Adjacent To The Custodian Office) - Sink (Right)	05/20/25	0.9						None.
15	20480101-015DW	20480101-015DW26A	Playground (Near Custodial Office) - Drinking Fountain (Left)	05/13/25	ND						None.
16	20480101-016DW	20480101-016DW26A	Playground (Near Custodial Office) - Drinking Fountain (Right)	05/13/25	ND						None.
17	20480101-017DW	20480101-017DW26A	Room 5 - Drinking Fountain	05/13/25	0.6						None.
18	20480101-018CF	20480101-018CF26A	Room 5 - Sink	05/13/25	ND						None.
19	20480101-019BF	20480101-019BF26A	Boy's Restroom In-between Rooms 5/6 - Sink (Hallway Access)	05/20/25	1.3						To be replaced summer 2025.
20	20480101-020BF	20480101-020BF26A	Girl's Restroom In-between Rooms 5/6 - Sink (Outside Access)	05/20/25	ND						To be replaced summer 2025.
21	20480101-021DW	20480101-021DW26A	Room 6 - Drinking Fountain	05/13/25	ND						None.
22	20480101-022CF	20480101-022CF26A	Room 6 - Sink	05/13/25	ND						None.
23	20480101-023DW	20480101-023DW26A	Room 7 - Drinking Fountain	05/13/25	ND						None.
24	20480101-024CF	20480101-024CF26A	Room 7 - Sink	05/13/25	ND						None.
25	20480101-025DW	20480101-025DW26A	Room 8 - Drinking Fountain	05/13/25	ND						None.
26	20480101-026CF	20480101-026CF26A	Room 8 - Sink	05/13/25	ND						None.

Lead Tests - Griffin Creek Elementary School- Rooms 26-29 Building - # 20480102											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Filtering For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20480102-001DW	20480102-001DW26A	Room 26 - Drinking Fountain	05/13/25	ND						None.
2	20480102-002CF	20480102-002CF26A	Room 26 - Sink	05/13/25	ND						None.
3	20480102-003DW	20480102-003DW26A	Room 27 - Drinking Fountain	05/13/25	ND						None.
4	20480102-004CF	20480102-004CF26A	Room 27 - Sink	05/13/25	ND						None.
5	20480102-005DW	20480102-005DW26A	Room 28 - Drinking Fountain	05/13/25	ND	Copper	10/10/18	11/17/23	Pentair F1B1-4C	Online	
6	20480102-006CF	20480102-006CF26A	Room 28 - Sink	05/13/25	ND						None.
7	20480102-007DW	20480102-007DW26A	Room 29 - Drinking Fountain	05/13/25	ND	Copper	10/10/18	04/01/19	American Plumber 600R	Ferguson	
8	20480102-008CF	20480102-008CF26A	Room 29 - Sink	05/13/25	ND						None.
9	20480102-009DW	20480102-009DW26A	Playground (Near Track) - Drinking Fountain (Upper)	05/13/25	ND	Lead	07/27/16	06/15/18	3US-MAX-F01H	Lowes	
10	20480102-010DW	20480102-010DW26A	Playground (Near Track) - Drinking Fountain (Lower)	05/13/25	ND	Lead	07/27/16	06/15/18	3US-MAX-F01H	Lowes	
Lead Tests - Griffin Creek Elementary School- Rooms 21-25 Building - # 20480103											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Filtering For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20480103-001DW	20480103-001DW26A	Room 21 - Drinking Fountain	05/13/25	ND						None.
2	20480103-002CF	20480103-002CF26A	Room 21 - Sink	05/13/25	ND						None.
3	20480103-003DW	20480103-003DW26A	Room 22 - Drinking Fountain	05/13/25	ND						None.
4	20480103-004CF	20480103-004CF26A	Room 22 - Sink	05/13/25	ND						None.
5	20480103-005DW	20480103-005DW26A	Room 23 - Drinking Fountain	05/13/25	ND						None.
6	20480103-006CF	20480103-006CF26A	Room 23 - Sink	05/13/25	0.6						None.
7	20480103-007DW	20480103-007DW26A	Room 24 - Drinking Fountain	05/13/25	ND						None.
8	20480103-008CF	20480103-008CF26A	Room 24 - Sink	05/13/25	ND						None.
9	20480103-009DW	20480103-009DW26A	Room 25 - Drinking Fountain	05/13/25	ND						None.
10	20480103-010CF	20480103-010CF26A	Room 25 - Sink	05/13/25	0.6						None.
11	20480103-011BF	20480103-011BF26A	Boy's Restroom Adjacent To Room 25 -Sink (1) Left side	05/13/25	1.0						None.
12	20480103-012BF	20480103-012BF26A	Boy's Restroom Adjacent To Room 25 -Sink (2)	05/13/25	0.9						None.
13	20480103-013BF	20480103-013BF26A	Boy's Restroom Adjacent To Room 25 -Sink (3)	05/13/25	1.3						None.
14	20480103-014BF	20480103-014BF26A	Boy's Restroom Adjacent To Room 25 -Sink (4)	05/13/25	0.8						None.
15	20480103-015BF	20480103-015BF26A	Boy's Restroom Adjacent To Room 25 -Sink (5) Right side	05/13/25	0.6						None.
16	20480103-016BF	20480103-016BF26A	Girl's Restroom Adjacent To Room 25 -Sink (1) Left side	05/20/25	ND						None.
17	20480103-017BF	20480103-017BF26A	Girl's Restroom Adjacent To Room 25 -Sink (2)	05/20/25	ND						None.
18	20480103-018BF	20480103-018BF26A	Girl's Restroom Adjacent To Room 25 -Sink (3)	05/20/25	ND						None.
19	20480103-019BF	20480103-019BF26A	Girl's Restroom Adjacent To Room 25 -Sink (4)	05/20/25	ND						None.
20	20480103-020BF	20480103-020BF26A	Girl's Restroom Adjacent To Room 25 -Sink (5) Right side	05/20/25	ND						None.
Lead Tests - Griffin Creek Elementary School- Gym Building - # 20480104											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Filtering For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20480104-001DW	20480104-001DW26A	Gym - Drinking Fountain (North)	05/13/25	2.5						None.
2	20480104-002DW	20480104-002DW26A	Gym - Drinking Fountain (South)	05/13/25	1.0						None.
3	20480104-003BF	20480104-003BF26A	Gym Women's Restroom - Sink	05/13/25	0.7						None.
4	20480104-004BF	20480104-004BF26A	Gym Men's Restroom - Sink	05/20/25	ND						None.
5	20480104-005OT	20480104-005OT26A	Stage - Sink (Utility)	05/13/25	ND						None.
6	20480104-006DW	20480104-006DW26A	Room Above The Stage (South) - Drinking Fountain	05/13/25	0.7						None.
7	20480104-007SF	20480104-007SF26A	Room Above The Stage (South) - Sink	05/13/25	2.9						None.
Lead Tests - Griffin Creek Elementary School- Cafeteria Building - # 20480105											
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Filtering For	Date Filter Installed	Date of Last Filter Change	Filter Type	Supplier	Remarks
1	20480105-001WB	20480105-001WB26A	Cafeteria - Bottle Filler (Upper)	05/13/25	ND	Sediment	01/15/23	02/01/24	Elkay	Ferguson	
2	20480105-002DW	20480105-002DW26A	Cafeteria - DW (Lower)	05/13/25	ND	Sediment	01/15/23	02/01/24	Elkay	Ferguson	
3	20480105-003KF	20480105-003KF26A	Kitchen - Sink (Food Prep - North Wall)	05/13/25	ND						None.
4	20480105-004KF	20480105-004KF26A	Kitchen - Sink (Hand/Eye Wash)	05/13/25	ND						None.
5	20480105-005KF	20480105-005KF26A	Kitchen - Sink (Pre-rinse/Dishwasher)	05/13/25	ND						None.
6	20480105-006BF	20480105-006BF26A	Cafeteria Staff Restroom - Sink	05/13/25	ND						None.

*None Detected (ND) = 0.500 Or Less PPB

= Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)

*The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.