



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 18, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Griffin Creek School Leads-AMENDED

Order No.: 25050593

Dear Andy Chasteen:

Neilson Research Corporation received 27 sample(s) on 5/13/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050593
Date: 7/18/2025

CLIENT: Medford School District

Project: Griffin Creek School Leads-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-01 **Client Sample ID:** Health Room-DF
Collection Date: 5/13/2025 5:29:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Health Room-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/2/2025	15.0	A

Lab ID: 25050593-02 **Client Sample ID:** Health Room-Sink
Collection Date: 5/13/2025 5:29:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Health Room-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/2/2025	15.0	A

Lab ID: 25050593-03 **Client Sample ID:** Health Room RR-Sink
Collection Date: 5/13/2025 5:29:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Health Room RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/2/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-04 Client Sample ID: Staff BR-Sink (Main Fixture)
Collection Date: 5/13/2025 5:31:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Staff BR-Sink (Main Fixture)

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/2/2025	15.0	A

Lab ID: 25050593-05 Client Sample ID: Staf BR-Sink (Bottle Filler)
Collection Date: 5/13/2025 5:31:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Staf BR-Sink (Bottle Filler)

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/2/2025	15.0	A

Lab ID: 25050593-06 Client Sample ID: Unisex RR Outside Staff BR-Sink
Collection Date: 5/13/2025 5:38:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Unisex RR Outside Staff BR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.30		0.500	ppb	1	6/2/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-07 **Client Sample ID:** Room 9-DF
Collection Date: 5/13/2025 5:39:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 9-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.613		0.500	ppb	1	6/2/2025	15.0	A

Lab ID: 25050593-08 **Client Sample ID:** Room 9-Sink
Collection Date: 5/13/2025 5:39:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 9-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.616		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-09 **Client Sample ID:** Room 10-DF
Collection Date: 5/13/2025 5:40:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 10-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.948		0.500	ppb	1	6/3/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-10 **Client Sample ID:** Room 10-Sink
Collection Date: 5/13/2025 5:41:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 10-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-11 **Client Sample ID:** Room 11-DF
Collection Date: 5/13/2025 5:43:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 11-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.501		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-12 **Client Sample ID:** Room 11-Sink
Collection Date: 5/13/2025 5:43:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 11-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.703		0.500	ppb	1	6/3/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-13 **Client Sample ID:** Staff Mens RR Between Rm 11/12-Sink
Collection Date: 5/13/2025 5:44:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Staff Mens RR Between Rm 11/12-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.713		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-14 **Client Sample ID:** Staff Womens RR Between Rm 11/12-Sink
Collection Date: 5/13/2025 5:45:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Staff Womens RR Between Rm 11/12-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-15 **Client Sample ID:** Girls RR Adj Room 12-Sink (L)
Collection Date: 5/13/2025 5:46:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Girls RR Adj Room 12-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-16 **Client Sample ID:** Girls RR Adj Room 12-Sink (R)
Collection Date: 5/13/2025 5:47:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Girls RR Adj Room 12-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-17 **Client Sample ID:** Boys RR Adj Room 12-Sink (L)
Collection Date: 5/13/2025 5:48:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Boys RR Adj Room 12-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.717		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-18 **Client Sample ID:** Boys RR Adj Room 12-Sink (R)
Collection Date: 5/13/2025 5:49:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Boys RR Adj Room 12-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.593		0.500	ppb	1	6/3/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-19 Client Sample ID: Room 12-DF
Collection Date: 5/13/2025 5:51:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 12-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.594		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-20 Client Sample ID: Room 12-Sink
Collection Date: 5/13/2025 5:52:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 12-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-21 Client Sample ID: Room 13-DF
Collection Date: 5/13/2025 5:53:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 13-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.575		0.500	ppb	1	6/3/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-22 Client Sample ID: Room 13-Sink
Collection Date: 5/13/2025 5:53:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 13-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-23 Client Sample ID: Room 14-DF
Collection Date: 5/13/2025 5:53:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 14-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-24 Client Sample ID: Room 14-Sink
Collection Date: 5/13/2025 5:56:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 14-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050593

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050593
Received Date: 5/13/2025 9:19:00 AM
Reported Date: 7/18/2025 4:09:59 PM

Sample Information:

Lab ID: 25050593-25 Client Sample ID: Room 15-DF
Collection Date: 5/13/2025 5:59:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 15-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-26 Client Sample ID: Room 15-Sink
Collection Date: 5/13/2025 6:00:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 15-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

Lab ID: 25050593-27 Client Sample ID: Room 16-DF
Collection Date: 5/13/2025 6:01:00 AM Collected By: Seth Barry
Matrix: Drinking Water Sample Location: Room 16-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/3/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050593
18-Jul-25

Client: Medford School District
Project: Griffin Creek School Leads-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31488	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939						
Client ID: PBW	Batch ID: 31488	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981158						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31488	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939						
Client ID: LCSW	Batch ID: 31488	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981159						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0	104	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25051311-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939						
Client ID: BatchQC	Batch ID: 31488	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981161						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.4	0.500	100	0.647	98.7	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25051311-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939						
Client ID: BatchQC	Batch ID: 31488	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981162						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.2	0.500	100	0.647	98.5	70	130	99.4	0.213	20	
------	------	-------	-----	-------	------	----	-----	------	-------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050593
18-Jul-25

Client: Medford School District
Project: Griffin Creek School Leads-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31490	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59994						
Client ID: PBW	Batch ID: 31490	TestNo: E200.8	E200.8	Analysis Date: 6/3/2025	SeqNo: 982051						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31490	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59994						
Client ID: LCSW	Batch ID: 31490	TestNo: E200.8	E200.8	Analysis Date: 6/3/2025	SeqNo: 982052						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	107	0.500	100	0	107	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050593-08AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59994						
Client ID: Room 9-Sink	Batch ID: 31490	TestNo: E200.8	E200.8	Analysis Date: 6/3/2025	SeqNo: 982054						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0.616	103	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 25050593-08AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59994						
Client ID: Room 9-Sink	Batch ID: 31490	TestNo: E200.8	E200.8	Analysis Date: 6/3/2025	SeqNo: 982055						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	106	0.500	100	0.616	105	70	130	104	1.72	20	
------	-----	-------	-----	-------	-----	----	-----	-----	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Revision v1

Sample Log-In Check List

Client Name: MedfordSchoolDist

Work Order Number: 25050593

RcptNo: 1

Logged by: Ashley Spiegelberg 5/13/2025 9:19:00 AM

Completed By: Coni Boyko 5/16/2025 12:38:22 PM

Reviewed By: Tamra Schmedemann 6/5/2025 12:27:02 PM

Coni Boyko
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

