



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 22, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Griffin Creek Lead Testing-AMENDED

Order No.: 25050920

Dear Andy Chasteen:

Neilson Research Corporation received 25 sample(s) on 5/20/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050920
Date: 7/22/2025

CLIENT: Medford School District

Project: Griffin Creek Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Sample ID 25050920-15A was not received.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920
Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-01 **Client Sample ID:** Health Room RR-Sink
Collection Date: 5/20/2025 6:24:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Health Room RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-02 **Client Sample ID:** Staff Men's RR By Rms 11/12-Sink
Collection Date: 5/20/2025 6:25:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Staff Men's RR By Rms 11/12-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.687		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-03 **Client Sample ID:** Staff Women's RR By Rms 11/12-Sink
Collection Date: 5/20/2025 6:26:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Staff Women's RR By Rms 11/12-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-04 **Client Sample ID:** Girl's RR Adj to Rm 12-Sink (L)
Collection Date: 5/20/2025 6:26:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Girl's RR Adj to Rm 12-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-05 **Client Sample ID:** Girl's RR Adj to Rm 12-Sink (R)
Collection Date: 5/20/2025 6:27:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Girl's RR Adj to Rm 12-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-06 **Client Sample ID:** Boy's RR Adj to Rm 12-Sink (L)
Collection Date: 5/20/2025 6:28:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Boy's RR Adj to Rm 12-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-07 **Client Sample ID:** Boy's RR Adj to Rm 12-Sink (R)
Collection Date: 5/20/2025 6:28:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Boy's RR Adj to Rm 12-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.580		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-08 **Client Sample ID:** Men's RR O/S Cafe-Sink (L)
Collection Date: 5/20/2025 6:31:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Men's RR O/S Cafe-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-09 **Client Sample ID:** Men's RR O/S Cafe-Sink (R)
Collection Date: 5/20/2025 6:31:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Men's RR O/S Cafe-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.603		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920
Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-10 **Client Sample ID:** Women's RR O/S Cafe-Sink (L)
Collection Date: 5/20/2025 6:33:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Women's RR O/S Cafe-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-11 **Client Sample ID:** Women's RR O/S Cafe-Sink (R)
Collection Date: 5/20/2025 6:33:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Women's RR O/S Cafe-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-12 **Client Sample ID:** Room 1 Unisex RR-Sink
Collection Date: 5/20/2025 6:36:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Room 1 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.866		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-13 Client Sample ID: Room 2 Unisex RR-Sink
Collection Date: 5/20/2025 6:37:00 AM Collected By: Larry Anderson
Matrix: Drinking Water Sample Location: Room 2 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.11		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-14 Client Sample ID: Boy's RR By Rm 4-Sink (L)
Collection Date: 5/20/2025 6:41:00 AM Collected By: Larry Anderson
Matrix: Drinking Water Sample Location: Boy's RR By Rm 4-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.05		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-15 Client Sample ID: Boy's RR By Rm 4-Sink (R)
Collection Date: 5/20/2025 6:41:00 AM Collected By: Larry Anderson
Matrix: Drinking Water Sample Location: Boy's RR By Rm 4-Sink (R)

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-16 **Client Sample ID:** Girl's RR By Rm 4-Sink (L)
Collection Date: 5/20/2025 6:40:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Girl's RR By Rm 4-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.940		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-17 **Client Sample ID:** Girl's RR By Rm 4-Sink (R)
Collection Date: 5/20/2025 6:40:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Girl's RR By Rm 4-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.917		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-18 **Client Sample ID:** Boy's RR By Rms 5/6-Sink (Hall)
Collection Date: 5/20/2025 6:44:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Boy's RR By Rms 5/6-Sink (Hall)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.34		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-19 **Client Sample ID:** Girl's RR By Rms 5/6-Sink (O/S)
Collection Date: 5/20/2025 6:45:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Girl's RR By Rms 5/6-Sink (O/S)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-20 **Client Sample ID:** Girl's RR By Rm 25-Sink 1 (L)
Collection Date: 5/20/2025 6:56:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Girl's RR By Rm 25-Sink 1 (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-21 **Client Sample ID:** Girl's RR By Rm 25-Sink 2
Collection Date: 5/20/2025 6:56:00 AM **Collected By:** Larry Anderson
Matrix: Drinking Water **Sample Location:** Girl's RR By Rm 25-Sink 2

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-22 Client Sample ID: Girl's RR By Rm 25-Sink 3
Collection Date: 5/20/2025 6:56:00 AM Collected By: Larry Anderson
Matrix: Drinking Water Sample Location: Girl's RR By Rm 25-Sink 3

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-23 Client Sample ID: Girl's RR By Rm 25-Sink 4
Collection Date: 5/20/2025 6:57:00 AM Collected By: Larry Anderson
Matrix: Drinking Water Sample Location: Girl's RR By Rm 25-Sink 4

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

Lab ID: 25050920-24 Client Sample ID: Girl's RR By Rm 25-Sink 5 (R)
Collection Date: 5/20/2025 6:57:00 AM Collected By: Larry Anderson
Matrix: Drinking Water Sample Location: Girl's RR By Rm 25-Sink 5 (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050920
Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050920
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 7/22/2025 7:58:08 AM

Sample Information:

Lab ID: 25050920-25 Client Sample ID: Gym Men's RR-Sink
Collection Date: 5/20/2025 7:01:00 AM Collected By: Larry Anderson
Matrix: Drinking Water Sample Location: Gym Men's RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.16		0.515	ppb	1	6/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050920
22-Jul-25

Client: Medford School District
Project: Griffin Creek Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31685	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: PBW	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986861						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31685	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: LCSW	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986862						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.520	100	0	102	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050768-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: BatchQC	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986864						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.520	100	0.453	102	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 25050768-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: BatchQC	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986865						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.520	100	0.453	102	70	130	103	0.0385	20	
------	-----	-------	-----	-------	-----	----	-----	-----	--------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050920
22-Jul-25

Client: Medford School District
Project: Griffin Creek Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31686	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: PBW	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986889
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31686	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: LCSW	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986890
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 104 0.520 100 0 104 85 115

Sample ID: 25050920-17AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: Girl's RR By Rm 4-Si	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986892
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.520 100 0.917 102 70 130

Sample ID: 25050920-17AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: Girl's RR By Rm 4-Si	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986893
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.520 100 0.917 101 70 130 103 1.35 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1

Sample Log-In Check List

Client Name: MedfordSchoolDist

Work Order Number: 25050920

RcptNo: 1

Logged by: Johanna Owen 5/20/2025 9:40:00 AM

Completed By: Coni Boyko 5/23/2025 11:52:02 AM

Reviewed By: Dorie Evans 6/16/2025 11:05:09 AM

JO
Coni Boyko
D. Evans

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

Page 1 of 3

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: MSD 549C
Address: 900 Kenyon
Medford, OR 97501
Email: andy.chasteen@medford.k12.or.us
Phone: 541-840-4315 Fax:
Collected By (Print): Larry Andersen
Collected By (Sign): *Larry Andersen*
Email Report ☐ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: Griffin Creek
Project Number:
Report andy.chasteen@medford.k12.o
Copy T seth.barry@medford.k12.or.us

Section C

Invoice Information

Attention: Accounting
Company Name: Medford School District
Address: 900 Kenyon
Medford, OR 97501
P.O. #

Section D

Rush Status (Subject to Scheduling)

☐ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										Remarks/Field Data	NRC Sample # (Lab Use Only)	(Lab Use)
Health Room - Sink <i>N/A</i>	DW	5/12/25	6:20	1												01	
Health Room Restroom - Sink	DW	5/12/25	6:24	1												02	
Staff Men's Restroom In-between Rooms 11/12 - Sink	DW	5/12/25	6:25	1												03	
Staff Women's Restroom In-between Rooms 11/12 - Sink	DW	5/12/25	6:26	1												04	
Girl's Restroom Adjacent To Room 12 - Sink (Left)	DW	5/12/25	6:26	1												05	
Girl's Restroom Adjacent To Room 12 - Sink (Right)	DW	5/12/25	6:27	1												06	
Boy's Restroom Adjacent To Room 12 - Sink (Left)	DW	5/12/25	6:28	1												07	
Boy's Restroom Adjacent To Room 12 - Sink (Right)	DW	5/12/25	6:29	1												08	
Men's Restroom Outside Cafeteria - Sink (Left)	DW	5/12/25	6:31	1												09	
Men's Restroom Outside Cafeteria - Sink (Right)	DW	5/12/25	6:31	1												10	
Women's Restroom Outside Cafeteria - Sink (Left)	DW	5/12/25	6:33	1												11	
Women's Restroom Outside Cafeteria - Sink (Right)	DW	5/12/25	6:33	1												12	
Room 1 Unisex Restroom - Sink	DW	5/12/25	6:36	1												13	
Room 2 Unisex Restroom - Sink	DW	5/12/25	6:37	1												14	
Boy's Restroom Next to Room 4 - Sink (Left)	DW	5/12/25	6:41	1												15	
Boy's Restroom Next to Room 4 - Sink (Right)	DW	5/12/25	6:41	1												16	
Girl's Restroom Next to Room 4 - Sink (Left)	DW	5/12/25	6:40	1												17	
Girl's Restroom Next to Room 4 - Sink (Right)	DW	5/12/25	6:40	1												18	
Boy's Restroom In-between Rooms 5/6 - Sink (Hallway Access)	DW	5/12/25	6:44	1												19	
Girl's Restroom In-between Rooms 5/6 - Sink (Outside Access)	DW	5/12/25	6:45	1													
Boy's Restroom Adjacent To Room 25 - Sink (1) Left side <i>N/A</i>	DW			1													
Boy's Restroom Adjacent To Room 25 - Sink (2) <i>N/A</i>	DW			1													
Boy's Restroom Adjacent To Room 25 - Sink (3) <i>N/A</i>	DW			1													
Boy's Restroom Adjacent To Room 25 - Sink (4) <i>N/A</i>	DW			1													
Boy's Restroom Adjacent To Room 25 - Sink (5) Right side <i>N/A</i>	DW			1													

NRC #25050920

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F


Relinquish/Receive

Sign

Print

Date _____

Time

Relinquished By		Mike Muel	5/20/25	407
Received By		Larry Anders		703
Relinquished By		Larry Anders		330
Received By		SETH BANDY		341
Relinquished By		SETH BANDY		940
Received By Laboratory		HANNA ANDREWS	5/20/25	914

Section G

Lab Use Only

Temp:			
4°C +/- 2°C:	Yes	No	
Received on Ice:	Yes	No	
Number of Bottles Received:			
pH Checked:			
COC Seals Intact:	Yes	No	NA
Field Blank Included:	Yes	No	

Received Via	UPS	FedEX	Other	☒ Hand
--------------	-----	-------	-------	--

Payment:	Invoice	Cash	VISA, M/C	Check #	Amount
----------	---------	------	-----------	---------	--------