



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 18, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Griffin Creek School Leads-AMENDED

Order No.: 25050588

Dear Andy Chasteen:

Neilson Research Corporation received 28 sample(s) on 5/13/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050588
Date: 7/18/2025

CLIENT: Medford School District

Project: Griffin Creek School Leads-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-01 **Client Sample ID:** Playground (Near CO)- DF(L)
Collection Date: 5/13/2025 5:31:00 AM **Collected By:** Cody Fleming
Matrix: Drinking Water **Sample Location:** Playground (Near CO)- DF(L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-02 **Client Sample ID:** Playground (Near CO)- DF(R)
Collection Date: 5/13/2025 5:32:00 AM **Collected By:** Cody Fleming
Matrix: Drinking Water **Sample Location:** Playground (Near CO)- DF(R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-03 **Client Sample ID:** Room 5-DF
Collection Date: 5/13/2025 5:34:00 AM **Collected By:** Cody Fleming
Matrix: Drinking Water **Sample Location:** Room 5-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.589		0.515	ppb	1	6/6/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-04
Collection Date: 5/13/2025 5:35:00 AM
Matrix: Drinking Water
Client Sample ID: Room 5-Sink
Collected By: Cody Fleming
Sample Location: Room 5-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-05
Collection Date: 5/13/2025 5:36:00 AM
Matrix: Drinking Water
Client Sample ID: Boys RR Between Rooms 5/6-Sink (Hallway)
Collected By: Cody Fleming
Sample Location: Boys RR Between Rooms 5/6-Sink (Hallway)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.0		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-06
Collection Date: 5/13/2025 5:37:00 AM
Matrix: Drinking Water
Client Sample ID: Girls RR Between Rooms 5/6-Sink (Outside)
Collected By: Cody Fleming
Sample Location: Girls RR Between Rooms 5/6-Sink (Outside)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-07
Collection Date: 5/13/2025 5:38:00 AM
Matrix: Drinking Water
Client Sample ID: Room 6 -DF
Collected By: Cody Fleming
Sample Location: Room 6 -DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-08
Collection Date: 5/13/2025 5:39:00 AM
Matrix: Drinking Water
Client Sample ID: Room 6-Sink
Collected By: Cody Fleming
Sample Location: Room 6-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-09
Collection Date: 5/13/2025 5:40:00 AM
Matrix: Drinking Water
Client Sample ID: Room 7-DF
Collected By: Cody Fleming
Sample Location: Room 7-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-10 **Client Sample ID:** Room 7-Sink
Collection Date: 5/13/2025 5:41:00 AM **Collected By:** Cody Fleming
Matrix: Drinking Water **Sample Location:** Room 7-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-11 **Client Sample ID:** Room 8-DF
Collection Date: 5/13/2025 5:43:00 AM **Collected By:** Cody Fleming
Matrix: Drinking Water **Sample Location:** Room 8-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-12 **Client Sample ID:** Room 8-Sink
Collection Date: 5/13/2025 5:44:00 AM **Collected By:** Cody Fleming
Matrix: Drinking Water **Sample Location:** Room 8-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-13
Collection Date: 5/13/2025 5:46:00 AM
Matrix: Drinking Water
Client Sample ID: Room 26-DF
Collected By: Cody Fleming
Sample Location: Room 26-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/6/2025	15.0	A

Lab ID: 25050588-14
Collection Date: 5/13/2025 5:47:00 AM
Matrix: Drinking Water
Client Sample ID: Room 26-Sink
Collected By: Cody Fleming
Sample Location: Room 26-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-15
Collection Date: 5/13/2025 5:48:00 AM
Matrix: Drinking Water
Client Sample ID: Room 27-DF
Collected By: Cody Fleming
Sample Location: Room 27-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-16
Collection Date: 5/13/2025 5:49:00 AM
Matrix: Drinking Water
Client Sample ID: Room 27-Sink
Collected By: Cody Fleming
Sample Location: Room 27-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-17
Collection Date: 5/13/2025 5:50:00 AM
Matrix: Drinking Water
Client Sample ID: Room 28-DF
Collected By: Cody Fleming
Sample Location: Room 28-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-18
Collection Date: 5/13/2025 5:51:00 AM
Matrix: Drinking Water
Client Sample ID: Room 28-Sink
Collected By: Cody Fleming
Sample Location: Room 28-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-19 Client Sample ID: Room 29-DF
Collection Date: 5/13/2025 5:52:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 29-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.49		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-20 Client Sample ID: Room 29-Sink
Collection Date: 5/13/2025 5:53:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 29-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.49		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-21 Client Sample ID: Playground (Near Track)-DF(Upper)
Collection Date: 5/13/2025 5:54:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Playground (Near Track)-DF(Upper)

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588

Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-22 Client Sample ID: Playground (Near Track)-DF(Lower)
Collection Date: 5/13/2025 5:55:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Playground (Near Track)-DF(Lower)

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-23 Client Sample ID: Room 21-DF
Collection Date: 5/13/2025 5:57:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 21-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-24 Client Sample ID: Room 21-Sink
Collection Date: 5/13/2025 5:58:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 21-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-25 Client Sample ID: Room 22-DF
Collection Date: 5/13/2025 6:00:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 22-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-26 Client Sample ID: Room 22-Sink
Collection Date: 5/13/2025 6:01:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 22-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

Lab ID: 25050588-27 Client Sample ID: Room 23-DF
Collection Date: 5/13/2025 6:03:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 23-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050588
Date Reported: 7/18/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050588
Received Date: 5/13/2025 9:18:00 AM
Reported Date: 7/18/2025 4:08:45 PM

Sample Information:

Lab ID: 25050588-28 Client Sample ID: Room 23-Sink
Collection Date: 5/13/2025 6:04:00 AM Collected By: Cody Fleming
Matrix: Drinking Water Sample Location: Room 23-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.588		0.515	ppb	1	6/4/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050588
18-Jul-25

Client: Medford School District
Project: Griffin Creek School Leads-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31530	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60046						
Client ID: PBW	Batch ID: 31530	TestNo: E200.8	E200.8	Analysis Date: 6/5/2025	SeqNo: 983164						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: LCS-31530	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60046						
Client ID: LCSW	Batch ID: 31530	TestNo: E200.8	E200.8	Analysis Date: 6/6/2025	SeqNo: 983165						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.520 100 0 101 85 115

Sample ID: 25050575-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60046						
Client ID: BatchQC	Batch ID: 31530	TestNo: E200.8	E200.8	Analysis Date: 6/6/2025	SeqNo: 983167						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.520 100 2.92 97.7 70 130

Sample ID: 25050575-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60046						
Client ID: BatchQC	Batch ID: 31530	TestNo: E200.8	E200.8	Analysis Date: 6/6/2025	SeqNo: 983168						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 96.8 0.520 100 2.92 93.9 70 130 101 3.89 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050588
18-Jul-25

Client: Medford School District
Project: Griffin Creek School Leads-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31531	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60091						
Client ID: PBW	Batch ID: 31531	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 984137						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31531	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60091						
Client ID: LCSW	Batch ID: 31531	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 984138						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.520	100	0	104	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050588-14AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60091						
Client ID: Room 26-Sink	Batch ID: 31531	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 984140						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.520	100	0.234	102	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 25050588-14AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/3/2025	RunNo: 60091						
Client ID: Room 26-Sink	Batch ID: 31531	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 984141						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.520	100	0.234	100	70	130	102	1.71	20	
------	-----	-------	-----	-------	-----	----	-----	-----	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist

Work Order Number: 25050588

RcptNo: 1

Logged by: Ashley Spiegelberg 5/13/2025 9:18:00 AM

Completed By: Coni Boyko 5/16/2025 12:39:14 PM

Reviewed By: Dorie Evans 6/10/2025 9:15:17 AM

Am
Coni Boyko
Dorie Evans

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

Page 1 of 3

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: MSD 549C Address: 900 Kenyon Medford, OR 97501 Email: andy.chasteen@medford.k12.or.us Phone: 541-840-4315 Fax: Collected By (Print): <u>Cody Fleming</u> Collected By (Sign): <u>Cody Fleming</u> Email Report ☐ Yes ☐ No Mail Report ☐ Yes ☐ No Fax Report ☐ Yes ☐ No	Section B Required Project Information Project Name: <u>Griffin Creek</u> Project Number: Report To: <u>andy.chasteen@medford.k12.or.us</u> Copy To: <u>seth.barry@medford.k12.or.us</u>	Section C Invoice Information Attention: Accounting Company Name: Medford School District Address: 900 Kenyon Medford, OR 97501 P.O. #	Section D Rush Status (Subject to Scheduling) ☐ Standard 10-14 Days ☐ 5 Business Days (50% surcharge) ☐ 3 Business Days (75% surcharge) ☐ 24 - 48 hours (100% surcharge) Other _____ Authorized ☐ Yes ☐ No
---	---	--	---

Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Playground (Near Custodial Office) - Drinking Fountain (Left)	DW	5/13/16	5:31	1			01
Playground (Near Custodial Office) - Drinking Fountain (Right)	DW		5:32	1			02
Room 5 - Drinking Fountain	DW		5:34	1			03
Room 5 - Sink	DW		5:35	1			04
Boy's Restroom In-between Rooms 5/6 - Sink (Hallway Access)	DW		5:36	1			05
Girl's Restroom In-between Rooms 5/6 - Sink (Outside Access)	DW		5:37	1			06
Room 6 - Drinking Fountain	DW		5:38	1			07
Room 6 - Sink	DW		5:39	1			08
Room 7 - Drinking Fountain	DW		5:40	1			09
Room 7 - Sink	DW		5:41	1			10
Room 8 - Drinking Fountain	DW		5:43	1			11
Room 8 - Sink	DW		5:44	1			12
	DW			1			13
Room 26 - Drinking Fountain	DW		5:46	1			14 13
Room 26 - Sink	DW		5:47	1			15 14
Room 27 - Drinking Fountain	DW		5:48	1			16 15
Room 27 - Sink	DW		5:49	1			17 16
Room 28 - Drinking Fountain	DW		5:50	1			18 17
Room 28 - Sink	DW		5:51	1			19 18
Room 29 - Drinking Fountain	DW		5:52	1			20 19
Room 29 - Sink	DW		5:53	1			21 20
Playground (Near Track) - Drinking Fountain (Upper)	DW		5:54	1			22 21
Playground (Near Track) - Drinking Fountain (Lower)	DW		5:55	1			23 22

