

J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



January 30, 2025

Mr. Mark Montemarno
Oceanside Union Free School District
Administration Building
145 Merle Avenue
Oceanside, New York 11572

Re: **Lead Testing in School Drinking Water
Remedial Action Plan – Update to Initial Report January 2025
2023-2025 Compliance 10 NYCRR Subpart 67-4**

JCB#: **23-53785**

Dear Mr. Montemarno:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan
Attachment 2: Outlet Inventory and Lead Testing Results
Attachment 3: Laboratory Analytical Reports
Attachment 4: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.
Sincerely,

A handwritten signature in black ink, appearing to read 'Anthony J. Lombardo', is positioned below the 'Sincerely,' text.

Anthony J. Lombardo
Project Manager
J.C. BRODERICK & ASSOCIATES, INC.

Attachment 1:

Lead in Water
Remediation Plan


J.C. Broderick & Associates, Inc.

Environmental Consulting & Testing

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395



Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

If the lead concentration of water at an outlet exceeds the action level, the school shall:

(a) prohibit use of the outlet until:

(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and

(2) test results indicate that the lead levels are at or below the action level;

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

Step 1A: Potable Outlets (Outlets intended to be used for drinking/cooking)

Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

Step 1B: Non-Potable Outlets (Outlets not intended for drinking/cooking)


See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead.pdf.



Do not use for drinking



Hand washing only



Step 2: Service & Repair or Outlet Replacement

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

Step 3: Retesting & Return to Service

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:

Outlet Inventory and
Lead Testing Results


J.C. Broderick & Associates, Inc.

Environmental Consulting & Testing

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395





Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53785

Oceanside Union Free School District

Florence A. Smith School #2

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0001	Room 29	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0003	Room 13	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0005	Room 14	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0007	Room 28	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0009	Room 15	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0011	Room 27	2006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0013	Room 26	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0015	Room 16	2008A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0017	Room 17	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0019	Women's Bathroom Across Room 17	2011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0020	Women's Bathroom Across Room 17	2011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0021	2nd Floor Custodial Closet	2012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0022	Men's Bathroom Across Room 17 (Storage)	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0023	Library Office	2015B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0024	Room 19	2017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0026	Room 20	2018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Florence A. Smith School #2

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0028	Room 25	2019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0029	Room 25	2019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0031	Room 21	2020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0033	Room 22	2021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0035	Room 24	2022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0037	Room 23	2023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0040	Corridor Room 119 To 123 (Outside Room 121)	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0042	ADA Toilet (Outside Room 120)	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0043	Room 10	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0045	Room 11	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0047	Room 9	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0049	Room 8	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0051	Room 7	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0053	Room 12	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0055	Literacy Resource Center Custodial Closet	1006A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0056	Unisex Bathroom Across Room 6	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0057	Room 110 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0058	Room 110	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0060	Room 111 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0061	Room 111	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Florence A. Smith School #2

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0063	Room 6	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0065	Room 6 Bathroom	1009A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0068	Room 5 Bathroom	1010A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0069	Room 4	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0071	Room 4 Bathroom	1011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0072	Faculty Room	1014	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0074	Faculty Men's Bathroom	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0075	Faculty Women's Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0076	Faculty Women's Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0077	Nurse's Office	1018	Nurse's Office Sink	Potable	12/3/2024	3.2			Result Below Action Level Continue O&M
OUFSD-0078	Nurse's Office Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0079	Room 1	1023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0081	Room 2	1024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0083	Main Office Break Room	1020B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0084	Main Office Break Room	1020B	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0085	Principal's Office Bathroom	1019A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0086	Room 3	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0088	Music Room (Steve Dunn, Patricia Hamilton)	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0090	Gym	1027	Water Fountain-No Chiller	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0091	Girl's Bathroom Across Auditorium	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Florence A. Smith School #2

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0092	Girl's Bathroom Across Auditorium	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0093	Boy's Bathroom Across Auditorium	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0094	Stage Storage	1032A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0097	Cafeteria	1037	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0098	Cafeteria	1037	Bottle Fill Station	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0102	Kitchen	1038	Kitchen Faucet (Cold)	Potable	12/3/2024	2.2			Result Below Action Level Continue O&M
OUFSD-0103	Kitchen Locker Room Bathroom	1038B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0104	Custodial Closet Across Auditorium	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0105	Boiler Room	1040A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0107	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1334	Corridor Room 3 To Auditorium (Outside Faculty	1034	Water Cooler	Potable	7/29/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1335	Corridor Room 3 To Auditorium (Outside Faculty	1034	Bottle Fill Station	Potable	7/29/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1336	Corridor Room 10 To Room 6 (Outside Room 110)	1012	Water Cooler	Potable	7/29/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1337	Corridor Room 10 To Room 6 (Outside Room 110)	1012	Bottle Fill Station	Potable	7/29/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1339	Stairwell Adjacent Room 26 (Outside Room 17)	2010	Bottle Fill Station	Potable	7/29/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1364	Corridor Room 29 To Room 17 (Outside Room 29)	2014	Bottle Fill Station	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1365	Corridor Room 29 To Room 17 (Outside Room 29)	2014	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1366	Stairwell Adjacent Room 26 (Outside Room 17)	2010	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1367	Custodial Closet (Outside Room 123)	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1368	Room 5	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Florence A. Smith School #2

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1369	Faculty Room	1014	Bottled Water Dispenser (Cold)	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1370	Faculty Room	1014	Bottled Water Dispenser (Hot)	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1371	Kitchen	1038	Kitchen Faucet (Cold)	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1372	Kitchen	1038	Spray Nozzle	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1373	Boiler Room	1040A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1374	Exterior Hose Bib (Outside Nurse's Office)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1375	Exterior Hose Bib (Outside Exit Door E)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1376	Exterior Hose Bib (Outside Room 11)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1377	Exterior Hose Bib (Outside Room 9)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1378	Exterior Hose Bib (Outside Auditorium)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1379	Exterior Hose Bib (Outside Kitchen)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1380	Exterior Hose Bib (Outside Main Lobby)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oaks School #3

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0113	Room A14	2000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0115	Room A13	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0117	Room A15	2003	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0119	2nd Floor All Gender Bathroom Adj. Room A15	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0121	Social Worker Office Bathroom	2007A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0122	Room A12	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0124	Room A9	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0126	Room A11	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0128	Room A8	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0130	Room A10	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0132	Room A7	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0134	Bathroom Adj. Room 10B	2019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0138	Room 16 Closet	2026A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0139	Room 12	2029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0142	Room 17	2032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0144	Large Classroom 13	2033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0145	Room 18	2034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0148	Girl's Bathroom Adj. Library	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0151	Room 4 Computer Lab Bathroom	1002A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0152	Corridor Main Office To Computer Room (Outside	1012	Water Fountain-No Chiller	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M

Oaks School #3

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0153	Room 3	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0156	Custodial Closet o/s Nurse's Office	1005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0157	Nurse's Office	1006	Nurse's Office Sink	Potable	12/3/2024	1.3			Result Below Action Level Continue O&M
OUFSD-0159	Faculty All Gender Restroom	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0160	Faculty All Gender Restroom	1013	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0161	Faculty Women's Restroom	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0162	Faculty Women's Restroom	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0165	Gym Storage	1018A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0167	Old Boy's Locker Room Bathroom	1019B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0169	Teacher's Lounge	1023	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0171	Room A4	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0173	Room A2	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0175	Room A5A	1028A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0177	Room A3	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0179	Room A6	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0181	All Gender Bathroom 1	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0182	All Gender Bathroom 2	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0183	Cafeteria	1036	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0184	Cafeteria	1036	Bottle Fill Station	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0185	Kitchen	1036A	Kitchen Service Area	Potable	12/3/2024	1.4			Result Below Action Level Continue O&M

Oaks School #3

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0186	Kitchen	1036A	Kitchen Faucet (Cold)	Potable	12/3/2024	9.3	1/17/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0187	Kitchen	1036A	Kitchen Faucet (Cold)	Potable	12/3/2024	10.1	1/7/2025	2.6	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0189	Kitchen	1036A	Spray Nozzle	Potable	12/3/2024	6.4	1/7/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0190	Kitchen	1036A	Kitchen Faucet (Cold)	Potable	12/3/2024	8.6	1/7/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0191	Art Room	0002	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0192	Art Room	0002	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0193	Art Room	0002	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0194	Art Room	0002	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0196	Art Room	0002	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0197	Storage Adjacent To Stairwell	0001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0198	Custodial Office Bathroom	0004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0203	Exterior Hose Bib (In Courtyard)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0204	Exterior Hose Bib (In Courtyard)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0205	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0206	Exterior Hose Bib (Outside Room 4)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1287	Corridor Main Office To Computer Room (Outside	1012	Bottle Fill Station	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1288	Corridor Main Office To Computer Room (Outside	1012	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1350	Corridor Room 10 to Room 18 (Outside Room 14)	2037	Bottle Fill Station	Potable	8/26/2024	1.1	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1351	Corridor Room 10 to Room 18 (Outside Room 14)	2037	Water Cooler	Potable	8/26/2024	1.2	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1352	Corridor Supply Storage to Custodial Closet (Outside	2016	Bottle Fill Station	Potable	8/26/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M

Oaks School #3

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1353	Corridor Supply Storage to Custodial Closet (Outside	2016	Water Cooler	Potable	8/26/2024	1.3	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1381	Art Room	0002	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1382	Girl's Bathroom Adj. Library	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1383	Library Office	1001A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1384	Boy's Bathroom Adj. Library	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1385	Boy's Bathroom Adj. Library	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1386	Nurse's Office	1006	Bottled Water Dispenser (Cold)	Potable					Testing Required Before Return to Service
OUFSD-1387	Nurse's Office	1006	Bottled Water Dispenser (Hot)	Potable					Testing Required Before Return to Service
OUFSD-1388	Gym	1018	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1389	Gym	1018	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1390	Gym Girl's Bathroom	1019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1391	Custodial Closet Adj. Room A4	1021	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1392	Custodial Closet Adj. Room A12	2005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1393	Girl's Bathroom Adj. Room 14	2020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1394	Girl's Bathroom Adj. Room 14	2020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1395	Boy's Bathroom Adj. Room 17	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1396	Boy's Bathroom Adj. Room 17	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1397	Girl's Bathroom Adj. Room 18	2035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1398	Girl's Bathroom Adj. Room 18	2035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1399	Exterior Hose Bib (Outside Main Entrance)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oaks School #3

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1400	Exterior Hose Bib (Outside Gym)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1401	Exterior Hose Bib (Outside Room A4)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1402	Exterior Hose Bib (Outside Cafeteria)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

South Oceanside Road School #4

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0207	Custodial Closet (Outside Faculty Room)	2000	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0208	Custodial Closet (Outside Faculty Room)	2000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0209	Faculty Room	2001	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0211	Faculty Room Men's Bathroom	2001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0212	Faculty Room Women's Bathroom	2001B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0213	Corridor Faculty Room To Room 211 (Outside Room 212)	2005	Water Fountain-No Chiller	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0214	Room 212	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0215	Room 211	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0216	Girl's Bathroom Adj. Room 201	2006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0217	Girl's Bathroom Adj. Room 201	2006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0218	Room 210	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0220	Room 201 Store Room	2008A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0222	Room 202	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0223	Room 208	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0224	Custodial Closet Across Room 203	2015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0225	Custodial Closet Across Room 203	2015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0226	Boy's Bathroom Adj. Room 207	2016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0227	Boy's Bathroom Adj. Room 207	2016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0228	Room 204	2018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0230	Room 206	2019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

South Oceanside Road School #4

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0231	Room 205	2020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0232	Girl's Bathroom Adj. Room 205	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0233	Faculty All Gender Bathroom Adj. Room 104	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0235	Room 105	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0237	Room 103	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0238	Room 106	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0240	Boy's Bathroom Adj. Room 106	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0241	Custodial Closet Across Health Office	1013	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0242	Custodial Closet Across Health Office	1013	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0243	Health Office	1015	Nurse's Office Sink	Potable	12/3/2024	2.9			Result Below Action Level Continue O&M
OUFSD-0245	Principal's Office Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0247	Room 101 Bathroom Vestibule	1022B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0248	Room 108	1023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0249	Girl's Bathroom Adj. Room 101	1024A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0250	Girl's Bathroom Adj. Room 101	1024A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0251	Cafeteria	1027	Water Cooler	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0252	Cafeteria	1027	Bottle Fill Station	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0254	Kitchen	1028	Kitchen Faucet (Cold)	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0256	Kitchen	1028	Spray Nozzle	Potable	12/3/2024	2.0			Result Below Action Level Continue O&M
OUFSD-0257	Kitchen	1028	Kitchen Faucet (Cold)	Potable	12/3/2024	3.1			Result Below Action Level Continue O&M

South Oceanside Road School #4

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0258	Corridor Gym To Cafeteria (Outside Cafeteria)	1035	Water Fountain-No Chiller	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0259	Custodial Closet (Outside Kitchen)	1029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0260	Custodial Closet (Outside Kitchen)	1029	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0261	Gym Lobby Girl's Bathroom	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0262	Gym Lobby Girl's Bathroom	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0263	Gym Lobby Boy's Bathroom	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0264	Gym Lobby Boy's Bathroom	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0265	Gym	1033	Water Fountain-No Chiller	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0266	Gym	1033	Water Fountain-No Chiller	Potable					Testing Required Before Return to Service
OUFSD-0267	Art Room	0004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0268	Art Room	0004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0269	Art Room	0004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0270	Art Room	0004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0271	Art Room	0004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0272	Custodial Office	0005	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0273	Basement Boy's Bathroom	0011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0274	Basement Girl's Bathroom	0012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0279	Exterior Hose Bib (Outside Stairwell 1025)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1354	Corridor Room 205 To Room 210 (Outside Room 204)	2022	Bottle Fill Station	Potable	10/9/2024	1.3	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1355	Corridor Room 205 To Room 210 (Outside Room 204)	2022	Water Cooler	Potable	10/9/2024	1.1	12/3/2024	<1.0	Result Below Action Level Continue O&M

South Oceanside Road School #4

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1356	Corridor Room 101 To 105 (Outside Room 105)	1026	Bottle Fill Station	Potable	10/9/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1357	Corridor Room 101 To 105 (Outside Room 105)	1026	Water Cooler	Potable	10/9/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1358	Corridor Room 101 To 105 (Outside Room 101)	1026	Bottle Fill Station	Potable	10/9/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1359	Corridor Room 101 To 105 (Outside Room 101)	1026	Water Cooler	Potable	10/9/2024	< 1.0	12/3/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1403	Faculty Room	2001	Bottled Water Dispenser (Cold)	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1404	Faculty Room	2001	Bottled Water Dispenser (Hot)	Potable	12/3/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1405	Room 209	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1406	Room 207	2017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1407	Room 104	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1408	Boy's Bathroom Adj. Room 106	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1409	Room 102	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1410	Boiler Pump Room	0013B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1411	Boiler Pump Room	0013B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1412	Boiler Room	0013	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1414	Exterior Hose Bib (Outside Stairwell 1025)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1415	Exterior Hose Bib (Outside Cafeteria)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1416	Exterior Hose Bib (Outside Gym)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1417	Exterior Hose Bib (Outside Room 103)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1418	Exterior Hose Bib (Outside Room 106)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1727	Kitchen	1028	Kitchen Faucet (Cold)	Potable	12/3/2024	3.0			Result Below Action Level Continue O&M

North Oceanside Road School #5

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0283	Girl's Bathroom Adj. Room 14	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0284	Copy Room Bathroom	2006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0286	Boy's Bathroom Adj. Room 12	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0287	Custodial Closet (Across Room 12)	2011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0289	Girl's Bathroom Adj. Room 18	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0290	Room 18	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0291	Room 11	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0292	Corridor Room 14 To 19 (Outside Room 11)	2020	Water Fountain-No Chiller	Potable	12/4/2024	1.1			Result Below Action Level Continue O&M
OUFSD-0293	Room 19	2015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0294	Room 10A	2018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0297	Room A10	2023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0299	Room A8	2024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0303	Room A7	2026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0308	Room A13	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0310	Room A13 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0311	Room A14	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0313	Room A14 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0314	Room A15	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0317	Room 9	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0318	Room 1	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

North Oceanside Road School #5

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0319	Room 1 Storage Bathroom	1001A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0321	Corridor Room 4 To Room 9 (Outside Room 1)	1016	Water Fountain-No Chiller	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0322	Room 2	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0323	Room 8	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0324	Boy's Bathroom Adj. Room 8	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0325	Boy's Bathroom Adj. Room 8	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0326	Custodial Closet (Across Room 3)	1005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0327	Main Office Bathroom	1008B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0328	Nurse's Office Patient Room Bathroom	1012B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0329	Girl's Bathroom Adj. Room 4	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0330	Girl's Bathroom Adj. Room 4	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0331	Corridor Room 4 To Room 9 (Outside Nurse's Office)	1016	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0332	Corridor Room 4 To Room 9 (Outside Nurse's Office)	1016	Bottle Fill Station	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0333	Women's Faculty Bathroom (Across Aud)	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0334	Women's Faculty Bathroom (Across Aud)	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0335	Band Room	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0337	Room A6 (Faculty Lounge)	1020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0340	Custodial Closet (Across Room A6)	1022	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0341	Room A1 Psychologist Office Bathroom	1023A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0342	Room A5	1024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

North Oceanside Road School #5

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0344	Room A2	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0346	Room A4	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0348	Room A3	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0350	Gymnasium	1029	Water Fountain-No Chiller	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0351	Gymnasium	1029	Water Fountain-No Chiller	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0352	Gym Kitchen	1029A	Kitchen Faucet (Cold)	Potable	12/4/2024	1.9			Result Below Action Level Continue O&M
OUFSD-0353	Social Worker Office Back Room	1033B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0354	Cafeteria Hallway All Gender Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0355	Cafeteria All Gender Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0356	Cafeteria	N/A	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0357	Cafeteria	N/A	Bottle Fill Station	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0358	Kitchen	N/A	Kitchen Service Area	Potable	12/4/2024	3.5			Result Below Action Level Continue O&M
OUFSD-0359	Kitchen	N/A	Kitchen Faucet (Cold)	Potable	12/4/2024	3.4			Result Below Action Level Continue O&M
OUFSD-0360	Kitchen	N/A	Kitchen Faucet (Cold)	Potable	12/4/2024	2.2			Result Below Action Level Continue O&M
OUFSD-0361	Kitchen	N/A	Kitchen Faucet (Cold)	Potable	12/4/2024	1.1			Result Below Action Level Continue O&M
OUFSD-0362	Custodial Office	0003	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0364	Boiler Room	0004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0365	Art/Music Room	0005	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0367	Library Staff/All Gender Bathroom	0010C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0368	Library Office	0010B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

North Oceanside Road School #5

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0371	Exterior Hose Bib (Outside Room A4)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0377	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1340	Corridor Room 14 To 19 (Outside Room 14)	2020	Bottle Fill Station	Potable	8/9/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1341	Corridor Room 14 To 19 (Outside Room 14)	2020	Water Cooler	Potable	8/9/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1342	Corridor Room A13 To A15 (Outside Room A13)	N/A	Bottle Fill Station	Potable	8/9/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1343	Corridor Room A13 To A15 (Outside Room A13)	N/A	Water Cooler	Potable	8/9/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1419	Girl's Bathroom Adj. Room 14	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1420	Boy's Bathroom Adj. Room 12	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1421	Custodial Closet (Across Room 12)	2011	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1422	Girl's Bathroom Adj. Room 18	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1423	Custodial Closet (Across Room 3)	1005	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1424	Computer Lab	0009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1425	Custodial Closet (Across Room A6)	1022	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1427	Room A15 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1428	Custodial Closet (Outside Room A7)	2028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1429	Custodial Closet (Outside Room A7)	2028	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1431	Room A12	2027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1434	Room A11	2025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1437	Room A9	2022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1438	Exterior Hose Bib (Outside Room 4)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

North Oceanside Road School #5

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1439	Exterior Hose Bib (Outside Room A3)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1440	Exterior Hose Bib (Outside Room A5)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1441	Exterior Hose Bib (Outside Cafeteria)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1442	Exterior Hose Bib (Outside Social Worker's Office)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1443	Exterior Hose Bib (Across Gas Garage)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1444	Exterior Hose Bib (Outside Faculty Lounge)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0378	Custodial Closet (Outside Room 313)	3005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0379	Women's Faculty Bathroom Adj. Room 335	3006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0380	Women's Faculty Bathroom Adj. Room 335	3006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0381	Corridor Room 319 To 327 (Outside Room 313)	3023	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0382	Room 324	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0384	Girl's Bathroom Adj. Room 323	3014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0385	Girl's Bathroom Adj. Room 323	3014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0386	Room 323	3015	Water Fountain-No Chiller	Potable	12/5/2024	3.8			Result Below Action Level Continue O&M
OUFSD-0387	Room 317 Art Room	3016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0388	Boy's Bathroom Adj. Room 320	3020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0389	Boy's Bathroom Adj. Room 320	3020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0390	Boy's Bathroom Adj. Room 320 Closet	3020A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0391	Corridor Room 319 To 327 (Outside Room 319)	3023	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0392	Room 320 Faculty Storage	3022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0393	Room L1	2000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0395	Room L2	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0397	Room 218A Bathroom	2004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0398	Room 218	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0401	Room 217C	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0403	Room 219	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0405	Room 217B	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0407	Room 220	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0409	Room 217A	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0411	Room 221	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0414	Girl's Bathroom Adj. Room 221	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0416	Room 216	2016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0418	Room 215	2017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0420	Room 222	2018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0423	Room 223	2019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0425	Women's Faculty Bathroom (Outside Room 223)	2020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0426	Women's Faculty Bathroom (Outside Room 223)	2020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0427	Women's Faculty Bathroom Closet (Outside Room 223)	2020A1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0428	Custodial Closet (Outside Room 224)	2021	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0429	Room 214 Nature Study	2022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0430	Room 214 Nature Study	2022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0431	Room 214 Nature Study	2022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0432	Room 224	2023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0434	Room 208	2025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0435	Girl's Bathroom Adj. Room 207	2027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0437	Bathroom Vestibule Closet	2027C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0438	Room 201	2028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0439	Room 207	2029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0440	Room 207A	2030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0441	Room 202	2031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0442	Room 203	2032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0443	Room 206	2033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0445	Room 205	2034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0446	Kitchen	2035	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0447	Kitchen	2035	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0448	Girl's Bathroom Across Room W26	2041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0449	Girl's Bathroom Across Room W26	2041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0451	Room W25 Tech Office	2043	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0453	Room W22 Conference Room	2050	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0454	Boy's Bathroom Adj. Room W22	2051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0455	Boy's Bathroom Adj. Room W22	2051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0456	Custodial Storage (Outside Indoor Playground #2)	2053	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0458	Indoor Playground #2 Bathroom	2056A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0459	Indoor Playground #2 Bathroom	2056A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0460	Indoor Playground #2 Bathroom	2056A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0461	Superintendent's Office Bathroom	7002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0462	Unisex Bathroom	7003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0463	District Office - 2nd Floor Custodial Closet	7015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0464	District Office - 2nd Floor Custodial Closet	7015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0465	Women's Bathroom Vestibule	7016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0467	Women's Bathroom	7016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0468	District Office - 1st Floor Corridor	6011	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0469	District Office - Men's Bathroom	6002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0470	District Office - 1st Floor Custodial Closet	6003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0471	Women's Bathroom	6006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0472	District Office - Basement Custodial Closet	5003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0473	District Office - Basement Custodial Closet	5003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0474	District Office - All Gender Bathroom	5004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0475	File Storage Bathroom	2059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0476	Unisex Bathroom (Across Office D)	2061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0477	Unisex Bathroom (Across Office D)	2061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0478	Custodial Closet (Outside Office B)	2062	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0479	Oceanside Consulting Center Corridor	2067	Water Fountain-No Chiller	Potable					Testing Required Before Return to Service
OUFSD-0480	Consulting Center - Main Office E Vestibule	2064	Bottled Water Dispenser (Cold)	Potable					Testing Required Before Return to Service
OUFSD-0481	Boy's Bathroom Across Room 218	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0482	Boy's Bathroom Across Room 218	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0483	Boy's Bathroom Across Room 218 Closet	2006A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0484	Room 102	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0486	Room 106	1033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0488	Room 105	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0490	Room 104	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0493	Room 103	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0495	Room 107	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0497	Room 101	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0499	Custodial Storage (Outside Room 101)	1038	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0500	Custodial Storage (Outside Room 101)	1038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0501	Room 108	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0503	Room 109	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0505	Boy's Bathroom Adj. Room 113	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0506	Boy's Bathroom Adj. Room 113	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0507	Custodial Closet (Outside Room 113)	1044	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0509	Room 113	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0511	Room 110	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0513	Room 111	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0515	Room 112	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0520	Custodial Closet (Outside Faculty Room 124)	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0521	Custodial Closet (Outside Faculty Room 124)	1052	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0525	Room 116	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0527	Nurse's Office	1058	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0528	Nurse's Office Large Bathroom	1058A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0529	Nurse's Office Small Bathroom	1058B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0530	PTA Office	1060	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0531	PTA Office Bathroom	1060B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0533	Girl's Bathroom Adj. Room 121	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0534	Girl's Bathroom Adj. Room 121	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0535	Girl's Bathroom Adj. Room 121 Closet	1063A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0536	Main Office Bathroom	1064B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0537	Main Office Hallway Bathroom	1064H	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0538	Principal's Office Bathroom	1067C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0539	Room 121	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0541	Room 120	1066	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0543	Room 119	1068	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0545	Boys Bathroom Adj. Room 119	1069B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0546	Boys Bathroom Adj. Room 119	1069B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0547	Boys Bathroom Adj. Room 119 Closet	1069A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0548	Room 118	1070	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0552	North Gymnasium Vestibule Boy's Bathroom	1075B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0553	North Gymnasium Vestibule Girl's Bathroom	1075B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0554	North Gymnasium Vestibule Girl's Bathroom Closet	1075B2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0555	Indoor Playground #1 Custodial Closet	1077B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0556	Indoor Playground #1 Bathroom	1077C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0557	Custodial Office	1078	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0558	Print Shop Custodial Closet	0001B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0559	Paint Storage	0014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0560	B&G Storage 2	0015	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0561	Paint Storage	0017	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0562	Paint Storage	0017	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0563	Basement Boiler Room	0020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0564	Maintenance Corridor	0027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0565	Basement Men's Bathroom Across B&G Office	0035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0566	Basement Men's Bathroom Across B&G Office	0035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0567	Conference Room Bathroom	0036D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0568	B&G Office Break Room	0037B	Bottled Water Dispenser (Cold)	Potable	12/5/2024	1.1			Result Below Action Level Continue O&M
OUFSD-0569	Room B3 Bathroom	0038D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0571	Basement Women's Bathroom Adj. Room B3	0039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0572	Basement Women's Bathroom Adj. Room B3	0039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0574	Basement Custodial Closet (Outside FoT Conf. Room)	0041	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0575	Basement Custodial Closet (Outside FoT Conf. Room)	0041	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0576	Auditorium Men's Bathroom	1000C2A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0577	Auditorium Women's Bathroom	1000C3A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0578	Room B1 Bathroom	1005A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0579	South Gymnasium Utensil Storage Bathroom	1010D2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0580	South Gymnasium Old Locker Room Bathroom	1010E1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0581	South Gymnasium Old Locker Room	1010E	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0582	Rotary Club Office	1007	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0583	Boiler Room (Across South Gym)	1011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0585	Cafeteria	1014	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0586	Cafeteria	1014	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0587	Cafeteria	1014	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0588	DOCA Office Bathroom	1017B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0590	Teacher's Center Corridor Women's Bathroom	1016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0591	Teacher's Center Corridor Men's Bathroom	1016B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0594	Girl's Bathroom Adj. Special Ed Office	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0595	All Gender Bathroom Adj. Special Ed Office	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0596	Boy's Bathroom Adj. Special Ed Office	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0597	Custodial Closet (Outside Room 104)	1026	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0598	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0599	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0600	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0601	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0602	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0603	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0604	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0605	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0606	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0607	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0608	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0609	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0610	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0611	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0612	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0626	Paint Storage	0014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1297	Corridor Room 118 To Room 124 (Outside Main Office)	1071	Bottle Fill Station	Potable	5/11/2023	<3.0 ND	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1298	Corridor Room 118 To Room 124 (Outside Main Office)	1071	Water Cooler	Potable	5/11/2023	<3.0 ND	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1302	Room 323 Vestibule Closet	3015A1	Hand Wash Only	Non-Applicable	12/23/2023	27.7			Placarded for Non-Drinking Use
OUFSD-1303	Corridor Room 319 To 327 (Outside Room 316)	3023	Bottle Fill Station	Potable	2/6/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1344	B&G Storage 2	0015	Bottled Water Dispenser (Cold)	Potable	8/9/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1345	B&G Storage 2	0015	Bottled Water Dispenser (Hot)	Potable	8/9/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1360	North Gym/Indoor Playground Vestibule	1076	Bottle Fill Station	Potable	10/9/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1361	North Gym/Indoor Playground Vestibule	1076	Water Cooler	Potable	10/9/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1362	Corridor Room 224 To Room 218A (Outside Room 221)	2024	Bottle Fill Station	Potable	10/9/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1363	Corridor Room 224 To Room 218A (Outside Room 221)	2024	Water Cooler	Potable	10/9/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1445	B&G Storage 2 Bathroom	0015B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1446	B&G Office Break Room	0037B	Bottled Water Dispenser (Hot)	Potable	12/5/2024	1.4			Result Below Action Level Continue O&M
OUFSD-1447	Boiler Room (Across South Gym)	1011	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1448	Special Education Office Check-in Area	1019	Bottled Water Dispenser (Cold)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1449	Special Education Office Check-in Area	1019	Bottled Water Dispenser (Hot)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1450	Faculty Room 124	1051	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1451	Girl's Bathroom Adj. Room 123	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1452	Girl's Bathroom Adj. Room 123	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1453	Girl's Bathroom Adj. Room 221	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1454	Custodial Closet (Outside Room 224)	2021	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1455	Boy's Bathroom Adj. Room 207	2027B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1456	Room W23	2046	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1457	Corridor Room W23 To W26 (Outside W23)	2054	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1458	Corridor Room W23 To W26 (Outside W23)	2054	Bottle Fill Station	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1460	Custodial Storage (Outside Indoor Playground #2)	2053	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1461	Consulting Center - Main Office E Vestibule	2064	Bottled Water Dispenser (Hot)	Potable					Testing Required Before Return to Service
OUFSD-1462	Custodial Closet (Outside Room 313)	3005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1463	Corridor Room 319 To 327 (Outside Room 316)	3023	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1464	Women's Bathroom Vestibule	7016	Bottled Water Dispenser (Cold)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1465	Women's Bathroom Vestibule	7016	Bottled Water Dispenser (Hot)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1466	Office 106	6005	Bottled Water Dispenser (Cold)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1467	Office 106	6005	Bottled Water Dispenser (Hot)	Potable					Testing Required Before Return to Service
OUFSD-1700	Corridor Gymnasium To Boys Bathroom (Outside)	1027	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1701	Corridor Gymnasium To Boys Bathroom (Outside)	1027	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1702	Corridor Gymnasium To Boys Bathroom (Outside Cafeteria)	1027	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1703	Corridor Gymnasium To Boys Bathroom (Outside Cafeteria)	1027	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1704	Corridor Room 101 to Room 105 (Outside Room 104)	1039	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1705	Corridor Room 101 to Room 105 (Outside Room 104)	1039	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1706	Corridor Room 109 to Room 112 (Outside Room 113)	1050	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1707	Corridor Room 109 to Room 112 (Outside Room 113)	1050	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1708	Corridor Room 118 To Room 124 (Outside Room 123)	1071	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1709	Corridor Room 118 To Room 124 (Outside Room 123)	1071	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1720	Corridor Room 224 To Room 218A (Outside Room 223)	2024	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1721	Corridor Room 224 To Room 218A (Outside Room 223)	2024	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M

Oceanside School #6 & Administration

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1722	Corridor Room 224 To Room 218A (Outside Room 218)	2024	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1723	Corridor Room 224 To Room 218A (Outside Room 218)	2024	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1724	Corridor Room 205 To Room 201 (Outside Room 204)	2037	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1725	Corridor Room 205 To Room 201 (Outside Room 204)	2037	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1726	Corridor Outside Teacher's Center (Outside DOCA Office)	1020	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0613	Room S141 Nurse's Office	1100	Nurse's Office Sink	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0614	Room S141 Nurse's Office Bathroom	1100B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0615	Room S141 Nurse's Office Handicap Bathroom	1100C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0616	Custodial Closet (Outside Room 232)	2000	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0617	Room S232 Bathroom	2001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0619	Room S235E Faculty Kitchen	2006A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0620	Room S235E Faculty Kitchen	2006A	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0621	Room S235E Faculty Kitchen Women's Bathroom	2006A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0622	Room S235E Faculty Kitchen Men's Bathroom	2006A2	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0623	Room S235E Faculty Kitchen Men's Bathroom	2006A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0624	Room S235E Faculty Kitchen Men's Bathroom	2006A2	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0628	Girl's Bathroom Adj. Room S229	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0629	Girl's Bathroom Adj. Room S229	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0630	Girl's Bathroom Adj. Room S229	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0631	Corridor Room S210 to Room S219 (Outside Room S226)	2031	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0635	Room N219 Back Room	2067A	Bottled Water Dispenser (Cold)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0638	Corridor Room S210 to Room S219 (Outside Room S223)	2031	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0639	Corridor Room S210 to Room S219 (Outside Room S223)	2031	Bottle Fill Station	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0640	Women's Bathroom Adj. Room S221	2016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0641	Women's Bathroom Adj. Room S221	2016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0642	Women's Bathroom Adj. Room S221	2016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0643	Custodial Closet (Outside Room S221)	2017	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0644	Room S219	2020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0645	Room S219	2020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0646	Room S219	2020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0647	Room S219	2020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0648	Room S218	2021	Home Economics Faucet (Cold)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0649	Room S218	2021	Home Economics Faucet (Cold)	Potable	12/5/2024	3.0			Result Below Action Level Continue O&M
OUFSD-0650	Room S218	2021	Home Economics Faucet (Cold)	Potable	12/5/2024	1.8			Result Below Action Level Continue O&M
OUFSD-0651	Room S218	2021	Home Economics Faucet (Cold)	Potable	12/5/2024	2.0			Result Below Action Level Continue O&M
OUFSD-0652	Room S216	2023	Home Economics Faucet (Cold)	Potable	12/5/2024	6.3	1/9/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0653	Corridor Room S210 to Room S219 (Outside Room S217)	2031	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0654	Custodial Closet (Outside Room S214)	2025	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0655	Custodial Closet (Outside Room S214)	2025	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0664	Custodial Closet (Outside Room S209)	2033	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0666	Boy's Bathroom Adj. Room S209	2034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0667	Boy's Bathroom Adj. Room S209	2034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0668	Boy's Bathroom Adj. Room S209	2034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0669	Corridor Room S231 To S202 (Outside Room S201)	2044	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0670	Room S204 Computer Room Bathroom	2042A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0671	Room S203 Science Classroom	2043A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0672	Room S203 Science Classroom	2043A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0673	Corridor Room N214 To Library (Outside Library)	2070	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0674	Corridor Room N214 To Library (Outside Library)	2070	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0709	Women's Bathroom Adj. Room N227	2053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0714	Men's Bathroom Adj. Room N210	2058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0715	Men's Bathroom Adj. Room N210	2058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0716	Men's Bathroom Adj. Room N210	2058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0717	Men's Bathroom Adj. Room N210	2058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0718	Men's Bathroom Adj. Room N210	2058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0719	Men's Bathroom Adj. Room N210	2058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0720	Men's Bathroom Adj. Room N210	2058	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0721	Custodial Closet N223 (Outside Room N210)	2059	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0722	Custodial Closet N223 (Outside Room N210)	2059	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0724	Women's Bathroom Adj. Room N222	2060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0725	Women's Bathroom Adj. Room N222	2060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0726	Women's Bathroom Adj. Room N222	2060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0727	Women's Bathroom Adj. Room N222	2060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0728	Women's Bathroom Adj. Room N222	2060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0729	Women's Bathroom Adj. Room N222	2060	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0812	Auditorium Lobby Women's Bathroom	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0813	Auditorium Lobby Women's Bathroom	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0814	Auditorium Lobby Women's Bathroom	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0815	Boys Dressing Room Bathroom	1009A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0816	Auditorium Lobby Men's Bathroom	1012A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0817	Auditorium Lobby Men's Bathroom	1012A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0818	Room S100 Vestibule	1017	Water Fountain-No Chiller	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0819	Room S103A Guidance Office Bathroom	1018J1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0824	Custodial Closet (Outside Guid. Office)	1023	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0826	Handicap Bathroom Adj. Room S154	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0827	Women's Bathroom Adj. Room S153	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0828	Women's Bathroom Adj. Room S153	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0829	Women's Bathroom Adj. Room S153	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0831	Room S153 Meeting Room Kitchen	1029A	Kitchen Faucet (Cold)	Potable	12/5/2024	7.3	1/9/2025	2.5	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0832	Girl's Locker Room Bathroom	1040E	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0833	Girl's Locker Room Bathroom	1040E	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0834	Girl's Locker Room Women's Bathroom 148	1040F	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0835	Girl's Locker Room Large Bathroom	1040G	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0836	Girl's Locker Room Large Bathroom	1040G	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0837	Girl's Locker Room Large Bathroom	1040G	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0838	Girl's Locker Room Closet Storage	1040B1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0839	Gymnasium Coach's Office Bathroom	1041B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0840	Auxiliary Gym Bathroom	1044A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0842	Boy's Team Room Bathroom	1045B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0843	Boy's Team Room Bathroom	1045B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0844	Boy's Team Room Bathroom	1045B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0845	Boy's Team Room Custodial Closet	1045E	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0846	Boy's Team Room Custodial Closet	1045E	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0847	Gym Lobby Men's Bathroom	1047	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0848	Gym Lobby Women's Bathroom	1048	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0853	Boy's Small Locker Room Bathroom	1053A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0855	Room S129	1056	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0857	Room S128	1057	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0858	Room S128	1057	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0860	Room S128	1057	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0863	Women's Bathroom Adj. Room S128	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0864	Women's Bathroom Adj. Room S128	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0865	Principal's Office Bathroom	1021B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0867	Room 100A Main Office File Storage Bathroom	1106B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0873	Boiler Room Bathroom	1064C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0874	Boiler Room	1064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0875	Room 126A Photo Lab Art Room	1067C	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0876	Room 126A Photo Lab Art Room	1067C	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0877	Room 126A Photo Lab Art Room	1067C	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0878	Men's Faculty Bathroom Adj. Room S125	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0879	Men's Faculty Bathroom Adj. Room S125	1070	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0880	Men's Faculty Bathroom Adj. Room S125	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0881	Custodial Closet (Outside Room S125)	1071	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0882	Custodial Closet (Outside Room S125)	1071	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0883	Room 124	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0884	Room 124	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0885	Room 124	1072	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0886	Room 123B	1073	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0887	Room 123B	1073	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0888	Room 123B	1073	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0889	Room 122	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0890	Room 122	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0891	Room 122	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0892	Room 122	1074	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0893	Room 122 Kiln Room	1074B	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0894	Girl's Dressing Room Bathroom	1076A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0895	Music Office 121C	1085	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0897	Room S139	1097	Home Economics Faucet (Cold)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0900	Cafeteria	1110	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0901	Cafeteria	1110	Bottle Fill Station	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0902	Cafeteria Serving Area	1110B	Kitchen Service Area	Potable	12/5/2024	7.9	1/9/2025	2.9	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0903	Kitchen	1116	Kitchen Faucet (Cold)	Potable	12/5/2024	3.5			Result Below Action Level Continue O&M
OUFSD-0904	Kitchen	1116	Kitchen Faucet (Cold)	Potable	12/5/2024	1.2			Result Below Action Level Continue O&M
OUFSD-0905	Kitchen	1116	Kitchen Faucet (Cold)	Potable	12/5/2024	2.5			Result Below Action Level Continue O&M
OUFSD-0906	Kitchen	1116	Kitchen Faucet (Cold)	Potable	12/5/2024	3.5			Result Below Action Level Continue O&M
OUFSD-0907	Kitchen	1116	Kitchen Faucet (Cold)	Potable	12/5/2024	4.1			Result Below Action Level Continue O&M
OUFSD-0908	Kitchen	1116	Kitchen Faucet (Cold)	Potable	12/5/2024	21.2	1/9/2025	2.2	Outlet Remediated and Returned to Service Continue O&M
OUFSD-0911	Kitchen Laundry Room	1116F	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0912	Kitchen Laundry Room	1116F	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0913	Basement Under Kitchen	0002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0914	Basement Under Kitchen	0002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0915	Faculty Dining Room	1114	Water Fountain-No Chiller	Potable	12/5/2024	3.8			Result Below Action Level Continue O&M
OUFSD-0919	Cafeteria Custodial Closet	1110A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0920	Cafeteria Custodial Closet	1110A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0921	Social Studies Resources Bathroom	1118A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0923	Women's Bathroom Adj. Room N138	1125A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0924	Women's Bathroom Adj. Room N138	1125A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0925	Men's Bathroom Adj. Room N137	1126	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0926	Men's Bathroom Adj. Room N137	1126	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0927	Room N118	1134	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0928	Boy's Bathroom Adj. Room N119	1138	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0929	Boy's Bathroom Adj. Room N119	1138	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0930	Boy's Bathroom Adj. Room N119	1138	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0931	Boy's Bathroom Adj. Room N119	1138	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0932	Boy's Bathroom Adj. Room N119	1138	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0933	Boy's Bathroom Adj. Room N119	1138	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0934	Boy's Bathroom Adj. Room N119	1138	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0935	Custodial Closet (Outside Room N120)	1139	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0936	Custodial Closet (Outside Room N120)	1139	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0937	Girl's Bathroom Adj. Room N130	1140	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0938	Girl's Bathroom Adj. Room N130	1140	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0939	Girl's Bathroom Adj. Room N130	1140	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0940	Girl's Bathroom Adj. Room N130	1140	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0941	Girl's Bathroom Adj. Room N130	1140	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0942	Girl's Bathroom Adj. Room N130	1140	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0943	Girl's Bathroom Adj. Room N130	1140	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0948	Exterior Hose Bib (Outside Concession Stand)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0952	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0953	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0954	Exterior Hose Bib (Outside Auditorium Lobby)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0955	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0956	Exterior Hose Bib (Outside Room N125A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0957	Exterior Hose Bib (Outside Room N134)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0958	Exterior Hose Bib (Outside Cafeteria Bridge)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1301	Football Locker Room	1049	Water Fountain-No Chiller	Potable	10/20/2023	<3.0 ND	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1306	Cafeteria	1110	Bottle Fill Station	Potable	2/13/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1307	Cafeteria	1110	Water Cooler	Potable	2/13/2024	1.2	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1308	Corridor Room N126 to Room N138 (Outside Resource	1152	Bottle Fill Station	Potable	2/13/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1309	Corridor Room N126 to Room N138 (Outside Resource	1152	Water Cooler	Potable	2/13/2024	1.1	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1310	Corridor Guidance Suite to Auditorium Lobby (Outside	1039	Bottle Fill Station	Potable	2/13/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1311	Corridor Guidance Suite to Auditorium Lobby (Outside	1039	Water Cooler	Potable	2/13/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1312	Auditorium Lobby	1014	Bottle Fill Station	Potable	2/13/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1313	Auditorium Lobby	1014	Water Cooler	Potable	2/13/2024	1.5	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1316	Corridor Guidance Suite to Auditorium Lobby (Outside	1039	Bottle Fill Station	Potable	3/7/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1317	Corridor Guidance Suite to Auditorium Lobby (Outside	1039	Water Cooler	Potable	3/7/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1324	Corridor Boiler Room To S114 (Outside Room S119)	1104	Bottle Fill Station	Potable	4/19/2024	<1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1468	Room 100A Main Office	1106	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1469	Men's Bathroom Adj. Guidance Office	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1470	Men's Bathroom Adj. Guidance Office	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1471	Men's Bathroom Adj. Guidance Office	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1472	Custodial Closet adj. Room S101	1023	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1473	Girl's Varsity Team Room	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1474	Girl's Varsity Team Room	N/A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1475	Corridor From Girl's Locker Room To Auxiliary Gym	1043	Water Cooler	Potable	10/24/2024	1.1	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1476	Corridor From Girl's Locker Room To Auxiliary Gym	1043	Bottle Fill Station	Potable	10/24/2024	1.1	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1477	Football Locker Room	1049	Ice Machine	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1478	Room S131	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1479	Room S131	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1480	Boy's Locker Room Shower Storage	1054B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1482	Corridor Room S131 to Women's Faculty Bathroom	1060	Water Cooler	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1483	Corridor Room S131 to Women's Faculty Bathroom	1060	Bottle Fill Station	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1484	Room S128	1057	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1485	Room S128	1057	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1486	Custodial Closet (Outside Room S128)	1058	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1487	Custodial Closet (Outside Room S128)	1058	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1488	Room S127A	1061	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1489	Room S127A	1061	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1490	Room S127B	1062	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1491	Room S127B	1062	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1492	Room S127B Office	1062A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1493	Room S127B Office	1062A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1495	Kitchen Laundry Room	1116F	Ice Machine	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1496	Kitchen Locker Room Bathroom	1116D1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1497	Cafeteria Women's Bathroom	1113	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1498	Cafeteria Men's Bathroom	1112	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1499	Cafeteria Men's Bathroom	1112	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1500	Corridor Room N126 to Room N138 (Outside Room N124)	1152	Bottle Fill Station	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1501	Corridor Room N126 to Room N138 (Outside Room N124)	1152	Water Cooler	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1502	Corridor Boiler Room To S114 (Outside Room S140)	1104	Water Cooler	Potable	10/24/2024	2.4	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1503	Corridor Boiler Room To S114 (Outside Room S140)	1104	Bottle Fill Station	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1504	Room S235E Faculty Kitchen	2006A	Bottle Fill Station	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1505	Room S229	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1506	Room S229	2008	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1507	Room S229	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1508	Room S229	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1509	Room S229	2008	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1510	Room S236 Dean's Office	2011	Bottled Water Dispenser (Cold)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1511	Room S236 Dean's Office	2011	Bottled Water Dispenser (Hot)	Potable					Testing Required Before Return to Service
OUFSD-1512	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1513	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1514	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1515	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1516	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1517	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1518	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1519	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1520	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1521	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1522	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1523	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1524	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1525	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1526	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1527	Room S224	2014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1528	Room S224	2014	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1529	Room S224	2014	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1530	Room S224	2014	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1531	Room S224 Office Server Room	2014A1	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1532	Room S224 Office Server Room	2014A1	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1533	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1534	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1535	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1536	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1537	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1538	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1539	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1540	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1541	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1542	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1543	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1544	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1545	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1546	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1547	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1548	Room S223	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1549	Room S223	2015	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1550	Room S223	2015	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1551	Room S223	2015	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1552	Room S219	2020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1553	Room S219	2020	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1554	Room S219	2020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1555	Room S219	2020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1556	Room S219	2020	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1557	Room S217	2022	Kitchen Faucet (Cold)	Potable	12/5/2024	1.1			Result Below Action Level Continue O&M
OUFSD-1558	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1559	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1560	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1561	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1562	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1563	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1564	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1565	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1566	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1567	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1568	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1569	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1570	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1571	Room S213	2027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1572	Room S213	2027	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1573	Room S213	2027	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1574	Room S213	2027	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1575	Room S213 Storage	2027A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1576	Room S213 Storage	2027A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1577	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1578	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1579	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1580	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1581	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1582	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1583	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1584	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1585	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1586	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1587	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1588	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1589	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1590	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1591	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1592	Room S212	2028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1593	Room S212	2028	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1594	Room S212	2028	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1595	Room S212	2028	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1596	Custodial Closet (Outside Room S209)	2033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1597	Room N233	2050	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1598	Room N233	2050	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1599	Room N233	2050	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1600	Room N233	2050	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1601	Room N233	2050	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1602	Room N233	2050	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1603	Room N230	2051	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1604	Room N230	2051	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1605	Room N230	2051	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1606	Room N230	2051	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1607	Room N230	2051	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1608	Room N230	2051	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1609	Room N230 Office Storage	2051A1	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1610	Room N230 Office Storage	2051A1	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1611	Room N227	2054	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1612	Room N227	2054	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1613	Room N227	2054	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1614	Room N227	2054	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1615	Room N227	2054	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1616	Women's Bathroom Adj. Room N222	2060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1617	Room N220	2064	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1618	Room N220	2064	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1619	Room N220	2064	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1620	Room N220	2064	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1621	Room N220	2064	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1622	Room N219	2067	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1623	Room N219	2067	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1624	Room N219	2067	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1625	Room N219	2067	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1626	Room N219	2067	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1627	Room N219	2067	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1628	Room N219 Back Room	2067A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1629	Room N219 Back Room	2067A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1630	Corridor Room N214 To Library (Outside Room N214)	2070	Water Cooler	Potable	10/24/2024	8.2	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1631	Corridor Room N214 To Library (Outside Room N214)	2070	Bottle Fill Station	Potable	10/24/2024	5.6	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1632	Room N216	2069	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1633	Room N216	2069	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1634	Room N216	2069	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1635	Room N216	2069	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1636	Room N216	2069	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1637	Room N216	2069	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1638	Room N220	2064	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1639	Exterior Hose Bib (Outside Auditorium)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1640	Exterior Hose Bib (Outside Music Wing)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1641	Exterior Hose Bib o/s Room S129	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1642	Exterior Hose Bib (Outside Room S129)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1643	Exterior Hose Bib (Outside Gym)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1644	Exterior Hose Bib (Outside Room N118)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1659	Corridor Boiler Room To S114 (Outside Room S127B)	1104	Bottle Fill Station	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1660	Corridor Boiler Room To S114 (Outside Room S127B)	1104	Water Cooler	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1661	Corridor Room S231 To S202 (Outside Room S235A)	2044	Bottle Fill Station	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1662	Corridor Room S231 To S202 (Outside Room S235A)	2044	Water Cooler	Potable	10/24/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M

Oceanside High School #7

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1710	Concession Stand Serving Area	3002	Kitchen Faucet (Cold)	Potable					Testing Required Before Return to Service
OUFSD-1711	Concession Stand Women's Bathroom	3002B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1712	Concession Stand Women's Bathroom	3002B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1713	Concession Stand Women's Bathroom	3002B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1714	Concession Stand Men's Bathroom	3002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1715	Concession Stand Men's Bathroom	3002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1716	Concession Stand Men's Bathroom	3002A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1717	Exterior Hose Bib (Outside Concession Stand Men's)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1718	Corridor Room S122 to Room S125 (Outside Art Room S122)	1075	Bottle Fill Station	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1719	Corridor Room S122 to Room S125 (Outside Art Room S122)	1075	Water Cooler	Potable	11/19/2024	< 1.0	12/5/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1729	Kitchen	1116	Pasta Pot/Steam Kettle	Potable	12/5/2024	1.1			Result Below Action Level Continue O&M
OUFSD-1730	Kitchen Storage	1116B	Kitchen Faucet (Cold)	Potable	12/5/2024	1.9			Result Below Action Level Continue O&M
OUFSD-1731	Kitchen Storage	1116B	Spray Nozzle	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1732	Room N219 Back Room	2067A	Bottled Water Dispenser (Hot)	Potable	12/5/2024	<1.0			Result Below Action Level Continue O&M

Fulton Avenue School #8

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0959	Room 32	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0961	Room 31	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0963	Room 30	1064	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0965	Room 28	1063	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0967	Room 29	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0969	Room 26	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0971	Room 27	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0977	Room 22	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0979	Girl's Bathroom Adj. Room 22	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0980	Girl's Bathroom Adj. Room 22	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0981	Girl's Bathroom Adj. Room 22	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0982	Room 23	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0984	Corridor Room 19 To Room 28 (Outside Room 23)	1065	Water Fountain-No Chiller	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-0986	Custodial Closet (Outside Room 20)	1054	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0988	Boy's Bathroom Adj. Room 20	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0989	Boy's Bathroom Adj. Room 20	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0990	Room 21	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0992	Room 20	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0994	Room 19	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0996	Room 19 Bathroom	1050A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Fulton Avenue School #8

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-0997	Room 18 A/B	1049B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-0999	Resource Room A	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1000	Corridor Main Entrance To Auditorium (Outside Music	1044	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1001	Corridor Main Entrance To Auditorium (Outside Music	1044	Bottle Fill Station	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1002	Room 14B Science Closet	1039B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1003	Music Room 12	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1005	Gym Office Bathroom	1032A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1006	Gym Office Bathroom	1032A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1007	Faculty Women's Bathroom (Outside Gym)	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1008	Library	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1010	Kitchen	1027A	Kitchen Service Area	Non-Applicable	12/4/2024	8.7	1/8/2025	28.3	Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
OUFSD-1015	Room 13	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1016	Custodial Office	1025	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1017	Principal's Office Bathroom	1020B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1018	Nurse's Office	1018	Nurse's Office Sink	Potable	12/4/2024	15.6	1/8/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1019	Boy's Bathroom Across Main Office	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1020	Boy's Bathroom Across Main Office	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1021	Custodial Closet (Outside Main Office)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1022	Custodial Closet (Outside Main Office)	1015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1023	Girl's Bathroom Across Main Office	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Fulton Avenue School #8

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1024	Girl's Bathroom Across Main Office	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1025	Room 11	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1027	Room 10A Bathroom	1011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1029	Room 9	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1031	Room 10	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1033	Room 7	1008	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1035	Room 8	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1037	Room 5	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1039	Room 6	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1041	Room 3	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1043	Room 4	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1045	Room 1	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1047	Room 2A	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1048	Room 101	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1050	Room 101 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1051	Room 102	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1053	Room 102 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1054	Boiler Room	0001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1055	Faculty Room P1	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1056	Faculty Room P1 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Fulton Avenue School #8

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1057	Resource Room P2 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1063	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1064	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1065	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1066	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1067	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1068	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1346	Cafeteria	1027	Bottle Fill Station	Potable	8/19/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1347	Cafeteria	1027	Water Cooler	Potable	8/19/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1348	Corridor Room 1 To Main Office (Outside Room 10A)	1021	Bottle Fill Station	Potable	8/19/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1349	Corridor Room 1 To Main Office (Outside Room 10A)	1021	Water Cooler	Potable	8/19/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1645	Room 24	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1646	Room 25	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1647	Custodial Closet (Outside Room 20)	1054	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1648	Boy's Bathroom Adj. Room 20	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1649	Corridor Main Entrance To Auditorium (Outisde	1044	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1650	Kitchen	1027A	Kitchen Faucet (Cold)	Potable	12/4/2024	10.6	1/8/2025	4.5	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1651	Kitchen	1027A	Kitchen Faucet (Cold)	Potable	12/4/2024	3.3			Result Below Action Level Continue O&M
OUFSD-1652	Kitchen	1027A	Kitchen Faucet (Cold)	Potable	12/4/2024	7.4	1/8/2025	1.1	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1653	Kitchen	1027A	Spray Nozzle	Potable	12/4/2024	1.5			Result Below Action Level Continue O&M

Fulton Avenue School #8

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1654	Exterior Hose Bib (Outside Faculty Lounge)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1655	Exterior Hose Bib (Outside Room 3)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1656	Exterior Hose Bib (Outside Room 21)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1657	Exterior Hose Bib (Outside Main Lobby)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1658	Exterior Hose Bib (Outside Room 12)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1069	3rd Floor Corridor A316 To A300 (Outside Room A315)	3021	Water Fountain-No Chiller	Potable	7/29/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1070	Boy's Bathroom Adj. Room A313	3006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1071	Boy's Bathroom Adj. Room A313	3006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1072	Boy's Bathroom Adj. Room A313	3006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1073	Boy's Bathroom Adj. Room A313	3006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1074	Boy's Bathroom Adj. Room A313	3006	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1075	Women's Faculty Bathroom Across Room A310	3007A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1076	Girl's Bathroom Adj. Room A310	3008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1077	Girl's Bathroom Adj. Room A310	3008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1078	Girl's Bathroom Adj. Room A310	3008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1079	Girl's Bathroom Adj. Room A310	3008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1080	Custodial Closet A11	3009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1081	Custodial Closet A11	3009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1082	Room A309 Bathroom	3011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1083	Room A309 Bathroom	3011A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1085	Room A307	3014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1086	Room A303	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1087	Room A303	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1088	3rd Floor Corridor A316 To A300 (Outside Room A302)	3021	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1089	3rd Floor Corridor A316 To A300 (Outside Room A302)	3021	Bottle Fill Station	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1090	Room A301	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1091	Room A301	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1092	Room A215	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1093	2nd Floor Corridor A216 To A200 (Outside Room A215)	2021	Water Fountain-No Chiller	Potable	7/29/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1094	Room A213	2002	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1095	Room A213	2002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1096	Boy's Bathroom Adj. Room A211	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1097	Boy's Bathroom Adj. Room A211	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1098	Boy's Bathroom Adj. Room A211	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1099	Boy's Bathroom Adj. Room A211	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1100	Boy's Bathroom Adj. Room A211	2006	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1101	Men's Bathroom Across Room A210	2007A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1102	Men's Bathroom Across Room A210	2007A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1103	Girl's Bathroom Adj. Room A210	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1104	Girl's Bathroom Adj. Room A210	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1105	Girl's Bathroom Adj. Room A210	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1106	Girl's Bathroom Adj. Room A210	2008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1107	Room A210	2010	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1108	Room A210	2010	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1109	Custodial Closet A212	2009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1110	Custodial Closet A212	2009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1111	Room A209 Bathroom	2011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1112	Room A209 Bathroom	2011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1113	Room A209 Bathroom	2011A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1114	Room A207	2013	Home Economics Faucet (Cold)	Potable	12/4/2024	9.5	1/17/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1115	Room A207	2013	Home Economics Faucet (Cold)	Potable	12/4/2024	6.3	1/17/2025	2.5	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1116	Room A207	2013	Home Economics Faucet (Cold)	Potable	12/4/2024	14.9	1/24/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1117	Room A207	2013	Home Economics Faucet (Cold)	Potable	12/4/2024	7.3	1/17/2025	2.5	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1118	Room A203	2016	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1119	Room A203	2016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1124	2nd Floor Corridor A216 To A200 (Outside Room A202)	2021	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1125	2nd Floor Corridor A216 To A200 (Outside Room A202)	2021	Bottle Fill Station	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1126	Room A202	2019	Home Economics Faucet (Cold)	Potable	12/4/2024	18.4	1/17/2025	2.5	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1130	Room A109 Tech Room	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1131	Room A109 Tech Room	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1136	Boy's Bathroom Adj. Room A109	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1137	Boy's Bathroom Adj. Room A109	1011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1138	Custodial Closet (Outside Room A109)	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1139	Custodial Closet (Outside Room A109)	1012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1141	Girl's Bathroom Adj. Room A109	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1142	Girl's Bathroom Adj. Room A109	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1143	Girl's Bathroom Adj. Room A109	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1144	Girl's Bathroom Adj. Room A109	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1145	Girl's Bathroom Adj. Room A109	1013	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1146	Main Lobby Faculty Women's Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1147	Main Lobby Faculty Women's Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1148	Corridor Room A113 To Room A100 (Outside Custodial	1030	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1149	Corridor Room A113 To Room A100	1030	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1150	Custodial Closet A122	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1151	Main Lobby Men's Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1152	Main Lobby Men's Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1153	Main Lobby Men's Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1154	Room A107	1022	Home Economics Faucet (Cold)	Potable	12/4/2024	1.7			Result Below Action Level Continue O&M
OUFSD-1155	Room A107	1022	Home Economics Faucet (Cold)	Potable	12/4/2024	8.1	1/17/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1156	Room A107	1022	Home Economics Faucet (Cold)	Potable	12/4/2024	18.9	1/17/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1157	Room A107	1022	Home Economics Faucet (Cold)	Potable	12/4/2024	490	1/17/2025	<1.0	Outlet Remediated and Returned to Service Continue O&M
OUFSD-1158	Room A103	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1163	Room A102	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1165	Main Office Bathroom	1033D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1166	9M Nurse's Office	1038	Nurse's Office Sink	Potable	12/4/2024	6.9	1/17/2025	1.5	Outlet Remediated and Returned to Service Continue O&M

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1167	Nurse's Office Bathroom	1038C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1169	Cafeteria A Kitchen	1036B	Kitchen Faucet (Cold)	Potable	12/4/2024	3.0			Result Below Action Level Continue O&M
OUFSD-1173	Cafeteria A Kitchen	1036B	Kitchen Faucet (Cold)	Potable	12/4/2024	1.6			Result Below Action Level Continue O&M
OUFSD-1174	Cafeteria A Kitchen	1036B	Spray Nozzle	Potable	12/4/2024	2.7			Result Below Action Level Continue O&M
OUFSD-1175	Cafeteria A Kitchen	1036B	Ice Machine	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1176	Cafeteria A Kitchen Office Bathroom	1036B1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1177	Cafeteria A Kitchen Custodial Closet	1036B2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1178	Cafeteria A Kitchen Custodial Closet	1036B2	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1182	Gym Lobby Women's Bathroom	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1183	Gym Lobby Women's Bathroom	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1184	Gym Lobby Women's Bathroom	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1185	Custodial Closet B144	1047	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1186	Custodial Closet B144	1047	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1187	Gym Lobby Men's Bathroom	1048	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1188	Gym Lobby Men's Bathroom	1048	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1189	Gym Lobby Men's Bathroom	1048	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1190	Boy's Locker Room Bathroom	1050C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1191	Boy's Locker Room Bathroom	1050C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1194	Faculty Work/Copy Room	6002	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1196	Faculty Work/Copy Room Bathroom	6002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1197	Room C223	6003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1198	Room C222	6005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1199	Women's Bathroom Adj. Room C222	6004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1200	Women's Bathroom Adj. Room C222	6004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1202	Girl's Bathroom Adj. Room C222	6007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1203	Girl's Bathroom Adj. Room C222	6007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1204	Girl's Bathroom Adj. Room C222	6007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1205	Girl's Bathroom Adj. Room C222	6007	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1206	Custodial Closet C209	6008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1207	Boy's Bathroom Adj. Room C221	6009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1208	Boy's Bathroom Adj. Room C221	6009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1209	Boy's Bathroom Adj. Room C221	6009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1210	Boy's Bathroom Adj. Room C221	6009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1211	Boy's Bathroom Adj. Room C221	6009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1212	Room C221	6010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1213	Room C220	6011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1214	Room C211	6012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1215	Room C219	6013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1216	Room C212	6014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1217	Room C218	6015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1218	Room C213	6016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1219	Room C217	6017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1221	Room C214 Speech Office	6019A1	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1223	Custodial Office Bathroom	1054B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1224	Custodial Office Bathroom	1054B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1225	9E Entrance Lobby Faculty Women's Bathroom	5002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1226	9E Entrance Lobby Faculty Women's Bathroom	5002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1227	9E Entrance Lobby Faculty Women's Bathroom	5002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1228	Room C133	5006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1230	Faculty Only Mail Room Bathroom	5007A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1231	Faculty Only Mail Room Bathroom	5007A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1232	Room C132	5008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1234	Occupational Therapy Room	5009	Classroom Faucet	Non-Applicable	12/4/2024	6.2			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
OUFSD-1237	Girl's Bathroom Adj. Room C131	5010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1238	Girl's Bathroom Adj. Room C131	5010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1239	Girl's Bathroom Adj. Room C131	5010	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1240	Custodial Closet C113	5011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1242	Boy's Bathroom Adj. Room C131	5012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1243	Boy's Bathroom Adj. Room C131	5012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1244	Boy's Bathroom Adj. Room C131	5012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1245	Boy's Bathroom Adj. Room C131	5012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1246	Room C131	5013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1248	Room C130	5015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1250	Room C115 Nurse's Office	5016	Nurse's Office Sink	Potable	12/4/2024	2.7			Result Below Action Level Continue O&M
OUFSD-1252	Room C115 Bathroom	5016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1253	Room C129	5017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1255	Room C122	5018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1257	Room C122 Bathroom	5018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1258	Room C128	5019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1260	Room C127	5021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1263	9E Cafeteria	N/A	Water Cooler	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1265	9E Kitchen	N/A	Kitchen Service Area	Potable	12/4/2024	1.5			Result Below Action Level Continue O&M
OUFSD-1266	9E Kitchen	N/A	Kitchen Faucet (Cold)	Potable	12/4/2024	4.6			Result Below Action Level Continue O&M
OUFSD-1267	9E Kitchen	N/A	Kitchen Faucet (Cold)	Potable	12/4/2024	1.8			Result Below Action Level Continue O&M
OUFSD-1268	9E Kitchen	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1269	9E Kitchen Storage	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1270	Girl's Locker Room Bathroom	1053D	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1273	Exterior Hose Bib (Outside Room A113)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1274	Exterior Hose Bib o/s New Construction	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1275	Exterior Hose Bib (Outside Cafeteria A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1278	Exterior Hose Bib (by Track)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1279	Exterior Hose Bib (Outside Cafeteria)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1280	Exterior Hose Bib (Outside Cafeteria)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1282	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1289	2nd Floor Corridor Room C215 To C223 (Outside Room	6023	Water Cooler	Potable	12/4/2024	1.6			Result Below Action Level Continue O&M
OUFSD-1290	2nd Floor Corridor Room C215 To C223 (Outside Room	6023	Bottle Fill Station	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1291	Cafeteria A	1036	Bottle Fill Station	Potable	3/3/2023	34	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1292	Cafeteria A	1036	Water Cooler	Potable	3/3/2023	28	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1293	Cafeteria B	1041	Bottle Fill Station	Potable	4/17/2023	< 6.0 ND	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1294	Cafeteria B	1041	Water Cooler	Potable	4/17/2023	3.3	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1295	Corridor Outside Of Cafeterias	1043	Bottle Fill Station	Potable	5/11/2023	<3.0 ND	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1296	Corridor Outside Of Cafeterias	1043	Water Cooler	Potable	5/11/2023	<3.0 ND	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1318	1st Floor Corridor Elevator to Lobby (Outside Occupational	5026	Bottle Fill Station	Potable	4/12/2024	<1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1319	1st Floor Corridor Elevator to Lobby (Outside Occupational	5026	Water Cooler	Potable	4/12/2024	<1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1320	1st Floor Corridor Elevator to Lobby (Outside Room C127)	5026	Bottle Fill Station	Potable	4/12/2024	<1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1321	1st Floor Corridor Elevator to Lobby (Outside Room C127)	5026	Water Cooler	Potable	4/12/2024	<1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1322	2nd Floor Corridor Room C215 To C223 (Outside Room	6023	Bottle Fill Station	Potable	4/12/2024	<1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1323	2nd Floor Corridor Room C215 To C223 (Outside Room	6023	Water Cooler	Potable	4/12/2024	<1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1325	Corridor Gymnasium To Elementary School (Outside	1057	Bottle Fill Station	Potable	5/2/2024	<1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1326	2nd Floor Corridor (Outside Room B224)	N/A	Bottle Fill Station	Potable	5/2/2024	2.1	12/4/2024	<1.0	Result Below Action Level Continue O&M

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1327	2nd Floor Corridor (Outside Room B224)	N/A	Water Cooler	Potable	5/2/2024	3.1	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1328	1st Floor Corridor (Outside Room B124)	N/A	Bottle Fill Station	Potable	6/4/2024	16.4	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1329	1st Floor Corridor (Outside Room B124)	N/A	Water Cooler	Potable	6/4/2024	1.2	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1330	Corridor Room A113 To Room A100	1030	Bottle Fill Station	Potable	6/4/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1331	Corridor Room A113 To Room A100	1030	Water Cooler	Potable	6/4/2024	2.8	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1332	Corridor Room A113 To Room A100 (Outside Room A102)	1030	Bottle Fill Station	Potable	7/9/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1333	Corridor Room A113 To Room A100 (Outside Room A102)	1030	Water Cooler	Potable	7/9/2024	< 1.0	12/4/2024	<1.0	Result Below Action Level Continue O&M
OUFSD-1663	Gym Lobby Women's Bathroom	1046	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1664	Boy's Bathroom Adj. Room A109	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1665	Boy's Bathroom Adj. Room A109	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1666	Boy's Bathroom Adj. Room A109	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1667	Boy's Bathroom Adj. Room A109	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1668	Girl's Bathroom Adj. Room A109	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1669	Room A103	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1670	Room A101	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1671	Room A101	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1672	Room A101	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1673	Room A101	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1674	Room A101	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1675	Room A101	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1676	Room A102	1027	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1677	Cafeteria A Kitchen	1036B	Kitchen Faucet (Cold)	Potable	12/4/2024	1.7			Result Below Action Level Continue O&M
OUFSD-1678	Cafeteria A Kitchen	1036B	Kitchen Faucet (Cold)	Potable	12/4/2024	1.9			Result Below Action Level Continue O&M
OUFSD-1679	Cafeteria A Kitchen	1036B	Spray Nozzle	Potable	12/4/2024	3.3			Result Below Action Level Continue O&M
OUFSD-1680	Room A215	2001	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1681	Room A201	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1682	Room A201	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1683	Room A201	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1684	Room A201	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1685	Room A201	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1686	Room A201	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1687	Women's Faculty Bathroom Across Room A310	3007A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1688	Room A307	3014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1689	Girl's Bathroom Adj. Room C131	5010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1690	Boy's Bathroom Adj. Room C131	5012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1691	9E Cafeteria	N/A	Bottle Fill Station	Potable	12/4/2024	<1.0			Result Below Action Level Continue O&M
OUFSD-1692	Faculty Work/Copy Room Bathroom	6002A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1693	Women's Bathroom Adj. Room C222	6004A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1694	Room C215	6020	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1695	Exterior Hose Bib (Outside Gym)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Oceanside Middle School #9M & Walter S. Boar

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
OUFSD-1696	Exterior Hose Bib (Outside 9E Entrance)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1697	Exterior Hose Bib (Outside 9E Entrance)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1698	Exterior Hose Bib (Outside Left of 9M Entrance)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1699	Exterior Hose Bib (Outside Room A101)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
OUFSD-1728	Cafeteria A Kitchen	1036B	Pasta Pot/Steam Kettle	Potable	12/4/2024	2.9			Result Below Action Level Continue O&M

Attachment 3:

Laboratory Analytical Reports

J.C. Broderick & Associates, Inc.


Environmental Consulting & Testing

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395





Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53785
Building: Florence A. Smith School #2
FLO2

Client: Oceanside Union Free School District
Retest/New Install []
Turn Around: Normal 1 wk Rush _____

Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0077	NO	1018	Nurse's Office	NS	12/3/2024	4:56:00 AM
OUFSD-0084	OF	1020B	Main Office Break Room	WC	12/3/2024	5:05:00 AM
OUFSD-0090	GY	1027	Gym	DW	12/3/2024	5:08:00 AM
OUFSD-0097	CA	1037	Cafeteria	WC	12/3/2024	4:51:00 AM
OUFSD-0098	CA	1037	Cafeteria	WF	12/3/2024	4:50:00 AM
OUFSD-0102	KI	1038	Kitchen	KC	12/3/2024	4:42:00 AM
OUFSD-1334	HA	1034	Corridor Room 3 To Auditorium (Outside Faculty Lounge)	WC	12/3/2024	4:54:00 AM
OUFSD-1335	HA	1034	Corridor Room 3 To Auditorium (Outside Faculty Lounge)	WF	12/3/2024	4:54:00 AM
OUFSD-1336	HA	1012	Corridor Room 10 To Room 6 (Outside Room 110)	WC	12/3/2024	4:57:00 AM
OUFSD-1337	HA	1012	Corridor Room 10 To Room 6 (Outside Room 110)	WF	12/3/2024	4:58:00 AM
OUFSD-1339	HA	2010	Stairwell Adjacent Room 26 (Outside Room 17)	WF	12/3/2024	5:00:00 AM
OUFSD-1364	HA	2014	Corridor Room 29 To Room 17 (Outside Room 29)	WF	12/3/2024	5:01:00 AM
OUFSD-1365	HA	2014	Corridor Room 29 To Room 17 (Outside Room 29)	WC	12/3/2024	5:02:00 AM
OUFSD-1366	HA	2010	Stairwell Adjacent Room 26 (Outside Room 17)	WC	12/3/2024	5:00:00 AM
OUFSD-1369	FL	1014	Faculty Room	BWC	12/3/2024	4:54:00 AM
OUFSD-1370	FL	1014	Faculty Room	BWH	12/3/2024	4:54:00 AM
OUFSD-1371	KI	1038	Kitchen	KC	12/3/2024	4:47:00 AM
OUFSD-1372	KI	1038	Kitchen	SN	12/3/2024	4:41:00 AM

RECEIVED
EMERGENCY ANALYTICAL, INC.

Carle Place, NY
DEC 03 2024 PM 12:53

Ph 200.8 888 12/4/24

Building Address
2745 Terrell Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

Signature:


James Han 12/3/24
253 PM

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo

ECS7949

**Lead in Water: Chain of Custody for**

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

Florence A. Smith School #2

FLO2

Client:

Oceanside Union Free School District

Retest/New Install ☐**Turn Around:** Normal 1 wk **Rush** ☐

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 18

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 03 2024 PM12:53

Pb 200.8 800 -> 12/4/24

Building Address

2745 Terrell Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5**Lab Received:**James Han 12/3/24**Signature:**[Signature] 12:53 PM**Samplers Name:**Conor Malanaphy**Samplers Signature:**Conor Malanaphy**JCB Project Manager:**Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457949**LIMS Reference ID:** EC57949**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53785 - Florence A. Smith School #2 FLO2
- Oceanside Union Free School District - 2745
Terrell Avenue Oceanside, NY 11572

Customer PO:
EMSL Sales Rep: Jeromy Bish
Received: 12/03/2024 12:53
Reported: 12/04/2024 15:47

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OUFSD-0077	Lims Reference ID: EC57949-01					Matrix: Drinking Water		Sampled: 12/03/24 04:56:00	
Metals									
Lead	3.2	1	1.0		µg/L	12/04/24 09:49	12/04/24 09:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0084	Lims Reference ID: EC57949-02					Matrix: Drinking Water		Sampled: 12/03/24 05:05:00	
Metals									
Lead	< 1.0	1	1.0		µg/L	12/04/24 09:51	12/04/24 09:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0090	Lims Reference ID: EC57949-03					Matrix: Drinking Water		Sampled: 12/03/24 05:08:00	
Metals									
Lead	< 1.0	1	1.0		µg/L	12/04/24 09:55	12/04/24 09:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0097	Lims Reference ID: EC57949-04					Matrix: Drinking Water		Sampled: 12/03/24 04:51:00	
Metals									
Lead	< 1.0	1	1.0		µg/L	12/04/24 09:56	12/04/24 09:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0098	Lims Reference ID: EC57949-05					Matrix: Drinking Water		Sampled: 12/03/24 04:50:00	
Metals									
Lead	< 1.0	1	1.0		µg/L	12/04/24 10:00	12/04/24 10:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0102	Lims Reference ID: EC57949-06					Matrix: Drinking Water		Sampled: 12/03/24 04:42:00	
Metals									
Lead	2.2	1	1.0		µg/L	12/04/24 10:01	12/04/24 10:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1334	Lims Reference ID: EC57949-07					Matrix: Drinking Water		Sampled: 12/03/24 04:54:00	
Metals									
Lead	< 1.0	1	1.0		µg/L	12/04/24 10:03	12/04/24 10:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1335	Lims Reference ID: EC57949-08					Matrix: Drinking Water		Sampled: 12/03/24 04:54:00	
Metals									
Lead	< 1.0	1	1.0		µg/L	12/04/24 10:04	12/04/24 10:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1336	Lims Reference ID: EC57949-09					Matrix: Drinking Water		Sampled: 12/03/24 04:57:00	
Metals									
Lead	< 1.0	1	1.0		µg/L	12/04/24 10:05	12/04/24 10:05	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457949**LIMS Reference ID:** EC57949**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53785 - Florence A. Smith School #2 FLO2
- Oceanside Union Free School District - 2745
Terrell Avenue Oceanside, NY 11572

Customer PO:
EMSL Sales Rep: Jeromy Bish
Received: 12/03/2024 12:53
Reported: 12/04/2024 15:47

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OUFSD-1337	Lims Reference ID: EC57949-10					Matrix: Drinking Water			Sampled: 12/03/24 04:58:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:06	12/04/24 10:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1339	Lims Reference ID: EC57949-11					Matrix: Drinking Water			Sampled: 12/03/24 05:00:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:08	12/04/24 10:08	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1364	Lims Reference ID: EC57949-12					Matrix: Drinking Water			Sampled: 12/03/24 05:01:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:26	12/04/24 10:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1365	Lims Reference ID: EC57949-13					Matrix: Drinking Water			Sampled: 12/03/24 05:02:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:30	12/04/24 10:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1366	Lims Reference ID: EC57949-14					Matrix: Drinking Water			Sampled: 12/03/24 05:00:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:31	12/04/24 10:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1369	Lims Reference ID: EC57949-15					Matrix: Drinking Water			Sampled: 12/03/24 04:54:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:33	12/04/24 10:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1370	Lims Reference ID: EC57949-16					Matrix: Drinking Water			Sampled: 12/03/24 04:54:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:34	12/04/24 10:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1371	Lims Reference ID: EC57949-17					Matrix: Drinking Water			Sampled: 12/03/24 04:47:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:38	12/04/24 10:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1372	Lims Reference ID: EC57949-18					Matrix: Drinking Water			Sampled: 12/03/24 04:41:00
Metals									
Lead	< 1.0	1		1.0	µg/L	12/04/24 10:39	12/04/24 10:39	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457949**LIMS Reference ID:** EC57949**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]

1775 Expressway Drive North, Suite 1

Hauppauge, NY 11788

(631) 584-5492

alombardo@jcbroderick.com

Project Name:

23-53785 - Florence A. Smith School #2 FLO2

- Oceanside Union Free School District - 2745

Terrell Avenue Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

12/03/2024 12:53

Reported:

12/04/2024 15:47

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	03/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457949**LIMS Reference ID:** EC57949**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]

1775 Expressway Drive North, Suite 1

Hauppauge, NY 11788

(631) 584-5492

alombardo@jcbroderick.com

Project Name:

23-53785 - Florence A. Smith School #2 FLO2

- Oceanside Union Free School District - 2745

Terrell Avenue Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

12/03/2024 12:53

Reported:

12/04/2024 15:47


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Oaks School #3

OS3

Client:

Oceanside Union Free School District

Retest/New Install ☐

Turn Around: Normal 1 wk Rush

Courier

of 2

EC57952

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0152	HA	1012	Corridor Main Office To Computer Room (Outside Room 4)	DW	12/3/2024	6:00:00 AM
OUFSD-0157	NO	1006	Nurse's Office	NS	12/3/2024	6:00:00 AM
OUFSD-0183	CA	1036	Cafeteria	WC	12/3/2024	6:06:00 AM
OUFSD-0184	CA	1036	Cafeteria	WF	12/3/2024	6:07:00 AM
OUFSD-0185	KI	1036A	Kitchen	SA	12/3/2024	6:09:00 AM
OUFSD-0186	KI	1036A	Kitchen	KC	12/3/2024	6:09:00 AM
OUFSD-0187	KI	1036A	Kitchen	KC	12/3/2024	6:10:00 AM
OUFSD-0189	KI	1036A	Kitchen	SN	12/3/2024	6:11:00 AM
OUFSD-0190	KI	1036A	Kitchen	KC	12/3/2024	6:12:00 AM
OUFSD-1287	HA	1012	Corridor Main Office To Computer Room (Outside Nurse's Office)	WF	12/3/2024	5:58:00 AM
OUFSD-1288	HA	1012	Corridor Main Office To Computer Room (Outside Nurse's Office)	WC	12/3/2024	5:59:00 AM
OUFSD-1350	HA	2037	Corridor Room 10 to Room 18 (Outside Room 14)	WF	12/3/2024	6:15:00 AM
OUFSD-1351	HA	2037	Corridor Room 10 to Room 18 (Outside Room 14)	WC	12/3/2024	6:15:00 AM
OUFSD-1352	HA	2016	Corridor Supply Storage to Custodial Closet (Outside Room A7)	WF	12/3/2024	6:13:00 AM
OUFSD-1353	HA	2016	Corridor Supply Storage to Custodial Closet (Outside Room A7)	WC	12/3/2024	6:13:00 AM
OUFSD-1388	GY	1018	Gym	WC	12/3/2024	6:02:00 AM
OUFSD-1389	GY	1018	Gym	WC	12/3/2024	6:04:00 AM

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

DEC 03 2024 PM12:52

Pb2008 8A 12/4/24

Building Address

2852 Fortesque Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Recieved: A. Minnifield


Signature: A. Minnifield

12/3/24 12:52 pm

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Oaks School #3

OS3

EC57952

Client:

Oceanside Union Free School District

Retest/New Install ☒

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 17

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 03 2024 PM12:52

12/3/24 12:52pm
12/3/24 12:52pm

Building Address

2852 Fortesque Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received: A. Minnifield

Signature: A. Minnifield
12/3/24 12:52pm

Samplers Name: Conor Mullanphy

Samplers Signature: Conor Mullanphy

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457952**LIMS Reference ID:** EC57952**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]

1775 Expressway Drive North, Suite 1

Hauppauge, NY 11788

(631) 584-5492

alombardo@jcbroderick.com

Project Name:

23-53785, Oaks School #3, OS3, Oceanside
Union Free School District, 2852 Fortesque
Avenue Oceanside NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

12/03/2024 12:52

Reported:

12/05/2024 13:34

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OUFSD-0152	Lims Reference ID: EC57952-01					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/05/24 09:02	12/05/24 09:02	SEH	EPA 200.8 (DA)/EPA 200.8	
Sample: OUFSD-0157	Lims Reference ID: EC57952-02					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	1.3	1	1.0	µg/L	12/05/24 09:03	12/05/24 09:03	SEH	EPA 200.8 (DA)/EPA 200.8	
Sample: OUFSD-0183	Lims Reference ID: EC57952-03					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/05/24 09:04	12/05/24 09:04	SEH	EPA 200.8 (DA)/EPA 200.8	
Sample: OUFSD-0184	Lims Reference ID: EC57952-04					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/05/24 09:06	12/05/24 09:06	SEH	EPA 200.8 (DA)/EPA 200.8	
Sample: OUFSD-0185	Lims Reference ID: EC57952-05					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	1.4	1	1.0	µg/L	12/05/24 09:07	12/05/24 09:07	SEH	EPA 200.8 (DA)/EPA 200.8	
Sample: OUFSD-0186	Lims Reference ID: EC57952-06					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	9.3	1	1.0	µg/L	12/05/24 11:41	12/05/24 11:41	SEH	EPA 200.8 (Dig)/EPA 200.8	
Sample: OUFSD-0187	Lims Reference ID: EC57952-07					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	10.1	1	1.0	µg/L	12/05/24 09:08	12/05/24 09:08	SEH	EPA 200.8 (DA)/EPA 200.8	
Sample: OUFSD-0189	Lims Reference ID: EC57952-08					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	6.4	1	1.0	µg/L	12/05/24 09:12	12/05/24 09:12	SEH	EPA 200.8 (DA)/EPA 200.8	
Sample: OUFSD-0190	Lims Reference ID: EC57952-09					Matrix: Drinking Water			Sampled: 12/03/24 00:00:00
Metals									
Lead	8.6	1	1.0	µg/L	12/05/24 09:14	12/05/24 09:14	SEH	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457952**LIMS Reference ID:** EC57952**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53785, Oaks School #3, OS3, Oceanside
Union Free School District, 2852 Fortesque
Avenue Oceanside NY 11572

Customer PO:
EMSL Sales Rep: Jeromy Bish
Received: 12/03/2024 12:52
Reported: 12/05/2024 13:34

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OUFSD-1287 Lims Reference ID: EC57952-10 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/05/24 09:18	12/05/24 09:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1288 Lims Reference ID: EC57952-11 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/05/24 09:19	12/05/24 09:19	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1350 Lims Reference ID: EC57952-12 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/05/24 09:20	12/05/24 09:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1351 Lims Reference ID: EC57952-13 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/24 14:26	12/04/24 14:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1352 Lims Reference ID: EC57952-14 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/24 14:30	12/04/24 14:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1353 Lims Reference ID: EC57952-15 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/24 14:31	12/04/24 14:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1388 Lims Reference ID: EC57952-16 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/24 14:32	12/04/24 14:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1389 Lims Reference ID: EC57952-17 Matrix: Drinking Water Sampled: 12/03/24 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/24 14:34	12/04/24 14:34	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457952**LIMS Reference ID:** EC57952**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53785, Oaks School #3, OS3, Oceanside
Union Free School District, 2852 Fortesque
Avenue Oceanside NY 11572

Customer PO:
EMSL Sales Rep: Jeremy Bish
Received: 12/03/2024 12:52
Reported: 12/05/2024 13:34

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062457952**LIMS Reference ID:** EC57952**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53785, Oaks School #3, OS3, Oceanside
Union Free School District, 2852 Fortesque
Avenue Oceanside NY 11572

Customer PO:
EMSL Sales Rep: Jeromy Bish

Received: 12/03/2024 12:52

Reported: 12/05/2024 13:34

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: South Oceanside Road School #4

SORS4

EC57950

Client:

Oceanside Union Free School District

Retest/New Install ☐

Turn Around: Normal 1 wk - Rush

Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0213	HA	2005	Corridor Faculty Room To Room 211 (Outside Room 212)	DW	12/3/2024	5:43:00 AM
OUFSD-0243	NO	1015	Health Office	NS	12/3/2024	5:28:00 AM
OUFSD-0251	CA	1027	Cafeteria	WC	12/3/2024	5:32:00 AM
OUFSD-0252	CA	1027	Cafeteria	WF	12/3/2024	5:32:00 AM
OUFSD-0254	KI	1028	Kitchen	KC	12/3/2024	5:34:00 AM
OUFSD-0256	KI	1028	Kitchen	SN	12/3/2024	5:35:00 AM
OUFSD-0257	KI	1028	Kitchen	KC	12/3/2024	5:35:00 AM
OUFSD-0258	HA	1035	Corridor Gym To Cafeteria (Outside Cafeteria)	DW	12/3/2024	5:38:00 AM
OUFSD-0265	GY	1033	Gym	DW	12/3/2024	5:39:00 AM
OUFSD-1354	HA	2022	Corridor Room 205 To Room 210 (Outside Room 204)	WF	12/3/2024	5:45:00 AM
OUFSD-1355	HA	2022	Corridor Room 205 To Room 210 (Outside Room 204)	WC	12/3/2024	5:46:00 AM
OUFSD-1356	HA	1026	Corridor Room 101 To 105 (Outside Room 105)	WF	12/3/2024	5:26:00 AM
OUFSD-1357	HA	1026	Corridor Room 101 To 105 (Outside Room 105)	WC	12/3/2024	5:27:00 AM
OUFSD-1358	HA	1026	Corridor Room 101 To 105 (Outside Room 101)	WF	12/3/2024	5:30:00 AM
OUFSD-1359	HA	1026	Corridor Room 101 To 105 (Outside Room 101)	WC	12/3/2024	5:31:00 AM
OUFSD-1403	FL	2001	Faculty Room	BWC	12/3/2024	5:41:00 AM
OUFSD-1404	FL	2001	Faculty Room	BWH	12/3/2024	5:41:00 AM
OUFSD-1727	KI	1028	Kitchen	KC	12/3/2024	5:35:00 AM

Building Address

3210 Oceanside Road
Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received: A. Minnifield

Signature: A. Minnifield
12/3/24 12:51pm

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy


JCB Project Manager: Anthony Lombardo

RECEIVED
ENGL ANALYTICAL, INC.

Carle Place, NY

DEC 03 2024 PM12:51

Pb2008 88 - 12/14/24



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

South Oceanside Road School #4

SORS4

Client:

Oceanside Union Free School District

Retest/New Install ☐Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 18

RECEIVED
 EMSL ANALYTICAL, INC.
 Carle Place, NY
 DEC 03 2024 PM12:51

Building Address

3210 Oceanside Road

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received: A. MinnifieldSignature: A. Minnifield
 12/3/24 12:51pmSamplers Name: Conor MulanaphySamplers Signature: Conor MulanaphyJCB Project Manager: Anthony Lombardo

2008
 Pb 12/4/24 8h
 12/4/24



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.EMSL.com>

LIMS Order	EC57950
EMSL Order ID	EC57950

1/2/2025

J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/03/2024
The results are tabulated on the attached pages for the following client designated project:

23-53785, North Oceanside Road School #5

The reference number for these samples is EMSL Order #: EC57950. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact the lab at 516.997.7251.

James Han, Chemistry Laboratory Manager

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
Accreditation Name/#: AIHA-LAP, LLC-ELLAP # 102344 | NYELAP #11469

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57950
 EMSL Order ID EC57950

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, North Oceanside Road School #5
 Received: December 3, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-0213		LIMS ID: EC57950-01			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0243		LIMS ID: EC57950-02			Matrix: Drinking Water		Collected: 12/03/24		
Lead	2.9		1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0251		LIMS ID: EC57950-03			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0252		LIMS ID: EC57950-04			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0254		LIMS ID: EC57950-05			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0256		LIMS ID: EC57950-06			Matrix: Drinking Water		Collected: 12/03/24		
Lead	2.0		1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0257		LIMS ID: EC57950-07			Matrix: Drinking Water		Collected: 12/03/24		
Lead	3.1		1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0258		LIMS ID: EC57950-08			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-0265		LIMS ID: EC57950-09			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-1354		LIMS ID: EC57950-10			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-1355		LIMS ID: EC57950-11			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-1356		LIMS ID: EC57950-12			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/4/2024	SEH	EPA 200.8
Sample ID: OUFSD-1357		LIMS ID: EC57950-13			Matrix: Drinking Water		Collected: 12/03/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/5/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57950
 EMSL Order ID EC57950

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, North Oceanside Road School #5
 Received: December 3, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1358		LIMS ID:	EC57950-14		Matrix:	Drinking Water	Collected:	12/03/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/5/2024	SEH	EPA 200.8
Sample ID: OUFSD-1359		LIMS ID:	EC57950-15		Matrix:	Drinking Water	Collected:	12/03/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/5/2024	SEH	EPA 200.8
Sample ID: OUFSD-1403		LIMS ID:	EC57950-16		Matrix:	Drinking Water	Collected:	12/03/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/5/2024	SEH	EPA 200.8
Sample ID: OUFSD-1404		LIMS ID:	EC57950-17		Matrix:	Drinking Water	Collected:	12/03/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/5/2024	SEH	EPA 200.8
Sample ID: OUFSD-1727		LIMS ID:	EC57950-18		Matrix:	Drinking Water	Collected:	12/03/24	
Lead	3.0		1	1.00	µg/L	12/4/2024	12/5/2024	SEH	EPA 200.8



EMSL Analytical

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57950
EMSL Order ID EC57950

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, North Oceanside Road School #5
Received: December 3, 2024
Reported: January 2, 2025

Notes and Definitions

Code	Description	Number	Expires
06-NYSDOH	New York Department of Public Health	11469	04/01/25
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/25
06-California ELAP	California Water Boards	2339	04/01/25
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/26

EC57994



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

Fulton Avenue School #8

FUL

Client:

Oceanside Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush _____

Page 1 of 1

Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0984	HA	1065	Corridor Room 19 To Room 28 (Outside Room 23)	DW	12/4/2024	5:25:00 AM
OUFSD-1000	HA	1044	Corridor Main Entrance To Auditorium (Outside Music Room 12)	WC	12/4/2024	5:23:00 AM
OUFSD-1001	HA	1044	Corridor Main Entrance To Auditorium (Outside Music Room 12)	WF	12/4/2024	5:23:00 AM
OUFSD-1010	KI	1027A	Kitchen	SA	12/4/2024	5:17:00 AM
OUFSD-1018	NO	1018	Nurse's Office	NS	12/4/2024	5:28:00 AM
OUFSD-1346	CA	1027	Cafeteria	WF	12/4/2024	5:20:00 AM
OUFSD-1347	CA	1027	Cafeteria	WC	12/4/2024	5:21:00 AM
OUFSD-1348	HA	1021	Corridor Room 1 To Main Office (Outside Room 10A)	WF	12/4/2024	5:23:00 AM
OUFSD-1349	HA	1021	Corridor Room 1 To Main Office (Outside Room 10A)	WC	12/4/2024	5:23:00 AM
OUFSD-1649	HA	1044	Corridor Main Entrance To Auditorium (Outside Computer Lab 15)	WC	12/4/2024	5:21:00 AM
OUFSD-1650	KI	1027A	Kitchen	KC	12/4/2024	5:17:00 AM
OUFSD-1651	KI	1027A	Kitchen	KC	12/4/2024	5:18:00 AM
OUFSD-1652	KI	1027A	Kitchen	KC	12/4/2024	5:18:00 AM
OUFSD-1653	KI	1027A	Kitchen	SN	12/4/2024	5:18:00 AM

Samples Submitted 14

2024 Pb JGL 12/7/24

Building Address

3252 Fulton Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received: A. Minnifield

Signature: A. Minnifield
12/4/24 1:02pm

Samplers Name: Anthony Lombardo

Samplers Signature: [Signature]

JCB Project Manager: LOMBARDO

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 04 2024 PM01:02



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.EMSL.com>

LIMS Order	EC57994
EMSL Order ID	EC57994

1/2/2025

J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/04/2024
The results are tabulated on the attached pages for the following client designated project:

23-53785, Fulton Avenue School #8

The reference number for these samples is EMSL Order #: EC57994. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact the lab at 516.997.7251.

James Han, Chemistry Laboratory Manager

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
Accreditation Name/#: AIHA-LAP, LLC-ELLAP # 102344 | NYELAP #11469

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57994
 EMSL Order ID EC57994

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Fulton Avenue School #8
 Received: December 4, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-0984		LIMS ID: EC57994-01			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1000		LIMS ID: EC57994-02			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1001		LIMS ID: EC57994-03			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1010		LIMS ID: EC57994-04			Matrix: Drinking Water		Collected: 12/04/24		
Lead	8.7		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1018		LIMS ID: EC57994-05			Matrix: Drinking Water		Collected: 12/04/24		
Lead	15.6	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1346		LIMS ID: EC57994-06			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1347		LIMS ID: EC57994-07			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1348		LIMS ID: EC57994-08			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1349		LIMS ID: EC57994-09			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1649		LIMS ID: EC57994-10			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1650		LIMS ID: EC57994-11			Matrix: Drinking Water		Collected: 12/04/24		
Lead	10.6		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1651		LIMS ID: EC57994-12			Matrix: Drinking Water		Collected: 12/04/24		
Lead	3.3		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1652		LIMS ID: EC57994-13			Matrix: Drinking Water		Collected: 12/04/24		
Lead	7.4		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57994
EMSL Order ID EC57994

Attention: J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Project Name: 23-53785, Fulton Avenue School #8
Received: December 4, 2024
Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1653		LIMS ID:	EC57994-14		Matrix: Drinking Water		Collected:	12/04/24	
Lead	1.5		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8



EMSL Analytical

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57994
EMSL Order ID EC57994

Attention: J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Project Name: 23-53785, Fulton Avenue School #8
Received: December 4, 2024
Reported: January 2, 2025

Notes and Definitions

Code	Description	Number	Expires
06-NYSDOH	New York Department of Public Health	11469	04/01/25
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/25
06-California ELAP	California Water Boards	2339	04/01/25
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/26

EC57995



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

North Oceanside Road School #5

NOR5

Client:

Oceanside Union Free School District

Retest/New Install ☐

Turn Around: Normal 1 wk Rush

Counter

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0292	HA	2020	Corridor Room 14 To 19 (Outside Room 11)	DW	12/4/2024	4:59:00 AM
OUFSD-0321	HA	1016	Corridor Room 4 To Room 9 (Outside Room 1)	DW	12/4/2024	4:56:00 AM
OUFSD-0331	HA	1016	Corridor Room 4 To Room 9 (Outside Nurse's Office)	WC	12/4/2024	4:54:00 AM
OUFSD-0332	HA	1016	Corridor Room 4 To Room 9 (Outside Nurse's Office)	WF	12/4/2024	4:54:00 AM
OUFSD-0350	GY	1029	Gymnasium	DW	12/4/2024	4:50:00 AM
OUFSD-0351	GY	1029	Gymnasium	DW	12/4/2024	4:51:00 AM
OUFSD-0352	KI	1029A	Gym Kitchen	KC	12/4/2024	4:50:00 AM
OUFSD-0356	CA	N/A	Cafeteria	WC	12/4/2024	4:48:00 AM
OUFSD-0357	CA	N/A	Cafeteria	WF	12/4/2024	4:49:00 AM
OUFSD-0358	KI	N/A	Kitchen	SA	12/4/2024	4:47:00 AM
OUFSD-0359	KI	N/A	Kitchen	KC	12/4/2024	4:47:00 AM
OUFSD-0360	KI	N/A	Kitchen	KC	12/4/2024	4:47:00 AM
OUFSD-0361	KI	N/A	Kitchen	KC	12/4/2024	4:48:00 AM
OUFSD-1340	HA	2020	Corridor Room 14 To 19 (Outside Room 14)	WF	12/4/2024	4:56:00 AM
OUFSD-1341	HA	2020	Corridor Room 14 To 19 (Outside Room 14)	WC	12/4/2024	4:57:00 AM
OUFSD-1342	HA	N/A	Corridor Room A13 To A15 (Outside Room A13)	WF	12/4/2024	4:49:00 AM
OUFSD-1343	HA	N/A	Corridor Room A13 To A15 (Outside Room A13)	WC	12/4/2024	4:50:00 AM

RECEIVED

Pb 200.8 J 12/7/24

EMSL ANALYTICAL, INC.
Carle Place, NY

DEC 04 2024 PM01:03

Building Address

2440 North Oceanside Road

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

A. Minnifield

Signature:

A. Minnifield

12-4-24 1:03pm

Samplers Name:


Anthony Lombardo

Samplers Signature:

[Signature]

JCB Project Manager:

LOMBARDO

Lead in Water: Chain of Custody for**Q EC57995**

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

North Oceanside Road School #5

NOR5

Client:

Oceanside Union Free School District

Retest/New Install ☐**Turn Around:** Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 17

12/17/24
12/17/24
12/17/24

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 04 2024 PM01:03

Building Address

2440 North Oceanside Road

Oceanside, NY 11572

Analysis Type: ELAP 200.5**Lab Received:**A. Minnick**Signature:**[Signature]

12/4/24 1:03pm

Samplers Name: Anthony Lombardo**Samplers Signature:**[Signature]**JCB Project Manager:** LOMBARDO



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.EMSL.com>

LIMS Order	EC57995
EMSL Order ID	EC57995

1/2/2025

J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/04/2024
The results are tabulated on the attached pages for the following client designated project:

23-53785, North Oceanside Road School #5

The reference number for these samples is EMSL Order #: EC57995. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact the lab at 516.997.7251.

James Han, Chemistry Laboratory Manager

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
Accreditation Name/#: AIHA-LAP, LLC-ELLAP # 102344 | NYELAP #11469

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57995
 EMSL Order ID EC57995

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, North Oceanside Road School #5
 Received: December 4, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-0292		LIMS ID: EC57995-01			Matrix: Drinking Water		Collected: 12/04/24		
Lead	1.1		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0321		LIMS ID: EC57995-02			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0331		LIMS ID: EC57995-03			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0332		LIMS ID: EC57995-04			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0350		LIMS ID: EC57995-05			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0351		LIMS ID: EC57995-06			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0352		LIMS ID: EC57995-07			Matrix: Drinking Water		Collected: 12/04/24		
Lead	1.9		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0356		LIMS ID: EC57995-08			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0357		LIMS ID: EC57995-09			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0358		LIMS ID: EC57995-10			Matrix: Drinking Water		Collected: 12/04/24		
Lead	3.5		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0359		LIMS ID: EC57995-11			Matrix: Drinking Water		Collected: 12/04/24		
Lead	3.4		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0360		LIMS ID: EC57995-12			Matrix: Drinking Water		Collected: 12/04/24		
Lead	2.2		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-0361		LIMS ID: EC57995-13			Matrix: Drinking Water		Collected: 12/04/24		
Lead	1.1		1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57995
 EMSL Order ID EC57995

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, North Oceanside Road School #5
 Received: December 4, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1340		LIMS ID:	EC57995-14		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1341		LIMS ID:	EC57995-15		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1342		LIMS ID:	EC57995-16		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1343		LIMS ID:	EC57995-17		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/7/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>


LIMS Order EC57995
EMSL Order ID EC57995

Attention: J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Project Name: 23-53785, North Oceanside Road School #5
Received: December 4, 2024
Reported: January 2, 2025

Notes and Definitions

Code	Description	Number	Expires
06-NYSDOH	New York Department of Public Health	11469	04/01/25
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/25
06-California ELAP	California Water Boards	2339	04/01/25
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/26

**Lead in Water: Chain of Custody for**

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F
WAL

Client:

Oceanside Union Free School District

Retest/New Install ☐**Turn Around:** Normal 1 wk Rush**EC57996**

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1069	HA	3021	3rd Floor Corridor A316 To A300 (Outside Room A315)	DW	12/4/2024	6:31:00 AM
OUFSD-1088	HA	3021	3rd Floor Corridor A316 To A300 (Outside Room A302)	WC	12/4/2024	6:32:00 AM
OUFSD-1089	HA	3021	3rd Floor Corridor A316 To A300 (Outside Room A302)	WF	12/4/2024	6:32:00 AM
OUFSD-1093	HA	2021	2nd Floor Corridor A216 To A200 (Outside Room A215)	DW	12/4/2024	6:29:00 AM
OUFSD-1114	HE	2013	Room A207	EC	12/4/2024	6:27:00 AM
OUFSD-1115	HE	2013	Room A207	EC	12/4/2024	6:27:00 AM
OUFSD-1116	HE	2013	Room A207	EC	12/4/2024	6:28:00 AM
OUFSD-1117	HE	2013	Room A207	EC	12/4/2024	6:28:00 AM
OUFSD-1124	HA	2021	2nd Floor Corridor A216 To A200 (Outside Room A202)	WC	12/4/2024	6:24:00 AM
OUFSD-1125	HA	2021	2nd Floor Corridor A216 To A200 (Outside Room A202)	WF	12/4/2024	6:24:00 AM
OUFSD-1126	HE	2019	Room A202	EC	12/4/2024	6:25:00 AM
OUFSD-1148	HA	1030	Corridor Room A113 To Room A100 (Outside Custodial Closet A122)	WC	12/4/2024	6:15:00 AM
OUFSD-1149	HA	1030	Corridor Room A113 To Room A100	WC	12/4/2024	6:15:00 AM
OUFSD-1154	HE	1022	Room A107	EC	12/4/2024	6:20:00 AM
OUFSD-1155	HE	1022	Room A107	EC	12/4/2024	6:20:00 AM
OUFSD-1156	HE	1022	Room A107	EC	12/4/2024	6:20:00 AM
OUFSD-1157	HE	1022	Room A107	EC	12/4/2024	6:21:00 AM
OUFSD-1166	NO	1038	9M Nurse's Office	NS	12/4/2024	6:42:00 AM

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
DEC 04 2024 PM 01:03

Building Address


186 Alice Avenue & 170 Beatrice Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5**Lab Received:** A. Minnifield

Signature: *A. Minnifield*
12/4/24 1:03pm

Samplers Name: *Conor Malanaphy***Samplers Signature:** *Conor Malanaphy***JCB Project Manager:** *Anthony Lombardo*

Courier



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F
WAL

Client:

Oceanside Union Free School District

Retest/New Install ☐Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1169	KI	1036B	Cafeteria A Kitchen	KC	12/4/2024	6:03:00 AM
OUFSD-1173	KI	1036B	Cafeteria A Kitchen	KC	12/4/2024	6:04:00 AM
OUFSD-1174	KI	1036B	Cafeteria A Kitchen	SN	12/4/2024	6:04:00 AM
OUFSD-1175	KI	1036B	Cafeteria A Kitchen	IM	12/4/2024	6:05:00 AM
OUFSD-1234	NO	5009	9E Nurse's Office	NS	12/4/2024	5:48:00 AM
OUFSD-1250	NO	5016	Room C115 Nurse's Office	NS	12/4/2024	6:45:00 AM
OUFSD-1263	CA	N/A	9E Cafeteria	WC	12/4/2024	5:52:00 AM
OUFSD-1265	KI	N/A	9E Kitchen	SA	12/4/2024	5:54:00 AM
OUFSD-1266	KI	N/A	9E Kitchen	KC	12/4/2024	5:54:00 AM
OUFSD-1267	KI	N/A	9E Kitchen	KC	12/4/2024	5:55:00 AM
OUFSD-1289	HA	6023	2nd Floor Corridor Room C215 To C223 (Outside Room C214)	WC	12/4/2024	5:57:00 AM
OUFSD-1290	HA	6023	2nd Floor Corridor Room C215 To C223 (Outside Room C214)	WF	12/4/2024	5:57:00 AM
OUFSD-1291	CA	1036	Cafeteria A	WF	12/4/2024	6:12:00 AM
OUFSD-1292	CA	1036	Cafeteria A	WC	12/4/2024	6:13:00 AM
OUFSD-1293	CA	1041	Cafeteria B	WF	12/4/2024	6:02:00 AM
OUFSD-1294	CA	1041	Cafeteria B	WC	12/4/2024	6:02:00 AM
OUFSD-1295	HA	1043	Corridor Outside Of Cafeterias	WF	12/4/2024	6:01:00 AM
OUFSD-1296	HA	1043	Corridor Outside Of Cafeterias	WC	12/4/2024	6:01:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 04 2024 11:03 AM

Building Address


186 Alice Avenue & 170 Beatrice Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5Lab Received: A. MinnifieldSignature: A. Minnifield
12/4/24 1:03pmSamplers Name: Conn MalanaphySamplers Signature: Conn MaryJCB Project Manager: Anthony Lombardo

pb 200.8 for 12/10/24

pb 200.8 for 12/7/24



Lead in Water: Chain of Custody for

EC57996

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Client:

Oceanside Union Free School District

Building:

Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F
WALRetest/New Install ☒Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1318	HA	5026	1st Floor Corridor Elevator to Lobby (Outside Occupational Therapy)	WF	12/4/2024	5:47:00 AM
OUFSD-1319	HA	5026	1st Floor Corridor Elevator to Lobby (Outside Occupational Therapy)	WC	12/4/2024	5:47:00 AM
OUFSD-1320	HA	5026	1st Floor Corridor Elevator to Lobby (Outside Room C127)	WF	12/4/2024	5:50:00 AM
OUFSD-1321	HA	5026	1st Floor Corridor Elevator to Lobby (Outside Room C127)	WC	12/4/2024	5:50:00 AM
OUFSD-1322	HA	6023	2nd Floor Corridor Room C215 To C223 (Outside Room C207)	WF	12/4/2024	5:58:00 AM
OUFSD-1323	HA	6023	2nd Floor Corridor Room C215 To C223 (Outside Room C207)	WC	12/4/2024	5:58:00 AM
OUFSD-1325	HA	1057	Corridor Gymnasium To Elementary School (Outside Phys Ed Office)	WF	12/4/2024	5:46:00 AM
OUFSD-1326	HA	N/A	2nd Floor Corridor (Outside Room B224)	WF	12/4/2024	6:37:00 AM
OUFSD-1327	HA	N/A	2nd Floor Corridor (Outside Room B224)	WC	12/4/2024	6:37:00 AM
OUFSD-1328	HA	N/A	1st Floor Corridor (Outside Room B124)	WF	12/4/2024	6:35:00 AM
OUFSD-1329	HA	N/A	1st Floor Corridor (Outside Room B124)	WC	12/4/2024	6:35:00 AM
OUFSD-1330	HA	1030	Corridor Room A113 To Room A100	WF	12/4/2024	6:19:00 AM
OUFSD-1331	HA	1030	Corridor Room A113 To Room A100	WC	12/4/2024	6:19:00 AM
OUFSD-1332	HA	1030	Corridor Room A113 To Room A100 (Outside Room A102)	WF	12/4/2024	6:23:00 AM
OUFSD-1333	HA	1030	Corridor Room A113 To Room A100 (Outside Room A102)	WC	12/4/2024	6:22:00 AM
OUFSD-1677	KI	1036B	Cafeteria A Kitchen	KC	12/4/2024	6:03:00 AM
OUFSD-1678	KI	1036B	Cafeteria A Kitchen	KC	12/4/2024	6:04:00 AM
OUFSD-1679	KI	1036B	Cafeteria A Kitchen	SN	12/4/2024	6:04:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 04 2024 PM 01:03

Building Address

186 Alice Avenue & 170 Beatrice Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5**Lab Received:****Signature:**


12/4/24 1:03pm

Samplers Name: Conor Malanaphy**Samplers Signature:** Conor Malanaphy**JCB Project Manager:** Anthony Lombardo

pb 200.8 & 12/10/24

pb 200.8 & 12/17/24

EC57996



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53785
Building: Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F
WAL

Client: Oceanside Union Free School District
Retest/New Install ☐
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1691	CA	N/A	9E Cafeteria	WF	12/4/2024	5:52:00 AM
OUFSD-1728	KI	1036B	Cafeteria A Kitchen	PK	12/4/2024	6:09:00 AM

Samples Submitted 56

Pb 200.88 12/10/24

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 04 2024 PM01:03

Pb 200.88 12/7/24

Building Address
186 Alice Avenue & 170 Beatrice Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5
Lab Received: A. Minnifield
Signature: A. Minnifield
12/4/24 1:03pm

Samplers Name: Conor Malanaphy
Samplers Signature: Conor Malanaphy
JCB Project Manager: Anthony Lombardo



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.EMSL.com>

LIMS Order	EC57996
EMSL Order ID	EC57996

1/2/2025

J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/04/2024
The results are tabulated on the attached pages for the following client designated project:

23-53785, Oceanside Middle School #9M & Walter S. Boardman Elementary School #9F

The reference number for these samples is EMSL Order #: EC57996. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact the lab at 516.997.7251.

James Han, Chemistry Laboratory Manager

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
Accreditation Name/#: AIHA-LAP, LLC-ELLAP # 102344 | NYELAP #11469

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57996
 EMSL Order ID EC57996

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

23-53785, Oceanside Middle School #9M & Walter S. Boardman
 Project Name: Elementary School #9F
 Received: December 4, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1069		LIMS ID: EC57996-01			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1088		LIMS ID: EC57996-02			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1089		LIMS ID: EC57996-03			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1093		LIMS ID: EC57996-04			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1114		LIMS ID: EC57996-05			Matrix: Drinking Water		Collected: 12/04/24		
Lead	9.5		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1115		LIMS ID: EC57996-06			Matrix: Drinking Water		Collected: 12/04/24		
Lead	6.3		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1116		LIMS ID: EC57996-07			Matrix: Drinking Water		Collected: 12/04/24		
Lead	14.9		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1117		LIMS ID: EC57996-08			Matrix: Drinking Water		Collected: 12/04/24		
Lead	7.3		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1124		LIMS ID: EC57996-09			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1125		LIMS ID: EC57996-10			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1126		LIMS ID: EC57996-11			Matrix: Drinking Water		Collected: 12/04/24		
Lead	18.4	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1148		LIMS ID: EC57996-12			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1149		LIMS ID: EC57996-13			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57996
 EMSL Order ID EC57996

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside Middle School #9M & Walter S. Boardman
 Received: Elementary School #9F
 Reported: December 4, 2024
 January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1154		LIMS ID:	EC57996-14		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	1.7		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1155		LIMS ID:	EC57996-15		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	8.1		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1156		LIMS ID:	EC57996-16		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	18.9	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1157		LIMS ID:	EC57996-17		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	490	E	10	10.0	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1166		LIMS ID:	EC57996-18		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	6.9		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1169		LIMS ID:	EC57996-19		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	3.0		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1173		LIMS ID:	EC57996-20		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	1.6		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1174		LIMS ID:	EC57996-21		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	2.7		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1175		LIMS ID:	EC57996-22		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1234		LIMS ID:	EC57996-23		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	6.2		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1250		LIMS ID:	EC57996-24		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	2.7		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1263		LIMS ID:	EC57996-25		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1265		LIMS ID:	EC57996-26		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	1.5		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57996
 EMSL Order ID EC57996

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

23-53785, Oceanside Middle School #9M & Walter S. Boardman
 Project Name: Elementary School #9F
 Received: December 4, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1266		LIMS ID:	EC57996-27		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	4.6		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1267		LIMS ID:	EC57996-28		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	1.8		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1289		LIMS ID:	EC57996-29		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	1.6		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1290		LIMS ID:	EC57996-30		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1291		LIMS ID:	EC57996-31		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1292		LIMS ID:	EC57996-32		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1293		LIMS ID:	EC57996-33		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1294		LIMS ID:	EC57996-34		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1295		LIMS ID:	EC57996-35		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1296		LIMS ID:	EC57996-36		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1318		LIMS ID:	EC57996-37		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1319		LIMS ID:	EC57996-38		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1320		LIMS ID:	EC57996-39		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57996
 EMSL Order ID EC57996

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

23-53785, Oceanside Middle School #9M & Walter S. Boardman
 Project Name: Elementary School #9F
 Received: December 4, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1321		LIMS ID:	EC57996-40		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1322		LIMS ID:	EC57996-41		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1323		LIMS ID:	EC57996-42		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1325		LIMS ID:	EC57996-43		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1326		LIMS ID:	EC57996-44		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1327		LIMS ID:	EC57996-45		Matrix:	Drinking Water	Collected:	12/04/24	
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57996
 EMSL Order ID EC57996

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

23-53785, Oceanside Middle School #9M & Walter S. Boardman
 Project Name: Elementary School #9F
 Received: December 4, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1328		LIMS ID: EC57996-46			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1329		LIMS ID: EC57996-47			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1330		LIMS ID: EC57996-48			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1331		LIMS ID: EC57996-49			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1332		LIMS ID: EC57996-50			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1333		LIMS ID: EC57996-51			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1677		LIMS ID: EC57996-52			Matrix: Drinking Water		Collected: 12/04/24		
Lead	1.7		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1678		LIMS ID: EC57996-53			Matrix: Drinking Water		Collected: 12/04/24		
Lead	1.9		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1679		LIMS ID: EC57996-54			Matrix: Drinking Water		Collected: 12/04/24		
Lead	3.3		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1691		LIMS ID: EC57996-55			Matrix: Drinking Water		Collected: 12/04/24		
Lead	<1.0	E	1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8
Sample ID: OUFSD-1728		LIMS ID: EC57996-56			Matrix: Drinking Water		Collected: 12/04/24		
Lead	2.9		1	1.00	µg/L	12/4/2024	12/7/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC57996
EMSL Order ID EC57996

Attention: J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Project Name: 23-53785, Oceanside Middle School #9M & Walter S.
Received: December 4, 2024
Reported: January 2, 2025

Notes and Definitions

Code	Description	Number	Expires
06-NYSDOH	New York Department of Public Health	11469	04/01/25
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/25
06-California ELAP	California Water Boards	2339	04/01/25
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/26



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Oceanside High School #7

OHS7

Client:

Oceanside Union Free School District

Retest/New Install | |

Turn Around: Normal 1 wk Rush

Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0613	NO	1100	Room S141 Nurse's Office	NS	12/5/2024	5:58:00 AM
OUFSD-0620	KI	2006A	Room S235E Faculty Kitchen	DW	12/5/2024	5:45:00 AM
OUFSD-0631	HA	2031	Corridor Room S210 to Room S219 (Outside Room S226)	WC	12/5/2024	5:47:00 AM
OUFSD-0635	OF	2067A	Room N219 Back Room	BWC	12/5/2024	6:08:00 AM
OUFSD-0638	HA	2031	Corridor Room S210 to Room S219 (Outside Room S223)	WC	12/5/2024	5:48:00 AM
OUFSD-0639	HA	2031	Corridor Room S210 to Room S219 (Outside Room S223)	WF	12/5/2024	5:48:00 AM
OUFSD-0648	HE	2021	Room S218	EC	12/5/2024	5:52:00 AM
OUFSD-0649	HE	2021	Room S218	EC	12/5/2024	5:52:00 AM
OUFSD-0650	HE	2021	Room S218	EC	12/5/2024	5:53:00 AM
OUFSD-0651	HE	2021	Room S218	EC	12/5/2024	5:53:00 AM
OUFSD-0652	HE	2021	Room S218	EC	12/5/2024	5:53:00 AM
OUFSD-0653	HA	2031	Corridor Room S210 to Room S219 (Outside Room S217)	DW	12/5/2024	5:50:00 AM
OUFSD-0669	HA	2044	Corridor Room S231 To S202 (Outside Room S201)	DW	12/5/2024	5:42:00 AM
OUFSD-0673	HA	2070	Corridor Room N214 To Library (Outside Library)	DW	12/5/2024	5:39:00 AM
OUFSD-0674	HA	2070	Corridor Room N214 To Library (Outside Library)	WC	12/5/2024	5:38:00 AM
OUFSD-0818	OF	1017	Room S100 Vestibule	DW	12/5/2024	6:02:00 AM
OUFSD-0831	FL	1029A	Room S153 Meeting Room Kitchen	KC	12/5/2024	6:00:00 AM
OUFSD-0897	HE	1097	Room S139	EC	12/5/2024	5:28:00 AM

RECEIVED
EMBL ANALYTICAL, INC.
Carle Place, NY
DEC 05 2024 12:46

Building Address

3160 Skillman Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Conor MalanaphySamplers Signature: Conor MalanaphyJCB Project Manager: Anthony Lombardo

12-5-24 12:46 PM
Conor Malanaphy

Lead in Water: Chain of Custody for

FC 58013

Client:

Oceanside Union Free School District

J. C. BRODERICK AND ASSOCIATES, INC.

JCB #:

23-53785

1775 Expressway North Hauppauge, NY 11788

Building: Oceanside High School #7

TEL: (631) 584-5492 FAX: (631) 584-3395

Retest/New Install ☐

Turn Around: Normal 1 wk Rush

OHS7

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0900	CA	1110	Cafeteria	WC	12/5/2024	4:59:00 AM
OUFSD-0901	CA	1110	Cafeteria	WF	12/5/2024	4:59:00 AM
OUFSD-0902	KI	1110B	Cafeteria Serving Area	SA	12/5/2024	4:54:00 AM
OUFSD-0903	KI	1116	Kitchen	KC	12/5/2024	4:51:00 AM
OUFSD-0904	KI	1116	Kitchen	KC	12/5/2024	4:52:00 AM
OUFSD-0905	KI	1116	Kitchen	KC	12/5/2024	4:52:00 AM
OUFSD-0906	KI	1116	Kitchen	KC	12/5/2024	4:53:00 AM
OUFSD-0907	KI	1116	Kitchen	KC	12/5/2024	4:55:00 AM
OUFSD-0908	KI	1116	Kitchen	KC	12/5/2024	4:55:00 AM
OUFSD-0915	CA	1114	Faculty Dining Room	DW	12/5/2024	4:58:00 AM
OUFSD-1301	LR	1049	Football Locker Room	DW	12/5/2024	5:18:00 AM
OUFSD-1306	CA	1110	Cafeteria	WF	12/5/2024	5:05:00 AM
OUFSD-1307	CA	1110	Cafeteria	WC	12/5/2024	5:05:00 AM
OUFSD-1308	HA	1152	Corridor Room N126 to Room N138 (Outside Resource Center)	WF	12/5/2024	5:33:00 AM
OUFSD-1309	HA	1152	Corridor Room N126 to Room N138 (Outside Resource Center)	WC	12/5/2024	5:34:00 AM
OUFSD-1310	HA	1039	Corridor Guidance Suite to Auditorium Lobby (Outside Room S153)	WF	12/5/2024	5:07:00 AM
OUFSD-1311	HA	1039	Corridor Guidance Suite to Auditorium Lobby (Outside Room S153)	WC	12/5/2024	5:06:00 AM
OUFSD-1312	HA	1014	Auditorium Lobby	WF	12/5/2024	5:10:00 AM

RECEIVED

ENCL ANAL UTICAL INC.

Building Address

3160 Skillman Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name:

Samplers Signature:

JCB Project Manager:

Carle Place, NY

DEC 05 2024 PM 12:46

Conc. Malanaphy

Conn. Malanaphy

Anthony Lombardo

12-5-24 12:46 PM



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Oceanside High School #7

OHS7

Client:

Oceanside Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush

EC 58013

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1313	HA	1014	Auditorium Lobby	WC	12/5/2024	5:10:00 AM
OUFSD-1316	HA	1039	Corridor Guidance Suite to Auditorium Lobby (Outside Guidance Office)	WF	12/5/2024	5:08:00 AM
OUFSD-1317	HA	1039	Corridor Guidance Suite to Auditorium Lobby (Outside Guidance Office)	WC	12/5/2024	5:08:00 AM
OUFSD-1324	HA	1104	Corridor Boiler Room To S114 (Outside Room S119)	WF	12/5/2024	5:15:00 AM
OUFSD-1468	OF	1106	Room 100A Main Office	WC	12/5/2024	5:31:00 AM
OUFSD-1475	HA	1043	Corridor From Girl's Locker Room To Auxiliary Gym	WC	12/5/2024	5:21:00 AM
OUFSD-1476	HA	1043	Corridor From Girl's Locker Room To Auxiliary Gym	WF	12/5/2024	5:21:00 AM
OUFSD-1477	LR	1049	Football Locker Room	IM	12/5/2024	5:18:00 AM
OUFSD-1482	HA	1060	Corridor Room S131 to Women's Faculty Bathroom (Outside Room S130)	WC	12/5/2024	5:16:00 AM
OUFSD-1483	HA	1060	Corridor Room S131 to Women's Faculty Bathroom (Outside Room S130)	WF	12/5/2024	5:16:00 AM
OUFSD-1495	KI	1116F	Kitchen Laundry Room	IM	12/5/2024	5:00:00 AM
OUFSD-1500	HA	1152	Corridor Room N126 to Room N138 (Outside Room N124)	WF	12/5/2024	5:36:00 AM
OUFSD-1501	HA	1152	Corridor Room N126 to Room N138 (Outside Room N124)	WC	12/5/2024	5:36:00 AM
OUFSD-1502	HA	1104	Corridor Boiler Room To S114 (Outside Room S140)	WC	12/5/2024	5:30:00 AM
OUFSD-1503	HA	1104	Corridor Boiler Room To S114 (Outside Room S140)	WF	12/5/2024	5:29:00 AM
OUFSD-1504	FL	2006A	Room S235E Faculty Kitchen	WF	12/5/2024	5:44:00 AM
OUFSD-1510	OF	2011	Room S236 Dean's Office	BWC	12/5/2024	5:44:00 AM
OUFSD-1557	SC	2022	Room S217	KC	12/5/2024	5:54:00 AM

RECEIVED
 EMS ANALYTICAL, INC.
 Carle Place, NY
 DEC 05 2024 PM 12:46

Building Address

3160 Skillman Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Conor MalanaphySamplers Signature: Conor MalanaphyJCB Project Manager: Anthony Lombardo

12-5-24 12:46 PM
 [Signature]

Ph 200-8 844-12924
 Ph 200-8 844-12/11/24

Lead in Water: Chain of Custody for

EC 58013



J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53785
Building: Oceanside High School #7
OHS7

Client: Oceanside Union Free School District
Retest/New Install ☐
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1630	HA	2070	Corridor Room N214 To Library (Outside Room N214)	WC	12/5/2024	5:39:00 AM
OUFSD-1631	HA	2070	Corridor Room N214 To Library (Outside Room N214)	WF	12/5/2024	5:39:00 AM
OUFSD-1659	HA	1104	Corridor Boiler Room To S114 (Outside Room S127B)	WF	12/5/2024	5:14:00 AM
OUFSD-1660	HA	1104	Corridor Boiler Room To S114 (Outside Room S127B)	WC	12/5/2024	5:15:00 AM
OUFSD-1661	HA	2044	Corridor Room S231 To S202 (Outside Room S235A)	WF	12/5/2024	5:43:00 AM
OUFSD-1662	HA	2044	Corridor Room S231 To S202 (Outside Room S235A)	WC	12/5/2024	5:42:00 AM
OUFSD-1718	HA	1075	Corridor Room S122 to Room S125 (Outside Art Room S122)	WF	12/5/2024	5:12:00 AM
OUFSD-1719	HA	1075	Corridor Room S122 to Room S125 (Outside Art Room S122)	WC	12/5/2024	5:13:00 AM
OUFSD-1729	KI	1116	Kitchen	PK	12/5/2024	4:56:00 AM
OUFSD-1730	KI	1116B	Kitchen Storage	KC	12/5/2024	5:01:00 AM
OUFSD-1731	KI	1116B	Kitchen Storage	SN	12/5/2024	5:02:00 AM
OUFSD-1732	CR	2067A	Room N219 Back Room	BWH	12/5/2024	6:08:00 AM

Samples Submitted 66

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 05 2024 PM12:47

Building Address

3160 Skillman Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received: 12-5-24 12:41 PM

Signature: [Signature]

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo

Pb200.584 ~ 12/9/24
Pb200.584 ~ 12/11/24



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.EMSL.com>

LIMS Order	EC58013
EMSL Order ID	EC58013

1/2/2025

J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/05/2024
The results are tabulated on the attached pages for the following client designated project:

23-53785, Oceanside High School #7

The reference number for these samples is EMSL Order #: EC58013. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact the lab at 516.997.7251.

James Han, Chemistry Laboratory Manager

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
Accreditation Name/#: AIHA-LAP, LLC-ELLAP # 102344 | NYELAP #11469

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58013
 EMSL Order ID EC58013

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside High School #7
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-0613		LIMS ID: EC58013-01			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0620		LIMS ID: EC58013-02			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0631		LIMS ID: EC58013-03			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0635		LIMS ID: EC58013-04			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0638		LIMS ID: EC58013-05			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0639		LIMS ID: EC58013-06			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0648		LIMS ID: EC58013-07			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0649		LIMS ID: EC58013-08			Matrix: Drinking Water		Collected: 12/05/24		
Lead	3.0		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0650		LIMS ID: EC58013-09			Matrix: Drinking Water		Collected: 12/05/24		
Lead	1.8		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0651		LIMS ID: EC58013-10			Matrix: Drinking Water		Collected: 12/05/24		
Lead	2.0		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0652		LIMS ID: EC58013-11			Matrix: Drinking Water		Collected: 12/05/24		
Lead	6.3		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0653		LIMS ID: EC58013-12			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0669		LIMS ID: EC58013-13			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58013
 EMSL Order ID EC58013

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside High School #7
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-0673		LIMS ID:	EC58013-14		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0674		LIMS ID:	EC58013-15		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0818		LIMS ID:	EC58013-16		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0831		LIMS ID:	EC58013-17		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	7.3		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0897		LIMS ID:	EC58013-18		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0900		LIMS ID:	EC58013-19		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0901		LIMS ID:	EC58013-20		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0902		LIMS ID:	EC58013-21		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	7.9		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0903		LIMS ID:	EC58013-22		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	3.5		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0904		LIMS ID:	EC58013-23		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	1.2		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0905		LIMS ID:	EC58013-24		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	2.5		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0906		LIMS ID:	EC58013-25		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	3.5		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0907		LIMS ID:	EC58013-26		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	4.1		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58013
EMSL Order ID EC58013

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside High School #7
Received: December 5, 2024
Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-0908		LIMS ID: EC58013-27		Matrix: Drinking Water		Collected: 12/05/24			
Lead	21.2	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-0915		LIMS ID: EC58013-28		Matrix: Drinking Water		Collected: 12/05/24			
Lead	3.8		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1301		LIMS ID: EC58013-29		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1306		LIMS ID: EC58013-30		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1307		LIMS ID: EC58013-31		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1308		LIMS ID: EC58013-32		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1309		LIMS ID: EC58013-33		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1310		LIMS ID: EC58013-34		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1311		LIMS ID: EC58013-35		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1312		LIMS ID: EC58013-36		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1313		LIMS ID: EC58013-37		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1316		LIMS ID: EC58013-38		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1317		LIMS ID: EC58013-39		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58013
 EMSL Order ID EC58013

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside High School #7
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1324		LIMS ID:	EC58013-40		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1468		LIMS ID:	EC58013-41		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1475		LIMS ID:	EC58013-42		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1476		LIMS ID:	EC58013-43		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1477		LIMS ID:	EC58013-44		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1482		LIMS ID:	EC58013-45		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58013
EMSL Order ID EC58013

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside High School #7
Received: December 5, 2024
Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1483		LIMS ID: EC58013-46		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1495		LIMS ID: EC58013-47		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1500		LIMS ID: EC58013-48		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1501		LIMS ID: EC58013-49		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1502		LIMS ID: EC58013-50		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1503		LIMS ID: EC58013-51		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1504		LIMS ID: EC58013-52		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1510		LIMS ID: EC58013-53		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1557		LIMS ID: EC58013-54		Matrix: Drinking Water		Collected: 12/05/24			
Lead	1.1		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1630		LIMS ID: EC58013-55		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1631		LIMS ID: EC58013-56		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1659		LIMS ID: EC58013-57		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1660		LIMS ID: EC58013-58		Matrix: Drinking Water		Collected: 12/05/24			
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58013
 EMSL Order ID EC58013

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside High School #7
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1661		LIMS ID:	EC58013-59		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1662		LIMS ID:	EC58013-60		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1718		LIMS ID:	EC58013-61		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1719		LIMS ID:	EC58013-62		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1729		LIMS ID:	EC58013-63		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	1.1		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1730		LIMS ID:	EC58013-64		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	1.9		1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1731		LIMS ID:	EC58013-65		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8
Sample ID: OUFSD-1732		LIMS ID:	EC58013-66		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/9/2024	12/9/2024	SEH	EPA 200.8



EMSL Analytical

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax:856-786-5974
<http://www.emsl.com>


LIMS Order EC58013
EMSL Order ID EC58013

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside High School #7
Received: December 5, 2024
Reported: January 2, 2025

Notes and Definitions

Code	Description	Number	Expires
06-NYSDOH	New York Department of Public Health	11469	04/01/25
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/25
06-California ELAP	California Water Boards	2339	04/01/25
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/26



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

Oceanside School #6 & Administration

OS6

Client:

Oceanside Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush _____

Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0381	HA	3023	Corridor Room 319 To 327 (Outside Room 313)	DW	12/5/2024	7:10:00 AM
OUFSD-0386	FL	3015	Room 323	DW	12/5/2024	7:12:00 AM
OUFSD-0391	HA	3023	Corridor Room 319 To 327 (Outside Room 319)	DW	12/5/2024	7:14:00 AM
OUFSD-0468	HA	6011	District Office - 1st Floor Corridor	DW	12/5/2024	6:24:00 AM
OUFSD-0527	NO	1058	Nurse's Office	DW	12/5/2024	6:52:00 AM
OUFSD-0568	OF	0037B	B&G Office Break Room	BWC	12/5/2024	7:31:00 AM
OUFSD-0581	ST	1010E	South Gymnasium Old Locker Room	DW	12/5/2024	6:30:00 AM
OUFSD-0586	CA	1014	Cafeteria	DW	12/5/2024	6:32:00 AM
OUFSD-0587	CA	1014	Cafeteria	WC	12/5/2024	6:32:00 AM
OUFSD-1297	HA	1071	Corridor Room 118 To Room 124 (Outside Main Office)	WF	12/5/2024	6:51:00 AM
OUFSD-1298	HA	1071	Corridor Room 118 To Room 124 (Outside Main Office)	WC	12/5/2024	6:52:00 AM
OUFSD-1303	HA	3023	Corridor Room 319 To 327 (Outside Room 316)	WF	12/5/2024	7:12:00 AM
OUFSD-1344	FL	0015	B&G Storage 2	BWC	12/5/2024	7:21:00 AM
OUFSD-1345	FL	0015	B&G Storage 2	BWH	12/5/2024	7:21:00 AM
OUFSD-1360	HA	1076	North Gym/Indoor Playground Vestibule	WF	12/5/2024	6:54:00 AM
OUFSD-1361	HA	1076	North Gym/Indoor Playground Vestibule	WC	12/5/2024	6:55:00 AM
OUFSD-1362	HA	2024	Corridor Room 224 To Room 218A (Outside Room 221)	WF	12/5/2024	6:59:00 AM
OUFSD-1363	HA	2024	Corridor Room 224 To Room 218A (Outside Room 221)	WC	12/5/2024	7:00:00 AM

RECEIVED
FMS ANALYTICAL, INC.
Carle Place, NY
DEC 05 2024 PM12:47

Building Address

146 Merle Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5


Lab Received:

Signature:

Samplers Name: Conor MalanaphySamplers Signature: Conor MalanaphyJCB Project Manager: Anthony Lombardo

Pb200 & SHA - 12/11/24

12-5-24 12:41 PM
[Signature]



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Oceanside School #6 & Administration

OS6

Client:

Oceanside Union Free School District

Retest/New Install ☐

Turn Around: Normal 1 wk Rush _____

Page 2 of 3

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1446	FL	0037B	B&G Office Break Room	BWH	12/5/2024	7:31:00 AM
OUFSD-1448	OF	1019	Special Education Office Check-in Area	BWC	12/5/2024	6:35:00 AM
OUFSD-1449	OF	1019	Special Education Office Check-in Area	BWH	12/5/2024	6:36:00 AM
OUFSD-1457	HA	2054	Corridor Room W23 To W26 (Outside W23)	WC	12/5/2024	6:38:00 AM
OUFSD-1458	HA	2054	Corridor Room W23 To W26 (Outside W23)	WF	12/5/2024	6:38:00 AM
OUFSD-1463	HA	3023	Corridor Room 319 To 327 (Outside Room 316)	WC	12/5/2024	7:12:00 AM
OUFSD-1464	BR	7016	Women's Bathroom Vestibule	BWC	12/5/2024	6:21:00 AM
OUFSD-1465	BR	7016	Women's Bathroom Vestibule	BWH	12/5/2024	6:23:00 AM
OUFSD-1466	CR	6005	Office 106	BWC	12/5/2024	6:23:00 AM
OUFSD-1700	HA	1027	Corridor Gymnasium To Boys Bathroom (Outside Gymnasium)	WC	12/5/2024	6:28:00 AM
OUFSD-1701	HA	1027	Corridor Gymnasium To Boys Bathroom (Outside Gymnasium)	WF	12/5/2024	6:28:00 AM
OUFSD-1702	HA	1027	Corridor Gymnasium To Boys Bathroom (Outside Cafeteria)	WC	12/5/2024	6:32:00 AM
OUFSD-1703	HA	1027	Corridor Gymnasium To Boys Bathroom (Outside Cafeteria)	WF	12/5/2024	6:32:00 AM
OUFSD-1704	HA	1039	Corridor Room 101 to Room 105 (Outside Room 104)	WC	12/5/2024	6:41:00 AM
OUFSD-1705	HA	1039	Corridor Room 101 to Room 105 (Outside Room 104)	WF	12/5/2024	6:41:00 AM
OUFSD-1706	HA	1050	Corridor Room 109 to Room 112 (Outside Room 113)	WC	12/5/2024	6:47:00 AM
OUFSD-1707	HA	1050	Corridor Room 109 to Room 112 (Outside Room 113)	WF	12/5/2024	6:48:00 AM
OUFSD-1708	HA	1071	Corridor Room 118 To Room 124 (Outside Room 123)	WC	12/5/2024	6:49:00 AM

revised EC58017

Building Address

146 Merle Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received: _____


Signature: _____

Samplers Name: Conor Malanaphy

Samplers Signature:

JCB Project Manager: Anthony Lombardo

12/11/21
Pb 200.8-0009



Lead in Water: Chain of Custody for

EC58017

Client:

J. C. BRODERICK AND ASSOCIATES, INC.

23-53785

Oceanside Union Free School District

1775 Expressway North Hauppauge, NY 11788

JCB #:

Building: Oceanside School #6 & Administration

Retest/New Install ☐

TEL: (631) 584-5492 FAX: (631) 584-3395

OS6

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1709	HA	1071	Corridor Room 118 To Room 124 (Outside Room 123)	WF	12/5/2024	6:49:00 AM
OUFSD-1720	HA	2024	Corridor Room 224 To Room 218A (Outside Room 223)	WF	12/5/2024	7:00:00 AM
OUFSD-1721	HA	2024	Corridor Room 224 To Room 218A (Outside Room 223)	WC	12/5/2024	7:01:00 AM
OUFSD-1722	HA	2024	Corridor Room 224 To Room 218A (Outside Room 218)	WF	12/5/2024	6:56:00 AM
OUFSD-1723	HA	2024	Corridor Room 224 To Room 218A (Outside Room 218)	WC	12/5/2024	6:57:00 AM
OUFSD-1724	HA	2037	Corridor Room 205 To Room 201 (Outside Room 204)	WF	12/5/2024	7:02:00 AM
OUFSD-1725	HA	2037	Corridor Room 205 To Room 201 (Outside Room 204)	WC	12/5/2024	7:03:00 AM
OUFSD-1726	HA	1020	Corridor Outside Teacher's Center (Outside DOCA Office)	WF	12/5/2024	6:33:00 AM

Samples Submitted 44

RECEIVED
 EMSL ANALYTICAL, INC.
 Carle Place, NY
 DEC 05 2024 PM12:47

Building Address

146 Merle Avenue
 Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Genor MalanaphySamplers Signature: Genor MalanaphyJCB Project Manager: Anthony Lombardo

Pb 200.8 SLL 12/11/24



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.EMSL.com>

LIMS Order	EC58017
EMSL Order ID	EC58017

1/2/2025

J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/05/2024
The results are tabulated on the attached pages for the following client designated project:

23-53785, Oceanside School #6 & Administration

The reference number for these samples is EMSL Order #: EC58017. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact the lab at 516.997.7251.

James Han, Chemistry Laboratory Manager

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
Accreditation Name/#: AIHA-LAP, LLC-ELLAP # 102344 | NYELAP #11469

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58017
 EMSL Order ID EC58017

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside School #6 & Administration
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-0381		LIMS ID: EC58017-01			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0386		LIMS ID: EC58017-02			Matrix: Drinking Water		Collected: 12/05/24		
Lead	3.8		1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0391		LIMS ID: EC58017-03			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0468		LIMS ID: EC58017-04			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0527		LIMS ID: EC58017-05			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0568		LIMS ID: EC58017-06			Matrix: Drinking Water		Collected: 12/05/24		
Lead	1.1		1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0581		LIMS ID: EC58017-07			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0586		LIMS ID: EC58017-08			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-0587		LIMS ID: EC58017-09			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1297		LIMS ID: EC58017-10			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1298		LIMS ID: EC58017-11			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1303		LIMS ID: EC58017-12			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1344		LIMS ID: EC58017-13			Matrix: Drinking Water		Collected: 12/05/24		
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58017
 EMSL Order ID EC58017

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside School #6 & Administration
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1345		LIMS ID:	EC58017-14		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1360		LIMS ID:	EC58017-15		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1361		LIMS ID:	EC58017-16		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1362		LIMS ID:	EC58017-17		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1363		LIMS ID:	EC58017-18		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1446		LIMS ID:	EC58017-19		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	1.4		1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1448		LIMS ID:	EC58017-20		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1449		LIMS ID:	EC58017-21		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1457		LIMS ID:	EC58017-22		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1458		LIMS ID:	EC58017-23		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1463		LIMS ID:	EC58017-24		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1464		LIMS ID:	EC58017-25		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1465		LIMS ID:	EC58017-26		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58017
 EMSL Order ID EC58017

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside School #6 & Administration
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1466		LIMS ID:	EC58017-27		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1700		LIMS ID:	EC58017-28		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1701		LIMS ID:	EC58017-29		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1702		LIMS ID:	EC58017-30		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1703		LIMS ID:	EC58017-31		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1704		LIMS ID:	EC58017-32		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1705		LIMS ID:	EC58017-33		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1706		LIMS ID:	EC58017-34		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1707		LIMS ID:	EC58017-35		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1708		LIMS ID:	EC58017-36		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1709		LIMS ID:	EC58017-37		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1720		LIMS ID:	EC58017-38		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1721		LIMS ID:	EC58017-39		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58017
 EMSL Order ID EC58017

Attention: J.C. Broderick and Associates
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788

Project Name: 23-53785, Oceanside School #6 & Administration
 Received: December 5, 2024
 Reported: January 2, 2025

Analytical Results

Analyte	Result	Q	DF	RL	Units	Preparation Date	Analysis Date	Analyst	Prep/Analytical Method
Sample ID: OUFSD-1722		LIMS ID:	EC58017-40		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1723		LIMS ID:	EC58017-41		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1724		LIMS ID:	EC58017-42		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1725		LIMS ID:	EC58017-43		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8
Sample ID: OUFSD-1726		LIMS ID:	EC58017-44		Matrix:	Drinking Water	Collected:	12/05/24	
Lead	<1.0	E	1	1.00	µg/L	12/11/2024	12/11/2024	SEH	EPA 200.8

**EMSL Analytical**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
<http://www.emsl.com>

LIMS Order EC58017
EMSL Order ID EC58017


Attention: J.C. Broderick and Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Project Name: 23-53785, Oceanside School #6 & Administration
Received: December 5, 2024
Reported: January 2, 2025

Notes and Definitions

Code	Description	Number	Expires
06-NYSDOH	New York Department of Public Health	11469	04/01/25
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/25
06-California ELAP	California Water Boards	2339	04/01/25
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/26

ED 50088



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53785
Building: Oaks School #3
OS3

Client: Oceanside Union Free School District


Retest/New Install []
Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0186	KI	1036A	Kitchen	KC	1/7/2025	6:28:00 AM
OUFSD-0187	KI	1036A	Kitchen	KC	1/7/2025	6:29:00 AM
OUFSD-0189	KI	1036A	Kitchen	SN	1/7/2025	6:29:00 AM
OUFSD-0190	KI	1036A	Kitchen	KC	1/7/2025	6:29:00 AM

Samples Submitted 4

Photo 8 Staff 1/8/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 07 2025 PM02:14



Building Address
2852 Fortesque Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5
Lab Received: [Signature]
Signature: [Signature]

Samplers Name: Anthony Lombardo
Samplers Signature: [Signature]
JCB Project Manager: LOMBARDO

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550088**LIMS Reference ID:** ED50088**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

JCB#: 23-53785, Oaks School #3, Oceanside
Union Free School District, 2852 Fortesque
Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/07/2025 14:14

Reported:

01/09/2025 13:30

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OUFSD-0186 Lims Reference ID: ED50088-01 Matrix: Drinking Water Sampled: 01/07/25 00:00:00									
Metals									
Lead	21.1		1	1.0	µg/L	01/08/25 11:59	01/08/25 11:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0187 Lims Reference ID: ED50088-02 Matrix: Drinking Water Sampled: 01/07/25 00:00:00									
Metals									
Lead	2.6		1	1.0	µg/L	01/08/25 12:03	01/08/25 12:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0189 Lims Reference ID: ED50088-03 Matrix: Drinking Water Sampled: 01/07/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/08/25 12:05	01/08/25 12:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-0190 Lims Reference ID: ED50088-04 Matrix: Drinking Water Sampled: 01/07/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/08/25 12:06	01/08/25 12:06	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550088**LIMS Reference ID:** ED50088**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

JCB#: 23-53785, Oaks School #3, Oceanside
Union Free School District, 2852 Fortesque
Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/07/2025 14:14

Reported:

01/09/2025 13:30

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550088**LIMS Reference ID:** ED50088**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

JCB#: 23-53785, Oaks School #3, Oceanside
Union Free School District, 2852 Fortesque
Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/07/2025 14:14

Reported:

01/09/2025 13:30


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Fulton Avenue School #8

FUL

Client:

Oceanside Union Free School District

Retest/New Install ☐

Turn Around: Normal 1 wk Rush 2 day

Walk In

ED50102

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1010	KI	1027A	Kitchen	SA	1/8/2025	6:29:00 AM
OUFSD-1018	NO	1018	Nurse's Office	NS	1/8/2025	6:36:00 AM
OUFSD-1650	KI	1027A	Kitchen	KC	1/8/2025	6:30:00 AM
OUFSD-1652	KI	1027A	Kitchen	KC	1/8/2025	6:31:00 AM

Samples Submitted 4

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 08 2025 AM11:49

Building Address

3252 Fulton Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

Signature:

1-8-25 11:49 AM
[Signature]

Samplers Name: Anthony Lombardo

Samplers Signature:

JCB Project Manager:

[Signature]
Lombardo

1084-1/9/25

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550102**LIMS Reference ID:** ED50102**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

Oceanside Union Free School District,
#23-53785, Fulton Avenue School #8, 3252
Fulton Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/08/2025 11:49

Reported:

01/09/2025 14:09

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OUFSD-1010 Lims Reference ID: ED50102-01 Matrix: Drinking Water Sampled: 01/08/25 00:00:00									
Metals									
Lead	28.3		1	1.0	µg/L	01/09/25 10:11	01/09/25 10:11	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: OUFSD-1018 Lims Reference ID: ED50102-02 Matrix: Drinking Water Sampled: 01/08/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/09/25 10:15	01/09/25 10:15	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: OUFSD-1650 Lims Reference ID: ED50102-03 Matrix: Drinking Water Sampled: 01/08/25 00:00:00									
Metals									
Lead	4.5		1	1.0	µg/L	01/09/25 10:16	01/09/25 10:16	SEH	EPA 200.8 (Dig)/EPA 200.8
Sample: OUFSD-1652 Lims Reference ID: ED50102-04 Matrix: Drinking Water Sampled: 01/08/25 00:00:00									
Metals									
Lead	1.1		1	1.0	µg/L	01/09/25 10:18	01/09/25 10:18	SEH	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550102**LIMS Reference ID:** ED50102**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

Oceanside Union Free School District,
#23-53785, Fulton Avenue School #8, 3252
Fulton Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/08/2025 11:49

Reported:

01/09/2025 14:09

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550102**LIMS Reference ID:** ED50102**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

Oceanside Union Free School District,
#23-53785, Fulton Avenue School #8, 3252
Fulton Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/08/2025 11:49

Reported:

01/09/2025 14:09


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Oceanside High School #7

OHS7

Walk In

Client:

Oceanside Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AMERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0652	HE	2023	Room S216	EC	1/9/2025	6:40:00 AM
OUFSD-0831	FL	1029A	Room S153 Meeting Room Kitchen	KC	1/9/2025	6:38:00 AM
OUFSD-0902	KI	1110B	Cafeteria Serving Area	SA	1/9/2025	6:36:00 AM
OUFSD-0908	KI	1116	Kitchen	KC	1/9/2025	6:34:00 AM

Samples Submitted 4

PB 2008 Belling 1/10/25

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
JAN 09 2025 PM07:25

Building Address

3160 Skillman Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

1/9/25 19:25

Signature:

Karen Wainwright

Samplers Name: Anthony Lombardo

Samplers Signature:

[Signature]

JCB Project Manager:

LOMBARDO

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550152**LIMS Reference ID:** ED50152**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

Oceanside High School #7: 3160 Skillman
Avenue, Oceanside, NY 11572: Oceanside
Union Free School District: Project# 23-53785

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/09/2025 19:25

Reported:

01/10/2025 13:46

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550152**LIMS Reference ID:** ED50152**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

Oceanside High School #7: 3160 Skillman
Avenue, Oceanside, NY 11572: Oceanside
Union Free School District: Project# 23-53785

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/09/2025 19:25

Reported:

01/10/2025 13:46


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building: Oaks School #3

OS3

ED50333

Client:

Oceanside Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush *2 day*

Page 1 of 1

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-0186	KI	1036A	Kitchen	KC	1/17/2025	6:11:00 AM

Samples Submitted 1

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 18 2025 PM02:55

Building Address

2852 Fortesque Avenue

Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Anthony Lombardo

Samplers Signature: *[Signature]*

JCB Project Manager: LOMBARDO

Page 4 of 4

*Ph 200-8 88-2
1/19/25*

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550333**LIMS Reference ID:** ED50333**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

#:23-53785, Oaks School #3, Oceanside
Union Free School District, 2852 Fortesque
Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/18/2025 14:55

Reported:

01/20/2025 09:23

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: OUFSD-0186**Lims Reference ID:** ED50333-01 **Matrix:** Drinking Water**Sampled:** 01/17/25 00:00:00**Metals**

Lead	< 1.0	1	1.0	µg/L	01/19/25 14:00	01/19/25 14:00	SEH	EPA 200.8 (DA)/EPA 200.8
------	-------	---	-----	------	----------------	----------------	-----	--------------------------

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550333**LIMS Reference ID:** ED50333**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

#:23-53785, Oaks School #3, Oceanside
Union Free School District, 2852 Fortesque
Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/18/2025 14:55

Reported:

01/20/2025 09:23

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550333**LIMS Reference ID:** ED50333**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

#:23-53785, Oaks School #3, Oceanside
Union Free School District, 2852 Fortesque
Avenue, Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/18/2025 14:55

Reported:

01/20/2025 09:23

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F
WAL

Client:

Oceanside Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush 2 day

Walk In

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1114	HE	2013	Room A207	EC	1/17/2025	6:35:00 AM
OUFSD-1115	HE	2013	Room A207	EC	1/17/2025	6:35:00 AM
OUFSD-1116	HE	2013	Room A207	EC	1/17/2025	6:35:00 AM
OUFSD-1117	HE	2013	Room A207	EC	1/17/2025	6:36:00 AM
OUFSD-1126	HE	2019	Room A202	EC	1/17/2025	6:33:00 AM
OUFSD-1155	HE	1022	Room A107	EC	1/17/2025	6:31:00 AM
OUFSD-1156	HE	1022	Room A107	EC	1/17/2025	6:32:00 AM
OUFSD-1157	HE	1022	Room A107	EC	1/17/2025	6:30:00 AM
OUFSD-1166	NO	1038	9M Nurse's Office	NS	1/17/2025	6:27:00 AM

Samples Submitted 9

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 18 2025 PM02:56

Building Address

186 Alice Avenue & 170 Beatrice Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received:

1-18-25 2:56 PM

Signature:

[Signature]

Samplers Name: Anthony Lombardo

Samplers Signature:

[Signature]

JCB Project Manager: LOMBARDO

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550334**LIMS Reference ID:** ED50334**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

#:23-53785, Oceanside Middle School #9M &
Walter S. Boardman Elementary School #9F,
186 Alice Avenue & 170 Beatrice Avenue,
Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/18/2025 14:56

Reported:

01/20/2025 09:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OUFSD-1114 Lims Reference ID: ED50334-01 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/19/25 14:59	01/19/25 14:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1115 Lims Reference ID: ED50334-02 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	2.5		1	1.0	µg/L	01/19/25 15:03	01/19/25 15:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1116 Lims Reference ID: ED50334-03 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	5.6		1	1.0	µg/L	01/19/25 15:04	01/19/25 15:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1117 Lims Reference ID: ED50334-04 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	2.5		1	1.0	µg/L	01/19/25 15:06	01/19/25 15:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1126 Lims Reference ID: ED50334-05 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	2.5		1	1.0	µg/L	01/19/25 15:07	01/19/25 15:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1155 Lims Reference ID: ED50334-06 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/19/25 15:11	01/19/25 15:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1156 Lims Reference ID: ED50334-07 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/19/25 15:12	01/19/25 15:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1157 Lims Reference ID: ED50334-08 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/19/25 15:14	01/19/25 15:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: OUFSD-1166 Lims Reference ID: ED50334-09 Matrix: Drinking Water Sampled: 01/17/25 00:00:00									
Metals									
Lead	1.5		1	1.0	µg/L	01/19/25 15:15	01/19/25 15:15	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550334**LIMS Reference ID:** ED50334**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

#:23-53785, Oceanside Middle School #9M &
Walter S. Boardman Elementary School #9F,
186 Alice Avenue & 170 Beatrice Avenue,
Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/18/2025 14:56

Reported:

01/20/2025 09:18

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550334**LIMS Reference ID:** ED50334**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

#:23-53785, Oceanside Middle School #9M &
Walter S. Boardman Elementary School #9F,
186 Alice Avenue & 170 Beatrice Avenue,
Oceanside, NY 11572

Customer PO:**EMSL Sales Rep:**

Jeromy Bish

Received:

01/18/2025 14:56

Reported:

01/20/2025 09:18


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53785

Building:

Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F
WAL

Client:

Oceanside Union Free School District

Retest/New Install ☐

Turn Around: Normal 1 wk Rush 2 day

ED50443

Page 1 of 1

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
OUFSD-1116	HE	2013	Room A207	EC	1/24/2025	6:28:00 AM

Samples Submitted 1

Pb 200.8 SLL
1/24/25



RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 27 2025 PM08:02

Building Address

186 Alice Avenue & 170 Beatrice Avenue
Oceanside, NY 11572

Analysis Type: ELAP 200.5

Lab Received: 1/27/25 20:02

Signature: [Signature]

Samplers Name: Anthony Lombardo

Samplers Signature: [Signature]

JCB Project Manager: LOMBARDO

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550443**LIMS Reference ID:** ED50443**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F: 186 Alice
Avenue & 170 Beatrice Avenue, Oceanside, NY
11572: Oceanside Union Free School District:
Project# 23-53785
Jeromy Bish

Customer PO:**EMSL Sales Rep:****Received:****Reported:**

01/27/2025 20:02
01/29/2025 12:25

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: OUFSD-1116**Lims Reference ID:** ED50443-01 **Matrix:** Drinking Water**Sampled:** 01/24/25 06:28:00**Metals**

Lead	< 1.0	1	1.0	µg/L	01/29/25 11:33	01/29/25 11:33	SEH	EPA 200.8 (Dig)/EPA 200.8
------	-------	---	-----	------	----------------	----------------	-----	---------------------------

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550443
LIMS Reference ID: ED50443
EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F: 186 Alice
Avenue & 170 Beatrice Avenue, Oceanside, NY
11572: Oceanside Union Free School District:
Project# 23-53785
Jeromy Bish
Customer PO:
EMSL Sales Rep:
Received: 01/27/2025 20:02
Reported: 01/29/2025 12:25

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062550443**LIMS Reference ID:** ED50443**EMSL Customer ID:** JCBR50**Attention:** Anthony Lombardo

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name:

Oceanside Middle School #9M & Walter S.
Boardman Elementary School #9F: 186 Alice
Avenue & 170 Beatrice Avenue, Oceanside, NY
11572: Oceanside Union Free School District:
Project# 23-53785
Jeromy Bish

Customer PO:**EMSL Sales Rep:****Received:****Reported:**

01/27/2025 20:02
01/29/2025 12:25

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Attachment 4:

Laboratory Certifications


J.C. Broderick & Associates, Inc.

Environmental Consulting & Testing

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2025
Issued April 01, 2024

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

Metals I

Lead, Total	EPA 200.5 EPA 200.8 Rev. 5.4
-------------	---------------------------------

Miscellaneous

Asbestos	EPA 100.2
----------	-----------



Serial No.: 68787

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

