

APPENDIX G

INSPECTION & COMPLIANCE MONITORING REPORT

NORTH READING PUBLIC SCHOOLS

NORTH READING MIDDLE AND HIGH SCHOOL

WASTEWATER TREATMENT FACILITY

CONTRACT OPERATION AND MAINTENANCE SERVICES

REQUEST FOR PROPOSAL

FEBRUARY 14, 2020

RFP No. 20 - 02





*Civil-Environmental Engineers
& Land Surveyors*

MARTINAGE ENGINEERING ASSOCIATES, INC.

131 Main Street, Third Floor
Reading, MA 01867-3966

TEL: 781-944-4808
FAX: 781-944-9676
mea@martinageengineering.com

October 22, 2019

Mr. Jon Bernard
Superintendent
North Reading High School
189 Park St.
North Reading, MA

**RE: Wastewater Treatment Plant
Groundwater Discharge Permit No. 931-0
North Reading High School
North Reading, MA**

Dear Mr. Bernard:

This correspondence is in regard to the operation of the above-referenced wastewater treatment plant.


Enclosed please find the engineering inspection report and the Compliance Discharge Monitoring Reports with the results of the monthly analysis for the Wastewater Treatment Plant conducted for the month of September as required by the Wastewater Treatment Plant Discharge Permit. The copies of the DMR's that were submitted via the internet to DEP are enclosed. Sampling was conducted on September 19-20, 2019. Monthly testing for the Monitoring Wells was conducted on September 5, 2019.

All parameters were met at the time of the inspection with the exception of Effluent Nitrate and Total Nitrogen. See Comment #15.

Should you have any questions, please contact our office.

Very truly yours,

MARTINAGE ENGINEERING ASSOCIATES, INC.


John E. Martinage, E.I.T.
Project Engineer

Reviewed by Donald E. Martinage, P.E.

Enclosures

- c. North Reading BOH, via email
- Wally Bruce, Weston & Sampson, via email
- John Bocchino, Weston & Sampson, via email
- Ken Nugent, Weston & Sampson, via email
- George Malonson, Weston & Sampson, via email



Groundwater Permit

DAILY LOG SHEET

931

1. Permit Number

2. Tax Identification Number

2019 SEP DAILY

3. Sampling Month & Frequency

C. Daily Readings/Analysis Information

Date	Effluent Flow GPD	Reuse Flow GPD	Irrigation Flow GPD	Turbidity	Influent pH	Effluent pH	Chlorine Residual (mg/l)	UV Intensity (%)
1	1175							
2	1175							
3	2100			0.31	7.44	7.61		ND
4	6200			0.31	7.63	7.20		60
5	2600			0.31	7.93	7.22		ND
6	2168			0.30	7.97	7.24		ND
7	2166							
8	2166							
9	4400			0.38	7.77	7.26		ND
10	4400			0.37	8.03	7.06		63
11	6600			0.39	8.14	7.54		ND
12	4700			0.35	8.05	7.17		63
13	1534			0.35	7.88	7.27		ND
14	1534							
15	1532							
16	4800			0.40	7.87	7.54		ND
17	4400			0.39	7.94	7.19		ND
18	4400			0.39	7.93	7.23		ND
19	2300			0.37	7.94	7.14		ND
20	2334			0.38	7.89	7.29		67
21	2334							
22	2332							
23	6800			0.40	7.68	7.38		62
24	4500			0.40	7.79	7.36		ND
25	ND			0.41	7.93	7.30		ND
26	8900			0.41	7.89	7.26		ND
27	3901			0.39	7.87	7.06		ND
28	3900							
29	3899							
30	4400			0.38	7.46	7.32		ND
31								



Groundwater Permit
DISCHARGE MONITORING REPORT

931
1. Permit Number

[REDACTED]
2. Tax identification Number

2019 SEP MONTHLY
3. Sampling Month & Frequency

D. Contaminant Analysis Information

- For "0", below detection limit, less than (<) value, or not detected, enter "ND"
- TNTC = too numerous to count. (Fecal results only)
- NS = Not Sampled

1. Parameter/Contaminant	2. Influent	3. Effluent	4. Effluent Method Detection limit
Units			
BOD	224	ND	6
MG/L			
TSS	132	ND	2
MG/L			
TOTAL SOLIDS	1080	890	50
MG/L			
AMMONIA-N	174		
MG/L			
NITRATE-N		17.2	1
MG/L			
TOTAL NITROGEN(NO3+NO2+TKN)		17.2	0.5
MG/L			
OIL & GREASE		ND	5
MG/L			
FOAMING AGENTS (MBAS)		0.102	0.1
MG/L			



Groundwater Permit
 MONITORING WELL DATA REPORT


931
 1. Permit Number
 2. Tax Identification Number
 2019 SEP MONTHLY
 3. Sampling Month & Frequency

C. Contaminant Analysis Information

- For "0", below detection limit, less than (<) value, or not detected, enter "ND"
- TNTC = too numerous to count. (Fecal results only)
- NS = Not Sampled
- DRY = Not enough water in well to sample.

<

Parameter/Contaminant	MW-1R	MW-4	MW-5	MW-6		
Units	Well #: 1	Well #: 2	Well #: 3	Well #: 4	Well #: 5	Well #: 6
PH	5.86	5.54	5.25	6.00		
S.U.						
STATIC WATER LEVEL	67.58	63.23	62.50	63.24		
FEET						
SPECIFIC CONDUCTANCE	2640	733	128	710		
UMHOS/C						



Groundwater Permit

931

1. Permit Number

2. Tax identification Number

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



Any person signing a document under 314 CMR 5.14(1) or (2) shall make the following certification

If you are filing electronic-ally and want to attach additional comments, select the check box.



Facility Information

NORTH READING HIGH/MIDDLE SCHOOL

a. Name

191 PARK STREET

b. Street Address

NORTH READING MA 01864

c. City

d. State

e. Zip Code

Certification

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

JULIA MARTINAGE 10/31/2019

a. Signature

b. Date (mm/dd/yyyy)

Reporting Package Comments

PLEASE NOTE: NITRATE-N AND TOTAL NITROGEN EXCEEDED THE PERMIT PARAMETERS ON THE DAY OF THE INSPECTION AT A CONCENTRATION OF 17.2 MG/L. THE EXCEEDANCE MAY BE ATTRIBUTED TO AN INSUFFICIENT CARBON SOURCE, METHANOL, AVAILABLE TO COMPLETE THE DEGREE OF DENITRIFICATION IN THE PROCESS. THE EXCEEDANCE MAY POSSIBLY BE ATTRIBUTED TO A RECENT CHANGE IN THE CARBON SOURCE FROM MICRO-C TO 20% METHANOL IN THE PROCESS THAT HAS YET TO STABILIZE. MEASURES ARE ALWAYS TAKEN BY THE OPERATOR TO ENSURE COMPLIANCE IN THE FINAL EFFLUENT BY MAKING NECESSARY OPERATIONAL ADJUSTMENTS.

**WASTEWATER TREATMENT PLANT INSPECTION REPORT
NORTH READING HIGH SCHOOL, NORTH READING, MA**

Permit #	931-1	Lab #	L2K19-2692	Month	September
Date of Inspection	9/19-20/19		11:00AM	Weather	clear

Operator Wally Bruce

Tests and Observations Made During Inspection

1. Recorded Wastewater Flow on Day of Inspection		2,334	GPD			
2. Temperature (±)	Influent	19	°C			
	Pre Anoxic Tank	22	°C			
	Aeration Tank	23	°C			
	Post Anoxic Effluent	24	°C			
	Permeate Tank	24	°C			
	Final Effluent	24	°C			
3. Dissolved Oxygen	Pre Anoxic Tank	3.00	mg/l	2.00 hi level		
	Aeration Tank	3.30	mg/l	1.5 desired		
	Post Anoxic Tank	1.10	mg/l	1.20 low level		
4. 30-Min Mallory Settleable Solids in Aeration Tank		.990	ml/l	Negligible		
5. On Site Operational Testing		Final Effluent	Pre Anoxic	Aeration	Post Anoxic	FET Influent
	pH (s.u.)	7.29	7.42	7.30	7.36	7.89
	NO3-N (mg/l)	15.7				
	NO2-N (mg/l)	1.00				
	NH3-N (mg/l)	0.20				
	Alkalinity (mg/l)	180	180	180	180	240
30 Min Mallory (ml/l)				990		
6. FET Flow Rate(+/-)		5.0	varied	flow conditions		
7. Chemical Pumps:						
(Carbon) 20% methanol						Flow Conditions
	Condition	On line				
	Inventory	100	GAL. (+/-)			
Citric Acid Pump (CIB)						Flow Conditions
	Pump Rate	varied	GAL/ per use			
	Condition	On line				
	Inventory	15	GAL. (+/-)			
Sodium Hydroxide (Caustic) Aeration (as needed)						Flow Conditions
	Pump Rate	varied	GAL/ per use			
	Condition	on line				
	Inventory	30	GPD (+/-)			

**WASTEWATER TREATMENT PLANT INSPECTION REPORT
NORTH READING HIGH SCHOOL, NORTH READING, MA**

Permit #	931-1	Lab #	L2K19-2692	Month	September
Date of Inspection	9/19-20/19		11:00AM	Weather	clear

Operator Wally Bruce

Sodium Hydroxide (Caustic) (CIB)	Pump Rate	as needed	GPD	Flow Conditions	
	Condition	on line			
Sodium Hypochlorite (Bleach) (Drain fill)	Pump Rate	0.50	GPD (+/-)	Flow Conditions	
	Condition	auto			
	Inventory	45	GAL (+/-)	Total	
8. Clarity of Final Effluent		clear			
9. Microscopic Examination of Activated Sludge		Predominance of crawling and stalked ciliates.			
10. Primary Settling Tanks	#1 Condition	12/12/12	inches		
	Settled Blanket Depth	24/28/30	inches		
	#2 Condition	off line			
	Settled Blanket Depth	-			
	Sludge Pumping Schedule				
11. Flow Equalization Tank	Condition	Grey in color, light floating mat noted.			
	Flow Rate	5.0	GPM	flow condition	
	Recycle Rate	30	GPM (+/-)		
	Level	28.6	%		
	Settled Blanket Depth	8" light surface			
12. Pre-Anoxic Tank	Condition	Negligible foam, color medium red brown.			
	Status	On line			
13. Aeration Tank	Air/Process Circulation	Status	On	Operational	
	Condition	Color: Medium red brown. Very light foam.			
14. Blowers	#1	Status	On line	Operational	Yes
	#2	Status	On line	Operational	Yes
15. Mixers	Pre Anoxic #1	Status	On line	Operational	Yes
	Aeration #2 Post Anoxic	Status	On line	Operational	Yes
	#3	Status	On line	Operational	Yes

SUMMARY OF LABORATORY ANALYSIS
NORTH READING HIGH SCHOOL, NORTH READING, MA

Permit #	931-1	Lab #	L2K19-2692
Sample Date	9/19-20/19		

COMPLIANCE DATA SUMMARY

Parameter	Units	Raw Influent FET		Final Effluent	% Removed	Meets Permit Levels
Flow	gpd			2,334		
BOD ₅	mg/l	224	<	6.0	97.32	meets permit
TSS	mg/l	132	<	2.00	98.5	meets permit
TVS	mg/l					
TS	mg/l	1080		890		
TVSS	mg/l					
% Volatile	ml/l/hr					
SVI						
pH	s.u.	7.89		7.29		
NO ₃ as N	mg/l			17.20		exceeds permit
NO ₂ -N	mg/l		<	0.50		
NH ₃ - N	mg/l	174				
Total Nitrogen	mg/l			17.20		
Total Kjeldahl Nitrogen	mg/l			<0.50		
Oil & Grease	mg/l		<	5.00		meets permit
Surfactant	mg/l			0.102		
Total VOC*	µg/l					
Total P**	mg/l					
PO ₄ as P**	mg/l					

* = Annual Test G= Grab Sample
 **Quarterly ND - NONE DETECTED

Wastewater Treatment Plant Permit #931-0
North Reading High School
North Reading, MA

COMMENTS/RECOMMENDATIONS

1. Measures always should be taken by the school department to ensure no recalcitrants such as lab chemicals, paints and floor strippers, waxes, cleaning or sanitized products containing Quaternary Ammonia Compounds (QAC) or Zinc are discharged into the sanitary collection system from the schools. Such compounds may be toxic or inhibitory to the biological treatment system.
2. The FET Pump Stations and Primary Settling Tanks should be regularly checked for any solids blanket in the bottom or floating surface mats and solids should be removed on an as needed basis. Pumping should be noted on the daily log. Measures should be taken by the School Department to ensure no non-biodegradable items (e.g. Wipes, reinforced paper towels, plastic items, etc.) are put into the Sewer Collection System.
3. Proper daily operational testing is an integral part of successfully operating a wastewater treatment facility. The operator is utilizing the lab equipment on a daily basis. The operator was completing necessary calibrations for laboratory testing. Daily calibration logs should continue to be kept up to date.
4. The operator will make notations on the daily operator report of weather conditions and any suspect inflow/infiltration at the facility. Measures should be taken to identify and remediate any contributory factors to the Inflow/infiltration at the site. Remediation maybe such as regrading and installation of infiltration covers in areas subject to flooding during snow melt and rain events.
5. It is required by the Discharge Permit that the operator enter daily flow data, and effluent pH data reading on a daily basis, (Monday thru Friday). The operator log summary will contain all entries as required on a monthly basis. The operator will continue to complete all necessary operational testing and make note of all operational settings to ensure the facility is in compliance with the discharge permit. This data should continue to be included with the monthly operator log for review by the engineer to determine proper plant performance and operations. The operator will continue to note any deficiencies encountered during the month and schedule to make necessary repairs. The operator will continue to keep current records relative to equipment preventive maintenance procedures and schedules. All records pertaining to the facility such as pumping records etc. should be kept on site.
6. The operator should continue to supplement all on site test kits with testing chemicals and necessary reagents on an as needed basis and maintain all test equipment in a calibrated and operational manner. Ph standards should always be fresh, dated and initialed by the operator when opened. First aid kit and eye

wash should always be up to date and safety glasses kept on site.

7. Typically, the operator completes Chemical Enhance Backwash (CEB) weekly. The TMP membrane feed at approximately 6.5 PSI and the Permeate TMP are maintaining at approximately 2.5-3.0 PSI.
8. Containment and segregation of chemical inventory are suggested.
9. Measures should be taken to ensure supervision and maintenance of the Field House pump station.
10. It was noted that the contents of the permeate tank were clear.
11. The operator reports he is conducting mixed liquor (Aeration Tank) TSS samples for solid management in the process as needed.
12. The odor control system was on line.
13. Process flow rates noted at the time of the inspection were as follows:

A)	Denitrification	30.0 GPM
B)	Skid Feed	300 GPM
C)	Permeate	10 GPM
14. Skid feed PH meter is in need of repair/calibration. This task should be completed.
15. All permit parameters were met at the time of the inspection with the exception of Nitrate-N and Total Nitrogen at concentrations of 17.2 mg/l. The exceedance may be attributed to an insufficient carbon source, methanol, available to complete the degree of Denitrification in the process. The exceedance may possibly be attributed to a recent change in the carbon source from Micro-C to 20% methanol in the process that has yet to stabilize. Measures are always taken by the operator to ensure compliance in the Final Effluent by making necessary operational adjustments.
16. On site Monitoring Well laboratory analysis for monitoring pH and Conductivity completed by: Martinage Engineering Associates, Inc., MA Lab Cert. #M-MA 129, 131 Main Street, Reading, MA. Compliance testing completed by Waste Water Environmental Management, Inc., Lab Cert. #077, 270 Littleton Road, Unit 30, Westford, MA 01866.



Billing
9A Quincy Road
Londonderry, NH 03053
(603) 434-8134

Laboratory
270 Littleton Road, Unit 30
Westford, MA 01886
(978) 692-8010

Test Report

Martinage Engineering Assoc. Inc.
131 Main Street
Reading MA. 01867

Subject: Wastewater Treatment Plant, North Reading High School
North Reading, MA
Sample Date: 9/19-20/19
Date Received: 9/20/19
Report ID: 67489
MEA #: L2K19-2692

Table with 7 columns: Parameter, Units, Raw Composite 67489A, FINAL COMPOSITE 67489B, FINAL GRAB 67489C, Method, Date Completed. Rows include BOD, ITS, TSS, NH3 as N, NO3 as N, !NO2 as N, TKN, Oil & Grease, !MBAS, and TOTAL NITROGEN.

! Certification Not Provided By State !

10/10/2019 15:01
page 1 of 1

Signature of Steven Hansen
Steven Hansen
Laboratory Director
Massachusetts Certification #M-MA077



*Civil-Environmental Engineers
& Land Surveyors*

MARTINAGE ENGINEERING ASSOCIATES, INC.
131 Main Street
Reading, MA 01867-3966

Client Name: NORTH READING HS
Address: 191 PARK STREET
NORTH READING, MASS 01864

Project: M-STP

LAB NO: L2K19- 2692

CHAIN OF CUSTODY

Sampled By: BFD

MONTHLY WASTEWATER TREATMENT PLANT

6786
9/20/19 67489 A-C

TEL: 781-944-4808
FAX: 781-944-9676

DATE	TIME	STATION LOCATION	SAMPLE TYPE	BOD ₅	NO ₃ -N	NO ₂ -N	TKN	NH ₃ -N	TS	TSS	O & G	SURFACTANTS	REMARKS
9/19 - 9/20/19	1100	FE	COMP	X	X	X	X		X	X			
9/20/19	1115	FE	GRAB								X	X	Preserved 4°C NOCI2
9/19 - 9/20/19	1130	RAW	COMP	X				X	X	X			
		RAW	GRAB										

Relinquished by: [Signature]
Date: 9/20/19
Time: 1300

Received By: [Signature]
Date: 9-20-19
Time: 1300

Relinquished by: _____
Date: _____
Time: _____

Received By: _____
Date: _____
Time: _____