MICROBAC®

Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

F5G1207

Freeport Area School District

Eric Mailki
PO BOX C
Freeport, PA 16229

Project Name: Water Testing

Project / PO Number: N/A
Received: 07/28/2025
Reported: 08/09/2025

Analytical Testing Parameters

Client Sample ID: HS Teachers Lounge = First Draw
Sample Matrix: Drinking Water
Lab Sample ID: F5G1207-01
Collected By: Tim McLaughlin
Collection Date: 07/28/2025 10:00

Analyses Performed by: Microbac Laboratories Inc., - Marietta, OH

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150 AL	0.000400	mg/L		08/06/25 1004	08/07/25 1326	JYH

Client Sample ID: HS Teachers Lounge = 30 seconds later
Sample Matrix: Drinking Water
Lab Sample ID: F5G1207-02
Collected By: Tim McLaughlin
Collection Date: 07/28/2025 10:00

Analyses Performed by: Microbac Laboratories Inc., - Marietta, OH

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150 AL	0.000400	mg/L		08/06/25 1004	08/07/25 1327	JYH

*Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

Definitions

AL: US EPA Action Level
mg/L: Milligrams per Liter
RL: Reporting Limit

Project Requested Certification(s)


Microbac Laboratories Inc., - Marietta, OH
68-01670
Microbac Laboratories Inc., Pittsburgh Division
02-00257
PA Department of Environmental Protection
Pennsylvania Department of Environmental Protection
Pennsylvania Department of Environmental Protection - PARULE

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. ***The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:



Carolyn Vollentine
Service Center Manager
Reported: 08/09/2025 10:04

MICROBAC®

Chain of Custody

Microbac Laboratories, Inc. - Erie

Lab Contact: Carolyn Vollentine

F5G1207

Page 2 of 2

TAT 7 days

Freeport Area School District

Eric Mailki
PO BOX C
Freeport, PA 16229
Phone: (724) 295-5143
mailki@freeport.k12.pa.us

Project Name: Water Testing

Project/PO Number: N/A
Tenatively Scheduled: 7/28/2025
Route:

Client Sample ID: HS Teachers Lounge = First Draw
Lab Sample ID: F5G1207-01
Matrix: Drinking Water
Sampled Date & Time: 7-28-25 10:00
Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
Turbidity Metals E180.1	EPA 180.1, Rv. 2 (1993)		2 days
		Container(s)	Designator
		250ml-Bottle HDPE-NoPres	A

Client Sample ID: HS Teachers Lounge = 30 seconds later
Lab Sample ID: F5G1207-02
Matrix: Drinking Water
Sampled Date & Time: 7-28-25 10:01
Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
Turbidity Metals E180.1	EPA 180.1, Rv. 2 (1993)		2 days
		Container(s)	Designator
		250ml-Bottle HDPE-NoPres	A

Sampled/Relinquished by:	Date/Time: 7-28-25 1345	Received by:	Date/Time: 7/28/25 1350
Printed Name: Tim McLaughlin		Printed Name:	
Relinquished by:	Date/Time:	Received by:	Date/Time:
Printed Name:		Printed Name:	
Relinquished by:	Date/Time:	Received by:	Date/Time:
Printed Name:		Printed Name:	

As Received at Laboratory: On Ice: Yes / No Temp: 26.5 °C Thermometer ID: TG-3 Custody Seal: Yes / No / NA

Total Containers: 2.00

Microbac Laboratories may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to an appropriately accredited laboratory. By signing this document you are acknowledging that you have been informed by Microbac that testing could be subcontracted and agree with this arrangement.

Notes: