*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

June 10, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Griffin Creek School Leads Order No.: 25050575

Dear Andy Chasteen:

Neilson Research Corporation received 27 sample(s) on 5/13/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501

Original

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Case Narrative

WO#: **25050575**
Date: **6/10/2025**

**CLIENT:** Medford School District
**Project:** Griffin Creek School Leads

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-01** Client Sample ID: Room 24-DF
Collection Date: 5/13/2025 6:14:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Room 24-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-02** Client Sample ID: Room 24-Sink
Collection Date: 5/13/2025 6:14:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Room 24-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-03** Client Sample ID: Room 25-DF
Collection Date: 5/13/2025 6:12:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Room 25-DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-04** Client Sample ID: Room 25-Sink
Collection Date: 5/13/2025 6:12:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Room 25-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.629 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-05** Client Sample ID: Boys RR Adj Room 25- Sink (1) Left
Collection Date: 5/13/2025 6:11:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Boys RR Adj Room 25- Sink (1) Left

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.01 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-06** Client Sample ID: Boys RR Adj Room 25- Sink (2)
Collection Date: 5/13/2025 6:11:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Boys RR Adj Room 25- Sink (2)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.902 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-07** Client Sample ID: Boys RR Adj Room 25- Sink (3)
Collection Date: 5/13/2025 6:10:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Boys RR Adj Room 25- Sink (3)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.27 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-08** Client Sample ID: Boys RR Adj Room 25- Sink (4)
Collection Date: 5/13/2025 6:09:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Boys RR Adj Room 25- Sink (4)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.799 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-09** Client Sample ID: Boys RR Adj Room 25- Sink (5) Right
Collection Date: 5/13/2025 6:08:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Boys RR Adj Room 25- Sink (5) Right

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.558 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

QUALIFIERS

| | |
|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. |
| DF | Dilution Factor |
| H | Holding times for preparation or analysis exceeded |
| MI | Recovery outside comtrol limits due to Matrix Interference |
| R | RPD outside accepted recovery limits |
| C1 | Sample container temperature is out of limit as specified at testcode |
| E | Value above quantitation range |
| J | Analyte detected below quantitation limits |
| ND | Not Detected at the Reporting Limit |
| RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-10** Client Sample ID: Girls RR Adj Room 25- Sink (1) Left
Collection Date: 5/13/2025 6:06:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Girls RR Adj Room 25- Sink (1) Left

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-11** Client Sample ID: Girls RR Adj Room 25- Sink (2)
Collection Date: 5/13/2025 6:05:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Girls RR Adj Room 25- Sink (2)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.808 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-12** Client Sample ID: Girls RR Adj Room 25- Sink (3)
Collection Date: 5/13/2025 6:04:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Girls RR Adj Room 25- Sink (3)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-13** Client Sample ID: Girls RR Adj Room 25- Sink (4)
Collection Date: 5/13/2025 6:03:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Girls RR Adj Room 25- Sink (4)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-14** Client Sample ID: Girls RR Adj Room 25- Sink (5) Right
Collection Date: 5/13/2025 6:02:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Girls RR Adj Room 25- Sink (5) Right

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-15** Client Sample ID: Gym-DF (North)
Collection Date: 5/13/2025 5:50:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Gym-DF (North)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 2.49 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-16** Client Sample ID: Gym-DF (South)
Collection Date: 5/13/2025 5:51:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Gym-DF (South)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.954 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-17** Client Sample ID: Gym Womens RR-Sink
Collection Date: 5/13/2025 5:44:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Gym Womens RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.697 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-18** Client Sample ID: Gym Mens RR-Sink
Collection Date: 5/13/2025 5:42:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Gym Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 1.09 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-19** Client Sample ID: Stage-Sink (Utility)
Collection Date: 5/13/2025 5:46:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Stage-Sink (Utility)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-20** Client Sample ID: Room Above Stage (South) DF
Collection Date: 5/13/2025 5:47:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Room Above Stage (South) DF

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 0.654 | | 0.515 | ppb | 1 | 6/4/2025 | 15.0 | |

**Lab ID:** **25050575-21** Client Sample ID: Room Above Stage (South)-Sink
Collection Date: 5/13/2025 5:48:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Room Above Stage (South)-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | 2.92 | | 0.515 | ppb | 1 | 6/6/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-22** Client Sample ID: Cafeteria-Bottle Filler (Upper)
Collection Date: 5/13/2025 5:36:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Cafeteria-Bottle Filler (Upper)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/6/2025 | 15.0 | |

**Lab ID:** **25050575-23** Client Sample ID: Cafeteria (Lower) Bottle Filler
Collection Date: 5/13/2025 5:38:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Cafeteria (Lower) Bottle Filler

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/6/2025 | 15.0 | |

**Lab ID:** **25050575-24** Client Sample ID: Kitchen-Sink (Food Prep-North)
Collection Date: 5/13/2025 5:35:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Sink (Food Prep-North)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/6/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Analytical Report

WO#: **25050575**
Date Reported: **6/10/2025**

Medford School District
900 Kenyon St
Medford , OR 97501

**Lab Order:** 25050575
**Received Date:** 5/13/2025 9:18:00 AM
**Reported Date:** 6/10/2025 9:12:09 AM

Sample Information:

**Lab ID:** **25050575-25** Client Sample ID: Kitchen-Sink (Hand/Eye Wash)
Collection Date: 5/13/2025 5:30:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Sink (Hand/Eye Wash)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/6/2025 | 15.0 | |

**Lab ID:** **25050575-26** Client Sample ID: Kitchen-Sink(Pre-rinse/Dishwasher)
Collection Date: 5/13/2025 5:33:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Sink(Pre-rinse/Dishwasher)

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/6/2025 | 15.0 | |

**Lab ID:** **25050575-27** Client Sample ID: Cafeteria Staff RR-Sink
Collection Date: 5/13/2025 5:33:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Cafeteria Staff RR-Sink

Trace Metals by EPA 200.8 ICP-MS — Analyst; CJS

| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
|---|---|---|---|---|---|---|---|---|
| Lead | ND | | 0.515 | ppb | 1 | 6/6/2025 | 15.0 | |

QUALIFIERS

| | | | |
|---|---|---|---|
| * | Value exceeds Maximum or Minimum Contaminant Level. | C1 | Sample container temperature is out of limit as specified at testcode |
| DF | Dilution Factor | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Limit |

NELAP

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# QC SUMMARY REPORT

WO#: **25050575**

***10-Jun-25***

**Client:** Medford School District
**Project:** Griffin Creek School Leads **TestCode:** **LEAD_SCHOOLS**

| Sample ID: | MB-31530 | SampType: | MBLK | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60046 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | PBW | Batch ID: | 31530 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/5/2025 | SeqNo: | 983164 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | ND | 0.515 | | | | | | | | | |

| Sample ID: | LCS-31530 | SampType: | LCS | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60046 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | LCSW | Batch ID: | 31530 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/6/2025 | SeqNo: | 983165 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 101 | 0.520 | 100 | 0 | 101 | 85 | 115 | | | | |

| Sample ID: | 25050575-21AMS | SampType: | MS | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60046 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | Room Above Stage ( | Batch ID: | 31530 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/6/2025 | SeqNo: | 983167 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 101 | 0.520 | 100 | 2.92 | 97.7 | 70 | 130 | | | | |

| Sample ID: | 25050575-21AMSD | SampType: | MSD | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60046 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | Room Above Stage ( | Batch ID: | 31530 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/6/2025 | SeqNo: | 983168 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 96.8 | 0.520 | 100 | 2.92 | 93.9 | 70 | 130 | 101 | 3.89 | 20 | |

**Qualifiers:**

| | | | | | |
|---|---|---|---|---|---|
| C1 | Sample container temperature is out of limit as specified at testcode | DF | Dilution Factor | H | Holding times for preparation or analysis exceed |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit | RL | Reporting Limit |

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# QC SUMMARY REPORT

WO#: **25050575**

***10-Jun-25***

**Client:** Medford School District
**Project:** Griffin Creek School Leads **TestCode:** **LEAD_SCHOOLS**

| Sample ID: | MB-31529 | SampType: | MBLK | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60091 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | PBW | Batch ID: | 31529 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/4/2025 | SeqNo: | 984109 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | ND | 0.515 | | | | | | | | | |

| Sample ID: | LCS-31529 | SampType: | LCS | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60091 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | LCSW | Batch ID: | 31529 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/4/2025 | SeqNo: | 984110 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 101 | 0.520 | 100 | 0 | 101 | 85 | 115 | | | | |

| Sample ID: | 25050575-01AMS | SampType: | MS | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60091 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | Room 24-DF | Batch ID: | 31529 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/4/2025 | SeqNo: | 984112 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 98.4 | 0.520 | 100 | 0.206 | 98.2 | 70 | 130 | | | | |

| Sample ID: | 25050575-01AMSD | SampType: | MSD | TestCode: | LEAD_SCHO | Units: | ppb | Prep Date: | 6/3/2025 | RunNo: | 60091 |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Client ID: | Room 24-DF | Batch ID: | 31529 | TestNo: | E200.8 | E200.8 | | Analysis Date: | 6/4/2025 | SeqNo: | 984113 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead | 100 | 0.520 | 100 | 0.206 | 100 | 70 | 130 | 98.4 | 1.88 | 20 | |

**Qualifiers:**

| | | | | | |
|---|---|---|---|---|---|
| C1 | Sample container temperature is out of limit as specified at testcode | DF | Dilution Factor | H | Holding times for preparation or analysis exceed |
| MI | Recovery outside comtrol limits due to Matrix Interference | ND | Not Detected at the Reporting Limit | RL | Reporting Limit |

Original

NEILSON RESEARCH CORPORATION

*Neilson Research Corporation*
*245 S Grape St*
*Medford, OR 97501*
*TEL: (541) 770-5678 FAX: (541) 770-2901*
*Website: www.nrclabs.com*

# Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 25050575 RcptNo: 1

| | | | |
|---|---|---|---|
| Logged by: | Ashley Spiegelberg | 5/13/2025 9:18:00 AM | |
| Completed By: | Coni Boyko | 5/16/2025 12:38:49 PM | Coni Boyko |
| Reviewed By: | Dorie Evans | 6/10/2025 9:00:39 AM | |

## Chain of Custody

1. Is Chain of Custody complete? Yes ☑ No ☐ Not Present ☐
2. How was the sample delivered? Client

## Log In

3. Coolers are present? Yes ☐ No ☐ NA ☑
4. Shipping container/cooler in good condition? Yes ☑ No ☐
   Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☑ NA ☐
   No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☑
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☑
7. Sample(s) in proper container(s)? Yes ☑ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☑ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☑ No ☐
10. Was preservative added to bottles? Yes ☐ No ☑ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☑
12. Were any sample containers received broken? Yes ☐ No ☑
13. Does paperwork match bottle labels? (Note discrepancies on chain of custody) Yes ☑ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☑ No ☐
15. Is it clear what analyses were requested? Yes ☑ No ☐
16. Were all holding times able to be met? (If no, notify customer for authorization.) Yes ☑ No ☐

## Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☑

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

| Cooler No | Temp ºC | Condition | Seal Intact | Seal No | Seal Date | Signed By |
|---|---|---|---|---|---|---|

NEILSON RESEARCH CORPORATION
Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.



**Section A**
**Required Client Information**

Company: MSD 549C
Address: 900 Kenyon
Medford, OR 97501
Email: andy.chasteen@medford.k12.or.us
Phone: 541-840-4315 Fax:
Collected By (Print): Mike Medel
Collected By (Sign):
Email Report ___ Yes ___ No | Mail Report ___ Yes ___ No
Fax Report ___ Yes ___No

**Section B**
**Required Project Information**

Project Name: Griffin Creek
Project Number:
Report andy.chasteen@medford.k12.or.us
Copy T seth.barry@medford.k12.or.us

**Section C**
**Invoice Information**

Attention: Accounting
Company Name: Medford School District
Address: 900 Kenyon
Medford, OR 97501
P.O. #

**Section D**
**Rush Status (Subject to Scheduling)**

___ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ____ Yes ____ No

**Section E**
**Sample Information**

NRC Workorder # (Lab Use Only) 25050575

| Sample ID | Matrix * | Date Collected | Time Collected | No. of Containers | Analysis Requested | | | | | | | | | | Remarks/Field Data | NRC Sample # (Lab Use Only) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Room 24 - Drinking Fountain | DW | 5/13/25 | 6:14 | 1 | | | | | | | | | | | | 01 |
| Room 24 - Sink | DW | 5/13/25 | 6:14 | 1 | | | | | | | | | | | | 02 |
| Room 25 - Drinking Fountain | DW | 5/13/25 | 6:12 | 1 | | | | | | | | | | | | 03 |
| Room 25 - Sink | DW | 5/13/25 | 6:12 | 1 | | | | | | | | | | | | 04 |
| Boy's Restroom Adjacent To Room 25 -Sink (1) Left side | DW | 5/13/25 | 6:11 | 1 | | | | | | | | | | | | 05 |
| Boy's Restroom Adjacent To Room 25 -Sink (2) | DW | 5/13/25 | 6:11 | 1 | | | | | | | | | | | | 06 |
| Boy's Restroom Adjacent To Room 25 -Sink (3) | DW | 5/13/25 | 6:10 | 1 | | | | | | | | | | | | 07 |
| Boy's Restroom Adjacent To Room 25 -Sink (4) | DW | 5/13/25 | 6:09 | 1 | | | | | | | | | | | | 08 |
| Boy's Restroom Adjacent To Room 25 -Sink (5) Right side | DW | 5/13/25 | 6:08 | 1 | | | | | | | | | | | | 09 |
| Girl's Restroom Adjacent To Room 25 -Sink (1) Left side | DW | 5/13/25 | 6:06 | 1 | | | | | | | | | | | | 10 |
| Girl's Restroom Adjacent To Room 25 -Sink (2) | DW | 5/13/25 | 6:05 | 1 | | | | | | | | | | | | 11 |
| Girl's Restroom Adjacent To Room 25 -Sink (3) | DW | 5/13/25 | 6:04 | 1 | | | | | | | | | | | | 12 |
| Girl's Restroom Adjacent To Room 25 -Sink (4) | DW | 5/13/25 | 6:03 | 1 | | | | | | | | | | | | 13 |
| Girl's Restroom Adjacent To Room 25 -Sink (5) Right side | DW | 5/13/25 | 6:02 | 1 | | | | | | | | | | | | 14 |
| | DW | | | 1 | | | | | | | | | | | | |
| Gym - Drinking Fountain (North) | DW | 5/13/25 | 5:50 | 1 | | | | | | | | | | | | 15 |
| Gym - Drinking Fountain (South) | DW | 5/13/25 | 5:51 | 1 | | | | | | | | | | | | 16 |
| Gym Women's Restroom - Sink | DW | 5/13/25 | 5:44 | 1 | | | | | | | | | | | | 17 |
| Gym Men's Restroom - Sink | DW | 5/13/25 | 5:42 | 1 | | | | | | | | | | | | 18 |
| Stage - Sink (Utility) | DW | 5/13/25 | 5:46 | 1 | | | | | | | | | | | | 19 |
| Room Above The Stage (South) - Drinking Fountain | DW | 5/13/25 | 5:47 | 1 | | | | | | | | | | | | 20 |
| Room Above The Stage (South) - Sink | DW | 5/13/25 | 5:48 | 1 | | | | | | | | | | | | 21 |
| | DW | | | 1 | | | | | | | | | | | | |

5:36

| | | | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Cafeteria - Bottle Filler (Upper) | DW | 5/13/25 | ~~5:30~~ | 1 | | | | | | | | | | | | 43 | 22 |
| Cafeteria - ~~DW~~ (Lower) ~~Bottle Filler~~ | DW | 5/13/25 | 5:38 | 1 | | | | | | | | | | | | 44 | 23 |
| Kitchen - Sink (Food Prep - North Wall) | DW | 5/13/25 | 5:35 | 1 | | | | | | | | | | | | 25 | 24 |
| Kitchen - Sink (Hand/Eye Wash) | DW | 5/13/25 | 5:30 | 1 | | | | | | | | | | | | 26 | 25 |
| Kitchen - Sink (Pre-rinse/Dishwasher) | DW | 5/13/25 | 5:33 | 1 | | | | | | | | | | | | 27 | 26 |
| Cafeteria Staff Restroom - Sink | DW | 5/13/25 | 5:33 | 1 | | | | | | | | | | | | | 27 |
| | DW | | | 1 | | | | | | | | | | | | | |
| | DW | | | 1 | | | | | | | | | | | | | |
| | DW | | | 1 | | | | | | | | | | | | | |
| | DW | | | 1 | | | | | | | | | | | | | |
| | DW | | | 1 | | | | | | | | | | | | | |
| | DW | | | 1 | | | | | | | | | | | | | |
| | DW | | | 1 | | | | | | | | | | | | | |

*Matrix: **DW** - Drinking Water **WW** - Wastewater **W** - Water **S** - Soil/Solid **SL** - Sludge **O** - Oil **WP** - Wipe **OT** - Other

**Section F**

| Relinquish/Receive | Sign | Print | Date | Time |
|---|---|---|---|---|
| Relinquished By: | | Mike Medel | 5/13/25 | 6:15 |
| Received By: | | SETH BARRY | 5/13/25 | 6:15 |
| Relinquished By: | | SETH BARRY | 5/13/25 | 9:18 |
| Received By: | | | | |
| Relinquished By: | | | | |
| Received By Laboratory: | | Ashley Spiegelberg | 5/13/25 | 9:18 |

**Section G**
**Lab Use Only** Amb

| | |
|---|---|
| Temp: | |
| 4°C +/- 2°C: Yes No | N/A |
| Received on Ice: ___ Yes ___ No | |
| Number of Bottles Received: | |
| pH Checked: | |
| COC Seals Intact: ___ Yes ___ No ___ NA | |
| Field Blank Included: ___ Yes ___ No | |

Received Via ___ UPS ___ FedEX ___ Other ___ (Hand)

Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____