



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 13, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Washington Elem Lead Testing

Order No.: 25050760

Dear Andy Chasteen:

Neilson Research Corporation received 25 sample(s) on 5/15/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



**NEILSON
RESEARCH
CORPORATION**

*Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com*

Case Narrative

WO#: **25050760**
Date: **6/13/2025**

CLIENT: Medford School District
Project: Washington Elem Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-01 Client Sample ID: Rm 1-DF
 Collection Date: 5/15/2025 5:23:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 1-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.50		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-02 Client Sample ID: Rm 1-Sink
 Collection Date: 5/15/2025 5:24:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 1-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.54		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-03 Client Sample ID: Rm 2-Sink
 Collection Date: 5/15/2025 5:25:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 2-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.49		0.500	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-04 Client Sample ID: Rm 3-DF
 Collection Date: 5/15/2025 5:26:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 3-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.96		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-05 Client Sample ID: Rm 3-Sink
 Collection Date: 5/15/2025 5:27:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 3-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.84		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-06 Client Sample ID: Rm 5-DF
 Collection Date: 5/15/2025 5:28:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 5-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.839		0.500	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-07 Client Sample ID: Rm 5-Sink
 Collection Date: 5/15/2025 5:29:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 5-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.37		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-08 Client Sample ID: Rm 6-DF
 Collection Date: 5/15/2025 5:30:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 6-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.77		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-09 Client Sample ID: Rm 6-Sink
 Collection Date: 5/15/2025 5:31:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 6-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.27		0.500	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-10 Client Sample ID: Rm 7-DF
 Collection Date: 5/15/2025 5:32:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 7-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.02		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-11 Client Sample ID: Rm 7-Sink
 Collection Date: 5/15/2025 5:33:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 7-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.658		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-12 Client Sample ID: Rm 8-DF
 Collection Date: 5/15/2025 5:34:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 8-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.09		0.500	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-13 Client Sample ID: Rm 8-Sink
 Collection Date: 5/15/2025 5:35:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 8-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-14 Client Sample ID: Media Ctr Work Rm-Sink
 Collection Date: 5/15/2025 5:38:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Media Ctr Work Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-15 Client Sample ID: Media Ctr Staff Unisex RR-Sink
 Collection Date: 5/15/2025 5:39:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Media Ctr Staff Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.34		0.500	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-16 Client Sample ID: Rm 9-DF
 Collection Date: 5/15/2025 5:40:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-17 Client Sample ID: Rm 9-Sink
 Collection Date: 5/15/2025 5:41:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-18 Client Sample ID: Rm 9 Unisex RR-Sink (L)
 Collection Date: 5/15/2025 5:43:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9 Unisex RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	7.80		0.500	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-19 Client Sample ID: Rm 9 Unisex RR-Sink (R)
 Collection Date: 5/15/2025 5:45:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 9 Unisex RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050760-20 Client Sample ID: Boy's RR O/S Rm 9-Sink (L)
 Collection Date: 5/15/2025 5:47:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.59		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050760-21 Client Sample ID: Boy's RR O/S Rm 9-Sink (C)
 Collection Date: 5/15/2025 5:48:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Sink (C)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.42		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-22 Client Sample ID: Boy's RR O/S Rm 9-Sink (R)
 Collection Date: 5/15/2025 5:49:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.40		0.515	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-23 Client Sample ID: Rm 10-DF
 Collection Date: 5/15/2025 5:50:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 10-DF


Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/11/2025	15.0		

Lab ID: 25050760-24 Client Sample ID: Rm 10-Sink
 Collection Date: 5/15/2025 5:51:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 10-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050760
 Date Reported: 6/13/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050760
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/13/2025 10:44:01 AM

Sample Information:

Lab ID: 25050760-25 Client Sample ID: Rm 10 Unisex RR-Sink
 Collection Date: 5/15/2025 5:52:00 AM Collected By: Cody Fleming
 Matrix: Drinking Water Sample Location: Rm 10 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/11/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050760
 13-Jun-25

Client: Medford School District
Project: Washington Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31655	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207
Client ID: PBW	Batch ID: 31655	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986322
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31655	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207
Client ID: LCSW	Batch ID: 31655	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986323
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 105 0.520 100 0 105 85 115

Sample ID: MB-31631	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60207
Client ID: PBW	Batch ID: 31631	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986340
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual


Lead ND 0.500

Sample ID: LCS-31631	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60207
Client ID: LCSW	Batch ID: 31631	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986342
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 108 0.500 100 0 108 85 115

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit
 RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050760
 13-Jun-25

Client: Medford School District
Project: Washington Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050758-23AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60207						
Client ID: BatchQC	Batch ID: 31631	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986344						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 105 0.500 100 0.742 104 70 130

Sample ID: 25050758-23AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60207						
Client ID: BatchQC	Batch ID: 31631	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986345						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.500 100 0.742 102 70 130 105 2.03 20

Sample ID: 25050719-51AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207						
Client ID: BatchQC	Batch ID: 31655	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986356						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 106 0.520 100 0.769 105 70 130

Sample ID: 25050719-51AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207						
Client ID: BatchQC	Batch ID: 31655	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986357						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 106 0.520 100 0.769 105 70 130 106 0.485 20

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit
 RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 25050760 RcptNo: 1

Logged by:	Ashley Spiegelberg	5/15/2025 8:46:00 AM	<i>Am</i>
Completed By:	Coni Boyko	5/16/2025 2:33:59 PM	<i>Coni Boyko</i>
Reviewed By:	Ashley Spiegelberg	6/13/2025 10:39:49 AM	<i>Am</i>

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present NA
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No HNO3 pH<2
 No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
- (Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
- (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: MSD 549C		Project Name: Washington		Attention: Accounting		<input type="checkbox"/> Standard 10-14 Days <input type="checkbox"/> 5 Business Days (50% surcharge) <input type="checkbox"/> 3 Business Days (75% surcharge) <input type="checkbox"/> 24 - 48 hours (100% surcharge) <input type="checkbox"/> Other _____	
Address: 900 Kenyon Medford, OR 97501		Project Number:		Company Name: Medford School District		<input type="checkbox"/> Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Email: <u>andy.chasteen@medford.k12.or.us</u>		Report To: <u>andy.chasteen@medford.k12.or.us</u>		Address: 900 Kenyon Medford, OR 97501			
Phone: 541-840-4315 Fax:		Copy To: <u>seth.barry@medford.k12.or.us</u>		P.O. #			
Collected By (Print): <u>Cody Fleming</u>							
Collected By (Sign): <u>Cody Fleming</u>							
Email Report <input type="checkbox"/> Yes <input type="checkbox"/> No		Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No					
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No							

Section E Sample Information				No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050760</u>		
Sample ID	Matrix*	Date Collected	Time Collected		1	2	3	4	5	6	7	8	9	10	11	12	Remarks/Field Data
Room 1 - Drinking Fountain	DW	5/15/2025	5:23	1													01
Room 1 - Sink	DW	5/15/2025	5:24	1													02
Room 2 - Sink	DW	5/15/2025	5:25	1													03
Room 3 - Drinking Fountain	DW	5/15/2025	5:26	1													04
Room 3 - Sink	DW	5/15/2025	5:27	1													05
Room 5 - Drinking Fountain	DW	5/15/2025	5:28	1													06
Room 5 - Sink	DW	5/15/2025	5:29	1													07
Room 6 - Drinking Fountain	DW	5/15/2025	5:30	1													08
Room 6 - Sink	DW	5/15/2025	5:31	1													09
Room 7 - Drinking Fountain	DW	5/15/2025	5:32	1													10
Room 7 - Sink	DW	5/15/2025	5:33	1													11
Room 8 - Drinking Fountain	DW	5/15/2025	5:34	1													12
Room 8 - Sink	DW	5/15/2025	5:35	1													13
Media Center Work Room - Sink	DW	5/15/2025	5:38	1													14
Media Center Staff Only Unisex Restroom - Sink	DW	5/15/2025	5:39	1													15
Room 9 - Drinking Fountain	DW	5/15/2025	5:40	1													16
Room 9 - Sink	DW	5/15/2025	5:41	1													17
Room 9 Unisex Restroom (Left) - Sink	DW	5/15/2025	5:43	1													18
Room 9 Unisex Restroom (Right) - Sink	DW	5/15/2025	5:45	1													19
Boy's Restroom Outside Room 9 - Sink (Left)	DW	5/15/2025	5:47	1													20
Boy's Restroom Outside Room 9 - Sink (Center)	DW	5/15/2025	5:48	1													21
Boy's Restroom Outside Room 9 - Sink (Right)	DW	5/15/2025	5:49	1													22
Room 10 - Drinking Fountain	DW	5/15/2025	5:50	1													23

