



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 16, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Washington Elem Lead Testing

Order No.: 25050768

Dear Andy Chasteen:

Neilson Research Corporation received 25 sample(s) on 5/15/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



**NEILSON
RESEARCH
CORPORATION**

*Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com*

Case Narrative

WO#: 25050768
Date: 6/16/2025

CLIENT: Medford School District
Project: Washington Elem Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-01 Client Sample ID: Health Rm-Sink
 Collection Date: 5/15/2025 5:37:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Health Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.30		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-02 Client Sample ID: Health Rm Unisex RR-Sink
 Collection Date: 5/15/2025 5:38:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Health Rm Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-03 Client Sample ID: 1st Flr Boy's RR across Rm 3-Sink (L)
 Collection Date: 5/15/2025 5:40:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Boy's RR across Rm 3-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-04 Client Sample ID: 1st Flr Boy's RR across Rm 3-Sink (C)
 Collection Date: 5/15/2025 5:40:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Boy's RR across Rm 3-Sink (C)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.20		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-05 Client Sample ID: 1st Flr Boy's RR accross Rm 3-Sink (R)
 Collection Date: 5/15/2025 5:41:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Boy's RR accross Rm 3-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-06 Client Sample ID: 1st Flr O/S Boy's RR-DF (L)
 Collection Date: 5/15/2025 5:41:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr O/S Boy's RR-DF (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-07 Client Sample ID: 1st Flr O/S Boy's RR-DF (R)
 Collection Date: 5/15/2025 5:42:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr O/S Boy's RR-DF (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-08 Client Sample ID: 1st Flr Girl's RR across Ofc-Sink (L)
 Collection Date: 5/15/2025 5:47:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Girl's RR across Ofc-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.06		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-09 Client Sample ID: 1st Flr Girl's RR across Ofc-Sink (C)
 Collection Date: 5/15/2025 5:47:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Girl's RR across Ofc-Sink (C)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.57		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-10 Client Sample ID: 1st Flr Girl's RR across Ofc-Sink (R)
 Collection Date: 5/15/2025 5:47:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Girl's RR across Ofc-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-11 Client Sample ID: 1st Flr by Ofc/Trophy Case-Elkay BF(Up)
 Collection Date: 5/15/2025 5:48:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr by Ofc/Trophy Case-Elkay BF(Up)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-12 Client Sample ID: 1st Flr by Ofc/Trophy Case-Elkay BF(Low)
 Collection Date: 5/15/2025 5:48:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr by Ofc/Trophy Case-Elkay BF(Low)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-13 Client Sample ID: 1st Flr Staff Men's Unisex RR by Ofc- Sink L
 Collection Date: 5/15/2025 5:54:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Staff Men's Unisex RR by Ofc- Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-14 Client Sample ID: 1st Flr Staff Women's Unisex RR by Ofc-Sink
 Collection Date: 5/15/2025 5:54:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: 1st Flr Staff Women's Unisex RR by Ofc-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.25		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-15 Client Sample ID: Kitchen-Sink (Food Prep-S Wall)
 Collection Date: 5/15/2025 5:27:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Kitchen-Sink (Food Prep-S Wall)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-16 Client Sample ID: Kitchen-Sink (Hand/Eye Wash-S Wall)
 Collection Date: 5/15/2025 5:29:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Kitchen-Sink (Hand/Eye Wash-S Wall)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.621		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-17 Client Sample ID: Kitchen-Sink (Triple Sink-S Wall)
 Collection Date: 5/15/2025 5:29:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Kitchen-Sink (Triple Sink-S Wall)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-18 Client Sample ID: Kitchen-Sink (Pre Rinse/DW-Sprayer)
 Collection Date: 5/15/2025 5:30:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Kitchen-Sink (Pre Rinse/DW-Sprayer)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.17		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-19 Client Sample ID: Kitchen-Sink (Hand Wash/Serving Ln)
 Collection Date: 5/15/2025 5:31:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Kitchen-Sink (Hand Wash/Serving Ln)

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.851		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-20 Client Sample ID: Kitchen Unisex RR-Sink
 Collection Date: 5/15/2025 5:31:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Kitchen Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.754		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050768-21 Client Sample ID: Playground-DF (O/S Cafeteria)-Upper
 Collection Date: 5/15/2025 5:57:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: Playground-DF (O/S Cafeteria)-Upper

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-22 Client Sample ID: La Clinica-Exam Rm #1-DF
 Collection Date: 5/15/2025 6:04:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: La Clinica-Exam Rm #1-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050768-23 Client Sample ID: La Clinica-Exam Rm #1-Sink
 Collection Date: 5/15/2025 6:05:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: La Clinica-Exam Rm #1-Sink


Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.584		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050768-24 Client Sample ID: La Clinica-Exam Rm #2-DF
 Collection Date: 5/15/2025 6:05:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: La Clinica-Exam Rm #2-DF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.29		0.515	ppb	1	6/12/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050768
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050768
Received Date: 5/15/2025 8:46:00 AM
Reported Date: 6/16/2025 12:20:48 PM

Sample Information:

Lab ID: 25050768-25 Client Sample ID: La Clinica-Handwash by O/S RR-Sink
 Collection Date: 5/15/2025 6:06:00 AM Collected By: Mike Medel
 Matrix: Drinking Water Sample Location: La Clinica-Handwash by O/S RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/12/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050768
 16-Jun-25

Client: Medford School District
Project: Washington Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31681	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: PBW	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986833						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: LCS-31681	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: LCSW	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986834						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.520 100 0 103 85 115

Sample ID: 25050768-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Health Rm-Sink	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986836						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual


Lead 106 0.520 100 3.30 103 70 130

Sample ID: 25050768-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Health Rm-Sink	Batch ID: 31681	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986837						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 105 0.520 100 3.30 101 70 130 106 1.26 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050768
 16-Jun-25

Client: Medford School District
Project: Washington Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31685	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: PBW	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986861						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: LCS-31685	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: LCSW	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986862						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 102 0.520 100 0 102 85 115

Sample ID: 25050768-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Playground-DF (O/S)	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986864						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.520 100 0.453 102 70 130

Sample ID: 25050768-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Playground-DF (O/S)	Batch ID: 31685	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986865						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.520 100 0.453 102 70 130 103 0.0385 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist Work Order Number: 25050768 RcptNo: 1

Logged by:	Ashley Spiegelberg	5/15/2025 8:46:00 AM	
Completed By:	Dorie Evans	6/16/2025 10:40:29 AM	
Reviewed By:	Dorie Evans	6/16/2025 10:40:34 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present NA
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
- (Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
- (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: MSD 549C	Project Name: Washington	Attention: Accounting	<input type="checkbox"/> Standard 10-14 Days
Address: 900 Kenyon Medford, OR 97501	Project Number:	Company Name: Medford School District	<input type="checkbox"/> 5 Business Days (50% surcharge)
Email: andy.chasteen@medford.k12.or.us	Report andy.chasteen@medford.k12.or.us	Address: 900 Kenyon	<input type="checkbox"/> 3 Business Days (75% surcharge)
Phone: 541-840-4315 Fax:	Copy T seth.barry@medford.k12.or.us	Medford, OR 97501	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Collected By (Print): <i>Mike Medel</i>		P.O. #	<input type="checkbox"/> Other _____
Collected By (Sign): <i>[Signature]</i>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information				No. of Containers	Analysis Requested						NRC Workorder # <i>25050768</i> (Lab Use Only)	
Sample ID	Matrix *	Date Collected	Time Collected		Remarks/Field Data							NRC Sample # (Lab Use Only)
Health Room - Sink	DW	5/15/2025	5:37	1								01
Health Room Unisex Restroom - Sink	DW	5/15/2025	5:38	1								02
1st Floor Boy's Restroom Across From Room 3 - Sink (Left)	DW	5/15/2025	5:40	1								03
1st Floor Boy's Restroom Across From Room 3 - Sink (Center)	DW	5/15/2025	5:40	1								04
1st Floor Boy's Restroom Across From Room 3 - Sink (Right)	DW	5/15/2025	5:41	1								05
1st Floor Outside Boy's Restroom - Drinking Fountain (Left)	DW	5/15/2025	5:41	1								06
1st Floor Outside Boy's Restroom - Drinking Fountain (Right)	DW	5/15/2025	5:42	1								07
1st Floor Girl's Restroom Across From Office - Sink (Left)	DW	5/15/2025	5:47	1								08
1st Floor Girl's Restroom Across From Office - Sink (Center)	DW	5/15/2025	5:47	1								09
1st Floor Girl's Restroom Across From Office - Sink (Right)	DW	5/15/2025	5:47	1								10
1st Floor By Office/Trophy Case - Elkay Bottle Filler (Upper)	DW	5/15/2025	5:48	1								11
1st Floor By Office/Trophy Case - Elkay Bottle Filler (Lower)	DW	5/15/2025	5:48	1								12
1st Floor Staff Men's Restroom Near Office - Sink <i>unisex left</i>	DW	5/15/2025	5:54	1								13
1st Floor Staff Women's Restroom Near Office - Sink <i>unisex right</i>	DW	5/15/2025	5:54	1								14
Kitchen - Sink (Food Prep - South Wall)	DW	5/15/2025	5:27	1								15
Kitchen - Sink (Hand/Eye Wash - South Wall)	DW	5/15/2025	5:29	1								16
Kitchen - Sink (Triple Sink - South Wall)	DW	5/15/2025	5:29	1								17
Kitchen - Sink (Pre-rinse/Dishwasher - Sprayer Only)	DW	5/15/2025	5:30	1								18
Kitchen - Sink (Hand Wash/Serving Line)	DW	5/15/2025	5:31	1								19
Kitchen Unisex Restroom - Sink	DW	5/15/2025	5:31	1								20
Playground - Drinking Fountain (Outside Cafeteria) - Upper	DW	5/15/2025	N/A	1	557							21
Playground - Drinking Fountain (Outside Cafeteria) - Lower <i>out of service</i>	DW	5/15/2025	5:57	1								22
La Clinica - Exam Room # 1 - Drinking Fountain	DW	5/15/2025	6:04	1								22

