



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 16, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: Washington Lead Testing

Order No.: 25050924

Dear Andy Chasteen:

Neilson Research Corporation received 28 sample(s) on 5/20/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



**NEILSON
RESEARCH
CORPORATION**

*Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com*

Case Narrative

WO#: 25050924
Date: 6/16/2025

CLIENT: Medford School District
Project: Washington Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-02 Client Sample ID: 1st Flr Boy's RR across from Rm 3-Lft
 Collection Date: 5/20/2025 6:18:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Boy's RR across from Rm 3-Lft

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.71		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050924-03 Client Sample ID: 1st Flr Boy's RR across from Rm 3-Center
 Collection Date: 5/20/2025 6:18:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Boy's RR across from Rm 3-Center

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.25		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050924-04 Client Sample ID: 1st Flr Boy's RR across from Rm 3-Rt
 Collection Date: 5/20/2025 6:18:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Boy's RR across from Rm 3-Rt

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.44		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-05 Client Sample ID: 1st Flr Girl's RR across from Office-Lft
 Collection Date: 5/20/2025 6:19:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Girl's RR across from Office-Lft

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.938		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050924-06 Client Sample ID: 1st Flr Girl's RR across from Office-Center
 Collection Date: 5/20/2025 6:19:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Girl's RR across from Office-Center

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.45		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050924-07 Client Sample ID: 1st Flr Girl's RR across from Office-Rt
 Collection Date: 5/20/2025 6:19:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Girl's RR across from Office-Rt

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.737		0.515	ppb	1	6/12/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-08 Client Sample ID: 1st Flr Left Staff RR near Office
 Collection Date: 5/20/2025 6:24:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Left Staff RR near Office

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.522		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050924-09 Client Sample ID: 1st Flr Right Staff RR near Office
 Collection Date: 5/20/2025 6:24:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 1st Flr Right Staff RR near Office

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.596		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050924-10 Client Sample ID: Kitchen Uni RR
 Collection Date: 5/20/2025 6:25:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Kitchen Uni RR

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.57		0.515	ppb	1	6/12/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-11 Client Sample ID: La Clinica-Hand Wash near RR
 Collection Date: 5/20/2025 6:26:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: La Clinica-Hand Wash near RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.769		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050924-12 Client Sample ID: Media Center Staff Only Uni RR
 Collection Date: 5/20/2025 6:31:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Media Center Staff Only Uni RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.02		0.515	ppb	1	6/12/2025	15.0	

Lab ID: 25050924-13 Client Sample ID: Rm 9 Uni RR-Lft
 Collection Date: 5/20/2025 6:33:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 9 Uni RR-Lft

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.42		0.515	ppb	1	6/12/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-14 Client Sample ID: Rm 9 Uni RR-Rt
 Collection Date: 5/20/2025 6:33:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 9 Uni RR-Rt

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	9.22		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050924-15 Client Sample ID: Boy's RR O/S Rm 9-Lft
 Collection Date: 5/20/2025 6:34:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Lft

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.58		0.515	ppb	1	6/12/2025	15.0		

Lab ID: 25050924-16 Client Sample ID: Boy's RR O/S Rm 9-Center
 Collection Date: 5/20/2025 6:34:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Center

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.87		0.515	ppb	1	6/12/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-17 Client Sample ID: Boy's RR O/S Rm 9-Rt
 Collection Date: 5/20/2025 6:34:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Boy's RR O/S Rm 9-Rt

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.64		0.515	ppb	1	6/13/2025	15.0	

Lab ID: 25050924-18 Client Sample ID: Rm 10 Uni RR
 Collection Date: 5/20/2025 6:37:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 10 Uni RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/13/2025	15.0	

Lab ID: 25050924-19 Client Sample ID: Rm 11 Uni RR
 Collection Date: 5/20/2025 6:38:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Rm 11 Uni RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.585		0.515	ppb	1	6/13/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-20 Client Sample ID: 2nd Flr Boy's RR across from Rm 22-Lft
 Collection Date: 5/20/2025 6:45:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 2nd Flr Boy's RR across from Rm 22-Lft

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.26		0.515	ppb	1	6/13/2025	15.0		

Lab ID: 25050924-21 Client Sample ID: 2nd Flr Boy's RR across from Rm 22-Center
 Collection Date: 5/20/2025 6:45:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 2nd Flr Boy's RR across from Rm 22-Center

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/13/2025	15.0		

Lab ID: 25050924-22 Client Sample ID: 2nd Flr Boy's RR across from Rm 22-Rt
 Collection Date: 5/20/2025 6:45:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 2nd Flr Boy's RR across from Rm 22-Rt

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.10		0.515	ppb	1	6/13/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-23 Client Sample ID: 2nd Flr Girl's RR across from Rm 23-Lft
 Collection Date: 5/20/2025 6:43:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 2nd Flr Girl's RR across from Rm 23-Lft

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.62		0.515	ppb	1	6/13/2025	15.0		

Lab ID: 25050924-24 Client Sample ID: 2nd Flr Girl's RR across from Rm 23-Center
 Collection Date: 5/20/2025 6:43:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 2nd Flr Girl's RR across from Rm 23-Center

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.61		0.515	ppb	1	6/13/2025	15.0		

Lab ID: 25050924-25 Client Sample ID: 2nd Flr Girl's RR across from Rm 23-Rt
 Collection Date: 5/20/2025 6:43:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: 2nd Flr Girl's RR across from Rm 23-Rt

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.37		0.515	ppb	1	6/13/2025	15.0		

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 25050924
 Date Reported: 6/16/2025

Medford School District
 900 Kenyon St
 Medford, OR 97501

Lab Order: 25050924
Received Date: 5/20/2025 9:40:00 AM
Reported Date: 6/16/2025 12:11:58 PM

Sample Information:

Lab ID: 25050924-26 Client Sample ID: Girl's RR across from Rm 29-Lft
 Collection Date: 5/20/2025 6:39:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Girl's RR across from Rm 29-Lft

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.04		0.515	ppb	1	6/13/2025	15.0	

Lab ID: 25050924-27 Client Sample ID: Girl's RR across from Rm 29-Center
 Collection Date: 5/20/2025 6:39:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Girl's RR across from Rm 29-Center

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.33		0.515	ppb	1	6/13/2025	15.0	

Lab ID: 25050924-28 Client Sample ID: Girl's RR across from Rm 29-Rt
 Collection Date: 5/20/2025 6:39:00 AM Collected By: Seth Barry
 Matrix: Drinking Water Sample Location: Girl's RR across from Rm 29-Rt

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	13.8		0.515	ppb	1	6/13/2025	15.0	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050924
 16-Jun-25

Client: Medford School District
Project: Washington Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31686	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: PBW	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986889
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31686	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: LCSW	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986890
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 104 0.520 100 0 104 85 115

Sample ID: 25050920-17AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: BatchQC	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986892
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual


Lead 103 0.520 100 0.917 102 70 130

Sample ID: 25050920-17AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228
Client ID: BatchQC	Batch ID: 31686	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986893
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.520 100 0.917 101 70 130 103 1.35 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050924
 16-Jun-25

Client: Medford School District
Project: Washington Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31688	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: PBW	Batch ID: 31688	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986917						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31688	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: LCSW	Batch ID: 31688	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986918						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: 25050924-13AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Rm 9 Uni RR-Lft	Batch ID: 31688	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986920						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	106	0.520	100	4.42	102	70	130				

Sample ID: 25050924-13AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/12/2025	RunNo: 60228						
Client ID: Rm 9 Uni RR-Lft	Batch ID: 31688	TestNo: E200.8	E200.8	Analysis Date: 6/12/2025	SeqNo: 986921						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.520	100	4.42	101	70	130	106	0.833	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit



Original

Sample Log-In Check List

Client Name: **MedfordSchoolDist**

Work Order Number: **25050924**

RcptNo: **1**

Logged by:	Johanna Owen	5/20/2025 9:40:00 AM	
Completed By:	Coni Boyko	5/23/2025 11:44:49 AM	
Reviewed By:	Ashley Spiegelberg	6/16/2025 11:53:16 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
Custody seals intact on shipping container/cooler? Yes No Not Present NA
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		


18. Additional remarks:
Bottle was not received for sample -01A as noted on Chain of Custody.

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: MSD 549C	Project Name: Washington	Attention: Accounting	<input type="checkbox"/> Standard 10-14 Days
Address: 900 Kenyon	Project Number:	Company Name: Medford School District	<input type="checkbox"/> 5 Business Days (50% surcharge)
Medford, OR 97501	Report <u>andy.chasteen@medford.k12.or.us</u>	Address: 900 Kenyon	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>andy.chasteen@medford.k12.or.us</u>	Copy T <u>seth.barry@medford.k12.or.us</u>	Medford, OR 97501	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: 541-840-4315 Fax:		P.O. #	<input type="checkbox"/> Other _____
Collected By (Print): <u>SETH BARRY</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): 			
Email Report <input type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No		
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information

Sample ID	Matrix*	Date Collected	Time Collect	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Health Room Unisex Restroom - Sink	DW	<u>5/20</u>	<u>615</u>	1			
1st Floor Boy's Restroom Across From Room 3 - Sink (Left)	DW		<u>618</u>	1			01
1st Floor Boy's Restroom Across From Room 3 - Sink (Center)	DW		<u>618</u>	1			02
1st Floor Boy's Restroom Across From Room 3 - Sink (Right)	DW		<u>618</u>	1			03
1st Floor Girl's Restroom Across From Office - Sink (Left)	DW		<u>618</u>	1			04
1st Floor Girl's Restroom Across From Office - Sink (Center)	DW		<u>619</u>	1			05
1st Floor Girl's Restroom Across From Office - Sink (Right)	DW		<u>619</u>	1			06
1st Floor Left Staff Restroom Near Office - Sink	DW		<u>624</u>	1			07
1st Floor Right Staff Restroom Near Office - Sink	DW		<u>624</u>	1			08
Kitchen Unisex Restroom - Sink	DW		<u>625</u>	1			09
Playground Drinking Fountain (Outside Cafeteria) - Lower	DW			1			10
La Clinica - Hand Wash Near Restroom - Sink	DW		<u>626</u>	1			11
Media Center Staff Only Unisex Restroom - Sink	DW		<u>631</u>	1			12
Room 9 Unisex Restroom (Left) - Sink	DW		<u>633</u>	1			13
Room 9 Unisex Restroom (Right) - Sink	DW		<u>633</u>	1			14
Boy's Restroom Outside Room 9 - Sink (Left)	DW		<u>634</u>	1			15
Boy's Restroom Outside Room 9 - Sink (Center)	DW		<u>634</u>	1			16
Boy's Restroom Outside Room 9 - Sink (Right)	DW		<u>634</u>	1			17
Room 10 Unisex Restroom - Sink	DW		<u>637</u>	1			18
Room 11 Unisex Restroom - Sink	DW		<u>638</u>	1			19
2nd Floor Boy's Restroom Across From Room 22 - Sink (Left)	DW		<u>645</u>	1			20
2nd Floor Boy's Restroom Across From Room 22 - Sink (Center)	DW		<u>645</u>	1			21
2nd Floor Boy's Restroom Across From Room 22 - Sink (Right)	DW		<u>645</u>	1			22
2nd Floor Girl's Restroom Across From Room 23 - Sink (Left)	DW		<u>643</u>	1			23

