

Lead in School Drinking Water Report

Bellingham Family Partnership Program At Larrabee



Date(s) collected: 2023-11-03

Date(s) analyzed: 2023-12-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
386236	Main Building	Sink	Floor1 Rm1	Only sink	Tap	<1
386237	Main Building	Sink	Floor1 Rm4	Only sink	Tap	<1
386238	Main Building	Fountain	Floor1 Hallway	Right of rm4	Water Fountain	<1
386239	Main Building	Sink	Floor1 Office	Only sink	Tap	<1
386240	Main Building	Sink	Floor1 Rm3	Only sink	Tap	<1
386241	Main Building	Fountain	Floor1 Hallway	Left of rm3	Water Fountain	<1
386242	Main Building	Fountain	Basement Hallway	Right of girls restroom	Water Fountain	<1
386243	Main Building	Sink - Multi-Compartment	Basement Kitchen	Under windows 1	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
386244	Main Building	Sink - Multi-Compartment	Basement Kitchen	Under windows 2 of 2	Tap	<1
386245	Main Building	Sink - Multi-Compartment	Basement Kitchen	Right of entry	Tap	<1
386246	Main Building	Sink	Basement Family Lounge	Only sink	Tap	<1
386247	Gymnasium	Fountain	Across From Stage	1 of 2	Water Fountain	<1
386248	Gymnasium	Fountain	Across From Stage	2 of 2	Water Fountain	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**