

Lead in School Drinking Water Report

Wade King Elementary School



Date(s) collected: 2023-05-18

Date(s) analyzed: 2023-05-24

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374002	Main Building	Sink	Room 3	Only sink	Tap	19
374005	Main Building	Sink	Room 1	Only sink	Tap	6
373981	Main Building	Sink	Kitchen	Left of oven	Tap	4
373951	Main Building	Sink	Room 23	Only sink	Water Fountain	3
374004	Main Building	Sink	Room 3	Kitchen in room	Tap	3
373949	Main Building	Sink	Room 30	Only sink	Water Fountain	2
373985	Main Building	Sink	Room 2	Only sink	Water Fountain	2
373996	Main Building	Sink	Room 9	Only sink	Water Fountain	2
374008	Main Building	Sink	Mrs Hagin Room Chinese. Old	Only sink	Tap	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374009	Main Building	Sink	Computer Lab Old Computer Lab Chinese Mrs Hagin	Only sink	Water Fountain	2
374013	Main Building	Sink	Room 22	Only sink	Water Fountain	2
374019	Main Building	Sink	Room 27	Only sink	Water Fountain	2
373943	Main Building	Sink	Room 28	Only sink	Water Fountain	1
373947	Main Building	Sink	Room 31	Only sink	Water Fountain	1
373950	Main Building	Sink	Room 23	Only sink	Tap	1
373989	Main Building	Sink	Room 5	Only sink	Water Fountain	1
373991	Main Building	Sink	Room 7	Only sink	Water Fountain	1
374017	Main Building	Sink	Room 25	Only sink	Water Fountain	1
373940	Main Building	Sink	Room 26	Only sink	Tap	<1
373941	Main Building	Sink	Room 26	Only sink	Water Fountain	<1
373942	Main Building	Sink	Room 28	Only sink	Tap	<1
373944	Main Building	Sink	Room 29	Only sink	Tap	<1
373945	Main Building	Sink	Room 29	Only sink	Water Fountain	<1
373946	Main Building	Sink	Room 31	Only sink	Tap	<1
373948	Main Building	Sink	Room 30	Only sink	Tap	<1
373952	Main	Sink	Music Room	Only sink	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	Building					
373980	Main Building	Sink - Multi-Compartment	Kitchen	Left of dishwasher	Sprayer	<1
373982	Main Building	Fountain - Multi-Level	Main Entrance Foyer	Outside cafeteria entrance higher fountain	Water Fountain	<1
373983	Main Building	Fountain - Multi-Level	Main Entrance Foyer	Next to cafeteria entrance	Water Fountain	<1
373984	Main Building	Sink	Room 2	Only sink	Tap	<1
373986	Main Building	Sink	Room 4	Only sink	Tap	<1
373987	Main Building	Sink	Room 4	Only sink	Water Fountain	<1
373988	Main Building	Sink	Room 5	Only sink	Tap	<1
373990	Main Building	Sink	Room 7	Only sink	Tap	<1
373992	Main Building	Sink	Room 6	Only sink	Tap	<1
373993	Main Building	Sink	Room 8	Only sink	Tap	<1
373994	Main Building	Sink	Room 8	Only sink	Water Fountain	<1
373995	Main Building	Sink	Room 9	Only sink	Tap	<1
373997	Main Building	Sink	Room 11	Only sink	Tap	<1
373999	Main Building	Sink	Room 11	Only sink	Water Fountain	<1
374000	Main Building	Sink	Room 10	Only sink	Tap	<1
374001	Main Building	Sink	Room 10	Only sink	Water Fountain	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374003	Main Building	Sink	Room 3	Only sink	Water Fountain	<1
374006	Main Building	Fountain - Multi-Level	2nd Floor Fountains	Next to restrooms. Higher fountain	Water Fountain	<1
374007	Main Building	Fountain - Multi-Level	2nd Floor Fountains	Near restrooms	Water Fountain	<1
374010	Main Building	Sink	Room 21	Only sink	Tap	<1
374011	Main Building	Sink	Room 21	Only sink	Water Fountain	<1
374012	Main Building	Sink	Room 22	Only sink	Tap	<1
374014	Main Building	Sink	Room 24	Only sink	Tap	<1
374015	Main Building	Sink	Room 24	Only sink	Water Fountain	<1
374016	Main Building	Sink	Room 25	Only sink	Tap	<1
374018	Main Building	Sink	Room 27	Only sink	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**