



1 North Bacton Hill Road  
Suite 208  
Malvern, PA 19355  
Phone 610•696•8980  
[www.envirosureinc.com](http://www.envirosureinc.com)

August 20, 2025

*Project No. SO3983*

Ms. Ruth Gonzalez  
Boys' Latin of Philadelphia Charter School  
5501 Cedar Avenue  
Philadelphia, Pennsylvania 19143

**RE: Potable Water Lead Sampling Summary Letter**  
5501 Cedar Avenue and 344 North Felton Street  
City of Philadelphia, Philadelphia County, Pennsylvania

Dear Ms. Gonzalez,

EnviroSure, Inc. (EnviroSure) has prepared this summary letter to document potable water sampling efforts conducted at the Boys' Latin of Philadelphia Charter School buildings located at 5501 Cedar Avenue and 344 North Felton Street in the City of Philadelphia. The sampling efforts were conducted to gain an understanding of environmental considerations for planning and management purposes, as well as compliance with the City of Philadelphia Water Quality Requirements for Schools and Day Care Facilities. A summary of the sampling efforts and analytical results follows.

EnviroSure conducted the potable water sampling efforts on August 11, 2025. EnviroSure collected 32 potable water samples from within the educational facilities on both the 5501 Cedar Avenue and 344 North Felton Street locations. It should be noted that taps within the gymnasium located at the 344 North Felton Street facility were not sampled as the building is brand new construction circa 2024, with all piping reported to be comprised of PVC. A total of fourteen (14) water samples were collected from sinks and fountains within the 5501 Cedar Avenue facility, and eighteen (18) water samples were collected from sinks and fountains within the 344 North Felton Street facility.

The samples were collected prior to building opening and represent the first draw of water from each sampling location at the start of each day. Water samples were collected directly from the sinks and fountains into laboratory-supplied, preserved bottleware. The sampler performed the sampling efforts using single-use nitrile gloves

for each sampling point to minimize potential cross-contamination. EnviroSure labeled the samples in the field, chilled the samples in a cooler with ice to approximately four degrees centigrade, and transported the samples via courier under chain of custody protocol to Eurofins/Lancaster Laboratories, Inc. (PA ID #36-0007) in Lancaster, Pennsylvania. The samples were submitted for potable drinking water lead analysis via USEPA Method 200.8.

Lead concentrations were detected below the Pennsylvania Department of Environmental Protection (PADEP) Drinking Water Maximum Contaminant Level of 5 micrograms per Liter ( $\mu\text{g/L}$ ) from all 32 sample locations. The potable water sampling analytical results are summarized in **Table 1**, attached, along with the laboratory analytical data packages.

Based on the analytical results for the building water sampling, EnviroSure does not recommend additional efforts for the potable water sinks or fountains in either building.

Sincerely,  
**ENVIROSURE, INC.**

A handwritten signature in cursive script that reads "Justin Garcia". The signature is written in black ink and includes a small mark at the end of the last name.

Justin Garcia  
*Project Manager*

Attachments:

## TABLE

**Table 1**  
**Potable Water Sample Analytical Results - Lead**  
**5501 Cedar Avenue & 344 North Felton Street**  
**City of Philadelphia, Philadelphia County, Pennsylvania**

<b>Sample ID</b>	<b>Address</b>	<b>Sample Date</b>	<b>PADEP Drinking Water Maximum Contaminant Level (ug/L)</b>	<b>Lead Concentration (ug/L)</b>
High School-3rd Floor Bathroom Sink	5501 Cedar Avenue	8/11/2025	5	0.42 J
High School-3rd Floor Lab Faucet		8/11/2025	5	1.1 J
High School-2nd Floor Staff Bathroom Sink		8/11/2025	5	0.38 J
High School-2nd Floor Bathroom Sink Center		8/11/2025	5	0.33 J
High School-2nd Floor Art Room Sink		8/11/2025	5	4.1
High School-1st Floor Nurse's Sink		8/11/2025	5	2.9
High School-1st Floor Staff Bathroom Sink		8/11/2025	5	0.27 J
High School-Mezzanine Mens Room Sink North		8/11/2025	5	0.28 J
High School-Mezzanine Womens Room Sink South		8/11/2025	5	0.47 J
High School-Ground Floor Fountain East		8/11/2025	5	2.0 U
High School-Ground Floor Fountain West		8/11/2025	5	2.0 U
High School-Ground Floor Hand Wash Sink		8/11/2025	5	1.4 J
High School-Ground Floor Dish Wash Sink		8/11/2025	5	1.5 J
High School-Ground Floor Teacher Lounge Faucet		8/11/2025	5	1.1 J
Main-1st Floor North Bathroom Sink	344 North Felton Street	8/11/2025	5	2.0 U
Main-1st Floor South Bathroom Sink		8/11/2025	5	0.50 J
Main-Cafeteria Dishwashing Sink		8/11/2025	5	0.69 J
Main-2nd Floor North Bathroom Sink		8/11/2025	5	0.62 J
Main-2nd Floor Single Bathroom Sink		8/11/2025	5	1.4 J
Main-2nd Floor Hallway Faucet		8/11/2025	5	1.2 J
Main-2nd Floor Hallway Fountain		8/11/2025	5	2.0 U
Main-3rd Floor Hallway Fountain		8/11/2025	5	2.0 U
Main-3rd Floor Bathroom Sink		8/11/2025	5	2.2
Main-Cafeteria Sink Left		8/11/2025	5	2.1
Steam-1st Floor Bathroom Sink East		8/11/2025	5	2.0 U
Steam-1st Floor Bathroom Sink West		8/11/2025	5	2.0 U
Steam-1st Floor Fountain North		8/11/2025	5	2.0 U
Steam-1st Floor Fountain South		8/11/2025	5	2.0 U
Steam-1st Floor Fountain East		8/11/2025	5	2.0 U
Steam-2nd Floor Fountain West		8/11/2025	5	2.0 U
Steam-2nd Floor Bathroom Sink		8/11/2025	5	0.53 J
Steam-3rd Floor Bathroom Sink		8/11/2025	5	0.33 J

**Notes:**

ug/L = micrograms per liter

J : Sample result is greater than the Method Detection Limit but below the Contract Required Detection Limit

U : Indicates analyzed for but not detected.

## LABORATORY ANALYTICAL DATA PACKAGES

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Justin Garcia  
EnviroSure Inc  
1 North Bacton Hill Road  
Suite 208  
Malvern, Pennsylvania 19355

Generated 8/19/2025 9:03:15 PM

## JOB DESCRIPTION

Boys Latin High School

## JOB NUMBER

460-332555-1

# Eurofins Edison

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Northeast, LLC Project Manager.

## Authorization



Generated  
8/19/2025 9:03:15 PM

Authorized for release by  
Julie Gilmore, Project Manager I  
[Julie.Gilmore@et.eurofinsus.com](mailto:Julie.Gilmore@et.eurofinsus.com)  
(484)685-0865



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Client Sample Results . . . . .	6
Lab Chronicle . . . . .	8
Certification Summary . . . . .	11
Method Summary . . . . .	12
Sample Summary . . . . .	13
Chain of Custody . . . . .	14
Receipt Checklists . . . . .	17

# Definitions/Glossary

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

## Qualifiers

### Metals

Qualifier	Qualifier Description
J	Sample result is greater than the MDL but below the CRDL
U	Indicates analyzed for but not detected.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: EnviroSure Inc  
Project: Boys Latin High School

Job ID: 460-332555-1

**Job ID: 460-332555-1**

**Eurofins Edison**

## Job Narrative 460-332555-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 8/11/2025 7:00 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.1°C.

### Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Edison

# Client Sample Results

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

## Client Sample ID: High School-3rd Floor Bathroom Sink

Lab Sample ID: 460-332555-1

Date Collected: 08/11/25 08:15

Matrix: Water

Date Received: 08/11/25 19:00

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.42	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 16:59	1

## Client Sample ID: High School-3rd Floor Lab Faucet

Lab Sample ID: 460-332555-2

Date Collected: 08/11/25 08:20

Matrix: Water

Date Received: 08/11/25 19:00

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:02	1

## Client Sample ID: High School-2nd Floor Staff Bathroom Sink

Lab Sample ID: 460-332555-3

Date Collected: 08/11/25 08:25

Matrix: Water

Date Received: 08/11/25 19:00

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.38	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:04	1

## Client Sample ID: High School-2nd Floor Bathroom Sink

Lab Sample ID: 460-332555-4

Center

Date Collected: 08/11/25 08:30

Matrix: Water

Date Received: 08/11/25 19:00

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.33	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:05	1

## Client Sample ID: High School-2nd Floor Art Room Sink

Lab Sample ID: 460-332555-5

Date Collected: 08/11/25 08:35

Matrix: Water

Date Received: 08/11/25 19:00

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.1		2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:07	1

## Client Sample ID: High School-1st Floor Nurse's Sink

Lab Sample ID: 460-332555-6

Date Collected: 08/11/25 08:40

Matrix: Water

Date Received: 08/11/25 19:00

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.9		2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:12	1

## Client Sample ID: High School-1st Floor Staff Bathroom Sink

Lab Sample ID: 460-332555-7

Date Collected: 08/11/25 08:45

Matrix: Water

Date Received: 08/11/25 19:00

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.27	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:13	1

Eurofins Edison

# Client Sample Results

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

## Client Sample ID: High School-Mezzanine Mens Room Sink North

Lab Sample ID: 460-332555-8

Date Collected: 08/11/25 08:50  
Date Received: 08/11/25 19:00

Matrix: Water

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.28	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:15	1

## Client Sample ID: High School-Mezzanine Womens Room Sink South

Lab Sample ID: 460-332555-9

Date Collected: 08/11/25 08:55  
Date Received: 08/11/25 19:00

Matrix: Water

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.47	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:17	1

## Client Sample ID: High School-Ground Floor Fountain East

Lab Sample ID: 460-332555-10

Date Collected: 08/11/25 09:00  
Date Received: 08/11/25 19:00

Matrix: Water

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:18	1

## Client Sample ID: High School-Ground Floor Fountain West

Lab Sample ID: 460-332555-11

Date Collected: 08/11/25 09:05  
Date Received: 08/11/25 19:00

Matrix: Water

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:20	1

## Client Sample ID: High School-Ground Floor Hand Wash Sink

Lab Sample ID: 460-332555-12

Date Collected: 08/11/25 09:10  
Date Received: 08/11/25 19:00

Matrix: Water

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:22	1

## Client Sample ID: High School-Ground Floor Dish Wash Sink

Lab Sample ID: 460-332555-13

Date Collected: 08/11/25 09:15  
Date Received: 08/11/25 19:00

Matrix: Water

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.25	ug/L		08/19/25 10:01	08/19/25 17:23	1

## Client Sample ID: High School-Ground Floor Teacher Lounge Faucet

Lab Sample ID: 460-332555-14

Date Collected: 08/11/25 09:20  
Date Received: 08/11/25 19:00

Matrix: Water

### Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.25	ug/L		08/19/25 08:51	08/19/25 19:41	1

Eurofins Edison

# Lab Chronicle

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

## Client Sample ID: High School-3rd Floor Bathroom Sink

Lab Sample ID: 460-332555-1

Date Collected: 08/11/25 08:15

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:59

## Client Sample ID: High School-3rd Floor Lab Faucet

Lab Sample ID: 460-332555-2

Date Collected: 08/11/25 08:20

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:02

## Client Sample ID: High School-2nd Floor Staff Bathroom Sink

Lab Sample ID: 460-332555-3

Date Collected: 08/11/25 08:25

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:04

## Client Sample ID: High School-2nd Floor Bathroom Sink Center

Lab Sample ID: 460-332555-4

Date Collected: 08/11/25 08:30

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:05

## Client Sample ID: High School-2nd Floor Art Room Sink

Lab Sample ID: 460-332555-5

Date Collected: 08/11/25 08:35

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:07

## Client Sample ID: High School-1st Floor Nurse's Sink

Lab Sample ID: 460-332555-6

Date Collected: 08/11/25 08:40

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:12

# Lab Chronicle

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

## Client Sample ID: High School-1st Floor Staff Bathroom Sink

Lab Sample ID: 460-332555-7

Date Collected: 08/11/25 08:45

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:13

## Client Sample ID: High School-Mezzanine Mens Room Sink North

Lab Sample ID: 460-332555-8

Date Collected: 08/11/25 08:50

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:15

## Client Sample ID: High School-Mezzanine Womens Room Sink South

Lab Sample ID: 460-332555-9

Date Collected: 08/11/25 08:55

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:17

## Client Sample ID: High School-Ground Floor Fountain East

Lab Sample ID: 460-332555-10

Date Collected: 08/11/25 09:00

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:18

## Client Sample ID: High School-Ground Floor Fountain West

Lab Sample ID: 460-332555-11

Date Collected: 08/11/25 09:05

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:20

## Client Sample ID: High School-Ground Floor Hand Wash Sink

Lab Sample ID: 460-332555-12

Date Collected: 08/11/25 09:10

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:22

# Lab Chronicle

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

## Client Sample ID: High School-Ground Floor Dish Wash Sink

Lab Sample ID: 460-332555-13

Date Collected: 08/11/25 09:15

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056376	CDC	EET EDI	08/19/25 10:01
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:23

## Client Sample ID: High School-Ground Floor Teacher Lounge

Lab Sample ID: 460-332555-14

### Faucet

Date Collected: 08/11/25 09:20

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056357	TAP	EET EDI	08/19/25 08:51
Total/NA	Analysis	200.8		1	1056500	DLE	EET EDI	08/19/25 19:41

#### Laboratory References:

EET EDI = Eurofins Edison, 777 New Durham Road, Edison, NJ 08817, TEL (732)549-3900

# Accreditation/Certification Summary

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

## Laboratory: Eurofins Edison

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Pennsylvania	NELAP	68-00522	02-28-26

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11

# Method Summary

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EET EDI
200	Preparation, Metals	EPA	EET EDI

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EET EDI = Eurofins Edison, 777 New Durham Road, Edison, NJ 08817, TEL (732)549-3900



# Sample Summary

Client: EnviroSure Inc  
Project/Site: Boys Latin High School

Job ID: 460-332555-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
460-332555-1	High School-3rd Floor Bathroom Sink	Water	08/11/25 08:15	08/11/25 19:00	Pennsylvania
460-332555-2	High School-3rd Floor Lab Faucet	Water	08/11/25 08:20	08/11/25 19:00	Pennsylvania
460-332555-3	High School-2nd Floor Staff Bathroom Sink	Water	08/11/25 08:25	08/11/25 19:00	Pennsylvania
460-332555-4	High School-2nd Floor Bathroom Sink Center	Water	08/11/25 08:30	08/11/25 19:00	Pennsylvania
460-332555-5	High School-2nd Floor Art Room Sink	Water	08/11/25 08:35	08/11/25 19:00	Pennsylvania
460-332555-6	High School-1st Floor Nurse's Sink	Water	08/11/25 08:40	08/11/25 19:00	Pennsylvania
460-332555-7	High School-1st Floor Staff Bathroom Sink	Water	08/11/25 08:45	08/11/25 19:00	Pennsylvania
460-332555-8	High School-Mezzanine Mens Room Sink North	Water	08/11/25 08:50	08/11/25 19:00	Pennsylvania
460-332555-9	High School-Mezzanine Womens Room Sink South	Water	08/11/25 08:55	08/11/25 19:00	Pennsylvania
460-332555-10	High School-Ground Floor Fountain East	Water	08/11/25 09:00	08/11/25 19:00	Pennsylvania
460-332555-11	High School-Ground Floor Fountain West	Water	08/11/25 09:05	08/11/25 19:00	Pennsylvania
460-332555-12	High School-Ground Floor Hand Wash Sink	Water	08/11/25 09:10	08/11/25 19:00	Pennsylvania
460-332555-13	High School-Ground Floor Dish Wash Sink	Water	08/11/25 09:15	08/11/25 19:00	Pennsylvania
460-332555-14	High School-Ground Floor Teacher Lounge Faucet	Water	08/11/25 09:20	08/11/25 19:00	Pennsylvania



Regulatory Program:  DW  NPDES  RCRA  Other

Project Manager: Justin Garcia  
Tel: 610 696 8480  
Email: jgarc@eurofins.com

Client Contact: Enviro Sure, Inc.  
Address: 1 N. Bacter Hill Road, Suite 208  
City/State/Zip: Malvern, PA 19355  
Phone: (610) 696-8480  
Fax: \_\_\_\_\_

Project Name: Boys Latin High School  
Site: S03983  
PO #: S03983

Date: 8/11/25  
COC No: 7 of 2 COCs  
Carrier: Nan - Spg

Site Contact: Justin Garcia  
Lab Contact: Nan - Spg

Analysis Turnaround Time:  CALENDAR DAYS  WORKING DAYS  
TAT if different from Below: \_\_\_\_\_  
 2 weeks  
 1 week  
 2 days  
 1 day

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=Grab)	Matrix	# of Cont.	Filtered Sample (Y/N)	Perform MS/MSD (Y/N)	Sample Specific Notes:
High School - 3rd Floor Bathroom Sink	8/11/25	8:15	G	BW	1	X	X	1
High School - 3rd Floor Lab Faucet		8:20			1	X	X	2
High School - 2nd Floor Staff Bathroom Sink		8:25			1	X	X	3
High School - 2nd Floor Bathroom Sink Center		8:30			1	X	X	4
High School - 2nd Floor Art Room Sink		8:35			1	X	X	5
High School - 1st Floor Nurse's Sink		8:40			1	X	X	6
High School - 1st Floor Staff Bathroom Sink		8:45			1	X	X	7
High School - Mezzanine Mens Room Sink North		8:50			1	X	X	8
High School - Mezzanine Womens Room Sink South		8:55			1	X	X	9
High School - Ground Floor Fountain East		9:00			1	X	X	10
High School - Ground Floor Fountain West		9:05			1	X	X	11
High School - Ground Floor Hand Wash Sink		9:10			1	X	X	12

Preservation Used: 1=Ice, 2=HCl, 3=H2SO4, 4=HNO3, 5=NaOH, 6=Other

Possible Hazard Identification: \_\_\_\_\_  
 Are any samples from a listed EPA Hazardous Waste? Please List any EPA Waste Codes for the sample in the Comments Section if the lab is to dispose of the sample.  
 Non-Hazard  Flammable  Skin Irritant  Poison B  Unknown

Special Instructions: QC Requirements & Comments \* BW = drinking/potable water

Custody Seal No: \_\_\_\_\_  
 Relinquished by: Justin Garcia  
 Relinquished by: \_\_\_\_\_

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)  
 Return to Client  Disposal by Lab  Archive for \_\_\_\_\_ Months

Received by: Justin Garcia  
 Received by: \_\_\_\_\_  
 Received in Laboratory by: \_\_\_\_\_

Company: Enviro Sure, Inc.  
 Company: Enviro Sure, Inc.  
 Company: Enviro Sure, Inc.

Date/Time: 8/12/25 10:50  
 Date/Time: 8/11  
 Date/Time: 8/11 1900



Address: 5501 Cedar Avenue  
Philadelphia, PA 19143

TAL-8210

Regulatory Program  DW  NPDES  RCRA  Other

Project Manager: Justin Garcia

Site Contact: Lab Contact: Nan - S20

Date: 8/11/25

COC No: 2 of 2 COCS

Company Name: Enviro Sure, Inc.

Address: 1 N. Baxton Hill Road, Suite 208

City/State/Zip: Malvern, PA 19353

Phone: (610) 696-8980

Project Name: Boys Latin High School

Site: S03983

P.O #: S03983

Analysis Turnaround Time:  CALENDAR DAYS  WORKING DAYS

TAT if different from Below:  2 weeks  1 week  2 days  1 day

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=Grab)	Matrix	# of Cont.	Filtered Sample (Y/N)	Perform MS/MSD (Y/N)	Sample Specific Notes:
High School - Ground Floor Dish Wash Sink	8/11/25	9:15	G	DW	1	MMX		13
High School - Ground Floor Teacher Lounge Faucet	↓	9:20	↓	↓	↓	↓		14

Preservation Used: 1=Ice, 2=HCl, 3=H2SO4, 4=HNO3, 5=NaOH, 6=Other

Possible Hazard Identification: 1, 4

Are any samples from a listed EPA Hazardous Waste? Please List any EPA Waste Codes for the sample in the Comments Section if the lab is to dispose of the sample.

Non-Hazard  Flammable  Skin Irritant  Poison B  Unknown

Special Instructions/QC Requirements & Comments: \* DW = drinking / potable water

Cooler Temp (°C): Obs'd: 6.3 Cor'd: 6.6 Therm ID No.: 10

Disposition:  Return to Client  Dispose by Lab  Archive for \_\_\_\_\_ Months

Custody Seal No: \_\_\_\_\_

Relinquished by: Jami Bannell

Relinquished by: H/D

Relinquished by: H/D

Company: Enviro Sure, Inc.

Company: Enviro Sure, Inc.

Company: Enviro Sure, Inc.

Date/Time: 8/11/25 10:50

Date/Time: 8/11/25 10:50

Date/Time: 8/11/25 19:00



TestAmerica Edison  
Receipt Temperature and pH Log

Job Number: 339 SSS  
 Number of Coolers: 1 IR Gun # 10

Cooler Temperatures

	RAW	CORRECTED
Cooler #1	43 °C	41 °C
Cooler #2	°C	°C
Cooler #3	°C	°C
Cooler #4	°C	°C
Cooler #5	°C	°C
Cooler #6	°C	°C
Cooler #7	°C	°C
Cooler #8	°C	°C
Cooler #9	°C	°C


TALS Sample Number	Ammonia (pH<2)	Nitrate Nitrite (pH<2)	Metals (pH<2)	Hardness (pH<2)	Pest (pH 5-9)	EPH or QAM (pH<2)	Phenols (pH<2)	Sulfide (pH>9)	TKN (pH<2)	TOC (pH<2)	Total Cyanide (pH>12)	Total Phos (pH<2)	Other	Other
12			<2											
34			<2											
86			<2											
76			<2											
910			<2											
1117			<2											
1314			<2											

If pH adjustments are required record the information below

Sample No(s), adjusted: \_\_\_\_\_  
 Preservative Name/Conc.: \_\_\_\_\_ Volume of Preservative used (ml): \_\_\_\_\_

Lot # of Preservative(s): \_\_\_\_\_ Expiration Date: \_\_\_\_\_  
 The appropriate Project Manager and Department Manager should be notified about the samples which were pH adjusted.  
 \* Samples for Metal analysis which are out of compliance must be acidified at least 24 hours prior to analysis.

Initials: HS Date: 8/11



## Login Sample Receipt Checklist

Client: EnviroSure Inc

Job Number: 460-332555-1

**Login Number: 332555**

**List Source: Eurofins Edison**

**List Number: 1**

**Creator: Thundathorn, Sukanan 1**

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	



# ANALYTICAL REPORT

## PREPARED FOR

Attn: Justin Garcia  
EnviroSure Inc  
1 North Bacton Hill Road  
Suite 208  
Malvern, Pennsylvania 19355

Generated 8/19/2025 9:02:44 PM

## JOB DESCRIPTION

Boys Latin Middle School

## JOB NUMBER

460-332554-1

# Eurofins Edison

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Northeast, LLC Project Manager.

## Authorization



Generated  
8/19/2025 9:02:44 PM

Authorized for release by  
Julie Gilmore, Project Manager I  
[Julie.Gilmore@et.eurofinsus.com](mailto:Julie.Gilmore@et.eurofinsus.com)  
(484)685-0865



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Client Sample Results . . . . .	6
Lab Chronicle . . . . .	9
Certification Summary . . . . .	12
Method Summary . . . . .	13
Sample Summary . . . . .	14
Chain of Custody . . . . .	15
Receipt Checklists . . . . .	18

# Definitions/Glossary

Client: EnviroSure Inc  
Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

## Qualifiers

### Metals

Qualifier	Qualifier Description
J	Sample result is greater than the MDL but below the CRDL
U	Indicates analyzed for but not detected.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: EnviroSure Inc  
Project: Boys Latin Middle School

Job ID: 460-332554-1

**Job ID: 460-332554-1**

**Eurofins Edison**

## Job Narrative 460-332554-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 8/11/2025 7:00 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.1°C.

### Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Edison

# Client Sample Results

Client: EnviroSure Inc  
 Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

**Client Sample ID: Main-1st Floor North Bathroom Sink**

**Lab Sample ID: 460-332554-1**

Date Collected: 08/11/25 06:40

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:19	1

**Client Sample ID: Main-1st Floor South Bathroom Sink**

**Lab Sample ID: 460-332554-2**

Date Collected: 08/11/25 07:20

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.50	J	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:22	1

**Client Sample ID: Main-Cafeteria Dishwashing Sink**

**Lab Sample ID: 460-332554-3**

Date Collected: 08/11/25 06:45

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.69	J	2.0	0.25	ug/L		08/19/25 08:51	08/19/25 19:37	1

**Client Sample ID: Main-2nd Floor North Bathroom Sink**

**Lab Sample ID: 460-332554-4**

Date Collected: 08/11/25 06:50

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.62	J	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:24	1

**Client Sample ID: Main-2nd Floor Single Bathroom Sink**

**Lab Sample ID: 460-332554-5**

Date Collected: 08/11/25 06:55

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4	J	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:26	1

**Client Sample ID: Main-2nd Floor Hallway Faucet**

**Lab Sample ID: 460-332554-6**

Date Collected: 08/11/25 07:00

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2	J	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:27	1

**Client Sample ID: Main-2nd Floor Hallway Fountain**

**Lab Sample ID: 460-332554-7**

Date Collected: 08/11/25 07:05

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:32	1

# Client Sample Results

Client: EnviroSure Inc  
 Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

**Client Sample ID: Main-3rd Floor Hallway Fountain**

**Lab Sample ID: 460-332554-8**

Date Collected: 08/11/25 07:10

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:34	1

**Client Sample ID: Main-3rd Floor Bathroom Sink**

**Lab Sample ID: 460-332554-9**

Date Collected: 08/11/25 07:15

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:36	1

**Client Sample ID: Main-Cafeteria Sink Left**

**Lab Sample ID: 460-332554-10**

Date Collected: 08/11/25 07:25

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:37	1

**Client Sample ID: Steam-1st Floor Bathroom Sink East**

**Lab Sample ID: 460-332554-11**

Date Collected: 08/11/25 07:30

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:39	1

**Client Sample ID: Steam-1st Floor Bathroom Sink West**

**Lab Sample ID: 460-332554-12**

Date Collected: 08/11/25 07:35

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:41	1

**Client Sample ID: Steam-1st Floor Fountain North**

**Lab Sample ID: 460-332554-13**

Date Collected: 08/11/25 07:40

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:42	1

**Client Sample ID: Steam-1st Floor Fountain South**

**Lab Sample ID: 460-332554-14**

Date Collected: 08/11/25 07:40

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:44	1

# Client Sample Results

Client: EnviroSure Inc  
 Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

**Client Sample ID: Steam-1st Floor Fountain East**

**Lab Sample ID: 460-332554-15**

Date Collected: 08/11/25 07:45

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:46	1

**Client Sample ID: Steam-2nd Floor Fountain West**

**Lab Sample ID: 460-332554-16**

Date Collected: 08/11/25 07:45

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0	U	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 16:47	1

**Client Sample ID: Steam-2nd Floor Bathroom Sink**

**Lab Sample ID: 460-332554-17**

Date Collected: 08/11/25 07:50

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53	J	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 17:32	1

**Client Sample ID: Steam-3rd Floor Bathroom Sink**

**Lab Sample ID: 460-332554-18**

Date Collected: 08/11/25 07:55

Matrix: Water

Date Received: 08/11/25 19:00

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.33	J	2.0	0.25	ug/L		08/19/25 09:53	08/19/25 17:33	1

# Lab Chronicle

Client: EnviroSure Inc  
Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

## Client Sample ID: Main-1st Floor North Bathroom Sink

Lab Sample ID: 460-332554-1

Date Collected: 08/11/25 06:40

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:19

## Client Sample ID: Main-1st Floor South Bathroom Sink

Lab Sample ID: 460-332554-2

Date Collected: 08/11/25 07:20

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:22

## Client Sample ID: Main-Cafeteria Dishwashing Sink

Lab Sample ID: 460-332554-3

Date Collected: 08/11/25 06:45

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056357	TAP	EET EDI	08/19/25 08:51
Total/NA	Analysis	200.8		1	1056500	DLE	EET EDI	08/19/25 19:37

## Client Sample ID: Main-2nd Floor North Bathroom Sink

Lab Sample ID: 460-332554-4

Date Collected: 08/11/25 06:50

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:24

## Client Sample ID: Main-2nd Floor Single Bathroom Sink

Lab Sample ID: 460-332554-5

Date Collected: 08/11/25 06:55

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:26

## Client Sample ID: Main-2nd Floor Hallway Faucet

Lab Sample ID: 460-332554-6

Date Collected: 08/11/25 07:00

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:27

# Lab Chronicle

Client: EnviroSure Inc  
 Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

## Client Sample ID: Main-2nd Floor Hallway Fountain

Lab Sample ID: 460-332554-7

Date Collected: 08/11/25 07:05

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:32

## Client Sample ID: Main-3rd Floor Hallway Fountain

Lab Sample ID: 460-332554-8

Date Collected: 08/11/25 07:10

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:34

## Client Sample ID: Main-3rd Floor Bathroom Sink

Lab Sample ID: 460-332554-9

Date Collected: 08/11/25 07:15

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:36

## Client Sample ID: Main-Cafeteria Sink Left

Lab Sample ID: 460-332554-10

Date Collected: 08/11/25 07:25

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:37

## Client Sample ID: Steam-1st Floor Bathroom Sink East

Lab Sample ID: 460-332554-11

Date Collected: 08/11/25 07:30

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:39

## Client Sample ID: Steam-1st Floor Bathroom Sink West

Lab Sample ID: 460-332554-12

Date Collected: 08/11/25 07:35

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:41

# Lab Chronicle

Client: EnviroSure Inc  
 Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

**Client Sample ID: Steam-1st Floor Fountain North**

**Lab Sample ID: 460-332554-13**

Date Collected: 08/11/25 07:40

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:42

**Client Sample ID: Steam-1st Floor Fountain South**

**Lab Sample ID: 460-332554-14**

Date Collected: 08/11/25 07:40

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:44

**Client Sample ID: Steam-1st Floor Fountain East**

**Lab Sample ID: 460-332554-15**

Date Collected: 08/11/25 07:45

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:46

**Client Sample ID: Steam-2nd Floor Fountain West**

**Lab Sample ID: 460-332554-16**

Date Collected: 08/11/25 07:45

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 16:47

**Client Sample ID: Steam-2nd Floor Bathroom Sink**

**Lab Sample ID: 460-332554-17**

Date Collected: 08/11/25 07:50

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:32

**Client Sample ID: Steam-3rd Floor Bathroom Sink**

**Lab Sample ID: 460-332554-18**

Date Collected: 08/11/25 07:55

Matrix: Water

Date Received: 08/11/25 19:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	200			1056370	CDC	EET EDI	08/19/25 09:53
Total/NA	Analysis	200.8		1	1056472	CDC	EET EDI	08/19/25 17:33

**Laboratory References:**

EET EDI = Eurofins Edison, 777 New Durham Road, Edison, NJ 08817, TEL (732)549-3900

# Accreditation/Certification Summary

Client: EnviroSure Inc  
Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

## Laboratory: Eurofins Edison

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Pennsylvania	NELAP	68-00522	02-28-26

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11

# Method Summary

Client: EnviroSure Inc  
Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EET EDI
200	Preparation, Metals	EPA	EET EDI

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EET EDI = Eurofins Edison, 777 New Durham Road, Edison, NJ 08817, TEL (732)549-3900



# Sample Summary

Client: EnviroSure Inc  
Project/Site: Boys Latin Middle School

Job ID: 460-332554-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
460-332554-1	Main-1st Floor North Bathroom Sink	Water	08/11/25 06:40	08/11/25 19:00	Pennsylvania
460-332554-2	Main-1st Floor South Bathroom Sink	Water	08/11/25 07:20	08/11/25 19:00	Pennsylvania
460-332554-3	Main-Cafeteria Dishwashing Sink	Water	08/11/25 06:45	08/11/25 19:00	Pennsylvania
460-332554-4	Main-2nd Floor North Bathroom Sink	Water	08/11/25 06:50	08/11/25 19:00	Pennsylvania
460-332554-5	Main-2nd Floor Single Bathroom Sink	Water	08/11/25 06:55	08/11/25 19:00	Pennsylvania
460-332554-6	Main-2nd Floor Hallway Faucet	Water	08/11/25 07:00	08/11/25 19:00	Pennsylvania
460-332554-7	Main-2nd Floor Hallway Fountain	Water	08/11/25 07:05	08/11/25 19:00	Pennsylvania
460-332554-8	Main-3rd Floor Hallway Fountain	Water	08/11/25 07:10	08/11/25 19:00	Pennsylvania
460-332554-9	Main-3rd Floor Bathroom Sink	Water	08/11/25 07:15	08/11/25 19:00	Pennsylvania
460-332554-10	Main-Cafeteria Sink Left	Water	08/11/25 07:25	08/11/25 19:00	Pennsylvania
460-332554-11	Steam-1st Floor Bathroom Sink East	Water	08/11/25 07:30	08/11/25 19:00	Pennsylvania
460-332554-12	Steam-1st Floor Bathroom Sink West	Water	08/11/25 07:35	08/11/25 19:00	Pennsylvania
460-332554-13	Steam-1st Floor Fountain North	Water	08/11/25 07:40	08/11/25 19:00	Pennsylvania
460-332554-14	Steam-1st Floor Fountain South	Water	08/11/25 07:40	08/11/25 19:00	Pennsylvania
460-332554-15	Steam-1st Floor Fountain East	Water	08/11/25 07:45	08/11/25 19:00	Pennsylvania
460-332554-16	Steam-2nd Floor Fountain West	Water	08/11/25 07:45	08/11/25 19:00	Pennsylvania
460-332554-17	Steam-2nd Floor Bathroom Sink	Water	08/11/25 07:50	08/11/25 19:00	Pennsylvania
460-332554-18	Steam-3rd Floor Bathroom Sink	Water	08/11/25 07:55	08/11/25 19:00	Pennsylvania

TAL-8210

Regulatory Program:  DW  NPDES  RCRA  Other

Client Contact  
 Company Name: EnviroSure, Inc.  
 Address: 1 N Baccan Hill Road, Suite 208  
 City/State/Zip: Malvern, PA 19355  
 Phone: (610) 696-8980  
 Fax:  
 Project Name: Boys Latin Middle School  
 Site: SO2983  
 PO#: SO2983

Project Manager: Justin Garcia  
 Tel/Email: jgarcia@envirosure.com  
 Analysis Turnaround Time  
 CALENDAR DAYS  WORKING DAYS  
 TAT if different from Below  
 2 weeks  
 1 week  
 2 days  
 1 day

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=Grab)	Matrix	# of Cont.	Filtered Sample (Y/N)	Perform MS/MSD (Y/N)	Carrier	Date	COC No.
Main-1st Floor North Bathroom Sink	8/11/25	6:40	G	DW	1	M	X	Lead	8/11/25	1
Main-1st Floor South Bathroom Sink		7:30					X			2
Main-Cafeteria Dishwashing Sink		6:45					X			3
Main-2nd Floor North Bathroom Sink		6:50					X			4
Main-2nd Floor Single Bathroom Sink		6:55					X			5
Main-2nd Floor Hallway Faucet		7:00					X			6
Main-2nd Floor Hallway Fountain		7:05					X			7
Main-3rd Floor Hallway Fountain		7:10					X			8
Main-3rd Floor Bathroom Sink		7:15					X			9
Main-Cafeteria Sink Left		7:25					X			10
Steam-1st Floor Bathroom Sink East		7:30					X			11
Steam-1st Floor Bathroom Sink West		7:35					X			12



5-Day RUSH

Possible Hazard Identification  
 Are any samples from a listed EPA Hazardous Waste? Please List any EPA Waste Codes for the sample in the Comments Section if the lab is to dispose of the sample.  
 Non-Hazard  Flammable  Skin Irritant  Poison B  Unknown

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)  
 Return to Client  Disposal by Lab  Archive for \_\_\_\_\_ Months

Specia, Instructions/QC Requirements & Comments: DW=drinking water/potable water

Custody Seal No.	Company: EnviroSure, Inc.	Date/Time: 8/11/25 10:50	Received by: [Signature]	Company: EPA	Date/Time: 8/11/25 10:50
Relinquished by: [Signature]	Company: EPA	Date/Time: 8/11/25	Received by: [Signature]	Company: EPA	Date/Time: 8/11/25
Relinquished by: [Signature]	Company: EPA	Date/Time: 8/11/25	Received by: [Signature]	Company: EPA	Date/Time: 8/11/25



# Chain of Custody Record 764007

Address 344 North Felton Street  
Philadelphia, PA 19139



Environment Testing

TAL-8210

Regulatory Program  DW  NPDES  RCRA  Other

Client Contact  
Company Name: Enviro-Sure, Inc.  
Address: 1 N. Back on Hill Road, Suite 208  
City/State/Zip: Malvern, PA 19355  
Phone: (610) 646-3980  
Fax: \_\_\_\_\_

Project Name: Boys' Latin Middle School  
Site: 503983  
PO #: 503983

Project Manager: Justin Garcia  
Tel/Email: justin.garcia@enviro-sure.com

Analysis Turnaround Time  
 CALENDAR DAYS  WORKING DAYS  
TAT if different from below \_\_\_\_\_  
 2 weeks  
 1 week  
 2 days  
 1 day

Site Contact:  
Lab Contact: Non-Sea  
Date: 8/11/25  
Carrier: \_\_\_\_\_

COC No: \_\_\_\_\_ of \_\_\_\_\_ COCs

Sampler: \_\_\_\_\_  
For Lab Use Only: \_\_\_\_\_  
Walk-in Client: \_\_\_\_\_  
Lab Sampling: \_\_\_\_\_  
Job / SDG No: \_\_\_\_\_

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=Grab)	Matrix	# of Cont.	Filtered Sample (Y/N)	Perform MS/MSD (Y/N)	Sample Specific Notes:
Steam-1st Floor Fountain North	8/11/25	7:40	G	DW	7	MMX		13
Steam-1st Floor Fountain South		7:40						14
Steam-2nd Floor Fountain East		7:45						15
Steam-2nd Floor Fountain West		7:45						16
Steam-2nd Floor Bathroom Sink		7:50						17
Steam-3rd Floor Bathroom Sink		7:55						18

Preservation Used: 1=Ice, 2=HC, 3=H2SO4, 4=HNO3, 5=NaOH, 6=Other

Possible Hazard Identification:  
Are any samples from a listed EPA Hazardous Waste? Please List any EPA Waste Codes for the sample in the Comments Section if the lab is to dispose of the sample

Non-Hazard  Flammable  Skin Irritant  Unknown  
 Return to Client  Disposal by Lab  Archive for \_\_\_\_\_ Months

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

Special Instructions/QC Requirements & Comments: \* DW = drinking/potable water

Custody Seals Intact:  Yes  No

Relinquished by: Justin Garcia  
Relinquished by: Justin Garcia  
Relinquished by: Justin Garcia

Company: Enviro-Sure, Inc.  
Company: Enviro-Sure, Inc.  
Company: Enviro-Sure, Inc.

Date/Time: 8/11/25 10:50  
Date/Time: 8/11/25 10:50  
Date/Time: 8/11/25 10:50

Received by: Justin Garcia  
Received by: Justin Garcia  
Received in Laboratory by: Justin Garcia

Company: ETA  
Company: ETA  
Company: ETA

Date/Time: 8/11/25 19:00  
Date/Time: 8/11/25 19:00  
Date/Time: 8/11/25 19:00



TestAmerica Edison  
Receipt Temperature and pH Log

Job Number: 338554

Number of Coolers: 1

IR Gun # 10

Cooler Temperatures

	RAW	CORRECTED		RAW	CORRECTED
Cooler #1	43 °C	41 °C	Cooler #4	°C	°C
Cooler #2	°C	°C	Cooler #5	°C	°C
Cooler #3	°C	°C	Cooler #6	°C	°C
			Cooler #7	°C	°C
			Cooler #8	°C	°C
			Cooler #9	°C	°C

TALS Sample Number	Ammonia (pH<2)	COD (pH<2)	Nitrate Nitrite (pH<2)	Metals (pH<2)	Hardness (pH<2)	Pest (pH 5-9)	EPH or QAM (pH<2)	Phenols (pH<2)	Sulfide (pH>9)	TKN (pH<2)	TOC (pH<2)	Total Cyanide (pH>12)	Total Phos (pH<2)	Other
12				CL										
3/4				CL										
5/6				CL										
7/8				CL										
9/10				CL										
11/12				CL										
13/14				CL										
15/16				CL										
17/18				CL										

If pH adjustments are required record the information below\*

Sample No(s). adjusted. \_\_\_\_\_  
 Preservative Name/Conc. \_\_\_\_\_ Volume of Preservative used (ml): \_\_\_\_\_  
 Lot # of Preservative(s): \_\_\_\_\_ Expiration Date: \_\_\_\_\_  
 The appropriate Project Manager and Department Manager should be notified about the samples which were pH adjusted.  
 \* Samples for Metal analysis which are out of compliance must be acidified at least 24 hours prior to analysis.

Initials HS

Date: 8/11



## Login Sample Receipt Checklist

Client: EnviroSure Inc

Job Number: 460-332554-1

**Login Number: 332554**

**List Number: 1**

**Creator: Thundathorn, Sukanan 1**

**List Source: Eurofins Edison**

Question	Answer	Comment
Radioactivity wasn't checked or is <=/ background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

