



Design Standard Wood Flooring

Purpose:

This design standard has the purpose of creating a consistent installation of Wood Flooring throughout the South San Francisco Unified School District thereby achieving a standard of aesthetic quality, maintenance and performance throughout all renovation and new building projects.

Design Standard:

Stage Flooring

- Clear finish for stage floor; use Varathane Crystal Clear/ Elite Diamond Floor Finish at existing floors to be re-finished.
- Maple flooring shall be 25/32 inch thick Northern Hard Maple, “2nd and better” grade, 2-1/4” wide, tongue and grooved, end matched, for new floors.

Athletic Wood Flooring

General Requirements

- Maple flooring shall be 25/32 inch thick Northern Hard Maple, “2nd and better” grade, 2-1/4” wide, tongue and grooved, end matched.
- Sub floor components: PVC resilient pads to be 3/8” thick by 2 1/4” wide by 3” long with six fully enclosed air channels. Sleepers shall be Northern Pine or Eastern Hemlock nominal size two inches by 3 inches by four feet, over continuous, un-penetrated waterproof membrane.
- Must have perimeter gap for ventilation and expansion.
- Finish shall be as follows:
 - First and second coats: Bona Sport Supersport Seal
 - Third through seventh coats: Bona Sport Supersport One, gloss finish



South San Francisco Unified School District



Section 09 64 00, 09 64 66

Version 1, 2011.9.30

Wall Base

- Heavy-duty molded rubber vented base. Vinyl is NOT ACCEPTABLE.
- Provide pre-molded inside and outside corners.
- Use water-based adhesives.

Approved Manufacturers

- o See above

Substitutes allowed?

- o Yes, if performance and quality equivalency can be evidenced.

Associated Design Standards

- o N/A

End of Document