



Design Standard Fans

Purpose:

Fans are an essential element of the mechanical space ventilation, cooling, and heating systems. This design standard has the purpose of creating a consistent application of fan requirements throughout the South San Francisco Unified School District thereby achieving a standard of quality for maintenance, energy efficiency, and reliability throughout all renovation and new building projects.

Design Standard:

Design and specify work to include materials, installation, and testing of fans used for ventilation and exhaust service for a complete and operating system

- Fans shall be AMCA rated for sound and air performance.
- All fans shall be statically and dynamically balanced and test run at the factory.
- The motor horsepower shall not be less than 120% of fan bhp, non-overloading.
- Where variable speed drives are utilized, all fans to be direct drive fans to reduce maintenance for belts. Consider fan's critical speed in selection of direct drive fans with variable speed operation.
- Fan types shall include but not be limited to:
 - Sidewall exhaust fans
 - Centrifugal belt drive roof exhaust fans
 - Utility sets
 - Inline cabinet fans
 - Plug fans
 - Wall propeller exhaust fans
 - Transfer filter fans
 - Duct mounted inline fans
 - Air curtains
- Dust Collectors
 - Design with material handling exhaust fan, heavy duty cotton sateen filters, explosion vent, (top mounted discharge silencer if required for acoustical



South San Francisco Unified School District



Section 23 34 00

Version 1, 2011.9.30

attenuation) dust storage hopper. Housing of 14 gauge hot rolled steel base with extended legs providing 42 inch clearance below hopper. Paint Finishes: One coat zinc chrome primer on interior and one coat grey machinery enamel on exterior.

- Heavy duty industrial type material handling direct drive exhaust fan.
- Filters: High efficient cotton sateen fabric with an efficiency rating of 99.9 percent by weight, allowing recirculation of the air. The filter pockets must have a metal insert to prevent the filter from collapsing and to maintain a positive connection to the filter shaker during the cleaning cycle. Foam inserts will not be allowed.
- Motorized shaker complete with motor. Solid state field adjustable controller governing shaking cycle duration, automatically actuated at each fan shutdown. Shaker must be high frequency type for maximum cleaning.
- Factory mounted and wired NEMA 4 control panel including magnetic starters with heaters for the blower motor and shaker motor. Single point electrical connection, provide for field wiring required for internally mounted start/stop station supplied by factory.
- Explosion vent designed for vacuum service to be supplied with the dust collector for field installation. The explosion vent is to be the same diameter as the main duct and installed in "T" connection at the highest point prior to entering the dust collector.

Approved Manufacturers:

- Fans
 - Greenheck
 - Loren Cook
 - Penn
 - Twin City
- Air curtains
 - Mars
 - Berner International
- Dust collectors
 - Sternvent
 - Donaldson/ Torit
 - American Air Filter



South San Francisco Unified School District



Section 23 34 00

Version 1, 2011.9.30

Substitutes Allowed:

Yes, if performance and quality equivalency can be evidenced.

Associated Design Standards

- 23 05 29 - Design Standard Hangers and Supports for HVAC Piping And Equipment
- 23 05 48 - Design Standard Vibration and Seismic Controls for HVAC Piping and Equipment
- 23 05 53 - Design Standard Identification for HVAC Piping and Equipment
- 23 05 93 - Design Standard Testing, Adjusting and Balancing
- 23 31 00 – Design Standard Ductwork

End of Document