PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

November 15, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Kingston High School** received at the laboratory on 10/29/24.

Date/Time Collected: 10/26/24 7:42-10:59am First Draw
Collected By: Kingston CSD
Project ID: 10292416
Secondary ID: KS244749-845

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
620 Bottle Filler Silver by VP office	EPA 200.8				
10292416-1	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
621 Bottle Filler by Auditorium	EPA 200.8				
10292416-2	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
622 M126 Faucet	EPA 200.8				
10292416-3	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
624 Bottle Filler by F-T08 Left	EPA 200.8				
10292416-4	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
623 Bottle Filler by TM101	EPA 200.8				
10292416-5	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
619 Faucet VP Office	EPA 200.8				
10292416-6	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
618 Bottle Filler Green by VP office	EPA 200.8				
10292416-7	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
616 M112 Faucet	EPA 200.8				
10292416-8	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
617 Bottle Filler M4 Stairs	EPA 200.8				
10292416-9	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

Kingston High School - 10292416

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
615 M011-1 Faucet Back	EPA 200.8				
10292416-10	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
611 M023 Faucet	EPA 200.8				
10292416-11	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
610 M023 Bottle Filler	EPA 200.8				
10292416-12	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
612 M023 Bubbler	EPA 200.8				
10292416-13	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
613 M028 Faucet	EPA 200.8				
10292416-14	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
614 M011-1 Front Faucet	EPA 200.8				
10292416-15	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
609 M022 Faucet	EPA 200.8				
10292416-16	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
608 M014 Faucet	EPA 200.8				
10292416-17	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
605 Nurse Front Faucet	EPA 200.8				
10292416-18	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
607 Nurse Back Faucet	EPA 200.8				
10292416-19	Lead	0.0015 mg/L		0.005 mg/L	11/05/24
606 Nurse Bottle Filler	EPA 200.8				
10292416-20	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
604 M016 Faucet	EPA 200.8				
10292416-21	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
603 M017 Faucet	EPA 200.8				
10292416-22	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
601 M019 Center Faucet	EPA 200.8				
10292416-23	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
600 M019 Left Sink	EPA 200.8				
10292416-24	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
602 M019 Right Faucet	EPA 200.8				
10292416-25	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

Kingston High School - 10292416

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
634 Bubbler Boys Locker Rm 10292416-26	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
625 Bottle Filler F-T08 Right 10292416-27	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
638 M223 Bottle Filler 10292416-28	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
642 M215-2 Middle Right Faucet 10292416-29	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
633 Boys Locker Rm Bottle Fill 10292416-30	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
626 F100 Faucet 10292416-31	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	11/05/24
635 Girls Locker Rm Bottle Fill 10292416-32	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
645 M215-2 Front Right 10292416-33	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
632 Bubbler Left FT03 10292416-34	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
631 Bubbler FT03 Right 10292416-35	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
636 Bubbler Girls Locker Rm Left 10292416-36	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
644 M215-2 Front Left Faucet 10292416-37	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
628 Bubbler F101 Right 10292416-38	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
630 Bottle Fill FT03 10292416-39	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
639 M215-2 Faucet Left 10292416-40	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

Kingston High School - 10292416

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
643 M215-2 Right Faucet 10292416-41	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
626 Athletic Office Faucet 10292416-42	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
628 F101 Bubbler Left 10292416-43	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
640 M215-2 Left 2 Faucet 10292416-44	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
647 M215-2 Bubbler Left 10292416-45	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
627 F101 Bottle Filler 10292416-46	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
637 Girls Locker Rm Right Bubbler 10292416-47	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
641 M215-2 Middle Left Faucet 10292416-48	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
648 M215-2 Right Bubbler 10292416-49	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
654 S216 Bottle Filler 10292416-50	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
650 Bubbler Right T-M203 10292416-51	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
660 TW101 Bottle Filler 10292416-52	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
671 Food Prep Faucet Kitchen Front 10292416-53	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
646 M215-2 Bottle Filler 10292416-54	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
655 W202 Faucet 10292416-55	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	11/05/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

Kingston High School - 10292416

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
461 W106 Faucet	EPA 200.8				
10292416-56	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
670 Kitchen Food Prep Faucet	EPA 200.8				
10292416-57	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
652 M209 Faucet	EPA 200.8				
10292416-58	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
656 Bottle Fill T-W201	EPA 200.8				
10292416-59	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
462 Bottle Fill S220 Right	EPA 200.8				
10292416-60	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
649 T-M203 Bottle Filler	EPA 200.8				
10292416-61	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
657 W208 Bottle Filler	EPA 200.8				
10292416-62	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
463 Bottle Filler S110 Left	EPA 200.8				
10292416-63	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
669 S127 Bottle Filler Right	EPA 200.8				
10292416-64	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
651 Bubbler T-M203 Left	EPA 200.8				
10292416-65	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
658 Bottle Filler TW301	EPA 200.8				
10292416-66	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
664 Faucet S111	EPA 200.8				
10292416-67	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
668 Bottle Filler S122 Left	EPA 200.8				
10292416-68	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
653 M210 Bottle Filler	EPA 200.8				
10292416-69	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
659 W307 Faucet	EPA 200.8				
10292416-70	Lead	0.0012 mg/L		0.005 mg/L	11/05/24
665 S112 Faucet	EPA 200.8				
10292416-71	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

Kingston High School - 10292416

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
666 Bottle Filler Outside Cafe	EPA 200.8				
10292416-72	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
691 E304 Faucet	EPA 200.8				
10292416-73	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
689 Bottle Filler TE-301	EPA 200.8				
10292416-74	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
683 E215B Back Faucet	EPA 200.8				
10292416-75	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
677 E015B Faucet	EPA 200.8				
10292416-76	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
690 E309 Faucet	EPA 200.8				
10292416-77	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
687 E203 Faucet	EPA 200.8				
10292416-78	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
682 E215A Faucet	EPA 200.8				
10292416-79	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
676 E015A Faucet	EPA 200.8				
10292416-80	Lead	<0.0010 mg/L		0.005 mg/L	11/05/24
692 S215 Bottle Filler	EPA 200.8				
10292416-81	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
688 E209 Faucet	EPA 200.8				
10292416-82	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
680 E009 Faucet	EPA 200.8				
10292416-83	Lead	0.0016 mg/L		0.005 mg/L	11/04/24
674 E103 Faucet	EPA 200.8				
10292416-84	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
6XX S105-1 Faucet	EPA 200.8				
10292416-85	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
686 E204 Faucet	EPA 200.8				
10292416-86	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
681 E004 Faucet	EPA 200.8				
10292416-87	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

Kingston High School - 10292416

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
675 E108 Faucet	EPA 200.8				
10292416-88	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
684 F215B Front Faucet	EPA 200.8				
10292416-89	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
685 TE202 Bottle Filler	EPA 200.8				
10292416-90	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
678 E003 Faucet	EPA 200.8				
10292416-91	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
673 TE101 Bubbler	EPA 200.8				
10292416-92	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
693 Carnegy Bubbler	EPA 200.8				
10292416-93	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
694 Carnegy Basement Faucet	EPA 200.8				
10292416-94	Lead	0.0697 mg/L	X	0.005 mg/L	11/07/24
679 TE001 Bottle Filler	EPA 200.8				
10292416-95	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
672 TE101 Bottle Filler	EPA 200.8				
10292416-96	Lead	<0.0010 mg/L		0.005 mg/L	11/04/24
667 S127 Faucet	EPA 200.8				
10292416-97	Lead	0.0084 mg/L	X	0.005 mg/L	11/04/24

Qualifier(Q):
X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director