



June 17, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Douglas County High School
2842 Front Street in Castle Rock, CO 80104
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Douglas County High School, located at 2842 Front Street in Castle Rock, Colorado.

Two hundred and twenty-two (222) AirChek radon test kits were placed on June 2, 2025, and two hundred and six (206) were retrieved on June 4, 2025. The attached laboratory report identifies the radon concentrations in two (2) of the sampled locations in the main building were above the EPA guideline of 4 pCi/L for acceptable radon concentrations: Rooms 113 and 117. QUEST recommends that the ventilation system be inspected to ensure that any existing radon mitigation systems are in operation or those areas are positively pressurized relative to the underlying soils, all floor gaps between the occupied areas and sub-slab areas are sealed (if not already done), and that follow-up radon sampling be conducted prior to entertaining the installation of a radon mitigation system.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Robert Head".

Robert Head
Environmental Technician

Attachment: Laboratory Report

Radon test result report for:
DOUGLAS COUNTY HS
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12095066	10	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095067	10 DUPLICATE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095061	11	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095094	110	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	2.1	2025-06-06
12095095	111	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.5	2025-06-06
12095096	112	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.7	2025-06-06
12095097	113	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	5.2	2025-06-06
12095088	115	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.3	2025-06-06
12095092	116	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.6	2025-06-06
12095093	117	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	6.5	2025-06-06
12095089	118	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	2.0	2025-06-06
12095090	118 DUPLICATE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.9	2025-06-06
12095091	119	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.1	2025-06-06
12095006	12 CONFERENCE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12095060	12B	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095059	13	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095058	14	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095057	15	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095051	16	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.7	2025-06-06
12095052	16/17 CONFERENCE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.6	2025-06-06
12095053	16/17 OFFICE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.6	2025-06-06
12095049	17 OFFICE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095008	18	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.8	2025-06-06
12095054	18	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.7	2025-06-06
12095010	18 BLANK	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.7	2025-06-06
12095056	18 BLANK	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095009	18 DUPLICATE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12095055	18 DUPLICATE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.8	2025-06-06
12095011	19	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12074085	2	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	< 0.3	2025-06-06
12074087	2 BLANK	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	< 0.3	2025-06-06
12074086	2 DUPLICATE	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	< 0.3	2025-06-06
12095013	20	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095012	21	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095003	22	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095002	23	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095001	24	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.5	2025-06-06

Radon test result report for:
DOUGLAS COUNTY HS
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12074084	3	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	< 0.3	2025-06-06
12074088	30	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	1.0	2025-06-06
12074089	31	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12074094	32	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.0	2025-06-06
12074095	33	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.0	2025-06-06
12074096	34	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.1	2025-06-06
12074097	35	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12074098	35 DUPLICATE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.0	2025-06-06
12074099	36	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.7	2025-06-06
12074100	37	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.1	2025-06-06
12074090	38	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.6	2025-06-06
12074091	38 OFFICE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.9	2025-06-06
12074093	39	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.7	2025-06-06
12074080	4	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	1.2	2025-06-06
12095019	41	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.0	2025-06-06
12095020	42	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.7	2025-06-06
12095021	42 DUPLICATE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12095018	43	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.7	2025-06-06
12095017	44	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.3	2025-06-06
12095016	45	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.8	2025-06-06
12095015	46	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.9	2025-06-06
12074079	5 EAST	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	1.4	2025-06-06
12074082	5 OFFICE	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	1.3	2025-06-06
12074083	5 WEST	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	1.3	2025-06-06
12095022	51	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095023	52 EAST	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.5	2025-06-06
12095025	52 OFFICE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.7	2025-06-06
12095024	52 WEST	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12095026	53	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.0	2025-06-06
12074077	6	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.7	2025-06-06
12095027	60	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.9	2025-06-06
12095029	60/61 OFFICE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.5	2025-06-06
12095028	61	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.5	2025-06-06
12095030	62	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.5	2025-06-06
12095031	63	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.4	2025-06-06
12095033	63 BLANK	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095032	63 DULICATE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.1	2025-06-06

Radon test result report for:
DOUGLAS COUNTY HS
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12095035	65	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12095040	66	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	2.7	2025-06-06
12095043	70 EAST	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.7	2025-06-06
12095044	70 EAST DUPLICATE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095045	70 LAB	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.5	2025-06-06
12095046	70 OFFICE 2	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.7	2025-06-06
12095047	70 OFFICE 3	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095042	70 WEST	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095083	81 CONFERENCE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095082	81 CUSTODIAN	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095062	83	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095063	83 CONFERENCE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.5	2025-06-06
12095064	83 LOUNGE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095065	83 OFFICE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12074067	ASSISSTANT PRINCIPAL	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	< 0.3	2025-06-06
12094906	AUX GYM E	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	< 0.3	2025-06-06
12094907	AUX GYM E	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	< 0.3	2025-06-06
12095085	COMONS N	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095086	COMONS S	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.7	2025-06-06
12074068	CONFERENCE	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.6	2025-06-06
12074066	COPY ROOM	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	< 0.3	2025-06-06
12095077	COUNSELING - 1	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.5	2025-06-06
12095078	COUNSELING - 1 BLANK	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095079	COUNSELING - 1 DUPLICATE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095070	COUNSELING - 2	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095071	COUNSELING - 3	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.7	2025-06-06
12095072	COUNSELING - 4	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.6	2025-06-06
12095073	COUNSELING - 5	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.9	2025-06-06
12095074	COUNSELING - 6	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.8	2025-06-06
12095075	COUNSELING - 7	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095076	COUNSELING - 8	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.6	2025-06-06
12095069	COUNSELING - CONFERENCE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.6	2025-06-06
12095068	COUNSELING OFFICE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.6	2025-06-06
12095037	COUNTY	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.0	2025-06-06
12095038	COUNTY OFFICE 1	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	1.0	2025-06-06
12095039	COUNTY OFFICE 2	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.1	2025-06-06
12074072	DEAN 1	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.7	2025-06-06

Radon test result report for:
DOUGLAS COUNTY HS
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12074073	DEAN 2 - SAM TERES	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	1.6	2025-06-06
12094908	F101	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	1.7	2025-06-06
12094909	F101A	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	2.8	2025-06-06
12094905	F106	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	1.1	2025-06-06
12074070	HEALTH ASSISTANT	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.5	2025-06-06
12074081	JOSH GALERSTEIN	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	1.2	2025-06-06
12074076	LEGACY THEATER N	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.9	2025-06-06
12074074	LEGACY THEATER S	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.7	2025-06-06
12074075	LEGACY THEATER S (DUPLICATE)	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.8	2025-06-06
12095041	LIBRARY OFFICE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12094904	MAIN GYM E	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	< 0.3	2025-06-06
12094903	MAIN GYM W	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	< 0.3	2025-06-06
12094902	MAIN GYM W BLANK	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	< 0.3	2025-06-06
12094901	MAIN GYM W DUPLICATE	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	< 0.3	2025-06-06
12074065	MAIN OFFICE	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.6	2025-06-06
12095080	N GYM N	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.6	2025-06-06
12095081	N GYM S	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	0.7	2025-06-06
12095036	NURSE MEGAN	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12074071	OFFICE	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.9	2025-06-06
12074078	OFFICE 6	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	< 0.3	2025-06-06
12095004	OFFICE A	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095005	OFFICE B	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12074069	PRINCIPAL	2025-06-02 @ 10:00 am	2025-06-04 @ 10:00 am	0.7	2025-06-06
12095007	SPEECH OFFICE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	< 0.3	2025-06-06
12095087	SSH OFFICE 1	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	1.0	2025-06-06
12095084	TEACHER LOUNGE	2025-06-02 @ 12:00 pm	2025-06-04 @ 12:00 pm	< 0.3	2025-06-06
12095014	THEATER OFFICE	2025-06-02 @ 11:00 am	2025-06-04 @ 11:00 am	0.6	2025-06-06
12095099	WRESTLING E	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	0.5	2025-06-06
12095100	WRESTLING OFFICE	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	< 0.3	2025-06-06
12095098	WRESTLING W	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	0.9	2025-06-06

Radon test result report for:
DOUGLAS COUNTY HS
SOUTH

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12094945	10S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.7	2025-06-06
12094947	10S OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.8	2025-06-06
12094944	11S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.5	2025-06-06
12094946	11S OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.0	2025-06-06
12094939	12S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.7	2025-06-06
12094941	12S OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.7	2025-06-06
12094940	13S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.3	2025-06-06
12094942	13S OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.1	2025-06-06
12094943	21S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.9	2025-06-06
12094937	22S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.1	2025-06-06
12094938	23S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.0	2025-06-06
12094968	2S	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	< 0.3	2025-06-06
12094979	32S	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.3	2025-06-06
12094978	33S	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.0	2025-06-06
12094966	3S	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	< 0.3	2025-06-06
12094977	43S	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.3	2025-06-06
12094967	4S	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	< 0.3	2025-06-06
12094975	50S BLANK MISSING	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	< 0.3	2025-06-06
12094926	51S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.9	2025-06-06
12094923	52S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.5	2025-06-06
12094925	52S BLANK	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	< 0.3	2025-06-06
12094924	52S DUPLICATE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.1	2025-06-06
12094921	54S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.0	2025-06-06
12094916	63S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.7	2025-06-06
12094917	64S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.0	2025-06-06
12094918	64S OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.3	2025-06-06
12094919	65S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.6	2025-06-06
12094965	6S	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	0.7	2025-06-06
12094927	70S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	< 0.3	2025-06-06
12094928	71S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	< 0.3	2025-06-06
12094929	72S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.3	2025-06-06
12094931	73S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.2	2025-06-06
12094932	74S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.3	2025-06-06
12094933	75S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.7	2025-06-06
12094934	76S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.5	2025-06-06
12094935	77S	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.8	2025-06-06
12094936	77S DUPLICATE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.6	2025-06-06

Radon test result report for:
DOUGLAS COUNTY HS
SOUTH

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12094970	ATHLETIC OFFICE	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.4	2025-06-06
12094972	ATHLETIC OFFICE STUDY	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.6	2025-06-06
12094962	COACHS OFFICE	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.2	2025-06-06
12094963	COACHS OFFICE DUPLICATE	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	0.8	2025-06-06
12094964	CONFERENCE ROOM	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	< 0.3	2025-06-06
12094958	CUSTODIAL OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	< 0.3	2025-06-06
12094971	DIANE SHUCK	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.6	2025-06-06
12094930	FOREIGN LAUNGUAGE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.8	2025-06-06
12094911	GYM E	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	0.9	2025-06-06
12094956	GYM W	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.5	2025-06-06
12094910	GYM W	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	0.6	2025-06-06
12094950	JESSICA DICKENSON	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.8	2025-06-06
12094954	JESSICA DICKENSON BLANK	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	< 0.3	2025-06-06
12094953	JESSICA DICKENSON DUPLICATE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.1	2025-06-06
12094912	LAB	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	0.9	2025-06-06
12094952	MAIL ROOM	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.0	2025-06-06
12094960	MAIN GYM E	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.6	2025-06-06
12094949	MATTHER WEBSTER	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.6	2025-06-06
12094961	MAUN GYM W	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	< 0.3	2025-06-06
12094951	NICOLE STONE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.0	2025-06-06
12094955	NOELLE DENNIS	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.6	2025-06-06
12094915	OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	1.2	2025-06-06
12094913	OFFICE	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	0.6	2025-06-06
12094914	OFFICE DUPLICATE	2025-06-02 @ 1:00 pm	2025-06-04 @ 1:00 pm	0.8	2025-06-06
12094959	S WEIGHT ROOM	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.5	2025-06-06
12094986	SCIENCE OFFICE	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	1.8	2025-06-06
12094948	SOUTH OFFICE	2025-06-02 @ 2:00 pm	2025-06-04 @ 2:00 pm	0.8	2025-06-06
12094976	W OFFICE TO WAR ROOM	2025-06-02 @ 3:00 pm	2025-06-04 @ 3:00 pm	0.6	2025-06-06



August 14, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Douglas County High School
2842 Front Street in Castle Rock, CO 80104
Radon Sampling Assessment – Follow-up**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon re-testing at Douglas County High School, located at 2842 Front Street in Castle Rock, Colorado.

Two (2) AirChek radon test kits were placed on August 5, 2025, and two (2) were retrieved on August 8, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Robert Head".

Robert Head
Environmental Technician

Attachment: Laboratory Report

August 12, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**DCHS
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11546790	113	2025-08-05 @ 10:00 am	2025-08-08 @ 11:00 am	0.9	2025-08-12
11546786	117	2025-08-05 @ 10:00 am	2025-08-08 @ 11:00 am	2.9	2025-08-12

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498