



August 15 , 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Cherry Valley Elementary School
9244 S State Hwy 83 in Franktown, CO 80116
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Cherry Valley Elementary School, located at 9244 S State Highway 83 in Franktown, Colorado.

Five (5) AirChek radon test kits were placed on August 11, 2025, and five (5) were retrieved on August 13, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Robert Head".

Robert Head
Environmental Technician

Attachment: Laboratory Report

August 15, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
CHERRY VALLEY ES
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12094873	CLASS	2025-08-11 @ 3:00 pm	2025-08-13 @ 4:00 pm	0.8	2025-08-15
12094884	GYM	2025-08-11 @ 3:00 pm	2025-08-13 @ 4:00 pm	0.9	2025-08-15
12094892	LOUNGE	2025-08-11 @ 3:00 pm	2025-08-13 @ 4:00 pm	0.8	2025-08-15
12094874	OFFICE	2025-08-11 @ 3:00 pm	2025-08-13 @ 4:00 pm	0.6	2025-08-15

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

August 15, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
CHERRY VALLEY ES
SIDE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12094888	2ND CLASS	2025-08-11 @ 3:00 pm	2025-08-13 @ 4:00 pm	1.5	2025-08-15

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498