Lead in School Drinking Water Report

Frank Wagner Elementary School - Corrected

EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per RCW 28A.210.410 sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

RCW 28A.210.410 does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing Location	Room/space where fixture is located (i.e. room number, gym, playground)
Fixture Housing Type	Structure that contains the individual fixtures where water samples were collected from. Fixture housing may contain one or more individual fixture for sampling.
Fixture Location Details	Location within a room or space where fixture housing is located, starting to the left of the entrance and rotating clockwise, of the total number of fixture housings in a room or space (e.g. 1/5, 2/5)
Fixture Type	Tap, Sprayer, Water Fountain, Water Bottle Filler, Icemaker
Fixture Position	Left, Center, Right

Date(s) collected: 2023-05-31, 2024-03-26
Date(s) analyzed: 2023-06-26, 2023-06-27, 2024-04-22

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	374187	Classroom wing	Sink	Room 132	Only sink	Water Fountain	right	29
2	374215	Classroom wing	Sink	Room 202	Only sink	Water Fountain	right	28
3	374188	Classroom wing	Sink	Room 131	Only sink	Tap	right	27
4	374218	Classroom wing	Fountain	2nd Floor Hallway	In between rooms 201 and 202	Water Fountain	right	25
5	374217	Classroom wing	Sink	Room 201	Only sink	Water Fountain	left	18
6	391463	Classroom wing	Fountain/Tap Combo	Rm134	Turned of f last time	Water Fountain	center	17
7	374205	Classroom wing	Sink	Room 216	Only sink	Water Fountain	left	16
8	374203	Classroom wing	Sink	Room 155	Only sink	Water Fountain	right	13
9	374181	Multipurpose	Sink	Kitchen	Closest sink to	Tap	right	12

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
					entrance /exit door. Also next to dish washer			
10	374182	Multipurpose	Sink	Kitchen	Closest sink to entrance /exit	Sprayer	left	11
11	374184	Multipurpose	Sink	Kitchen	Next to fridge hand washing sink	Tap	center	10
12	391462	Classroom wing	Fountain/Tap Combo	Rm131	Turned of f before	Water Fountain	left	9
13	374189	Classroom wing	Fountain	End Of Hallway	Between rooms 132 and 131	Water Fountain	right	7
14	374191	Classroom wing	Sink	Room 139	Only sink	Tap	right	7

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
15	374213	Classroom wing	Sink	Room 204	Only sink	Water Fountain	right	7
16	374216	Classroom wing	Sink	Room 201	Only sink	Tap	right	7
17	374204	Classroom wing	Sink	Room 216	Only sink	Tap	right	6
18	374207	Classroom wing	Sink	Room 211	Only sink	Water Fountain	right	6
19	374209	Classroom wing	Sink	Room 206	Only sink	Water Fountain	left	6
20	374210	Classroom wing	Sink	Room 209	Only sink	Tap	right	5
21	374214	Classroom wing	Sink	Room 202	Only sink	Tap	left	5
22	374190	Classroom wing	Sink	Room 134	Only sink	Tap	left	4
23	374186	Classroom wing	Sink	Room 132	Only sink	Tap	left	3
24	374208	Classroom wing	Sink	Room 206	Only sink	Tap	right	3
25	374183	Multipurpose	Sink	Kitchen	In corner next to ovens	Sprayer	center	2

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
26	374185	Multipurpose	Fountain	Entrance Foyer	Only fountain	Water Fountain	right	2
27	374211	Classroom wing	Sink	Room 209	Only sink	Water Fountain	left	2
28	374212	Classroom wing	Sink	Room 204	Only sink	Tap	left	2
29	391464	Classroom wing	Fountain/Tap Combo	Rm139	Turned of f last time	Water Fountain	left	2
30	374206	Classroom wing	Sink	Room 211	Only sink	Tap	left	1
31	374180	Multipurpose	Sink	Kitchen	Left of dish washer	Sprayer	center	<1
32	374192	Classroom wing	Sink	Room 136	Only sink	Tap	right	<1
33	374193	Classroom wing	Sink	Room 136	Only sink	Water Fountain	left	<1
34	374194	Classroom wing	Sink	Room 141	Only sink	Tap	left	<1
35	374195	Classroom wing	Sink	Room 141	Only sink	Water Fountain	right	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
36	374196	Classroom wing	Sink	Room 147	Only sink	Tap	right	<1
37	374197	Classroom wing	Sink	Room 147	Only sink	Water Fountain	left	<1
38	374198	Classroom wing	Sink	Room 152	Only sink	Tap	right	<1
39	374199	Classroom wing	Sink	Room 152	Only sink	Water Fountain	left	<1
40	374200	Classroom wing	Sink	Room 154	Only sink	Tap	right	<1
41	374201	Classroom wing	Sink	Room 154	Only sink	Water Fountain	left	<1
42	374202	Classroom wing	Sink	Room 155	Only sink	Tap	left	<1