



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5H0524

Wyoming County Health Department

Project Name: Letchworth Central School

Andy Meyer
5362 Mungers Mill RD
Silver Springs, NY 14550

Project / PO Number: N/A
Received: 08/15/2025
Reported: 08/26/2025

Analytical Testing Parameters

Client Sample ID: #63
Sample Matrix: Drinking Water
Lab Sample ID: S5H0524-01
Collected By: Todd Brant
Collection Date: 08/12/2025 6:43

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Method: EPA 200.8, Rv. 5.4 (1994), Lead, 0.00718, 0.015 AL, 0.000400, mg/L, 08/19/25 1650, 08/20/25 1537, JXY

Client Sample ID: #67
Sample Matrix: Drinking Water
Lab Sample ID: S5H0524-02
Collected By: Todd Brant
Collection Date: 08/12/2025 6:45

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Method: EPA 200.8, Rv. 5.4 (1994), Lead, 0.00471, 0.015 AL, 0.000400, mg/L, 08/19/25 1650, 08/20/25 1538, JXY

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
mg/L: Milligrams per Liter
NYVOA: New York DOH Part 5 Public Water System MCLs
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., Pittston Division
12150

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at https://www.microbac.com/standard-terms-conditions.

Reviewed and Approved By:

Handwritten signature of Joseph Palanza

Joseph Palanza
Project Manager
Reported: 08/26/2025 23:56