



Adopted 4/18/2025

Updated 8/20/2025

Cedar Way Elementary Action Plan: Lead in Drinking Water

School Information

School Name(s): Cedar Way Elementary

School District: Edmonds School District

County: Snohomish

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
Cedar Way ES	3/18/2025	4/16/2025	Washington State Dept of Health

Testing Requirements

[RCW 28A.210.410](#) and [RCW 43.70.830](#) require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an [accredited lab](#).

Action Plan Requirements

If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If your school has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per [RCW 28A.210.410](#), a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with [DOH's technical guidance](#).
- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI [Lead in Water Remediation Grant](#) is a potential source of funding.
- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.
- For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.
- The action plan must include:
 - 1) **Mitigation measures** implemented since receiving elevated lead test results.
 - 2) A schedule of **remediation activities** that adhere to the [technical guidance](#). The schedule may be based on the availability of state or federal funding for remediation activities.
 - 3) A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb.

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as “hand wash only,” to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the [technical guidance](#).

Cedar Way Elementary has identified 24 drinking water outlets with elevated lead levels requiring mitigation. **Mitigation measures** have been implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	3/18/2025	393253	Cedar Way Elementary	Water Fountain	34	Water shut off, temporary water stations provided as needed	4/18/2025
2)	3/18/2025	393737	Cedar Way Elementary	Sink Fixture	14	Water shut off, temporary water stations provided as needed	4/18/2025
3)	3/18/2025	393246	Cedar Way Elementary	Bubbler	13	Water shut off, temporary water stations provided as needed	4/18/2025
4)	3/18/2025	393274	Cedar Way Elementary	Sink Fixture	13	Water shut off, temporary water stations provided as needed	4/18/2025
5)	3/18/2025	393742	Cedar Way Elementary	Water Fountain	12	Water shut off, temporary water stations provided as needed	4/18/2025
6)	3/18/2025	393276	Cedar Way Elementary	Sink Fixture	11	Water shut off, temporary water stations provided as needed	4/18/2025
7)	3/18/2025	393244	Cedar Way Elementary	Water Fountain	9	Water shut off, temporary water stations provided as needed	4/18/2025
8)	3/18/2025	393248	Cedar Way Elementary	Bubbler	9	Water shut off, temporary water stations provided as needed	4/18/2025

Cedar Way Elementary

9)	3/18/2025	393265	Cedar Way Elementary	Sink Fixture	9	Water shut off, temporary water stations provided as needed	4/18/2025
10)	3/18/2025	393241	Cedar Way Elementary	Water Fountain	8	Water shut off, temporary water stations provided as needed	4/18/2025
11)	3/18/2025	393278	Cedar Way Elementary	Sink Fixture	8	Water shut off, temporary water stations provided as needed	4/18/2025
12)	3/18/2025	393743	Cedar Way Elementary	Sink Fixture	8	Water shut off, temporary water stations provided as needed	4/18/2025
13)	3/18/2025	393753	Cedar Way Elementary	Sink Fixture	8	Water shut off, temporary water stations provided as needed	4/18/2025
14)	3/18/2025	393242	Cedar Way Elementary	Sink Fixture	7	Water shut off, temporary water stations provided as needed	4/18/2025
15)	3/18/2025	393747	Cedar Way Elementary	Sink Fixture	7	Water shut off, temporary water stations provided as needed	4/18/2025
16)	3/18/2025	393751	Cedar Way Elementary	Sink Fixture	7	Water shut off, temporary water stations provided as needed	4/18/2025
17)	3/18/2025	393258	Cedar Way Elementary	Sink Fixture	6	Water shut off, temporary water stations provided as needed	4/18/2025
18)	3/18/2025	393261	Cedar Way Elementary	Sink Fixture	6	Water shut off, temporary water stations provided as needed	4/18/2025
19)	3/18/2025	393273	Cedar Way Elementary	Water Fountain	6	Water shut off, temporary water stations provided as needed	4/18/2025
20)	3/18/2025	393277	Cedar Way Elementary	Bubbler	6	Water shut off, temporary water stations provided as needed	4/18/2025
21)	3/18/2025	393759	Cedar Way Elementary	Sink Fixture	6	Water shut off, temporary water stations provided as needed	4/18/2025
22)	3/18/2025	393245	Cedar Way Elementary	Sink Fixture	5	Water shut off, temporary water stations provided as needed	4/18/2025
23)	3/18/2025	393249	Cedar Way Elementary	Sink Fixture	5	Water shut off, temporary water stations provided as needed	4/18/2025

24)	3/18/2025	393755	Cedar Way Elementary	Sink Fixture	5	Water shut off, temporary water stations provided	4/18/2025
-----	-----------	--------	----------------------	--------------	---	---	-----------

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the [technical guidance](#) for remediation options.

Cedar Way Elementary has identified 24 drinking water outlets with elevated lead levels requiring remediation. (Outlets listed in the previous table with **temporary** mitigation measures are repeated in the table below.) **Remediation activities** have been or will be implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Planned or Completed Implementation Date
1)	3/18/2025	393253	Cedar Way Elementary	Water Fountain	34	Replace fixtures	ASAP
2)	3/18/2025	393737	Cedar Way Elementary	Sink Fixture	14	Replace fixtures	ASAP
3)	3/18/2025	393246	Cedar Way Elementary	Bubbler	13	Replace fixtures	ASAP
4)	3/18/2025	393274	Cedar Way Elementary	Sink Fixture	13	Replace fixtures	ASAP
5)	3/18/2025	393742	Cedar Way Elementary	Water Fountain	12	Replace fixtures	ASAP
6)	3/18/2025	393276	Cedar Way Elementary	Sink Fixture	11	Replace fixtures	ASAP
7)	3/18/2025	393244	Cedar Way Elementary	Water Fountain	9	Replace fixtures	ASAP
8)	3/18/2025	393248	Cedar Way Elementary	Bubbler	9	Replace fixtures	ASAP
9)	3/18/2025	393265	Cedar Way Elementary	Sink Fixture	9	Replace fixtures	ASAP

Cedar Way Elementary

10)	3/18/2025	393241	Cedar Way Elementary	Water Fountain	8	Replace fixtures	ASAP
11)	3/18/2025	393278	Cedar Way Elementary	Sink Fixture	8	Replace fixtures	ASAP
12)	3/18/2025	393743	Cedar Way Elementary	Sink Fixture	8	Replace fixtures	ASAP
13)	3/18/2025	393753	Cedar Way Elementary	Sink Fixture	8	Replace fixtures	ASAP
14)	3/18/2025	393242	Cedar Way Elementary	Sink Fixture	7	Replace fixtures	ASAP
15)	3/18/2025	393747	Cedar Way Elementary	Sink Fixture	7	Replace fixtures	ASAP
16)	3/18/2025	393751	Cedar Way Elementary	Sink Fixture	7	Replace fixtures	ASAP
17)	3/18/2025	393258	Cedar Way Elementary	Sink Fixture	6	Replace fixtures	ASAP
18)	3/18/2025	393261	Cedar Way Elementary	Sink Fixture	6	Replace fixtures	ASAP
19)	3/18/2025	393273	Cedar Way Elementary	Water Fountain	6	Replace fixtures	ASAP
20)	3/18/2025	393277	Cedar Way Elementary	Bubbler	6	Replace fixtures	ASAP
21)	3/18/2025	393759	Cedar Way Elementary	Sink Fixture	6	Replace fixtures	ASAP
22)	3/18/2025	393245	Cedar Way Elementary	Sink Fixture	5	Replace fixtures	ASAP
23)	3/18/2025	393249	Cedar Way Elementary	Sink Fixture	5	Replace fixtures	ASAP
24)	3/18/2025	393755	Cedar Way Elementary	Sink Fixture	5	Replace fixtures	ASAP

Cedar Way Elementary

Post-Remediation Testing

School Name	Planned Post-Remediation Testing
Cedar Way Elementary	24 outlets will be sampled and retested by: Washington State Dept of Health Sampling is scheduled for: Not yet scheduled