



September 6, 2019

Mr. Josh Warriner

Operations
Pepper Construction Company
411 Lake Zurich Road
Barrington, IL 60010

E-mail: JWarriner@pepperconstruction.com

**RE: DRINKING WATER SAMPLING REPORT AND RESULTS
COVENTRY ELEMENTARY SCHOOL**

Dear Mr. Warriner:


Pepper Environmental is pleased to provide you with the results of the water testing performed on August 30, 2019 at Coventry Elementary School in Crystal Lake, Illinois.

On August 30, 2019 a first draw water samples were collected from two (2) water sources in various locations throughout the above referenced school. A first draw water samples is a 1 liter sample of tap water that has stood motionless in the plumbing pipes for at least 6 hours and is collected without flushing the tap (40 CFR 141.2). All tap water samples that were collected were first draw samples for lead and collected in accordance with 40 CFR 141.86(b)(2). The water samples were then taken and analyzed at STAT Analysis Corporation in Chicago; for the presence of lead. Sampling locations and the lab results are attached.

All samples collected were below the EPA recommended action level of 15 ppb. No further testing will be required.

If you have any questions please call me at 847.304.1326. Please sign the authorization line below if you agree with this proposal.

Sincerely,
Pepper Environmental Technologies, Inc.


Vlastimil Korec – Project Engineer

FLUSH FOLLOW UP WATER SAMPLING LOCATIONS AND RESULTS

Sample Number & Location	First Draw Water Sampling Result (parts per billion)	Result After Flush (parts per billion)
COVENTRY ELEMENTARY SCHOOL		
1. East Fountain	<2.0	<2.0
2. West Fountain	<2.0	<2.0

STAT Analysis Corporation

2242 West Harrison St., Suite 200, Chicago, IL 60612-3766

Tel: (312) 733-0551 Fax: (312) 733-2386 STATinfo@STATAnalysis.com

Accreditations: IEPA ELAP 100445; ORELAP IL300001; AIHA-LAP, LLC 101160; NVLAP LabCode 101202-0

September 05, 2019

Pepper Environmental Technologies
411 Lake Zurich Road
Barrington, IL 60610
Telephone: (847) 304-1326
Fax: (847) 304-0121

Analytical Report for STAT Work Order: 19081297 Revision 0

RE: Coventry School, 820 Darlington Ln., Crystal Lake

Dear Vlastimil Korec:


STAT Analysis received 4 samples for the referenced project on 8/30/2019 8:55:00 AM. The analytical results are presented in the following report.

All analyses were performed in accordance with the requirements of 35 IAC Part 186 / NELAP standards. Analyses were performed in accordance with methods as referenced on the analytical report. Those analytical results expressed on a dry weight basis are also noted on the analytical report.

All analyses were performed within established holding time criteria, and all Quality Control criteria met EPA or laboratory specifications except when noted in the Case Narrative or Analytical Report. If required, an estimate of uncertainty for the analyses can be provided. A listing of accredited methods/parameters can also be provided.

Thank you for the opportunity to serve you and I look forward to working with you in the future. If you have any questions regarding the enclosed materials, please contact me at (312) 733-0551.

Sincerely,



Antonio Nevarez
Project Manager

The information contained in this report and any attachments is confidential information intended only for the use of the individual or entities named above. The results of this report relate only to the samples as received and tested. If you have received this report in error, please notify us immediately by phone. This report shall not be reproduced, except in its entirety, unless written approval has been obtained from the laboratory. This analytical report shall become property of the Customer upon payment in full. Otherwise, STAT will be under no obligation to support, defend or discuss the analytical report.

Client: Pepper Environmental Technologies
Project: Coventry School, 820 Darlington Ln., Crystal Lake
Work Order: 19081297 Revision 0

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
19081297-001A	1-A		8/30/2019 6:40:00 AM	8/30/2019
19081297-002A	1-B		8/30/2019 6:42:00 AM	8/30/2019
19081297-003A	2-A		8/30/2019 6:50:00 AM	8/30/2019
19081297-004A	2-B		8/30/2019 6:52:00 AM	8/30/2019

STAT Analysis Corporation

2242 West Harrison St., Suite 200, Chicago, IL 60612-3766

Tel: (312) 733-0551 Fax: (312) 733-2386 STATinfo@STATanalysis.com

Accreditation Numbers : IEPA ELAP 100445 ; ORELAP IL300001 ; AIHA-LAP, LLC 101160

Date Reported: September 05, 2019

ANALYTICAL RESULTS

Date Printed: September 05, 2019

Client: Pepper Environmental Technologies
 Work Order: 19081297 Revision 0
 Project: Coventry School, 820 Darlington Ln., Crystal Lake

Client ID	Additional Info	Sample ID	Matrix	Lead Result	Units	Qualifier	Analyst	Date Analyzed	Analytical Method
1-A		19081297-001A	Water	< 2.00	µg/L (ppb)		JG	09/03/2019	E200.8R5.4
1-B		19081297-002A	Water	< 2.00	µg/L (ppb)		JG	09/03/2019	E200.8R5.4
2-A		19081297-003A	Water	< 2.00	µg/L (ppb)		JG	09/03/2019	E200.8R5.4
2-B		19081297-004A	Water	< 2.00	µg/L (ppb)		JG	09/03/2019	E200.8R5.4

Qualifiers: B - Analyte detected in the associated Method Blank
 S - Spike Recovery outside accepted recovery limits

R - RPD outside accepted recovery limits
 E - Value above quantitation range
 * - Non-accredited parameter

Client: Pepper Environmental
 Street Address: 411 Lake Zurich Rd.
 City, State, Zip: Barrington, IL
 Phone: _____
 Fax: _____
 e-mail/Alt. Fax: _____
 Project Number: _____
 Project Name: Covenantry School
 Project Location: 820 Parkington by Crystal
 Project Manager: Washington Kovacs
 P.O. Number: _____

Turn Around: 4 Hrs: 8 Hrs: 24 Hrs: 1 Day: 2 Days: 3 Days: 5 Days:

Date Due: _____ Time Due: _____
 Note: Not all turn around times are available for all analysis.

OFFICE USE ONLY BELOW:
 Batch No.: 1908/297
 Samples Acceptable: Yes: No:
 Checked by (Initial/Date): ADN 9/5/19
 QC by (Initial/Date): _____
 Reported By (Initial/Date/Time/Method): _____
 Comments: _____

Relinquished by: _____ Date/Time: 8/30/19 9:17
 Received by: _____ Date/Time: 8/30/19 8:55
 Relinquished by: _____ Date/Time: _____
 Received by: _____ Date/Time: _____
 Relinquished by: _____ Date/Time: _____
 Received by: _____ Date/Time: _____

Client Sample Number/Description: Date Taken	Time		Rate (lpm)	Volume (Liters)	Area Wiped (ft ²)	Laboratory Sample No.	Lead Air	Lead Ambient Air	Lead Based Paint	Lead Soil	Lead Drinking Water	Lead Waste Water	Lead Wipe	TCLP Lead	TCLP RCRA Metals	Dust NIOSH 500	Dust NIOSH 600	Hexavalent Chromium	Other:
	On	Off																	
1-A drinking fountain 8-30-19	6:47	6:50				001					X								
1-B I	6:47	6:47				002					I								
2-A drinking foun - West	6:47	6:53				003					I								
2-B I	6:52					004					I								

Comments: Please email results to vkovacs@pepperenvironmental.com