



**Business Services
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824
(916) 643-2464

*Janea Marking, Chief Business Officer
Robert Aldama, Purchasing Manager II*

ADDENDUM NO. 1

Date: July 30, 2025

Issued by: Sacramento City Unified School District

**Project: Project #: 0480-411
Sam Brannan MS Telecenter**

This addendum shall supersede the original Information, attachments, and specifications regarding Project No. 0480-411 where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

Part A – BIDDING AND CONTRACT REQUIREMENTS:

00 42 00 Proposal Form – Updated to clarify that the allowance for unforeseen conditions shall be equal to 10% of the bid amount.

Part B – TECHNICAL REQUIREMENTS:

No changes.

PART C – DRAWINGS:

Sheet T000 – updated detail references

Sheet T010 – added Keynote 12 and related picture detail; demo scope at office headend equipment

Sheet T703 – updated equipment schedule

PART D – BIDDERS QUESTIONS & RESPONSES:

AD1.01 QUESTIONS:

Please confirm if summer school will be in session during this project. If so, please provide the summer school schedule and occupied areas of the campus.

AD1.01 ANSWER

Summer school will not be in session during this project.

Project No: 0480-411
Sam Brannan MS Telecenter
ADDENDUM NO. 1

AD1.02 QUESTION

The RFP states Pollution Liability insurance is required if the scope includes any elements that may give rise to a pollution claim. Please confirm if that is applicable to this project.

AD1.02 ANSWER

No, not for the Sam Brannan MS Telecenter project.

AD1.03 QUESTION

Section 3.15 of the RFP states that Builders Risk Insurance will be required. Please confirm if that is applicable to this project, given the nature of work defined in the plans and specifications.

AD1.03 ANSWER

No, not for the Sam Brannan MS Telecenter project.

AD1.04 QUESTION

I would like to submit Primex as a substitute for notification boards & clocks for two more projects at the district: 1) Sam Brannan Telecenter

AD1.04 ANSWER

Refer to 00 72 00 11.08 which states, in part, "Substitution proposals will not be considered prior to bidding."

AD1.05 QUESTION

Can you please identify the ceiling types on sheet T202?

AD1.05 ANSWER

All of the locations on Sheet T202 are hard-lid.

AD1.06 QUESTION

Sheet T205 shows hard lids with multiple 6A drops. Will a Wiremold trunkline be required? Other wings show Wiremold trunk or J hooks in similar situations. This same question would apply to the previous question about T202 if it is hard lid.

AD1.06 ANSWER

The locations on T202 and T205 are fed from an existing exterior 2" backbone on the canopy. Refer to the site plan on T100 for more detail. Assume the exterior backbone and penetrations to each classroom are adequate for the new data drops required at these locations.

Project No: 0480-411
Sam Brannan MS Telecenter
ADDENDUM NO. 1

ATTACHMENTS:

Contract Documents:
00 42 00 Proposal Form

Drawings:
Sheet T000
Sheet T010
Sheet T703

END OF ADDENDUM NO. 1

Acknowledgement of this Addendum will be required at time of bid.