



PATERSON PUBLIC SCHOOLS



Department of Facilities
200 Sheridan Avenue Paterson NJ 07502
Office (973) 321-2262 Fax (973) 321-0965

Neil Mapp
Chief Officer of Facilities and Custodial Services
Email: nmapp@paterson.k12.nj.us

Laurie W. Newell, PhD
Superintendent of Schools

August 29, 2025

Facilities Department
Paterson Public Schools
200 Sheridan Ave

Dear Paterson Community,

Paterson Public Schools is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Paterson Public Schools tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Paterson Public Schools implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]).

We are pleased to report that all fixtures that were previously tested and had results higher than 15 µg/l (parts per billion [ppb]) have been retested. After remedial actions were taken on all outlets, the results were within acceptable levels or no lead was detected (ND).

Buildings and results are as follows:

Building	Fixture location	Result
SAGE	WF6/3rd FI Hallway by Room 310	ND
PS1 + PS26	16 - WF8/Basement Hallway by Room B5	9.91
Roberto Clemente	WF4/Inside Room 3	8.01
International HS	SF8/Kitchen	ND
PS9	SF8/2nd FI Library - Back Room	1.13
JFK HS	WF5/1st Floor Hallway by Auditorium – Exit Door #40	ND
PS28	WF9/Inside Classroom 102	12.0
PS28	SF2/Inside Nurses Office	ND
PS28	SF/Inside Nurses Office	ND
PS28	SF4/3rd FI Staff Lounge	6.44

cc: Superintendent
SBA
Deputy & Assistant Superintendents/ Principals
Security
Central Stores
Food Service
Staff Attendance
Payroll