

Addendum #1 to the Bid Documents for
Gallia Storage Shed
for Gallipolis City Schools

Addendum Issued: 9/4/25 at 2:00 PM

The following items shall be added to the Bid Documents originally issued for the Subject Project. Bidders shall acknowledge receipt of this Addendum.



ARCHITECTURAL ITEMS:

A1. Sheet A111 Plans, Elevations, Sections

- A. Where metal panels and metal trim are indicated in Numbered Notes and details, REVISE to 26 ga. 24 ga. or 26 ga. metal may be used in these locations at contractor's option.

STRUCTURAL ITEMS:

S1. Sheet S331 Framing Plan and Details

- A. REVISE Detail 7/S331: Wall bracing requirements: 24 ga. or 26 ga. structural steel panels installed to exterior wall purlins with screws.
- B. ADD Framing General Note L: At contractor's option, PT 3 ply 2x8 laminated posts may be site assembled. Assembly must be approved by Architect prior to construction.

ATTACHED:

none

END OF ADDENDUM #1