

# J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



1775 Expressway Drive North  
Hauppauge, NY 11788  
631.584.5492  
Fax: 631.584.3395  
www.jcbroderick.com

August 18, 2025

Mr. Severino Fasulo  
Syosset Central School District  
99 Pell Lane  
Syosset, New York 11791

Re: **Lead Testing in School Drinking Water  
Remedial Action Plan  
2023 Compliance 10 NYCRR Subpart 67-4**

JCB#: **23-53856**

Dear Mr. Fasulo:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan  
Attachment 2: Outlet Inventory and Lead Testing Results  
Attachment 3: Laboratory Analytical Reports  
Attachment 4: Laboratory Certifications


If you have any questions, or if more information is needed, please contact our office.

Sincerely,

A handwritten signature in black ink, appearing to read 'Bryan Ezelius', is written over a light blue horizontal line.

Bryan Ezelius  
J C Broderick & Associates, Inc.

Attachment 1:  
  
Lead in Water  
Remediation Plan



**J.C. Broderick & Associates, Inc.**  
*Environmental Consulting & Testing*  
1775 Expressway Drive North  
Hauppauge, New York 11788  
631.584.5492 fax 631.584.3395

# Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

*If the lead concentration of water at an outlet exceeds the action level, the school shall:*

*(a) prohibit use of the outlet until:*

- (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and*
- (2) test results indicate that the lead levels are at or below the action level;*

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

## **Step 1A: Potable Outlets** (Outlets intended to be used for drinking/cooking)

Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

## **Step 1B: Non-Potable Outlets** (Outlets not intended for drinking/cooking)


See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: [https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns\\_lead .pdf](https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead.pdf).



Do not use for drinking



Hand washing only




## **Step 2: Service & Repair or Outlet Replacement**

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

## **Step 3: Retesting & Return to Service**

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:  
  
Outlet Inventory and  
Lead Testing Results



**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395



# Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856

## Syosset Central School District

### Syosset High School

| Outlet Number | Room Name                             | Space ID | Outlet Type                  | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|---------------------------------------|----------|------------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0001     | Custodial Lounge Head Office Bathroom | 2360     | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0002     | Custodial Lounge                      | 2362     | Hand Wash Only               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0003     | S03                                   | 2364     | Slop Sink                    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0004     | S03                                   | 2364     | Tempered Water Outlet        | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0005     | Men's Bathroom Adjacent S03           | 2365     | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0006     | S02                                   | 2367     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0007     | S01                                   | 2371     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0008     | S01                                   | 2371     | Water Fountain-No Chiller    | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0009     | Band Room                             | 2376     | Hand Wash Only               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0010     | HE 2 Bathroom                         | 2382     | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0011     | HE 2                                  | 2381     | Home Economics Faucet (Cold) | Potable                        | 5/31/2025           | 1.9                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0012     | HE 2                                  | 2381     | Home Economics Faucet (Cold) | Potable                        | 5/31/2025           | 1.9                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0013     | HE 3                                  | 2380     | Home Economics Faucet (Cold) | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0014     | HE 3                                  | 2380     | Home Economics Faucet (Cold) | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0015     | HE 3                                  | 2380     | Home Economics Faucet (Cold) | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0016     | HE 3                                  | 2380     | Home Economics Faucet (Cold) | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |

# Syosset High School

| Outlet Number | Room Name                       | Space ID | Outlet Type                  | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|---------------------------------|----------|------------------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0017     | HE 3                            | 2380     | Home Economics Faucet (Cold) | Potable                  | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0018     | Auditorium Corridor             | 2340     | Bottle Fill Station          | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-0019     | Auditorium Corridor             | 2340     | Water Cooler                 | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-0020     | Women's Bathroom B6             | 2344     | Bathroom Faucet              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0021     | Women's Bathroom B6             | 2344     | Bathroom Faucet              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0022     | Men's Bathroom Custodial Closet | 2334A    | Slop Sink                    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0023     | Men's Bathroom                  | 2334     | Bathroom Faucet              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0024     | Art Room                        | 2251     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0025     | Art Room                        | 2251     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0026     | Photography Room                | 2250     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0027     | Photography Room                | 2250     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0028     | Photography Room                | 2250     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0029     | Dark Room                       | 2249     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0030     | Art Room                        | 2245     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0031     | Art Room                        | 2245     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0032     | Art Room                        | 2245     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0033     | Art Room                        | 2245     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0034     | Art Room                        | 2245     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0035     | Art Room                        | 2245     | Classroom Faucet             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0036     | Chorus Girl's Bathroom (Left)   | 2353     | Bathroom Faucet              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

# Syosset High School

| Outlet Number | Room Name                                       | Space ID | Outlet Type            | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status                       |
|---------------|---|----------|------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0037     | <b>Chorus Men's Room (Right)</b>                | 2352     | Bathroom Faucet        | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0038     | <b>Chemical Storage</b>                         | 2348     | Slop Sink              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0039     | <b>Corridor In Front Of 1st Floor Cafeteria</b> | 1001     | Hand Wash Only         | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0040     | <b>Corridor In Front Of 1st Floor Cafeteria</b> | 1001     | Hose Bib               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0041     | <b>Cafeteria East Office/Snack Area</b>         | 2244A    | Kitchen Faucet (Cold)  | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0042     | <b>Cafeteria East</b>                           | 2244     | Bottle Fill Station    | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0043     | <b>Cafeteria East</b>                           | 2244     | Water Cooler           | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0044     | <b>Cafeteria East Custodial Closet</b>          | 2243     | Slop Sink              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0045     | <b>Serving Area East</b>                        | 2240     | Kitchen Faucet (Cold)  | Potable                        | 5/31/2025           | 9.3                  | 8/13/2025                    | 4.3                           | Outlet Remediated Result Below Action Level Continue O&M |
| SCSD-0046     | <b>Kitchen</b>                                  | 2242     | Kitchen Faucet (Cold)  | Potable                        | 5/31/2025           | 1.2                  |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0047     | <b>Kitchen</b>                                  | 2242     | Hand Wash Only         | Non-Potable                    | 5/31/2025           | 2.7                  |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0048     | <b>Kitchen</b>                                  | 2242     | Kitchen Faucet (Cold)  | Potable                        | 5/31/2025           | 3.5                  |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0049     | <b>Kitchen</b>                                  | 2242     | Ice Machine            | Potable                        | 5/31/2025           | 3.0                  |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0050     | <b>Kitchen</b>                                  | 2242     | Pasta Pot/Steam Kettle | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                               |
| SCSD-0051     | <b>Attached Hose</b>                            | 2242     | Kitchen Faucet (Cold)  | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                               |
| SCSD-0052     | <b>Kitchen</b>                                  | 2242     | Kitchen Faucet (Cold)  | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                               |
| SCSD-0053     | <b>Kitchen</b>                                  | 2242     | Kitchen Faucet (Cold)  | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                               |
| SCSD-0054     | <b>Kitchen</b>                                  | 2242     | Pasta Pot/Steam Kettle | Potable                        | 5/31/2025           | 2.1                  |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0055     | <b>Kitchen</b>                                  | 2242     | Kitchen Faucet (Cold)  | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-0056     | <b>Serving Area West</b>                        | 2237     | Kitchen Faucet (Cold)  | Potable                        | 5/31/2025           | 2.9                  |                              |                               | Result Below Action Level Continue O&M                   |

# Syosset High School

| Outlet Number | Room Name   | Space ID | Outlet Type           | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status  |
|---------------|---|----------|-----------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|-------------------------------------|
| SCSD-0057     | Cafeteria West                                      | 2234     | Bottle Fill Station   | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1448 |
| SCSD-0058     | Cafeteria West                                      | 2234     | Water Cooler          | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1449 |
| SCSD-0059     | Faculty Men's Bathroom                              | 2231     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0060     | Women's Faculty Bathroom                            | 2228     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0061     | Boy's Bathroom                                      | 2084     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0062     | Boy's Bathroom                                      | 2084     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0063     | Boy's Bathroom                                      | 2084     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0064     | Boy's Bathroom                                      | 2084     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0065     | Boy's Bathroom                                      | 2084     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0066     | Art Office  | 2075     | Kitchen Faucet (Cold) | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed          |
| SCSD-0067     | Men's Bathroom (now all gender restroom)            | 2082A    | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0068     | Kitchen   | 2082     | Slop Sink             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0069     | New Women's Faculty Bathroom (Former Room CD6)      | 2061     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0070     | New Women's Faculty Bathroom (Former Room CD6)      | 2061     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0071     | New Men's Faculty Bathroom (Former Room CD4 Chorus) | 2060     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0072     | Girl's Bathroom                                     | 2081     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0073     | Girl's Bathroom                                     | 2081     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0074     | Girl's Bathroom                                     | 2081     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0075     | Girl's Bathroom                                     | 2081     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0076     | Girl's Bathroom                                     | 2081     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |

# Syosset High School

| Outlet Number | Room Name                                | Space ID | Outlet Type           | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status  |
|---------------|--|----------|-----------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|-------------------------------------|
| SCSD-0077     | Room C3A                                 | 2067A    | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0078     | Year Book Room                           | 2067B    | Kitchen Faucet (Cold) | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed          |
| SCSD-0079     | Corridor From Room 243 To Room 230       | 2058     | Kitchen Faucet (Cold) | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed          |
| SCSD-0080     | Corridor D Wing to Cafeteria             | 2045     | Bottle Fill Station   | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1450 |
| SCSD-0081     | Corridor D Wing to Cafeteria             | 2045     | Water Cooler          | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1451 |
| SCSD-0082     | Art Room                                 | 2057     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0083     | Art Room                                 | 2057     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0084     | Art Room                                 | 2052     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0085     | Art Room                                 | 2052     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0086     | Room 217 Office                          | 2023B    | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0087     | Room 217 Office                          | 2023B    | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0088     | Room 217 Office                          | 2023B    | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0089     | Corridor Room D6A to D10 o/s 105B Office | 2033     | Bottle Fill Station   | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1452 |
| SCSD-0090     | Corridor Room D6A to D10 o/s 105B Office | 2033     | Water Cooler          | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1453 |
| SCSD-0091     | 105B                                     | 2032     | Kitchen Faucet (Cold) | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed          |
| SCSD-0092     | Women's Bathroom (all-gender restroom)   | 2023A    | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0093     | 107 Closet                               | 2021     | Slop Sink             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0094     | Room 215                                 | 2020     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0095     | Room 215                                 | 2020     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0096     | Room 215                                 | 2020     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |

# Syosset High School

| Outlet Number | Room Name | Space ID | Outlet Type           | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|-----------|----------|-----------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0097     | Room 215  | 2020     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0098     | Room 215  | 2020     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0099     | Room D4A  | 2014B    | Kitchen Faucet (Cold) | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed         |
| SCSD-0100     | Room 206  | 2010     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0101     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0102     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0103     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0104     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0105     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0106     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0107     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0108     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0109     | E104      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0110     | E103      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0111     | E103      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0112     | E103      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0113     | E103      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0114     | E103      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0115     | E103      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0116     | E103      | NA       | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Syosset High School

| Outlet Number | Room Name        | Space ID | Outlet Type         | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status  |
|---------------|------------------|----------|---------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|-------------------------------------|
| SCSD-0117     | E103             | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0118     | E103             | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0119     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0120     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0121     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0122     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0123     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0124     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0125     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0126     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0127     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0128     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0129     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0130     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0131     | E99              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0132     | Corridor (E90's) | NA       | Bottle Fill Station | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1513 |
| SCSD-0133     | Corridor (E90's) | NA       | Water Cooler        | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1514 |
| SCSD-0134     | E98              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0135     | E98              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0136     | E98              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |

# Syosset High School

| Outlet Number | Room Name                   | Space ID | Outlet Type    | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|-----------------------------|----------|----------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0137     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0138     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0139     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0140     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0141     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0142     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0143     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0144     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0145     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0146     | E98                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0147     | E97                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0148     | E97                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0149     | E97                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0150     | Science Storage Adj. to E96 | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0151     | Science Storage Adj. to E96 | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0152     | E96                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0153     | E96                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0154     | E96                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0155     | E96                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0156     | E96                         | NA       | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Syosset High School

| Outlet Number | Room Name        | Space ID | Outlet Type         | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status  |
|---------------|------------------|----------|---------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|-------------------------------------|
| SCSD-0157     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0158     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0159     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0160     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0161     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0162     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0163     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0164     | E96              | NA       | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0165     | Corridor (E30's) | NA       | Bottle Fill Station | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1454 |
| SCSD-0166     | Corridor (E30's) | NA       | Water Cooler        | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1453 |
| SCSD-0167     | 127              | 2130     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0168     | 127              | 2130     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0169     | 127              | 2130     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0170     | Room E10         | 2098     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0171     | Room E10         | 2098     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0172     | Room E10         | 2098     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0173     | Room E10         | 2098     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0174     | Room E10         | 2098     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0175     | Room E10         | 2098     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-0176     | Room E10         | 2098     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |

# Syosset High School

| Outlet Number | Room Name           | Space ID | Outlet Type    | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|---------------------|----------|----------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0177     | Passage From E9-E10 | 2098B    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0178     | Room E9             | 2098A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0179     | Room E9             | 2098A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0180     | Room E9             | 2098A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0181     | Room E9             | 2098A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0182     | Room E9             | 2098A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0183     | Room E9             | 2098A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0184     | Room E9             | 2098A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0185     | 120 Storage         | 2133     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0186     | 120 Storage         | 2133     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0187     | 120 Storage         | 2133     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0188     | Room E8             | 2099     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0189     | Room E8             | 2099     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0190     | Room E8             | 2099     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0191     | Room E8             | 2099     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0192     | Room E8             | 2099     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0193     | Room E8             | 2099     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0194     | Room E8             | 2099     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0195     | Passage From E7-E8  | 2099A    | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0196     | Room E7             | 2102     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Syosset High School

| Outlet Number | Room Name                         | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|-----------------------------------|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0197     | Room E7                           | 2102     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0198     | Room E7                           | 2102     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0199     | Room E7                           | 2102     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0200     | Room E7                           | 2102     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0201     | Room E7                           | 2102     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0202     | Room E7                           | 2102     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0203     | Room E6                           | 2103     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0204     | Room E6                           | 2103     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0205     | Room E6                           | 2103     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0206     | Room E6                           | 2103     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0207     | Room E6                           | 2103     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0208     | Corridor E6-E11                   | 2131     | Bottle Fill Station | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0209     | Corridor E6-E11                   | 2131     | Water Cooler        | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0210     | E Wing Downstairs Men's Room      | 2106     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0211     | E Wing Downstairs Men's Room      | 2106     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0212     | E Wing Downstairs Men's Room      | 2106     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0213     | Slop Sink Area                    | 2107     | Slop Sink           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0214     | E Wing Downstairs Girl's Bathroom | 2109     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0215     | E Wing Downstairs Girl's Bathroom | 2109     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0216     | E Wing Downstairs Girl's Bathroom | 2109     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Syosset High School

| Outlet Number | Room Name | Space ID | Outlet Type    | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|-----------|----------|----------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0217     | Copy Room | 2112     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0218     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0219     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0220     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0221     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0222     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0223     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0224     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0225     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0226     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0227     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0228     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0229     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0230     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0231     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0232     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0233     | Room E5   | 2113     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0234     | Room E4   | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0235     | Room E4   | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0236     | Room E4   | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Syosset High School

| Outlet Number | Room Name                       | Space ID | Outlet Type    | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|---------------------------------|----------|----------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0237     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0238     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0239     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0240     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0241     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0242     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0243     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0244     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0245     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0246     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0247     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0248     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0249     | Room E4                         | 2114     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0250     | Basement Stairwell Adjacent 130 | 2115     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0251     | Room E3                         | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0252     | Room E3                         | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0253     | Room E3                         | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0254     | Room E3                         | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0255     | Room E3                         | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0256     | Room E3                         | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Syosset High School

| Outlet Number | Room Name | Space ID | Outlet Type    | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|-----------|----------|----------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0257     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0258     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0259     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0260     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0261     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0262     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0263     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0264     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0265     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0266     | Room E3   | 2117     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0267     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0268     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0269     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0270     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0271     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0272     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0273     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0274     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0275     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0276     | Room E2   | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Syosset High School

| Outlet Number | Room Name                    | Space ID | Outlet Type    | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|------------------------------|----------|----------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0277     | Room E2                      | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0278     | Room E2                      | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0279     | Room E2                      | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0280     | Room E2                      | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0281     | Room E2                      | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0282     | Room E2                      | 2118     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0283     | Faculty Lounge               | 2119     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0284     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0285     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0286     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0287     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0288     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0289     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0290     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0291     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0292     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0293     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0294     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0295     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0296     | Faculty Lounge Phone Booth 2 | 2121     | Science Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Syosset High School

| Outlet Number | Room Name                            | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--------------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0297     | Faculty Lounge Phone Booth 2         | 2121     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0298     | Faculty Lounge Phone Booth 2         | 2121     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0299     | Faculty Lounge Phone Booth 2         | 2121     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0300     | Corridor E1-E5                       | 2136     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0301     | Faculty Lounge Phone Booth 1         | 2120     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0302     | 130                                  | 2116     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0303     | Science Office                       | 2125     | Kitchen Faucet (Cold)     | Potable                        | 5/31/2025           | 2.1                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0304     | Room E22                             | 3395     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0305     | Room E22                             | 3395     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0306     | Room E22                             | 3395     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0307     | Room E22                             | 3395     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0308     | Room E21                             | 3396     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0309     | Room E21                             | 3396     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0310     | Room E21                             | 3396     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0311     | Room E21 Prep Room                   | 3396A    | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0312     | Room E21 Prep Room                   | 3396A    | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0313     | E Wing Men's Faculty Bathroom        | 3419B    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0314     | Faculty Room (Interior Wall Removed) | 3426A    | Kitchen Faucet (Cold)     | Potable                        | 5/31/2025           | 2.0                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0315     | E Wing Boy's Bathroom                | 3405     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0316     | E Wing Boy's Bathroom                | 3405     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Syosset High School

| Outlet Number | Room Name                                | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0317     | E Wing Boy's Bathroom                    | 3405     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0318     | E Wing Custodial Closet                  | 3405A    | Slop Sink           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0319     | Corridor E12-E15                         | 3431     | Bottle Fill Station | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0320     | Corridor E12-E15                         | 3431     | Water Cooler        | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0321     | E Wing Girl's Bathroom                   | 3407     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0322     | E Wing Girl's Bathroom                   | 3407     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0323     | E Wing Girl's Bathroom                   | 3407     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0324     | E Wing Upstairs Faculty Women's Bathroom | 3422B    | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0325     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0326     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0327     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0328     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0329     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0330     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0331     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0332     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0333     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0334     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0335     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0336     | Room E12                                 | 3415     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Syosset High School

| Outlet Number | Room Name                      | Space ID | Outlet Type           | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|--------------------------------|----------|-----------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0337     | Room E12                       | 3415     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0338     | Room E12 Closet                | 3415A    | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0339     | Room E11                       | 3416     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0340     | Room E11                       | 3416     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0341     | Room E11                       | 3416     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0342     | Room E11                       | 3416     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0343     | Room E11A                      | 3417     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0344     | Room E11A                      | 3417     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0345     | Science Copy Room              | 2132     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0346     | Inside Fume Hood               | 2099     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0347     | Inside Fume Hood               | 2113     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0348     | Inside Fume Hood               | 2114     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0349     | Inside Fume Hood               | 2117     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0350     | Inside Fume Hood               | 2118     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0351     | Room B6A                       | 2224     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0352     | Room B6A                       | 2224     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0353     | Room B6A                       | 2224     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0354     | Room B6A                       | 2224     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0355     | Room B6A                       | 2224     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0356     | Room B12A AV Tech Large Office | 2203     | Kitchen Faucet (Cold) | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed         |

# Syosset High School

| Outlet Number | Room Name                 | Space ID | Outlet Type           | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|---------------------------|----------|-----------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0357     | Custodial Closet          | 2211     | Slop Sink             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0358     | Room B6B                  | 2222     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0359     | Room B6B                  | 2222     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0360     | Room B6B                  | 2222     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0361     | Room B6B                  | 2222     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0362     | Room B6B                  | 2222     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0363     | Auditorium Closet         | 2219     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0364     | Auditorium Closet         | 2219     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0365     | Auditorium Closet         | 2219     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0366     | Auditorium Closet         | 2219     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0367     | Auditorium Closet         | 2219     | Science Faucet        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0368     | B Wing Boy's Bathroom     | 2213     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0369     | B Wing Boy's Bathroom     | 2213     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0370     | B Wing Boy's Bathroom     | 2213     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0371     | B Wing Boy's Bathroom     | 2213     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0372     | B-Wing Single Toilet Room | 2213A    | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0373     | Faculty Women's Bathroom  | 2210     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0374     | Faculty Women's Bathroom  | 2210     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0375     | Room B3A                  | 2194A    | Kitchen Faucet (Cold) | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-0376     | Library Office            | 2189     | Kitchen Faucet (Cold) | Potable                  | 5/31/2025           | 2.3                  |                              |                               | Result Below Action Level Continue O&M |

# Syosset High School

| Outlet Number | Room Name                              | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0377     | Quarter Mile Corridor South            | 2191     | Bottle Fill Station   | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0378     | Quarter Mile Corridor South            | 2191     | Water Cooler          | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0379     | Nurse Bathroom                         | 2269     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0380     | Nurse's Office                         | 2274     | Nurse's Office Sink   | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0381     | Nurse's Office                         | 2274     | Nurse's Office Sink   | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0382     | Nurse Storage Room                     | 2274A    | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0383     | Main Hall Copy Room                    | 2265B    | Kitchen Faucet (Cold) | Potable                        | 5/31/2025           | 1.6                  |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0384     | Attendance Office<br>Kitchen/Copy Room | 2272     | Kitchen Faucet (Cold) | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-0385     | Main Entrance Corridor                 | 2257     | Bottle Fill Station   | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0386     | Main Entrance Corridor                 | 2257     | Water Cooler          | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0387     | Main Entrance Women's Room             | 2258     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0388     | Main Entrance Men's Room               | 2259     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0389     | Quarter Mile Corridor South            | 2191     | Bottle Fill Station   | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0390     | Quarter Mile Corridor South            | 2191     | Water Cooler          | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0391     | Business Education Office              | 2281     | Kitchen Faucet (Cold) | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0392     | Room A14 (Alarmed)                     | 2285     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0393     | Guidance Office Kitchen G10            | 2178A    | Kitchen Faucet (Cold) | Potable                        | 5/31/2025           | 2.8                  |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0394     | Men's Faculty A Wing Bathroom          | 2170A    | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0395     | Men's Faculty A Wing Bathroom          | 2170A    | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0396     | Men's Faculty A Wing Bathroom          | 2170A    | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

# Syosset High School

| Outlet Number | Room Name                       | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|---------------------------------|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0397     | A Wing Custodial Closet         | 2168     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0398     | Women's Faculty A Wing Bathroom | 2170     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0399     | A Wing Corridor                 | 2147     | Bottle Fill Station   | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0400     | A Wing Corridor                 | 2147     | Water Cooler          | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0401     | Custodial Office Bathroom       | 2150     | Kitchen Faucet (Cold) | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-0402     | Girl's Bathroom A Wing          | 2167     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0403     | Girl's Bathroom A Wing          | 2167     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0404     | Coach's Office Bathroom         | 2295A    | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0405     | Courtyard o/s 2178              | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0406     | Courtyard o/s 2099              | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0407     | Courtyard Greenhouse o/s 2052   | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0408     | Courtyard Greenhouse o/s 2052   | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0409     | Courtyard o/s 2117              | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0410     | Courtyard o/s 2190A             | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0411     | Courtyard o/s 2188              | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0412     | Courtyard o/s 2256              | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0413     | Exterior o/s 2285               | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0414     | Exterior o/s 2262               | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0415     | Exterior o/s 2332               | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0416     | Exterior o/s 2332               | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

# Syosset High School

| Outlet Number | Room Name                           | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|-------------------------------------|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0417     | Exterior o/s 2319                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0418     | Exterior o/s E96                    | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0419     | Exterior o/s 2017                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0420     | Exterior o/s 2019                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0421     | Exterior o/s 2085                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0422     | Exterior o/s 2351                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0423     | Exterior o/s 2362                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0424     | Exterior o/s 2380                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0425     | Exterior o/s 2340                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0426     | Exterior o/s 2257                   | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1214     | Main Gym Lobby Men's Bathroom       | 2302     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1215     | Girl's Locker Room                  | 2331     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1216     | Girl's Locker Room                  | 2331     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1217     | Girl's Locker Room                  | 2331     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1218     | Girl's Locker Room                  | 2331     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1219     | Girl's Locker Room                  | 2331     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1220     | Girl's Locker Room                  | 2331     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1221     | Girl's Locker Room                  | 2331     | Bottle Fill Station | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1222     | Girl's Locker Room                  | 2331     | Water Cooler        | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1223     | Girl's Locker Room Custodial Closet | 2331B    | Slop Sink           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

# Syosset High School

| Outlet Number | Room Name   | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|---|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1224     | Girl's Locker Room  | 2331     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1225     | Auxiliary Gym Electrical Equipment Room                   | 2329     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1226     | Auxiliary Gym   | 2332     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | 3.9                  |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1227     | Boy's Locker Room B2                                      | 2306I    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1228     | Boy's Locker Room B4                                      | 2306P    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1229     | Boy's Locker Room B3                                      | 2306L    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1230     | Boy's Pool Locker Room                                    | 2312     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1231     | Corridor Between Gym & Locker Rooms                       | 2308     | Bottle Fill Station       | RFI                            |                     |                      |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1232     | Corridor Between Gym & Locker Rooms                       | 2308     | Water Cooler              | RFI                            |                     |                      |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1233     | Boy's Locker Room B1                                      | 2306B    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1234     | Main Gym Lobby Women's Bathroom                           | 2303     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1235     | Exit Vestibule Bathroom Adjacent Athletic Director 1      | 2314     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1236     | Laundry Room  | 2315     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1237     | Laundry Room  | 2319     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1238     | Men's Bathroom Near Pool                                  | 2322A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1239     | Girl's Pool Bathroom                                      | 2322B    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1278     | Boy's Pool Locker Room Shower/Bathroom                    | 2327A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1279     | Main Gym  | 2293     | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1456    |
| SCSD-1280     | Trainer's Office and Part of Locker Room share a Space ID | 2306A    | Hand Wash Only            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1286     | Trainer's Office and Part of Locker Room share a Space ID | 2306A    | Ice Machine               | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |

# Syosset High School

| Outlet Number | Room Name  | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1287     | <b>Trainer's Office and Part of Locker Room share a Space ID</b> | 2306A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1288     | <b>Main Gym</b>  | 2293     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | 2.5                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1348     | <b>Boy's Bathroom by Room 19</b>                                 | 2064     | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1378     | <b>Auxiliary Gym</b>   | 2332     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | 102                  | 8/13/2025                    | 52.5                          | Removed From Service, Pending Remediation |
| SCSD-1380     | <b>Room D3A Office</b>   | 2013     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1381     | <b>Room D3A Office</b>   | 2013     | Hand Wash Only            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1383     | <b>Men's Bathroom (Fitness Center); Tempered</b>                 | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1384     | <b>Corridor (Fitness Center)</b>                                 | NA       | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1385     | <b>Corridor (Fitness Center)</b>                                 | NA       | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1386     | <b>Corridor (Fitness Center)</b>                                 | NA       | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1387     | <b>Women's Bathroom (Fitness Center); Tempered</b>               | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1388     | <b>Men's Bathroom (Fitness Center)</b>                           | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1389     | <b>Women's Bathroom (Fitness Center)</b>                         | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1390     | <b>Custodial Closet (Fitness Center)</b>                         | NA       | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1391     | <b>Admin Office (Fitness Center)</b>                             | NA       | Kitchen Faucet (Cold)     | Potable                        | 5/31/2025           | 1.8                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1392     | <b>Fitness Center</b>  | NA       | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1393     | <b>Fitness Center</b>  | NA       | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1394     | <b>Fitness Center</b>  | NA       | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1395     | <b>Girls' Locker Room (Fitness Center); Tempered</b>             | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1396     | <b>Girls' Locker Room (Fitness Center); Tempered</b>             | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Syosset High School

| Outlet Number | Room Name                                     | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|---|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1397     | Girls' Locker Room (Fitness Center); Tempered | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1398     | Girls' Locker Room (Fitness Center)           | NA       | Shower Head               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1399     | Girls' Locker Room (Fitness Center)           | NA       | Shower Head               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1400     | Girls' Locker Room (Fitness Center)           | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1401     | Boys' Locker Room (Fitness Center)            | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1402     | Boys' Locker Room (Fitness Center)            | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1403     | Boys' Locker Room (Fitness Center)            | NA       | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1404     | Boys' Locker Room (Fitness Center)            | NA       | Shower Head               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1405     | Boys' Locker Room (Fitness Center)            | NA       | Shower Head               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1406     | Boys' Locker Room (Fitness Center)            | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1407     | Exterior Girls' Bathroom (Fitness Center)     | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1408     | Exterior Girls' Bathroom (Fitness Center)     | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1409     | Exterior Girls' Bathroom (Fitness Center)     | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1410     | Exterior Boys' Bathroom (Fitness Center)      | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1411     | Exterior Boys' Bathroom (Fitness Center)      | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1412     | Exterior Boys' Bathroom (Fitness Center)      | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1413     | Exterior o/s Fitness Center                   | NA       | Bottle Fill Station       | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-1414     | Exterior o/s Fitness Center                   | NA       | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-1448     | Cafeteria West                                | 2234     | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1449     | Cafeteria West                                | 2234     | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |

# Syosset High School

| Outlet Number | Room Name                                | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1450     | Corridor D Wing to Cafeteria             | 2045     | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1451     | Corridor D Wing to Cafeteria             | 2045     | Water Cooler              | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1452     | Corridor Room D6A to D10 o/s 105B Office | 2033     | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1453     | Corridor Room D6A to D10 o/s 105B Office | 2033     | Water Cooler              | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1454     | Corridor E30's                           | N/A      | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1455     | Corridor E30's                           | N/A      | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1456     | Main Gym                                 | 2293     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | 1.2                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1513     | Corridor (E90's)                         | NA       | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1514     | Corridor (E90's)                         | NA       | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1515     | Corridor Between Gym & Locker Rooms      | 2308     | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1516     | Corridor Between Gym & Locker Rooms      | 2308     | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1777     | Exterior of Barn                         | N/A      | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1778     | Exterior of Barn                         | N/A      | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1779     | Exterior o/s Fitness Center              | N/A      | Bottle Fill Station       | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1780     | Exterior o/s Fitness Center              | N/A      | Water Cooler              | Potable                        | 5/31/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |

# South Woods Middle School

| Outlet Number | Room Name                                   | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|---|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0427     | Gym Girl's Locker Room                      | 2091     | Water Fountain-No Chiller | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0428     | Gym Girl's Locker Room                      | 2091     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0429     | Gym Girl's Locker Room                      | 2091     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0430     | Gym Girl's Locker Room Custodial Storage    | 2091A    | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0431     | Gym Girl's Coach Office Bathroom            | 2093A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0432     | Gym Boy's Locker Room                       | 2095     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0433     | Gym Boy's Locker Room                       | 2095     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0434     | Gym Boy's Locker Room Coach Office Bathroom | 2094A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0435     | Corridor North Cafeteria to Boy's Bathroom  | 2143     | Bottle Fill Station       | Potable                        | 6/6/2025            | 1.4                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0436     | Corridor North Cafeteria to Boy's Bathroom  | 2143     | Water Cooler              | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0437     | Boy's Bathroom                              | 3201     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0438     | Boy's Bathroom                              | 3201     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0439     | Boy's Bathroom                              | 3201     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0440     | Custodial Closet O                          | 3202     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0441     | Girl's Bathroom                             | 3200     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0442     | Girl's Bathroom                             | 3200     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0443     | Girl's Bathroom                             | 3200     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0444     | Corridor Room 200 to 210                    | 3192     | Bottle Fill Station       | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1517       |
| SCSD-0445     | Corridor Room 200 to 210                    | 3192     | Water Cooler              | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1518       |
| SCSD-0446     | Art Room                                    | 3191     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# South Woods Middle School

| Outlet Number | Room Name                | Space ID | Outlet Type                  | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--------------------------|----------|------------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0447     | Art Room                 | 3191     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0448     | Art Room                 | 3191     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0449     | Art Room                 | 3191     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0450     | Art Room                 | 3189     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0451     | Art Room                 | 3189     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0452     | Art Room                 | 3189     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0453     | Art Room                 | 3189     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0454     | Art Room                 | 3189     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0455     | Art Room                 | 3189     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0456     | Room 204                 | 3187     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0457     | Room 204                 | 3187     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0458     | Room 204                 | 3187     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | 1.5                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0459     | Room 204                 | 3187     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0460     | Room 204                 | 3187     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | 2.2                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0461     | Corridor Room 200 to 210 | 3192     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0462     | Room 202                 | 3186     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | 10.1                 | 8/13/2025                    | 18                            | Removed From Service, Pending Remediation |
| SCSD-0463     | Room 202                 | 3186     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0464     | Room 202                 | 3186     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0465     | Room 202                 | 3186     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | 1.3                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0466     | Room 202                 | 3186     | Home Economics Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |

# South Woods Middle School

| Outlet Number | Room Name  | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0467     | Art Room   | 3185     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0468     | Art Room   | 3185     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0469     | Art Room   | 3185     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0470     | Art Room   | 3185     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0471     | Art Room   | 3185     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0472     | Art Room   | 3185     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0473     | Men's Faculty Bathroom                               | 2131     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0474     | Men's Faculty Bathroom                               | 2131     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0475     | Faculty Women's Bathroom                             | 2129     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0476     | Faculty Women's Bathroom                             | 2129     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0477     | Main Office Kitchen                                  | 2165     | Kitchen Faucet (Cold) | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1440       |
| SCSD-0478     | Corridor Main Entrance to Exterior Exit by Copy Room | 2157     | Bottle Fill Station   | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0479     | Corridor Main Entrance to Exterior Exit by Copy Room | 2157     | Water Cooler          | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0480     | Nurse's Office Bathroom                              | 2175     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0481     | Nurse's Sick Room                                    | 2173     | Nurse's Office Sink   | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0482     | Nurse's Sick Room Side Room                          | 2173B    | Nurse's Office Sink   | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0483     | Girl's Restroom                                      | 2041     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0484     | Boy's Restroom                                       | 2040     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0485     | Women's Faculty Restroom                             | 2038     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0486     | Women's Faculty Restroom                             | 2038     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# South Woods Middle School

| Outlet Number | Room Name                    | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0487     | Women's Faculty Restroom     | 2038     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0488     | Custodial Closet             | 2036     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0489     | Faculty Men                  | 2037     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0490     | Faculty Men                  | 2037     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0491     | Faculty Men                  | 2037     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0492     | Corridor Library to Room 102 | 2060     | Water Cooler              | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0493     | Room 114                     | 2047     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0494     | Room 114                     | 2047     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0495     | Room 114                     | 2047     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0496     | Room 114                     | 2047     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0497     | Corridor Library to Room 102 | 2060     | Water Fountain-No Chiller | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0498     | Room 113                     | 2049     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0499     | Room 113                     | 2049     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0500     | Room 116                     | 2053     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0501     | Room 116                     | 2053     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0502     | Room 116                     | 2053     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0503     | Room 116                     | 2053     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0504     | Room 115                     | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0505     | Room 115                     | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0506     | Room 115                     | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# South Woods Middle School

| Outlet Number | Room Name          | Space ID | Outlet Type      | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|--------------------|----------|------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0507     | Room 116 Prep Room | 2055     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0508     | Room 118           | 2059     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0509     | Room 118           | 2059     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0510     | Room 118           | 2059     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0511     | Room 118           | 2059     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0512     | Room 120           | 2065     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0513     | Room 120           | 2065     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0514     | Room 120           | 2065     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0515     | Room 120           | 2065     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0516     | Room 120 Prep Room | 2066     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0517     | Room 119           | 2061     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0518     | Room 119           | 2061     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0519     | Room 119           | 2061     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0520     | Room 122           | 2067     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0521     | Room 122           | 2067     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0522     | Room 122           | 2067     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0523     | Room 122           | 2067     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0524     | Room 122           | 2067     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0525     | Room 122           | 2067     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0526     | Room 122           | 2067     | Science Faucet   | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# South Woods Middle School

| Outlet Number | Room Name                    | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|------------------------------|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0527     | Room 122                     | 2067     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0528     | Room 122                     | 2067     | Science Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0529     | Corridor Library to Room 102 | 2060     | Bottle Fill Station | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0530     | Corridor Library to Room 102 | 2060     | Water Cooler        | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0531     | Custodial Closet by A2       | NA       | Slop Sink           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0532     | Boys' Bathroom by A2         | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0533     | Boys' Bathroom by A2         | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0534     | Boys' Bathroom by A2         | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0535     | Girls' Bathroom by A2        | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0536     | Girls' Bathroom by A2        | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0537     | Girls' Bathroom by A2        | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0538     | Faculty Bathroom by A2       | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0539     | Corridor by Locker Rooms     | NA       | Water Cooler        | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0540     | Corridor by Locker Rooms     | NA       | Water Cooler        | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0541     | Boy's Bathroom               | 2100     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0542     | Boy's Bathroom               | 2100     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0543     | Boy's Bathroom               | 2100     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0544     | Girl's Bathroom              | 2008     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0545     | Girl's Bathroom              | 2008     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0546     | Girl's Bathroom              | 2008     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# South Woods Middle School

| Outlet Number | Room Name   | Space ID | Outlet Type                  | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|---|----------|------------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0547     | Tech-shop room  | 2111A    | Hand Wash Only               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0548     | Tech-shop room  | 2111A    | Hand Wash Only               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0549     | Tech-shop room  | 2111A    | Hand Wash Only               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0550     | Room 129A Wood Shop                                   | 2099A    | Tempered Water Outlet        | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0551     | Gym Boy's Locker Room<br>Coach Office                 | 2095B    | Slop Sink                    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0552     | Gym Boy's Locker Room<br>Coach Office                 | 2095B    | Ice Machine                  | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1459       |
| SCSD-0553     | Psychological Conference<br>Room & Personnel Services | 2112B    | Water Fountain-No<br>Chiller | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0554     | Room 133 Chorus                                       | 2103     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0555     | Head Custodial Office<br>Bathroom                     | 2125A    | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0556     | Basement Bathroom in 0009                             | NA       | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0557     | Basement Garage Open Area                             | 0020     | Hose Bib                     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0558     | Corridor North Cafeteria to<br>Boy's Bathroom         | 2143     | Water Fountain-No<br>Chiller | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0559     | South Cafeteria                                       | 2132     | Bottle Fill Station          | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0560     | South Cafeteria                                       | 2132     | Water Cooler                 | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0561     | Kitchen   | 2136     | Kitchen Faucet (Cold)        | Potable                        | 6/6/2025            | 1.1                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0562     | Kitchen   | 2136     | Kitchen Faucet (Cold)        | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No.1457        |
| SCSD-0563     | Kitchen   | 2136     | Kitchen Faucet (Cold)        | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No.1458        |
| SCSD-0564     | Kitchen   | 2136     | Kitchen Faucet (Cold)        | Potable                        | 6/6/2025            | 1.5                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0565     | Kitchen   | 2136     | Pasta Pot/Steam<br>Kettle    | Potable                        | 6/6/2025            | 2330                 | 8/13/2025                    | 479                           | Removed From Service, Pending Remediation |
| SCSD-0566     | Kitchen   | 2136     | Ice Machine                  | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |

# South Woods Middle School

| Outlet Number | Room Name                     | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status              |
|---------------|-------------------------------|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0567     | Kitchen Pantry                | 2136A    | Hand Wash Only        | Non-Potable                    | 6/6/2025            | 19.4                 | 8/13/2025                    | 111                           | Placarded for Non-Drinking Use Until Remediated |
| SCSD-0568     | Kitchen Laundry Room Bathroom | 2138     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0569     | Kitchen Custodial Room        | 2135     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0570     | Kitchen Custodial Room        | 2135     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0571     | Kitchen Custodial Room        | 2135     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0572     | North Cafeteria               | 2142     | Water Cooler          | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-0573     | Faculty Lounge                | 2139     | Kitchen Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-0574     | Superintendent's Kitchen      | 2179B    | Kitchen Faucet (Cold) | Potable                        | 6/6/2025            | 1.2                  |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-0575     | Courtyard o/s 2067            | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0576     | Courtyard o/s 2128            | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0577     | Walkway o/s 2095              | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0578     | Exterior o/s 2139             | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0579     | Exterior o/s 2111A            | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0580     | Exterior o/s 2095             | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0581     | Exterior o/s 2037             | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0582     | Exterior o/s 2056             | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0583     | Exterior o/s 2017             | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1419     | Corridor Library to Room 102  | 2060     | Bottle Fill Station   | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1420     | Corridor Library to Room 102  | 2060     | Water Cooler          | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1421     | Main Entrance Corridor        | 2157     | Bottle Fill Station   | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |

# South Woods Middle School

| Outlet Number | Room Name                             | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|---------------------------------------|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1422     | Main Entrance Corridor                | 2157     | Water Cooler          | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1423     | South Cafeteria                       | 2132     | Bottle Fill Station   | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1424     | South Cafeteria                       | 2132     | Water Cooler          | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1429     | Basement Open Storage/Copy Area       | 010      | Bottle Fill Station   | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1430     | Basement Open Storage/Copy Area       | 010      | Water Cooler          | Potable                        | 6/6/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1439     | Library                               | 2011     | Kitchen Faucet (Cold) | Potable                        | 6/6/2025            | 4.9                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1440     | Main Office Kitchen                   | 2165     | Kitchen Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1457     | Kitchen                               | 2136     | Kitchen Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1458     | Kitchen                               | 2136     | Kitchen Faucet (Cold) | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1459     | Gym Boy's Locker Room<br>Coach Office | 2095B    | Ice Machine           | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1517     | Corridor Room 200 to 210              | 3192     | Bottle Fill Station   | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1518     | Corridor Room 200 to 210              | 3192     | Water Cooler          | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1783     | North Cafeteria                       | 2142     | Bottle Fill Station   | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1784     | North Cafeteria                       | 2142     | Water Cooler          | Potable                        | 6/6/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |

# Berry Hill Elementary School

| Outlet Number | Room Name              | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0584     | Nurse's Bathroom       | 2048     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0585     | D3 Bathroom            | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0586     | D4 Bathroom            | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0587     | Girls' Bathroom by D5  | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0588     | Girls' Bathroom by D5  | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0589     | Girls' Bathroom by D5  | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0590     | Girls' Bathroom by D5  | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0591     | Custodial Closet by D5 | NA       | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0592     | Corridor by D5         | NA       | Water Cooler              | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1425       |
| SCSD-0593     | Corridor by D5         | NA       | Water Cooler              | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1426       |
| SCSD-0594     | Boys' Bathroom by D5   | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0595     | Boys' Bathroom by D5   | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0596     | Boys' Bathroom by D5   | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0597     | Boys' Bathroom by D5   | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0598     | Room 10 ESL (Now C1)   | 2049A    | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0599     | Room 9 (Now Room C2)   | 2074     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0600     | Room 9 (Now Room C2)   | 2074     | Water Fountain-No Chiller | Potable                        | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0601     | Room 8 (Now C3)        | 2050     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0602     | Room 8 (Now C3)        | 2050     | Water Fountain-No Chiller | Potable                        | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0603     | Room 7 (Now Room C4)   | 2071     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Berry Hill Elementary School

| Outlet Number | Room Name                                | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0604     | Room 7 (Now Room C4)                     | 2071     | Water Fountain-No Chiller | Potable                        | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0605     | Room 6 (Now C5)                          | 2053     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0606     | Room 6 (Now C5)                          | 2053     | Water Fountain-No Chiller | Potable                        | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0607     | Room 5 (Now Room C6)                     | 2068     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0608     | Room 5 (Now Room C6)                     | 2068     | Water Fountain-No Chiller | Potable                        | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0609     | Room 4 (Now C7)                          | 2057     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0610     | Room 4 (Now C7)                          | 2057     | Water Fountain-No Chiller | Potable                        | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0611     | Room 4 Bathroom                          | 2058     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0612     | Room 3 (Now C8)                          | 2065     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0613     | Room 3 (Now C8)                          | 2065     | Water Fountain-No Chiller | Potable                        | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0614     | Room 3 Bathroom                          | 2067     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0615     | Multi Purpose Room Corridor              | 2063     | Bottle Fill Station       | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0616     | Multi Purpose Room Corridor              | 2063     | Water Cooler              | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0617     | Multi Purpose Room Corridor              | 2063     | Hand Wash Only            | Non-Potable                    | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0618     | Multi Purpose Room Corridor              | 2063     | Hose Bib                  | Non-Potable                    | 6/2/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0619     | Multi-purpose Room                       | 2061     | Hand Wash Only            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0620     | Kitchen Room                             | 2063A    | Kitchen Faucet (Cold)     | Potable                        | 6/2/2025            | 1.2                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0621     | Corridor Coach's Office to Main Entrance | 2081     | Bottle Fill Station       | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1433       |
| SCSD-0622     | Corridor Coach's Office to Main Entrance | 2081     | Water Cooler              | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1434       |
| SCSD-0623     | Men's Bathroom                           | 2044     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Berry Hill Elementary School

| Outlet Number | Room Name                            | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--------------------------------------|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0624     | Women's Bathroom                     | 2043     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0625     | Library                              | 2039     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0626     | Room E/Gym Office                    | 2034     | Kitchen Faucet (Cold) | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0627     | Room 11 (Now A1)                     | 2029     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0628     | Young Gentlemen's Bathroom           | 2027     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0629     | Young Gentlemen's Bathroom           | 2027     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0630     | Young Gentlemen's Bathroom           | 2027     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0631     | Young Gentlemen's Bathroom           | 2027     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0632     | Custodial Closet F                   | 2028     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0633     | Young Ladies Bathroom                | 2026     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0634     | Young Ladies Bathroom                | 2026     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0635     | Young Ladies Bathroom                | 2026     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0636     | Young Ladies Bathroom                | 2026     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0637     | Room 13 (Now A3)                     | 2024     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0638     | Room 12 (Now A2)                     | 2022     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0639     | Room 15 (Now A5)                     | 2020     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0640     | Room 14 (Now A4)                     | 2018     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0641     | Room 17 (Now A7)                     | 2014     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0642     | Room 16 Closet                       | 2017     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0643     | Corridor Room A7 (17) To Boiler Room | 2082     | Bottle Fill Station   | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1435    |

# Berry Hill Elementary School

| Outlet Number | Room Name                                | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0644     | Corridor Room A7 (17) To Boiler Room     | 2082     | Water Cooler        | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1436    |
| SCSD-0645     | Art Room                                 | 2083     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0646     | Art Room                                 | 2083     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0647     | Room 1 Bathroom                          | 2083A    | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0648     | Room 18 Bathroom                         | 2012     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0649     | Room 19 Bathroom                         | 2010     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0650     | Room 20 Bathroom                         | 2008     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0651     | Room 2 Bathroom                          | 2085A    | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0652     | Courtyard o/s 2071                       | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0653     | Exterior o/s 2029                        | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0654     | Exterior o/s 2061                        | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0655     | Exterior o/s 2053                        | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0656     | Exterior o/s 2039                        | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1425     | Corridor by D5                           | NA       | Bottle Fill Station | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1426     | Corridor by D5                           | NA       | Water Cooler        | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1433     | Corridor Coach's Office to Main Entrance | 2081     | Bottle Fill Station | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1434     | Corridor Coach's Office to Main Entrance | 2081     | Water Cooler        | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1435     | Corridor                                 | 2082     | Bottle Fill Station | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1436     | Corridor                                 | 2082     | Water Cooler        | Potable                        | 6/2/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |

# Village Elementary School

| Outlet Number | Room Name                              | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0657     | Kindergarten 17 Bathroom               | 2010B    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0658     | Kindergarten 17 (Now Room 12)          | 2010     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0659     | Kindergarten 17 (Now Room 12)          | 2010     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0660     | Kindergarten 16 Bathroom               | 2009A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0661     | Kindergarten 16 (Now Room 11)          | 2009     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0662     | Kindergarten 16 (Now Room 11)          | 2009     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0663     | Room 15 (Now Room 13)                  | 2011     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0664     | Room 15 (Now Room 13)                  | 2011     | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                |
| SCSD-0665     | Room 14 (Now Room 10)                  | 2008     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0666     | Room 14 (Now Room 10)                  | 2008     | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                |
| SCSD-0667     | Room 13 (Now Room 14)                  | 2012     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0668     | Room 13 (Now Room 14)                  | 2012     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0669     | Room 12 (Now Room 9)                   | 2007     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0670     | Room 12 (Now Room 9)                   | 2007     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0671     | Room 18 Bathroom                       | 2005A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0672     | Room 19 Bathroom                       | 2004A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0673     | Room 20 Bathroom                       | 2003A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0674     | Room 21 Bathroom                       | 2001A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0675     | Corridor Multi Purpose Room to Library | 2045     | Bottle Fill Station       | Potable                        | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0676     | Corridor Multi Purpose Room to Library | 2045     | Water Cooler              | Potable                        | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |

# Village Elementary School

| Outlet Number | Room Name                              | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0677     | Library Office                         | 2014A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0678     | Room 2 (Now Room 3)                    | 2016     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0679     | Room 2 (Now Room 3)                    | 2016     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0680     | Room 3 (Now Room 2)                    | 2017     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0681     | Room 3 (Now Room 2)                    | 2017     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0682     | Room 4 (Now Room 1)                    | 2018     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0683     | Room 4 (Now Room 1)                    | 2018     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0684     | Corridor Multi Purpose Room to Library | 2045     | Bottle Fill Station       | Potable                        | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0685     | Corridor Multi Purpose Room to Library | 2045     | Water Cooler              | Potable                        | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0686     | Unisex Bathroom                        | 2022B    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0687     | Custodial Closet                       | 2033     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0688     | Nurse's Office                         | 2022D    | Nurse's Office Sink       | Potable                        | 5/29/2025           | 1.7                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0689     | Nurse's Office Bathroom                | 2022C    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0690     | Room 5 (Now Room 19)                   | 2023     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0691     | Room 5 (Now Room 19)                   | 2023     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0692     | Coach's Office                         | 2032     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0693     | Music Room Bathroom                    | 2031A1   | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0694     | Room 6 (Now Room 20)                   | 2024     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0695     | Room 6 (Now Room 20)                   | 2024     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0696     | Room 7 (Now Room 21)                   | 2025     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Village Elementary School

| Outlet Number | Room Name                    | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0697     | Room 7 (Now Room 21)         | 2025     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0698     | Girl's Bathroom              | 2029     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0699     | Girl's Bathroom              | 2029     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0700     | Girl's Bathroom              | 2029     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0701     | Room 8 (Now Room 22)         | 2026     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0702     | Room 8 (Now Room 22)         | 2026     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0703     | Band/Orchestra Room Bathroom | 2035B    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0704     | Band/Orchestra Room          | 2035     | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0705     | Boy's Bathroom               | 2028     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0706     | Boy's Bathroom               | 2028     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0707     | Boy's Bathroom               | 2028     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0708     | Multi Purpose Room           | 2047     | Hand Wash Only            | Non-Potable                    | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0709     | Multi Purpose Room           | 2047     | Bottle Fill Station       | Potable                        | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0710     | Multi Purpose Room           | 2047     | Water Cooler              | Potable                        | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0711     | Kitchen                      | 2047A    | Kitchen Faucet (Cold)     | Potable                        | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0712     | Multi Purpose Room           | 2047     | Hand Wash Only            | Non-Potable                    | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0713     | Room 26                      | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0714     | Room 26 Bathroom             | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0715     | Room 27                      | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0716     | Room 27 Bathroom             | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Village Elementary School

| Outlet Number | Room Name        | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0717     | Boiler Room 2    | NA       | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0718     | Room 35          | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0719     | Room 35          | NA       | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0720     | Room 35 Bathroom | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0721     | Room 28          | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0722     | Room 28          | NA       | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0723     | Room 28 Bathroom | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0724     | Room 34          | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0725     | Room 34          | NA       | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0726     | Room 34 Bathroom | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0727     | Room 29          | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0728     | Room 29          | NA       | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0729     | Room 29 Bathroom | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0730     | Room 33          | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0731     | Room 33          | NA       | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0732     | Room 33 Bathroom | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0733     | Room 30          | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0734     | Room 30          | NA       | Water Fountain-No Chiller | Potable                        | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0735     | Room 30 Bathroom | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0736     | Room 32          | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Village Elementary School

| Outlet Number | Room Name                     | Space ID | Outlet Type               | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|-------------------------------|----------|---------------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0737     | Room 32                       | NA       | Water Fountain-No Chiller | Potable                  | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0738     | Room 32 Bathroom - tempered   | NA       | Tempered Water Outlet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0739     | Room 31                       | NA       | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0740     | Room 31                       | NA       | Water Fountain-No Chiller | Potable                  | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0741     | Room 31 Bathroom - tempered   | NA       | Tempered Water Outlet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0742     | Faculty Lounge                | 2038     | Kitchen Faucet (Cold)     | Potable                  | 5/29/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0743     | Faculty Lounge Bathroom       | 2038B    | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0744     | Room 9 Art Room (Now Room 23) | 2027     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0745     | Room 9 Art Room (Now Room 23) | 2027     | Water Fountain-No Chiller | Potable                  | 5/29/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0746     | Courtyard o/s 2047            | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0747     | Exterior o/s Room 35          | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0748     | Exterior o/s Room 32          | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0749     | Exterior o/s 2040             | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0750     | Exterior o/s 2011             | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0751     | Exterior o/s 2008             | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0752     | Exterior o/s 2017             | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0753     | Exterior o/s 2024             | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0754     | Exterior o/s 2025             | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Thompson Middle School

| Outlet Number | Room Name                      | Space ID | Outlet Type         | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--------------------------------|----------|---------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0755     | Server Room Vestibule          | 2175     | Slop Sink           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0756     | Head Custodian Office Bathroom | 2177A1   | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0757     | Art Room                       | 2082     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0758     | Art Room                       | 2082     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0759     | Room 116                       | 2074     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0760     | Science Prep Room C            | 2073     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0761     | Room 120                       | 2086     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0762     | Room 120                       | 2086     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0763     | Room 115                       | 2071     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0764     | Room 115                       | 2071     | Science Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0765     | Room 121                       | 2088     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0766     | Room 121                       | 2088     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0767     | Room 121                       | 2088     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0768     | Corridor Custodial - Gym       | 2092     | Bottle Fill Station | Potable                  | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0769     | Corridor Custodial - Gym       | 2092     | Water Cooler        | Potable                  | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-0770     | Faculty Men's Bathroom         | 2093B    | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0771     | Boy's Bathroom                 | 2095     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0772     | Boy's Bathroom                 | 2095     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0773     | Boy's Bathroom                 | 2095     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0774     | Boy's Bathroom                 | 2095     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

# Thompson Middle School

| Outlet Number | Room Name                                | Space ID | Outlet Type                  | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--|----------|------------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0775     | Custodial Closet                         | 2178     | Slop Sink                    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0776     | Girl's Bathroom                          | 2096     | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0777     | Girl's Bathroom                          | 2096     | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0778     | Girl's Bathroom                          | 2096     | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0779     | Girl's Bathroom                          | 2096     | Bathroom Faucet              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0780     | FCSC Family & Consumer Service C Room 99 | 2097     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0781     | FCSB Family & Consumer Service B         | 2098     | Home Economics Faucet (Cold) | Potable                        | 5/30/2025           | 21.4                 |                              |                               | Removed From Service, Pending Remediation |
| SCSD-0782     | FCSB Family & Consumer Service B         | 2098     | Home Economics Faucet (Cold) | Potable                        | 5/30/2025           | 5.8                  |                              |                               | Removed From Service, Pending Remediation |
| SCSD-0783     | FCSB Family & Consumer Service B         | 2098     | Home Economics Faucet (Cold) | Potable                        | 5/30/2025           | 5.6                  |                              |                               | Removed From Service, Pending Remediation |
| SCSD-0784     | FCSA Family & Consumer Service A         | 2099     | Home Economics Faucet (Cold) | Potable                        | 5/30/2025           | 1.9                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0785     | FCSA Family & Consumer Service A         | 2099     | Home Economics Faucet (Cold) | Potable                        | 5/30/2025           | 2.2                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0786     | FCSA Family & Consumer Service A         | 2099     | Home Economics Faucet (Cold) | Potable                        | 5/30/2025           | 6.2                  |                              |                               | Removed From Service, Pending Remediation |
| SCSD-0787     | FCSA Family & Consumer Service A         | 2099     | Home Economics Faucet (Cold) | Potable                        | 5/30/2025           | 7.7                  |                              |                               | Removed From Service, Pending Remediation |
| SCSD-0788     | Room 108                                 | 2030     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0789     | Room 108                                 | 2030     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0790     | Room 108                                 | 2030     | Classroom Faucet             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0791     | Room 108                                 | 2030     | Hose Bib                     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0792     | Room 114                                 | 2051     | Science Faucet               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0793     | Room 114                                 | 2051     | Science Faucet               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0794     | Room 114                                 | 2051     | Science Faucet               | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Thompson Middle School

| Outlet Number | Room Name                | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0795     | Room 114                 | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0796     | Room 114                 | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0797     | Room 114                 | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0798     | Room 114                 | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0799     | Room 114                 | 2051     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0800     | Room 113 Prep Room       | 2050     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0801     | Room 113 Prep Room       | 2050     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0802     | Room 109                 | 2032     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0803     | Room 109                 | 2032     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0804     | Corridor Rooms 108-114   | 2090     | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0805     | Room 113                 | 2048     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0806     | Art Room                 | 2036     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0807     | Art Room                 | 2036     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0808     | Corridor Custodial - Gym | 2092     | Bottle Fill Station       | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0809     | Corridor Custodial - Gym | 2092     | Water Cooler              | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0810     | Faculty Men's Bathroom   | 2102     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0811     | Faculty Men's Bathroom   | 2102     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0812     | Faculty Men's Bathroom   | 2102     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0813     | Custodial Closet         | 2103     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0814     | Women's Faculty Bathroom | 2104     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Thompson Middle School

| Outlet Number | Room Name                      | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0815     | Women's Faculty Bathroom       | 2104     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0816     | Women's Faculty Bathroom       | 2104     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0817     | Women's Faculty Bathroom       | 2104     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0818     | Room 101                       | 2003     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0819     | Room 101                       | 2003     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0820     | Room 101                       | 2003     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0821     | Room 107                       | 2019     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0822     | Room 107                       | 2019     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0823     | Room 107                       | 2019     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0824     | Room 106 Prep Room             | 2018     | Science Faucet            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0825     | Room 106                       | 2016     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0826     | Room 102                       | 2005     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0827     | Room 102                       | 2005     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0828     | Room 102                       | 2005     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0829     | Art Room                       | 2009     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0830     | Art Room                       | 2009     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0831     | Corridor North Gym - South Gym | 2182     | Bottle Fill Station       | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0832     | Corridor North Gym - South Gym | 2182     | Water Cooler              | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0833     | Girl's Locker Room Vestibule   | 2106A    | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0834     | Girl's Locker Room Vestibule   | 2106A    | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |

# Thompson Middle School

| Outlet Number | Room Name                           | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|-------------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0835     | Girls Coach's Office Bathroom       | 2107     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0836     | Girl's Locker Room                  | 2111     | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0837     | Girl's Locker Room                  | 2111     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0838     | Girl's Locker Room                  | 2111     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0839     | Girl's Locker Room                  | 2111     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0840     | Girl's Locker Room Slop Sink        | 2111B    | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0841     | Nurse's Vestibule Bathroom          | 2126     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0842     | Nurse's Office                      | 2125     | Nurse's Office Sink       | Potable                        | 5/30/2025           | 15.9                 | 8/12/2025                    | 7.8                           | Removed From Service, Pending Remediation |
| SCSD-0843     | Main Office Conference Room         | 2132     | Kitchen Faucet (Cold)     | Potable                        | 5/30/2025           | 16.4                 | 8/12/2025                    | 8.4                           | Removed From Service, Pending Remediation |
| SCSD-0844     | Main Office Principal Bathroom      | 2134     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0845     | Main Entrance Corridor              | 2180     | Bottle Fill Station       | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0846     | Main Entrance Corridor              | 2180     | Water Cooler              | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0847     | Vestibule                           | 2118A    | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0848     | Vestibule                           | 2118A    | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0849     | Boys Coach's Office Bathroom        | 2118B    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0850     | Boy's Locker Room Bathroom          | 2117A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0851     | Boy's Locker Room Bathroom          | 2117A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0852     | Boy's Locker Room Bathroom          | 2117A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0853     | Boy's Locker Room Bathroom          | 2117A    | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0854     | Boys Locker Room Bathroom Slop Sink | 2117A1   | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Thompson Middle School

| Outlet Number | Room Name                         | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status                                  |
|---------------|-----------------------------------|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0855     | Women's Bathroom Near Main Office | 2180B    | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                                      |
| SCSD-0856     | Women's Faculty Bathroom          | 2146     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                                      |
| SCSD-0857     | Custodial Closet                  | 2145     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                                      |
| SCSD-0858     | Men's Faculty Bathroom            | 2144     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                                      |
| SCSD-0859     | Main Entrance Corridor            | 2180     | Bottle Fill Station   | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                              |
| SCSD-0860     | Main Entrance Corridor            | 2180     | Water Cooler          | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service                           |
| SCSD-0861     | Men's Faculty Bathroom            | 2152     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                                      |
| SCSD-0862     | Snack Shop                        | 2154C    | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 11.2                 | 8/12/2025                    | 5.6                           | Removed From Service, Pending Remediation                           |
| SCSD-0863     | North Cafeteria                   | 2154A    | Bottle Fill Station   | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                              |
| SCSD-0864     | North Cafeteria                   | 2154A    | Water Cooler          | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service                           |
| SCSD-0865     | South Cafeteria                   | 2154B    | Bottle Fill Station   | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                              |
| SCSD-0866     | South Cafeteria                   | 2154B    | Water Cooler          | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service                           |
| SCSD-0867     | Faculty Lounge                    | 2155     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 46.9                 | 8/12/2025                    | < 1.0                         | Outlet Remediated Remediated Result Below Action Level Continue O&M |
| SCSD-0868     | Faculty Lounge                    | 2155     | Spray Nozzle          | Non-Potable                    | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                              |
| SCSD-0869     | Kitchen                           | 2156     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 3.1                  |                              |                               | Result Below Action Level Continue O&M                              |
| SCSD-0870     | Kitchen                           | 2156     | Spray Nozzle          | Non-Potable                    | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service                           |
| SCSD-0871     | Kitchen                           | 2156     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service                           |
| SCSD-0872     | Kitchen                           | 2156     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service                           |
| SCSD-0873     | Kitchen                           | 2156     | Ice Machine           | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service                           |
| SCSD-0874     | Kitchen                           | 2156     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 1.9                  |                              |                               | Result Below Action Level Continue O&M                              |

# Thompson Middle School

| Outlet Number | Room Name                     | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status              |
|---------------|-------------------------------|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0875     | Kitchen                       | 2156     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 1.5                  |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-0876     | Kitchen                       | 2156     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-0877     | Kitchen Bathroom/Laundry Room | 2160     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0878     | Kitchen Can Wash Room         | 2159     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0879     | Boy's Bathroom                | 2151     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0880     | Boy's Bathroom                | 2151     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0881     | Girl's Bathroom               | 2150     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0882     | Fan Room Across Tech C        | 2149     | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0883     | Tech C                        | 2164     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0884     | Room ITB Tech B Wood Shop     | 2167A    | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0885     | Room ITA Tech A Wood Shop     | 2170A    | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0886     | Room ITA Tech A Wood Shop     | 2170A    | Spray Nozzle          | Non-Potable                    | 5/30/2025           | 7.9                  |                              |                               | Placarded for Non-Drinking Use Until Remediated |
| SCSD-0887     | Art Room                      | 3183     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0888     | Art Room                      | 3183     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0889     | Art Room                      | 3183     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0890     | Art Room                      | 3183     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-0891     | Corridor Room 224 to 228      | 3277     | Water Cooler          | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-0892     | 2nd Floor Main Corridor       | 3280     | Bottle Fill Station   | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-0893     | 2nd Floor Main Corridor       | 3280     | Water Cooler          | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-0894     | Boy's Bathroom                | 3215     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |

# Thompson Middle School

| Outlet Number | Room Name                | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0895     | Boy's Bathroom           | 3215     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0896     | Boy's Bathroom           | 3215     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0897     | Boy's Bathroom           | 3215     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0898     | Custodial Closet         | 3217     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0899     | Girl's Bathroom          | 3216     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0900     | Girl's Bathroom          | 3216     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0901     | Girl's Bathroom          | 3216     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0902     | Girl's Bathroom          | 3216     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0903     | Corridor Room 211 to 215 | 3278     | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0904     | Men's Faculty Bathroom   | 3272     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0905     | Men's Faculty Bathroom   | 3272     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0906     | Men's Faculty Bathroom   | 3272     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0907     | 2nd Floor Main Corridor  | 3280     | Bottle Fill Station       | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0908     | 2nd Floor Main Corridor  | 3280     | Water Cooler              | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0909     | Custodial Closet         | 3273     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0910     | Women's Faculty Bathroom | 3271     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0911     | Women's Faculty Bathroom | 3271     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0912     | Women's Faculty Bathroom | 3271     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0913     | Women's Faculty Bathroom | 3271     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0914     | Corridor Room 201 to 205 | 3281     | Water Fountain-No Chiller | Potable                        | 5/30/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |

# Thompson Middle School

| Outlet Number | Room Name                       | Space ID | Outlet Type     | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|---------------------------------|----------|-----------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0915     | <b>Courtyard</b>                | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0916     | <b>Courtyard</b>                | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0917     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0918     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0919     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0920     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0921     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0922     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0923     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0924     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0925     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0926     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0927     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0928     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0929     | <b>Exterior</b>                 | NA       | Hose Bib        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1282     | <b>Women's Faculty Bathroom</b> | 2093A    | Bathroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1377     | <b>Women's Faculty Bathroom</b> | 2093A    | Bathroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Willits Elementary School

| Outlet Number | Room Name                                      | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status                       |
|---------------|--|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0930     | Cafeteria                                      | NA       | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 21.3                 | 8/13/2025                    | 1.9                           | Outlet Remediated Result Below Action Level Continue O&M |
| SCSD-0931     | Cafeteria                                      | NA       | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 5.7                  | 8/13/2025                    | 1.4                           | Outlet Remediated Result Below Action Level Continue O&M |
| SCSD-0932     | Room 207 Psychologist Office                   | 2004     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0933     | Room 14  | 2007     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0934     | Room 13  | 2011     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0935     | Girls Bathroom Vestibule (Space Reconstructed) | 2009     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0936     | Room 214 Speech Therapist Office               | 2012     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0937     | Library  | 2021     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0938     | Stairwell                                      | 2017     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0939     | Stairwell                                      | 2017     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0940     | Stairwell                                      | 2017     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0941     | Stairwell                                      | 2017     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0942     | Stairwell                                      | 2019     | Slop Sink             | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0943     | Corridor Room 211 To Room 219                  | 2018     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0944     | Corridor Room 211 To Room 219                  | 2018     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0945     | Corridor Room 211 To Room 219                  | 2018     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0946     | Corridor Room 211 To Room 219                  | 2018     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0947     | Gym Kitchen                                    | 2042     | Kitchen Faucet (Cold) | Potable                        | 5/30/2025           | 5.6                  | 8/13/2025                    | 8.5                           | Removed From Service, Pending Remediation                |
| SCSD-0948     | Room 18  | 2026     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-0949     | Room 17  | 2032     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |

# Willits Elementary School

| Outlet Number | Room Name                             | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|---------------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0950     | Room 20                               | 2027     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0951     | Room 19                               | 2031     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0952     | Room 210                              | 2028     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0953     | Room 21                               | 2030     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0954     | Corridor Room 21 to Gym               | 2029     | Bottle Fill Station       | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0955     | Corridor Room 21 to Gym               | 2029     | Water Cooler              | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0956     | Faculty Room                          | 2038     | Kitchen Faucet (Cold)     | Potable                        | 5/30/2025           | 1.3                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0957     | Faculty Room                          | 2038     | Water Fountain-No Chiller | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0958     | Women's Bathroom                      | 2049     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0959     | Corridor Boiler Room to Main Entrance | 2037     | Bottle Fill Station       | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0960     | Corridor Boiler Room to Main Entrance | 2037     | Water Cooler              | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0961     | Men's Bathroom                        | 2048     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0962     | Nurse's Bathroom                      | 2045     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0963     | Room 8                                | 2073     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0964     | Room 8                                | 2073     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0965     | Room 6                                | 2069     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0966     | Room 6                                | 2069     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0967     | Room 4/GT Room                        | 2065     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0968     | Computer Room 3                       | 2056     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0969     | Computer Room 3                       | 2056     | Water Fountain-No Chiller | Potable                        | 5/31/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |

# Willits Elementary School

| Outlet Number | Room Name       | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|-----------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-0970     | Room 2          | 2062     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0971     | Room 2          | 2062     | Water Fountain-No Chiller | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0972     | Room 2 Bathroom | 2063     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0973     | Room 1          | 2070     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0974     | Room 1 Bathroom | 2058     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0975     | 4N              | NA       | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0976     | 7N              | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0977     | 8N              | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0978     | 10N             | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0979     | 11N             | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0980     | 17N             | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0981     | 14N             | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0982     | 18N             | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0983     | 21N             | 21N      | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0984     | Boiler Room     | 2022     | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0985     | Exterior        | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0986     | Exterior        | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0987     | Exterior        | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0988     | Exterior        | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-0989     | Exterior        | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Willits Elementary School

| Outlet Number | Room Name                                      | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-0990     | Exterior                                       | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-0991     | Exterior                                       | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1283     | 6N   | NA       | Bottle Fill Station | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1284     | 6N   | NA       | Water Cooler        | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1431     | Corridor Boiler Room to Main Entrance o/s 2019 | 2037     | Bottle Fill Station | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1432     | Corridor Boiler Room to Main Entrance o/s 2019 | 2037     | Water Cooler        | Potable                        | 5/30/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |

# South Grove Elementary School

| Outlet Number | Room Name                | Space ID | Outlet Type           | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--------------------------|----------|-----------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-0992     | Room 32                  | 2086     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0993     | Room 31                  | 2081     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0994     | Room 31 Bathroom         | 2082     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0995     | Room 33                  | 2089     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0996     | Room 30                  | 2078     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-0997     | Multi Purpose Room       | 2092     | Bottle Fill Station   | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-0998     | Multi Purpose Room       | 2092     | Water Cooler          | Potable                  | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-0999     | Multi Purpose Room       | 2092     | Kitchen Faucet (Cold) | Potable                  | 6/3/2025            | 1.5                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1000     | Multi Purpose Room       | 2092     | Kitchen Faucet (Cold) | Potable                  | 6/3/2025            | 1.6                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1001     | Room 29                  | 2075     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1002     | Room 28                  | 2071     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1003     | Men's Bathroom           | 2094     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1004     | Women's Bathroom         | 2095     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1005     | Custodial Office         | 2096     | Slop Sink             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1006     | 14A-Music Room           | 2068     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1007     | 14B-Band/Orchestra Room  | 2068B    | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1008     | Faculty Lounge - Room 15 | 2044     | Kitchen Faucet (Cold) | Potable                  | 6/3/2025            | 4.3                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1009     | Room 18 Closet           | 2064     | Classroom Faucet      | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1010     | Boy's Bathroom           | 2047     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1011     | Boy's Bathroom           | 2047     | Bathroom Faucet       | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# South Grove Elementary School

| Outlet Number | Room Name                           | Space ID | Outlet Type         | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status  |
|---------------|-------------------------------------|----------|---------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|-------------------------------------|
| SCSD-1012     | Boy's Bathroom                      | 2047     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1013     | Custodial Closet 20                 | 2048     | Slop Sink           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1014     | Girl's Bathroom                     | 2049     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1015     | Girl's Bathroom                     | 2049     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1016     | Girl's Bathroom                     | 2049     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1017     | Room 22                             | 2060     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1018     | Room 22                             | 2060     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1019     | Room 23                             | 2050     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1020     | Room 23                             | 2050     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1021     | Room 24                             | 2058     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1022     | Room 24                             | 2058     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1023     | Room 25                             | 2052     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1024     | Room 25                             | 2052     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1025     | Room 26                             | 2056     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1026     | Room 26                             | 2056     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1027     | Room 27                             | 2054     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1028     | Room 27                             | 2054     | Classroom Faucet    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |
| SCSD-1029     | Corridor Main Office to Boiler Room | 2046     | Bottle Fill Station | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1441 |
| SCSD-1030     | Corridor Main Office to Boiler Room | 2046     | Water Cooler        | RFI                      |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1442 |
| SCSD-1031     | Nurse's Office Bathroom             | 2034     | Bathroom Faucet     | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use      |

# South Grove Elementary School

| Outlet Number | Room Name                        | Space ID | Outlet Type               | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|----------------------------------|----------|---------------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-1032     | Men's Staff Bathroom             | 2037     | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1033     | Library                          | 2018     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1034     | Room 7                           | 2023     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1035     | Room 7                           | 2023     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1036     | Library Bathroom                 | 2019     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1037     | Library Bathroom                 | 2019     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1038     | Room 5                           | 2015     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1039     | Room 5                           | 2015     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1040     | Room 3                           | 2008     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1041     | Room 3                           | 2008     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1042     | Learning Center Bathroom         | 2003     | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1043     | Room 1 Art                       | 2005     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1044     | Room 1 Art                       | 2005     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1045     | Room 1 Art                       | 2005     | Slop Sink                 | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1046     | Room 1 Bathroom/Kiln room        | 2006     | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1071     | Corridor Room 32 - Main Entrance | 2098     | Water Fountain-No Chiller | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1246     | Boys Bathroom                    | NA       | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1247     | Boys Bathroom                    | NA       | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1248     | Girls Bathroom                   | NA       | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1249     | Girls Bathroom                   | NA       | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# South Grove Elementary School

| Outlet Number | Room Name                           | Space ID | Outlet Type           | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|-------------------------------------|----------|-----------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1250     | Custodial Closet                    | NA       | Slop Sink             | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1251     | Gym Hallway                         | NA       | Bottle Fill Station   | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1252     | Gym Hallway                         | NA       | Water Cooler          | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1253     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1254     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1255     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1256     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1257     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1260     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1261     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1262     | Exterior                            | NA       | Hose Bib              | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1441     | Corridor Main Office to Boiler Room | 2046     | Bottle Fill Station   | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1442     | Corridor Main Office to Boiler Room | 2046     | Water Cooler          | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1443     | Corridor Room 32 - Main Entrance    | 2098     | Bottle Fill Station   | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1444     | Corridor Room 32 - Main Entrance    | 2098     | Water Cooler          | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1445     | Multi Purpose Room                  | 2092     | Kitchen Faucet (Cold) | Potable                  | 6/3/2025            | 7.8                  | 8/13/2025                    | 5.6                           | Removed From Service, Pending Remediation |

# South Grove Annex

| Outlet Number | Room Name                 | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status              |
|---------------|---------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1047     | Nurse Bathroom            | 2014     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1048     | Scope Bathroom            | 2008     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1049     | Corridor near Boiler Room | 2034     | Bottle Fill Station       | Potable                        | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1050     | Corridor near Boiler Room | 2034     | Water Cooler              | Potable                        | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1051     | Women's Bathroom          | 2007     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1052     | Kitchen                   | 2006     | Kitchen Faucet (Cold)     | Potable                        | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1053     | Kitchen                   | 2006     | Kitchen Faucet (Cold)     | Potable                        | 6/3/2025            | 1.4                  |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1054     | Room 1                    | 2016     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1055     | Room 1                    | 2016     | Water Fountain-No Chiller | Potable                        | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1056     | Room 2                    | 2018     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1057     | Room 2                    | 2018     | Water Fountain-No Chiller | Potable                        | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1058     | Corridor Rooms 1-3        | 2032     | Water Fountain-No Chiller | Potable                        | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1059     | Room 3                    | 2020     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1060     | Room 3                    | 2020     | Water Fountain-No Chiller | Potable                        | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1061     | Faculty Room              | 2024     | Classroom Faucet          | Non-Potable                    | 6/3/2025            | 17.0                 | 8/13/2025                    | 7.1                           | Placarded for Non-Drinking Use Until Remediated |
| SCSD-1062     | Faculty Room              | 2024     | Water Fountain-No Chiller | Potable                        | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1063     | Classroom 7               | 2029     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1064     | Classroom 7               | 2029     | Water Fountain-No Chiller | Potable                        | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1065     | Corridor Room 5-7         | 2033     | Bottle Fill Station       | Potable                        | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1066     | Corridor Room 5-7         | 2033     | Water Cooler              | Potable                        | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M          |

# South Grove Annex

| Outlet Number | Room Name          | Space ID | Outlet Type               | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|--------------------|----------|---------------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1067     | Classroom 6        | 2027     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1068     | Classroom 6        | 2027     | Water Fountain-No Chiller | Potable                  | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1069     | Classroom 5        | 2025     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1070     | Classroom 5        | 2025     | Water Fountain-No Chiller | Potable                  | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1240     | Room 8             | NA       | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1241     | Room 8             | NA       | Water Fountain-No Chiller | Potable                  | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1242     | Room 8 Bathroom    | NA       | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1243     | Room 9             | NA       | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1244     | Room 9             | NA       | Water Fountain-No Chiller | Potable                  | 6/3/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1245     | Room 9 Bathroom    | NA       | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1258     | Exterior           | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1259     | Exterior           | NA       | Hose Bib                  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1379     | Multi Purpose Room | 2031     | Hand Wash Only            | Non-Potable              | 6/3/2025            | 2.4                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1446     | Corridor Rooms 1-3 | 2032     | Bottle Fill Station       | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1447     | Corridor Rooms 1-3 | 2032     | Water Cooler              | Potable                  | 6/3/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |

# Baylis Elementary School

| Outlet Number | Room Name                   | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|-----------------------------|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1072     | Corridor Room 9 to 14       | 2084     | Bottle Fill Station | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1073     | Corridor Room 9 to 14       | 2084     | Water Cooler        | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1074     | Classroom 15                | 2068     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1075     | Classroom 14 (Now Room C5)  | 2070     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1076     | Classroom 10 (Now Room C1)  | 2073     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1077     | Classroom 13 (Now Room C6)  | 2065     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1078     | Classroom 10 (Now Room C1)  | 2073     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1079     | Classroom 11 (Now Room C4)  | 2063     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1080     | Classroom 9 (Now Room C2)   | 2061     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1081     | Girl's Bathroom             | 2075     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1082     | Girl's Bathroom             | 2075     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1083     | Girl's Bathroom             | 2075     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1084     | Girl's Bathroom             | 2075     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1085     | Custodial Closet E          | 2078     | Slop Sink           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1086     | Boy's Bathroom              | 2076     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1087     | Boy's Bathroom              | 2076     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1088     | Boy's Bathroom              | 2076     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1089     | Boy's Bathroom              | 2076     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1090     | Corridor Fish Bowl to Stage | 2079     | Bottle Fill Station | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1486    |
| SCSD-1091     | Corridor Fish Bowl to Stage | 2079     | Water Cooler        | RFI                            |                     |                      |                              |                               | Outlet Replaced by Sticker No. 1487    |

# Baylis Elementary School

| Outlet Number | Room Name                    | Space ID | Outlet Type      | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|------------------------------|----------|------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-1092     | Girl's Bathroom              | 2051     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1093     | Men's Room                   | 2052     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1094     | Nurse's Bathroom             | 2056     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1095     | Library Room 8               | 2044     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1096     | Custodial Closet             | 2026     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1097     | Women's Bathroom Entrance    | 2029     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1098     | Classroom 4 - Faculty Lounge | 2041     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1099     | 218                          | 2032     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1100     | Classroom 1 (Now Room B7)    | 2035     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1101     | Classroom 1 Bathroom         | 2034     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1102     | Classroom 2 (Now Room B4)    | 2038     | Classroom Faucet | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1103     | Corridor 206 To 214          | 2036     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1104     | 2BES                         | NA       | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1105     | 4BES                         | NA       | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1106     | Boy's Bathroom               | 2018     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1107     | Boy's Bathroom               | 2018     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1108     | Boy's Bathroom               | 2018     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1109     | Men's Bathroom               | 2019     | Slop Sink        | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1110     | Girl's Bathroom              | 2017     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1111     | Girl's Bathroom              | 2017     | Bathroom Faucet  | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Baylis Elementary School

| Outlet Number | Room Name                         | Space ID | Outlet Type           | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|-----------------------------------|----------|-----------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1112     | Girl's Bathroom                   | 2017     | Bathroom Faucet       | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1113     | 205                               | 2015     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1114     | Room 16 (Now Room A2)             | 2013     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1115     | Room 19 (Now Room A3)             | 2012     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1116     | Room 19 (Now Room A3)             | 2012     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1117     | Room 21 (Now Room A5)             | 2011     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1118     | 211                               | 2009     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1119     | 212                               | 2008     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1120     | Room 22 (Now Room A8)             | 2006     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1121     | 213                               | 2007     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1122     | 216                               | 2005     | Classroom Faucet      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1123     | Corridor Main Office to Cafeteria | 2083     | Bottle Fill Station   | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1124     | Corridor Main Office to Cafeteria | 2083     | Water Cooler          | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1125     | Cafeteria                         | 2002     | Kitchen Faucet (Cold) | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1126     | Cafeteria                         | 2002     | Kitchen Faucet (Cold) | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1127     | Cafeteria                         | 2002     | Kitchen Faucet (Cold) | Potable                        | 6/5/2025            | 1.7                  |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1271     | Exterior                          | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1272     | Exterior                          | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1273     | Exterior                          | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1274     | Exterior                          | NA       | Hose Bib              | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

# Baylis Elementary School

| Outlet Number | Room Name                            | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--------------------------------------|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1275     | Exterior                             | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1276     | Exterior                             | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1277     | Exterior                             | NA       | Hose Bib            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1437     | Corridor Fish Bowl to Stage          | 2079     | Bottle Fill Station | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1438     | Corridor Fish Bowl to Stage          | 2079     | Water Cooler        | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1486     | Corridor Fish Bowl to Stage o/s 2046 | 2079     | Bottle Fill Station | Potable                        | 6/27/2025           | < 1.0                |                              |                               |  |
| SCSD-1487     | Corridor Fish Bowl to Stage o/s 2046 | 2079     | Water Cooler        | Potable                        | 6/27/2025           | < 1.0                |                              |                               |  |

# Robbins Lane Elementary School

| Outlet Number | Room Name                         | Space ID | Outlet Type               | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status              |
|---------------|-----------------------------------|----------|---------------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1128     | Faculty Room                      | 2030     | Kitchen Faucet (Cold)     | Potable                  | 5/28/2025           | 1.7                  |                              |                               | Result Below Action Level Continue O&M          |
| SCSD-1129     | Faculty Room                      | 2030     | Spray Nozzle              | Non-Potable              | 5/28/2025           | 6.5                  | 8/12/2025                    | 6.5                           | Placarded for Non-Drinking Use Until Remediated |
| SCSD-1130     | Room 12                           | 2029     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1131     | Room 12                           | 2029     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1132     | Nurse Vestibule                   | 2024     | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1133     | Nurse's Office                    | 2022     | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1134     | Room 8                            | 2018     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1135     | Room 8                            | 2018     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1136     | Corridor Room 10 to Main Entrance | 2028     | Water Fountain-No Chiller | RFI                      |                     |                      |                              |                               | Outlet Permanently Removed                      |
| SCSD-1137     | Male/Female Bathroom              | 2019A    | Bathroom Faucet           | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1138     | Room 6                            | 2017     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1139     | Room 6                            | 2017     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1140     | Room 5                            | 2015     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1141     | Room 5                            | 2015     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1142     | Room 4                            | 2011     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1143     | Room 4                            | 2011     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1144     | Room 7 (Now Room 3)               | 2013     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1145     | Room 7 (Now Room 3)               | 2013     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |
| SCSD-1146     | Room 2                            | 2004     | Classroom Faucet          | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use                  |
| SCSD-1147     | Room 2                            | 2004     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service       |

# Robbins Lane Elementary School

| Outlet Number | Room Name                         | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|-----------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1148     | Room 1&2 Vestibule Toilet Room 2  | 2005     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1149     | Room 1 & 2 Vestibule Toilet Room  | 2006     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1150     | Room 9 (Now Room 1)               | 2003     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1151     | Room 9 (Now Room 1)               | 2003     | Water Fountain-No Chiller | Potable                        | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1152     | Room 12 (Now Room 15)             | 2037     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1153     | Room 11 (Now Room 16)             | 2032     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1154     | Room 14 (Now Room 17)             | 2036     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1155     | Corridor Room 10 to Main Entrance | 2028     | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                |
| SCSD-1156     | Room 13 (Now Room 18)             | 2033     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1157     | Room 13 (Now Room 18)             | 2033     | Water Fountain-No Chiller | Potable                        | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1158     | Room 16 (Now Room 19)             | 2035     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1159     | Room 16 (Now Room 19)             | 2035     | Water Fountain-No Chiller | Potable                        | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1160     | Room 15 (Now Room 20)             | 2034     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1161     | Room 15 (Now Room 20)             | 2034     | Water Fountain-No Chiller | Potable                        | 5/28/2025           | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1162     | Room 21                           | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1163     | Room 22                           | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1164     | Room 23                           | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1165     | Girls Bathroom                    | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1166     | Girls Bathroom                    | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1167     | Girls Bathroom                    | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |

# Robbins Lane Elementary School

| Outlet Number | Room Name                 | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|---------------------------|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1168     | Custodial Closet          | NA       | Slop Sink           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1169     | Boys Bathroom             | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1170     | Boys Bathroom             | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1171     | Boys Bathroom             | NA       | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1172     | Room 24                   | NA       | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1173     | Room 25                   | NA       | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1174     | Room 26                   | NA       | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1175     | Corridor Speech - Room 31 | 2052     | Bottle Fill Station | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1176     | Corridor Speech - Room 31 | 2052     | Water Cooler        | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1177     | Room 30 (Now Room 27)     | 2051     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1178     | Room 31 (Now Room 28)     | 2053     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1179     | Room 28 (Now Room 29)     | 2050     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1180     | Room 29 (Now Room 30)     | 2054     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1181     | Room 26 (Now Room 31)     | 2049     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1182     | Room 27 (Now Room 32)     | 2055     | Classroom Faucet    | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1183     | Girl's Bathroom           | 2048     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1184     | Girl's Bathroom           | 2048     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1185     | Girl's Bathroom           | 2048     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1186     | Girl's Bathroom           | 2048     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1187     | Custodial Closet          | 2045     | Slop Sink           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

# Robbins Lane Elementary School

| Outlet Number | Room Name                             | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status                       |
|---------------|---------------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1188     | Boy's Room Opposite Room 33           | 2046     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1189     | Boy's Room Opposite Room 33           | 2046     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1190     | Boy's Room Opposite Room 33           | 2046     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1191     | Boy's Room Opposite Room 33           | 2046     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1192     | Room 25 (Now Room 33)                 | 2056     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1193     | Room 24 (Now Room 34)                 | 2057     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1194     | Room 23 Art Room (Now Room 35)        | 2058     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1195     | Room 23 Art Room (Now Room 35)        | 2058     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1196     | Adult Bathroom                        | 2066     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1197     | Resource Room 22 (Now Room 38)        | 2067     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1198     | Learning Center Room 21 (Now Room 40) | 2068     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1199     | Cafeteria                             | 2076     | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed                               |
| SCSD-1200     | Men's Kitchen Bathroom & Vestibule    | 2079     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1201     | Kitchen                               | 2080     | Hand Wash Only            | Non-Potable                    | 5/28/2025           | 1.4                  |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-1202     | Kitchen                               | 2080     | Kitchen Faucet (Cold)     | Potable                        | 5/28/2025           | 6.9                  | 8/12/2025                    | 4.5                           | Outlet Remediated Result Below Action Level Continue O&M |
| SCSD-1203     | Gymnasium                             | 2083     | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-1204     | Corridor Boy's Room to Resource Room  | 2071     | Bottle Fill Station       | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-1205     | Corridor Boy's Room to Resource Room  | 2071     | Water Cooler              | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M                   |
| SCSD-1206     | Girl's Room by Gym                    | 2039     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |
| SCSD-1207     | Girl's Room by Gym                    | 2039     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use                           |

# Robbins Lane Elementary School

| Outlet Number | Room Name                            | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--------------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1208     | Custodial Closet by Gym              | 2040     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1209     | Boy's Room by Gym                    | 2038     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1210     | Boy's Room by Gym                    | 2038     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1211     | Boiler Room (New)                    | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1212     | Boiler Room (New)                    | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1213     | Boiler Room 2                        | 2062     | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1263     | Courtyard                            | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1264     | Exterior                             | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1265     | Exterior                             | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1266     | Exterior                             | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1267     | Exterior                             | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1268     | Exterior                             | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1269     | Exterior                             | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1270     | Exterior                             | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1281     | Faculty Bathroom Next To Space# 2073 | NA       | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1285     | Room 26 (Now Room 31)                | 2049     | Water Fountain-No Chiller | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-1481     | Corridor Room 10 to Main Entrance    | 2028     | Bottle Fill Station       | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1482     | Corridor Room 10 to Main Entrance    | 2028     | Water Cooler              | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1483     | Cafeteria                            | 2076     | Bottle Fill Station       | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1484     | Cafeteria                            | 2076     | Water Cooler              | Potable                        | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |

# Robbins Lane Elementary School

| Outlet Number | Room Name | Space ID | Outlet Type               | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|-----------|----------|---------------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1485     | Gymnasium | 2083     | Water Fountain-No Chiller | Potable                  | 5/28/2025           | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |

# Maintenance Building

| Outlet Number | Room Name          | Space ID | Outlet Type         | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|--------------------|----------|---------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1289     | Locker/Common Room | 1003     | Bottle Fill Station | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-1290     | Locker/Common Room | 1003     | Water Cooler        | RFI                            |                     |                      |                              |                               | Outlet Permanently Removed             |
| SCSD-1291     | Storage Area       | 1005     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1292     | Women's Bathroom   | 1002     | Bathroom Faucet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1293     | Garage             | 1009     | Hand Wash Only      | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1427     | Locker/Common Room | 1003     | Bottle Fill Station | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1428     | Locker/Common Room | 1003     | Water Cooler        | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |

# Walt Whitman Elementary School

| Outlet Number | Room Name                 | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|---------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1294     | Room 11                   | 2055B    | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1295     | Room 6                    | 2026     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1296     | Room 6 Bathroom           | 2024     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1297     | Corridor Room 2 to Room 6 | 2068     | Bottle Fill Station       | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1298     | Corridor Room 2 to Room 6 | 2068     | Water Cooler              | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1299     | Room 5                    | 2022     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1300     | Room 5 Bathroom           | 2027     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1301     | Nurse's Office Bathroom   | 2030     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1302     | Custodial Closet          | 2032     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1303     | Women's Bathroom          | 2031     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1304     | Women's Bathroom          | 2031     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1305     | Room 4                    | 2020     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1306     | Room 4 Bathroom           | 2021     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1307     | Room 3                    | 2015     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1308     | Room 3 Bathroom           | 2018     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1309     | Room 2                    | 2013     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1310     | Room 2                    | 2013     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1311     | Room 2 Bathroom           | 2011     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1312     | Room 1                    | 2007     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1313     | Room 1                    | 2007     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |

# Walt Whitman Elementary School

| Outlet Number | Room Name            | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|----------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1314     | Room 1 Bathroom      | 2009     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1315     | Modular Room A       | 2076     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1316     | Modular Room B       | 2077     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1317     | Corridor to Room A-C | 2075     | Bottle Fill Station       | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1318     | Corridor to Room A-C | 2075     | Water Cooler              | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1319     | Modular Room C       | 2078     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1320     | Room 8               | 2036     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1321     | Room 8               | 2036     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1322     | Library Room 7       | 2035     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1323     | Gymnasium            | 2037     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1324     | Girl's Bathroom      | 2049     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1325     | Girl's Bathroom      | 2049     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1326     | Girl's Bathroom      | 2049     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1327     | Girl's Bathroom      | 2049     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1328     | Boy's Bathroom       | 2052     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1329     | Boy's Bathroom       | 2052     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1330     | Boy's Bathroom       | 2052     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1331     | Custodial Closet     | 2080     | Slop Sink                 | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1332     | Room 9               | 2053     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1333     | Faculty Lounge       | 2028     | Kitchen Faucet (Cold)     | Potable                        | 6/5/2025            | 4.3                  |                              |                               | Result Below Action Level Continue O&M    |

# Walt Whitman Elementary School

| Outlet Number | Room Name                               | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|---|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1334     | Room 13                                 | 2057     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1335     | Room 13                                 | 2057     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1336     | Corridor from Room 19 to Boy's Bathroom | 2067     | Bottle Fill Station       | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1337     | Corridor from Room 19 to Boy's Bathroom | 2067     | Water Cooler              | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1338     | Room 15                                 | 2059     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1339     | Room 15                                 | 2059     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1340     | Room 17                                 | 2061     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1341     | Room 17                                 | 2061     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1342     | Room 19                                 | 2063     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1343     | Room 19                                 | 2063     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1344     | Room 21                                 | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1345     | Room 21                                 | NA       | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1346     | Room 22, Art Room                       | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1347     | Room 22, Art Room                       | NA       | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1349     | Boy's Bathroom by Room 19               | 2064     | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1350     | Psychologist Room                       | 2066     | Hand Wash Only            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1351     | Girl's Bathroom                         | 2065     | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1352     | Girl's Bathroom                         | 2065     | Tempered Water Outlet     | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1353     | Room 18                                 | 2062     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1354     | Room 18                                 | 2062     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |

# Walt Whitman Elementary School

| Outlet Number | Room Name                          | Space ID | Outlet Type               | Potable/<br>Applicable/<br>RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status        |
|---------------|------------------------------------|----------|---------------------------|--------------------------------|---------------------|----------------------|------------------------------|-------------------------------|---|
| SCSD-1355     | Room 16                            | 2060     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1356     | Room 16                            | 2060     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1357     | Room 14                            | 2058     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1358     | Room 14                            | 2058     | Water Fountain-No Chiller | Potable                        | 6/5/2025            | OOS                  |                              |                               | Testing Required Before Return to Service |
| SCSD-1359     | Room 12                            | 2056     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1360     | Room 10                            | 2054     | Classroom Faucet          | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1361     | Kitchen/Serving Area               | 2043     | Hand Wash Only            | Non-Potable                    | 6/5/2025            | 2.0                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1362     | Kitchen/Serving Area               | 2043     | Kitchen Faucet (Cold)     | Potable                        | 6/5/2025            | 3.6                  |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1363     | Corridor Music Room to Main Office | 2069A    | Bottle Fill Station       | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1364     | Corridor Music Room to Main Office | 2069A    | Water Cooler              | Potable                        | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M    |
| SCSD-1365     | Unisex Bathroom                    | 2045     | Bathroom Faucet           | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1366     | Boiler Room                        | 1001     | Hand Wash Only            | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1367     | Exterior o/s 2013                  | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1368     | Exterior o/s 2015                  | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1369     | Exterior o/s 2035                  | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1370     | Exterior o/s 1370                  | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1371     | Exterior o/s 2066                  | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1372     | Exterior o/s Room 21               | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1373     | Exterior o/s 2053                  | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |
| SCSD-1374     | Exterior o/s 2074                  | NA       | Hose Bib                  | Non-Applicable                 |                     |                      |                              |                               | Placarded for Non-Drinking Use            |


# Walt Whitman Elementary School

| Outlet Number | Room Name         | Space ID | Outlet Type | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status |
|---------------|-------------------|----------|-------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|------------------------------------|
| SCSD-1375     | Exterior o/s 2044 | NA       | Hose Bib    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |
| SCSD-1376     | Exterior o/s 2022 | NA       | Hose Bib    | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use     |

# Maintenance Garage

| Outlet Number | Room Name             | Space ID | Outlet Type             | Potable/ Applicable/ RFI | Initial Sample Date | Initial Result (ppb) | Post Remediation Sample Date | Post Remediation Result (ppb) | Remediation Actions/Current Status     |
|---------------|-----------------------|----------|-------------------------|--------------------------|---------------------|----------------------|------------------------------|-------------------------------|--|
| SCSD-1415     | Wood Storage (Barn)   | NA       | Bottled Water Dispenser | Potable                  | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1416     | Wood Storage (Barn)   | NA       | Water Cooler            | Potable                  | 6/5/2025            | <1.00 ND             |                              |                               | Result Below Action Level Continue O&M |
| SCSD-1417     | Wood Storage (Barn)   | NA       | Slop Sink               | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |
| SCSD-1418     | Men's Bathroom (Barn) | NA       | Bathroom Faucet         | Non-Applicable           |                     |                      |                              |                               | Placarded for Non-Drinking Use         |

Attachment 3:  
  
Laboratory  
Analytical Reports



**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395

ED53001

Ps 200 - 887 - 6/19/25



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-53856  
Building: Robbins Lane Elementary School  
RLE

Client: Syosset Central School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                     | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--------------------------------------|-------------|-------------|-------------|
| SCSD-1128 | FL                    | 2030     | Faculty Room                         | KC          | 5/28/2025   | 5:43:00 AM  |
| SCSD-1129 | FL                    | 2030     | Faculty Room                         | SN          | 5/28/2025   | 5:43:00 AM  |
| SCSD-1175 | HA                    | 2052     | Corridor Speech - Room 31            | WF          | 5/28/2025   | 6:04:00 AM  |
| SCSD-1176 | HA                    | 2052     | Corridor Speech - Room 31            | WC          | 5/28/2025   | 6:05:00 AM  |
| SCSD-1201 | KI                    | 2080     | Kitchen                              | HW          | 5/28/2025   | 6:23:00 AM  |
| SCSD-1202 | KI                    | 2080     | Kitchen                              | KC          | 5/28/2025   | 6:23:00 AM  |
| SCSD-1204 | HA                    | 2071     | Corridor Boy's Room to Resource Room | WF          | 5/28/2025   | 6:07:00 AM  |
| SCSD-1205 | HA                    | 2071     | Corridor Boy's Room to Resource Room | WC          | 5/28/2025   | 6:08:00 AM  |
| SCSD-1481 | HA                    | 2028     | Corridor Room 10 to Main Entrance    | WF          | 5/28/2025   | 5:49:00 AM  |
| SCSD-1482 | HA                    | 2028     | Corridor Room 10 to Main Entrance    | WC          | 5/28/2025   | 5:49:00 AM  |
| SCSD-1483 | CA                    | 2076     | Cafeteria                            | WF          | 5/28/2025   | 6:12:00 AM  |
| SCSD-1484 | CA                    | 2076     | Cafeteria                            | WC          | 5/28/2025   | 6:12:00 AM  |
| SCSD-1485 | GY                    | 2083     | Gymnasium                            | DW          | 5/28/2025   | 6:16:00 AM  |

Samples Submitted RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 06 25, PM03:53



Building Address  
157 Robbins Lane  
Syosset, NY 11791

Analysis Type: ELAP 200.5  
Lab Received: Astanley 6/19/25  
Signature: [Signature] 3:53pm

Samplers Name: [Signature]  
Samplers Signature: [Signature]  
JCB Project Manager: Bryant Zelaz



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553001

LIMS Reference ID: ED53001

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Robbins Lane Elementary School, RLE,  
Syosset Central School District , 157 Robbins Lane  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**

**Analytical Results**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1128 Lims Reference ID: ED53001-01 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead 1.7 1 1.0 µg/L 06/09/25 12:40 06/09/25 12:40 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1129 Lims Reference ID: ED53001-02 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead 6.5 1 1.0 µg/L 06/09/25 12:44 06/09/25 12:44 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1175 Lims Reference ID: ED53001-03 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 12:46 06/09/25 12:46 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1176 Lims Reference ID: ED53001-04 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 12:47 06/09/25 12:47 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1201 Lims Reference ID: ED53001-05 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead 1.4 1 1.0 µg/L 06/09/25 12:48 06/09/25 12:48 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1202 Lims Reference ID: ED53001-06 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead 6.9 1 1.0 µg/L 06/09/25 12:52 06/09/25 12:52 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1204 Lims Reference ID: ED53001-07 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 12:54 06/09/25 12:54 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1205 Lims Reference ID: ED53001-08 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 12:55 06/09/25 12:55 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1481 Lims Reference ID: ED53001-09 Matrix: Drinking Water Sampled: 05/28/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553001

LIMS Reference ID: ED53001

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Robbins Lane Elementary School, RLE,  
Syosset Central School District , 157 Robbins Lane  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**

**Analytical Results**  
(Continued)

| Analyte  | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|--|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-1481 (Continued) Lims Reference ID: ED53001-09 Matrix: Drinking Water Sampled: 05/28/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals (Continued)</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 12:56     | 06/09/25 12:56     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1482 Lims Reference ID: ED53001-10 Matrix: Drinking Water Sampled: 05/28/25 00:00:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 12:58     | 06/09/25 12:58     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1483 Lims Reference ID: ED53001-11 Matrix: Drinking Water Sampled: 05/28/25 00:00:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 12:59     | 06/09/25 12:59     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1484 Lims Reference ID: ED53001-12 Matrix: Drinking Water Sampled: 05/28/25 00:00:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:03     | 06/09/25 13:03     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1485 Lims Reference ID: ED53001-13 Matrix: Drinking Water Sampled: 05/28/25 00:00:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:04     | 06/09/25 13:04     | SEH              | EPA 200.8 (DA)/EPA 200.8 |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553001

LIMS Reference ID: ED53001

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Robbins Lane Elementary School, RLE,  
Syosset Central School District , 157 Robbins Lane  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553001

**LIMS Reference ID:** ED53001

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Robbins Lane Elementary School, RLE,  
Syosset Central School District , 157 Robbins Lane  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED 53003



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-53856  
Building: Village Elementary School  
VES

Client: Syosset Central School District

Retest/New Install   
Turn Around: Normal 1 wk Rush

Probes & SAs - 0 labels

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                       | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--|-------------|-------------|-------------|
| SCSD-0675 | HA                    | 2045     | Corridor Multi Purpose Room to Library | WF          | 5/29/2025   | 5:56:00 AM  |
| SCSD-0676 | HA                    | 2045     | Corridor Multi Purpose Room to Library | WC          | 5/29/2025   | 5:56:00 AM  |
| SCSD-0684 | HA                    | 2045     | Corridor Multi Purpose Room to Library | WF          | 5/29/2025   | 6:20:00 AM  |
| SCSD-0685 | HA                    | 2045     | Corridor Multi Purpose Room to Library | WC          | 5/29/2025   | 6:20:00 AM  |
| SCSD-0688 | NO                    | 2022D    | Nurse's Office                         | NS          | 5/29/2025   | 6:25:00 AM  |
| SCSD-0708 | CA                    | 2047     | Multi Purpose Room                     | HW          | 5/29/2025   | 6:41:00 AM  |
| SCSD-0709 | CA                    | 2047     | Multi Purpose Room                     | WF          | 5/29/2025   | 6:40:00 AM  |
| SCSD-0710 | CA                    | 2047     | Multi Purpose Room                     | WC          | 5/29/2025   | 6:40:00 AM  |
| SCSD-0711 | KI                    | 2047A    | Kitchen                                | KC          | 5/29/2025   | 6:42:00 AM  |
| SCSD-0712 | CA                    | 2047     | Multi Purpose Room                     | HW          | 5/29/2025   | 6:44:00 AM  |
| SCSD-0742 | FL                    | 2038     | Faculty Lounge                         | KC          | 5/29/2025   | 6:22:00 AM  |

Samples Submitted 11

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 06 25, PM 03:53



**Building Address**  
90 Convent Road  
Syosset, NY 11791

**Analysis Type:** ELAP 200.5  
**Lab Recieved:** ASTanley 6/6/25  
**Signature:** [Signature] 3:03 PM

**Samplers Name:** Fran Gorge  
**Samplers Signature:** [Signature]  
**JCB Project Manager:** Fran Zelas



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553003

LIMS Reference ID: ED53003

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Village Elementary School, VES, Syosset  
Central School District, 90 Convent Road, Syosset,  
NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**

**Analytical Results**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-0675</b> Lims Reference ID: ED53003-01 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:08     | 06/09/25 13:08     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0676</b> Lims Reference ID: ED53003-02 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:09     | 06/09/25 13:09     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0684</b> Lims Reference ID: ED53003-03 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:11     | 06/09/25 13:11     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0685</b> Lims Reference ID: ED53003-04 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:12     | 06/09/25 13:12     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0688</b> Lims Reference ID: ED53003-05 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.7    |   | 1  | 1.0 | µg/L  | 06/09/25 13:13     | 06/09/25 13:13     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0708</b> Lims Reference ID: ED53003-06 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:15     | 06/09/25 13:15     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0709</b> Lims Reference ID: ED53003-07 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 13:16     | 06/09/25 13:16     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0710</b> Lims Reference ID: ED53003-08 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 14:05     | 06/09/25 14:05     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0711</b> Lims Reference ID: ED53003-09 Matrix: Drinking Water <b>Sampled: 05/29/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553003

**LIMS Reference ID:** ED53003

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Village Elementary School, VES, Syosset  
Central School District, 90 Convent Road, Syosset,  
NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0711 (Continued) Lims Reference ID: ED53003-09 Matrix: Drinking Water Sampled: 05/29/25 00:00:00

**Metals (Continued)**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/09/25 14:06 | 06/09/25 14:06 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|

Sample: SCSD-0712 Lims Reference ID: ED53003-10 Matrix: Drinking Water Sampled: 05/29/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/09/25 14:08 | 06/09/25 14:08 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|

Sample: SCSD-0742 Lims Reference ID: ED53003-11 Matrix: Drinking Water Sampled: 05/29/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/09/25 14:09 | 06/09/25 14:09 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553003

**LIMS Reference ID:** ED53003

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Village Elementary School, VES, Syosset  
Central School District, 90 Convent Road, Syosset,  
NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553003

**LIMS Reference ID:** ED53003

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 24-53856, Village Elementary School, VES, Syosset  
Central School District, 90 Convent Road, Syosset,  
NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/06/2025 15:53  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

# ED52884

**JCB #:** 23-53856  
**Building:** Willits Elementary School

**Client:** Syosset Central School District



**Retest/New Install**   
**Turn Around:** Normal / wk Rush \_\_\_\_\_

WES

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                               | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--|-------------|-------------|-------------|
| SCSD-0930 | CA                    | NA       | Cafeteria                                      | KC          | 5/30/2025   | 6:48:00 AM  |
| SCSD-0931 | CA                    | NA       | Cafeteria                                      | KC          | 5/30/2025   | 6:49:00 AM  |
| SCSD-0947 | ST                    | 2042     | Gym Kitchen                                    | KC          | 5/30/2025   | 6:40:00 AM  |
| SCSD-0954 | HA                    | 2029     | Corridor Room 21 to Gym                        | WF          | 5/30/2025   | 6:52:00 AM  |
| SCSD-0955 | HA                    | 2029     | Corridor Room 21 to Gym                        | WC          | 5/30/2025   | 6:52:00 AM  |
| SCSD-0956 | FL                    | 2038     | Faculty Room                                   | KC          | 5/30/2025   | 6:44:00 AM  |
| SCSD-0959 | HA                    | 2037     | Corridor Boiler Room to Main Entrance          | WF          | 5/30/2025   | 6:55:00 AM  |
| SCSD-0960 | HA                    | 2037     | Corridor Boiler Room to Main Entrance          | WC          | 5/30/2025   | 6:55:00 AM  |
| SCSD-1283 | HA                    | NA       | 6N   | WF          | 5/30/2025   | 7:00:00 AM  |
| SCSD-1284 | HA                    | NA       | 6N   | WC          | 5/30/2025   | 7:00:00 AM  |
| SCSD-1431 | HA                    | 2037     | Corridor Boiler Room to Main Entrance o/s 2019 | WF          | 5/30/2025   | 7:00:00 AM  |
| SCSD-1432 | HA                    | 2037     | Corridor Boiler Room to Main Entrance o/s 2019 | WC          | 5/30/2025   | 7:01:00 AM  |

Samples Submitted 12

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 04 25. AM 11:53

*to 200.8 Willits Jones 6/16/25*

**Building Address**  
99 Nana Place  
Syosset, NY 11791

**Analysis Type:** ELAP 200.5

**Lab Received:** *A. Minnifield*

**Signature:** *A. Minnifield*

**Samplers Name:** *Betty George*

**Samplers Signature:** *[Signature]*

**JCB Project Manager:** *Bryan Tschlus*



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552884

LIMS Reference ID: ED52884

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Willits Elementary School, WES, Syosset Central School District, 99 Nana Place, Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:53  
**Reported:**

**Analytical Results**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-0930</b> Lims Reference ID: ED52884-01 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 21.3   |   | 1  | 1.0 | µg/L  | 06/06/25 20:32     | 06/06/25 20:32     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0931</b> Lims Reference ID: ED52884-02 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 5.7    |   | 1  | 1.0 | µg/L  | 06/06/25 20:33     | 06/06/25 20:33     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0947</b> Lims Reference ID: ED52884-03 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 5.6    |   | 1  | 1.0 | µg/L  | 06/06/25 20:34     | 06/06/25 20:34     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0954</b> Lims Reference ID: ED52884-04 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:36     | 06/06/25 20:36     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0955</b> Lims Reference ID: ED52884-05 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:51     | 06/06/25 20:51     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0956</b> Lims Reference ID: ED52884-06 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.3    |   | 1  | 1.0 | µg/L  | 06/06/25 20:55     | 06/06/25 20:55     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0959</b> Lims Reference ID: ED52884-07 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:56     | 06/06/25 20:56     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0960</b> Lims Reference ID: ED52884-08 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:58     | 06/06/25 20:58     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1283</b> Lims Reference ID: ED52884-09 Matrix: Drinking Water <b>Sampled: 05/30/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062552884

**LIMS Reference ID:** ED52884

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Willits Elementary School, WES, Syosset  
Central School District, 99 Nana Place, Syosset NY  
11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:53  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte                              | Result | Q | DF                                   | RL  | Units | Prepared Date/Time            | Analyzed Date/Time | Analyst Initials                  | Prep /Analytical Method  |
|--------------------------------------|--------|---|--------------------------------------|-----|-------|-------------------------------|--------------------|-----------------------------------|--------------------------|
| <b>Sample: SCSD-1283 (Continued)</b> |        |   | <b>Lims Reference ID: ED52884-09</b> |     |       | <b>Matrix: Drinking Water</b> |                    | <b>Sampled: 05/30/25 00:00:00</b> |                          |
| <b>Metals (Continued)</b>            |        |   |                                      |     |       |                               |                    |                                   |                          |
| Lead                                 | < 1.0  |   | 1                                    | 1.0 | µg/L  | 06/06/25 20:59                | 06/06/25 20:59     | KT                                | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1284</b>             |        |   | <b>Lims Reference ID: ED52884-10</b> |     |       | <b>Matrix: Drinking Water</b> |                    | <b>Sampled: 05/30/25 00:00:00</b> |                          |
| <b>Metals</b>                        |        |   |                                      |     |       |                               |                    |                                   |                          |
| Lead                                 | < 1.0  |   | 1                                    | 1.0 | µg/L  | 06/06/25 21:03                | 06/06/25 21:03     | KT                                | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1431</b>             |        |   | <b>Lims Reference ID: ED52884-11</b> |     |       | <b>Matrix: Drinking Water</b> |                    | <b>Sampled: 05/30/25 00:00:00</b> |                          |
| <b>Metals</b>                        |        |   |                                      |     |       |                               |                    |                                   |                          |
| Lead                                 | < 1.0  |   | 1                                    | 1.0 | µg/L  | 06/06/25 21:04                | 06/06/25 21:04     | KT                                | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1432</b>             |        |   | <b>Lims Reference ID: ED52884-12</b> |     |       | <b>Matrix: Drinking Water</b> |                    | <b>Sampled: 05/30/25 00:00:00</b> |                          |
| <b>Metals</b>                        |        |   |                                      |     |       |                               |                    |                                   |                          |
| Lead                                 | < 1.0  |   | 1                                    | 1.0 | µg/L  | 06/06/25 21:05                | 06/06/25 21:05     | KT                                | EPA 200.8 (DA)/EPA 200.8 |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552884

LIMS Reference ID: ED52884

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Willits Elementary School, WES, Syosset Central School District, 99 Nana Place, Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:53  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062552884

**LIMS Reference ID:** ED52884

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Willits Elementary School, WES, Syosset  
Central School District, 99 Nana Place, Syosset NY  
11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:53  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: Thompson Middle School  
TMS

# ED52890

Client: Syosset Central School District  
RECEIVED  
EWB ANALYTICAL, INC.  
Retest/New Install (Carle Place, NY)  
Turn Around: Normal 1-wk. Rush 2-3 Business Days

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                 | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|----------------------------------|-------------|-------------|-------------|
| SCSD-0768 | HA                    | 2092     | Corridor Custodial - Gym         | WF          | 5/30/2025   | 5:57:00 AM  |
| SCSD-0769 | HA                    | 2092     | Corridor Custodial - Gym         | WC          | 5/30/2025   | 5:57:00 AM  |
| SCSD-0781 | HE                    | 2098     | FCSB Family & Consumer Service B | EC          | 5/30/2025   | 6:17:00 AM  |
| SCSD-0782 | HE                    | 2098     | FCSB Family & Consumer Service B | EC          | 5/30/2025   | 6:18:00 AM  |
| SCSD-0783 | HE                    | 2098     | FCSB Family & Consumer Service B | EC          | 5/30/2025   | 6:18:00 AM  |
| SCSD-0784 | HE                    | 2099     | FCSA Family & Consumer Service A | EC          | 5/30/2025   | 6:20:00 AM  |
| SCSD-0785 | HE                    | 2099     | FCSA Family & Consumer Service A | EC          | 5/30/2025   | 6:21:00 AM  |
| SCSD-0786 | HE                    | 2099     | FCSA Family & Consumer Service A | EC          | 5/30/2025   | 6:22:00 AM  |
| SCSD-0787 | HE                    | 2099     | FCSA Family & Consumer Service A | EC          | 5/30/2025   | 6:23:00 AM  |
| SCSD-0808 | HA                    | 2092     | Corridor Custodial - Gym         | WF          | 5/30/2025   | 5:59:00 AM  |
| SCSD-0809 | HA                    | 2092     | Corridor Custodial - Gym         | WC          | 5/30/2025   | 5:59:00 AM  |
| SCSD-0831 | HA                    | 2182     | Corridor North Gym - South Gym   | WF          | 5/30/2025   | 5:21:00 AM  |
| SCSD-0842 | NO                    | 2125     | Nurse's Office                   | NS          | 5/30/2025   | 6:12:00 AM  |
| SCSD-0843 | OF                    | 2132     | Main Office Conference Room      | KC          | 5/30/2025   | 6:14:00 AM  |
| SCSD-0845 | HA                    | 2180     | Main Entrance Corridor           | WF          | 5/30/2025   | 5:29:00 AM  |
| SCSD-0859 | HA                    | 2180     | Main Entrance Corridor           | WF          | 5/30/2025   | 5:31:00 AM  |
| SCSD-0862 | CA                    | 2154C    | Snack Shop                       | KC          | 5/30/2025   | 5:52:00 AM  |
| SCSD-0863 | CA                    | 2154A    | North Cafeteria                  | WF          | 5/30/2025   | 5:35:00 AM  |

**Building Address**

98 Ann Drive  
Syosset, NY 11791

Analysis Type: ELAP 200.5


Lab Recieved: S. Cherofsky 6/1/25

Signature: S. Chung 11:47am

Samplers Name: Jean George

Samplers Signature: [Signature]

JCB Project Manager: Bryan Fielus



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: Thompson Middle School  
TMS

# ED52890

Client: Syosset Central School District

~~Retest~~ New Install  
Turn Around: Normal 1 wk Rush

| Sample ID | Functional Space Type | AHERA ID | Common Room Name          | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|---------------------------|-------------|-------------|-------------|
| SCSD-0865 | CA                    | 2154B    | South Cafeteria           | WF          | 5/30/2025   | 5:33:00 AM  |
| SCSD-0867 | FL                    | 2155     | Faculty Lounge            | KC          | 5/30/2025   | 5:46:00 AM  |
| SCSD-0868 | FL                    | 2155     | Faculty Lounge            | SN          | 5/30/2025   | 5:46:00 AM  |
| SCSD-0869 | KI                    | 2156     | Kitchen                   | KC          | 5/30/2025   | 5:37:00 AM  |
| SCSD-0874 | KI                    | 2156     | Kitchen                   | KC          | 5/30/2025   | 5:39:00 AM  |
| SCSD-0875 | KI                    | 2156     | Kitchen                   | KC          | 5/30/2025   | 5:42:00 AM  |
| SCSD-0886 | CR                    | 2170A    | Room ITA Tech A Wood Shop | SN          | 5/30/2025   | 5:56:00 AM  |
| SCSD-0892 | HA                    | 3280     | 2nd Floor Main Corridor   | WF          | 5/30/2025   | 6:04:00 AM  |
| SCSD-0907 | HA                    | 3280     | 2nd Floor Main Corridor   | WF          | 5/30/2025   | 6:03:00 AM  |

Samples Submitted 27

RECEIVED  
ENSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 04 25, AM 11:47

**Building Address**  
98 Ann Drive  
Syosset, NY 11791

Analysis Type: ELAP 200.5

Lab Received: S. Cherofsky 6/4/25

Signature: S. Chung 11:47am

Samplers Name: Jessica Gorge

Samplers Signature: [Signature]

JCB Project Manager: Ryan Ezzelus



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552890

LIMS Reference ID: ED52890

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District,  
Thompson Middle School TMS, 98 Ann Drive,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:47  
**Reported:**

**Analytical Results**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0768 Lims Reference ID: ED52890-01 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:07 06/06/25 21:07 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0769 Lims Reference ID: ED52890-02 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:08 06/06/25 21:08 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0781 Lims Reference ID: ED52890-03 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 21.4 1 1.0 µg/L 06/06/25 21:09 06/06/25 21:09 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0782 Lims Reference ID: ED52890-04 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 5.8 1 1.0 µg/L 06/06/25 21:13 06/06/25 21:13 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0783 Lims Reference ID: ED52890-05 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 5.6 1 1.0 µg/L 06/06/25 21:15 06/06/25 21:15 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0784 Lims Reference ID: ED52890-06 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 1.9 1 1.0 µg/L 06/06/25 21:19 06/06/25 21:19 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0785 Lims Reference ID: ED52890-07 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 2.2 1 1.0 µg/L 06/06/25 21:20 06/06/25 21:20 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0786 Lims Reference ID: ED52890-08 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 6.2 1 1.0 µg/L 06/06/25 21:21 06/06/25 21:21 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0787 Lims Reference ID: ED52890-09 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552890

LIMS Reference ID: ED52890

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District,  
Thompson Middle School TMS, 98 Ann Drive,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:47  
**Reported:**

**Analytical Results**  
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0787 (Continued) Lims Reference ID: ED52890-09 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals (Continued)**

Lead 7.7 1 1.0 µg/L 06/06/25 21:23 06/06/25 21:23 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0808 Lims Reference ID: ED52890-10 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:24 06/06/25 21:24 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0809 Lims Reference ID: ED52890-11 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:25 06/06/25 21:25 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0831 Lims Reference ID: ED52890-12 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:27 06/06/25 21:27 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0842 Lims Reference ID: ED52890-13 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 15.9 1 1.0 µg/L 06/06/25 21:41 06/06/25 21:41 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0843 Lims Reference ID: ED52890-14 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 16.4 1 1.0 µg/L 06/06/25 21:44 06/06/25 21:44 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0845 Lims Reference ID: ED52890-15 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:46 06/06/25 21:46 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0859 Lims Reference ID: ED52890-16 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:47 06/06/25 21:47 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0862 Lims Reference ID: ED52890-17 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062552890  
**LIMS Reference ID:** ED52890  
**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District,  
Thompson Middle School TMS, 98 Ann Drive,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:47  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0862 (Continued) Lims Reference ID: ED52890-17 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals (Continued)**

Lead 11.2 1 1.0 µg/L 06/06/25 21:48 06/06/25 21:48 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0863 Lims Reference ID: ED52890-18 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:52 06/06/25 21:52 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0865 Lims Reference ID: ED52890-19 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:54 06/06/25 21:54 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0867 Lims Reference ID: ED52890-20 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 46.9 1 1.0 µg/L 06/16/25 18:19 06/16/25 18:19 KT1 EPA 200.8 (Dig)/EPA 200.8

Sample: SCSD-0868 Lims Reference ID: ED52890-21 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/06/25 21:55 06/06/25 21:55 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0869 Lims Reference ID: ED52890-22 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 3.1 1 1.0 µg/L 06/06/25 21:56 06/06/25 21:56 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0874 Lims Reference ID: ED52890-23 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 1.9 1 1.0 µg/L 06/06/25 21:58 06/06/25 21:58 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0875 Lims Reference ID: ED52890-24 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

Lead 1.5 1 1.0 µg/L 06/06/25 21:59 06/06/25 21:59 KT EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0886 Lims Reference ID: ED52890-25 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552890

LIMS Reference ID: ED52890

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District,  
Thompson Middle School TMS, 98 Ann Drive,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:47  
**Reported:**

**Analytical Results**  
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0886 (Continued) Lims Reference ID: ED52890-25 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals (Continued)**

|      |     |  |   |     |      |                |                |    |                          |
|------|-----|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | 7.9 |  | 1 | 1.0 | µg/L | 06/06/25 22:03 | 06/06/25 22:03 | KT | EPA 200.8 (DA)/EPA 200.8 |
|------|-----|--|---|-----|------|----------------|----------------|----|--------------------------|

Sample: SCSD-0892 Lims Reference ID: ED52890-26 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |    |                          |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/06/25 22:04 | 06/06/25 22:04 | KT | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|

Sample: SCSD-0907 Lims Reference ID: ED52890-27 Matrix: Drinking Water Sampled: 05/30/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |    |                          |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/06/25 22:08 | 06/06/25 22:08 | KT | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552890

LIMS Reference ID: ED52890

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District,  
Thompson Middle School TMS, 98 Ann Drive,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:47  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552890

LIMS Reference ID: ED52890

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District,  
Thompson Middle School TMS, 98 Ann Drive,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:47  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

# ED52900

**JCB #:** 23-53856  
**Building:** Syosset High School  
SHS

**Client:** Syosset Central School District

**Retest/New Install [ ]**  
**Turn Around:** Normal 1 wk Rush



RECEIVED  
LAB ANALYTICAL, INC.  
CARLE PLACE, NY  
JUN 04 2025

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                 | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|----------------------------------|-------------|-------------|-------------|
| SCSD-0011 | HE                    | 2381     | HE 2                             | EC          | 5/31/2025   | 5:40:00 AM  |
| SCSD-0012 | HE                    | 2381     | HE 2                             | EC          | 5/31/2025   | 5:41:00 AM  |
| SCSD-0013 | HE                    | 2380     | HE 3                             | EC          | 5/31/2025   | 5:42:00 AM  |
| SCSD-0014 | HE                    | 2380     | HE 3                             | EC          | 5/31/2025   | 5:43:00 AM  |
| SCSD-0015 | HE                    | 2380     | HE 3                             | EC          | 5/31/2025   | 5:44:00 AM  |
| SCSD-0016 | HE                    | 2380     | HE 3                             | EC          | 5/31/2025   | 5:45:00 AM  |
| SCSD-0017 | HE                    | 2380     | HE 3                             | EC          | 5/31/2025   | 5:46:00 AM  |
| SCSD-0041 | OF                    | 2244A    | Cafeteria East Office/Snack Area | KC          | 5/31/2025   | 6:04:00 AM  |
| SCSD-0042 | HA                    | 2244     | Cafeteria East                   | WF          | 5/31/2025   | 6:02:00 AM  |
| SCSD-0043 | HA                    | 2244     | Cafeteria East                   | WC          | 5/31/2025   | 6:03:00 AM  |
| SCSD-0045 | KI                    | 2240     | Serving Area East                | KC          | 5/31/2025   | 6:05:00 AM  |
| SCSD-0046 | KI                    | 2242     | Kitchen                          | KC          | 5/31/2025   | 6:06:00 AM  |
| SCSD-0047 | KI                    | 2242     | Kitchen                          | HW          | 5/31/2025   | 6:07:00 AM  |
| SCSD-0048 | KI                    | 2242     | Kitchen                          | KC          | 5/31/2025   | 6:10:00 AM  |
| SCSD-0049 | KI                    | 2242     | Kitchen                          | IM          | 5/31/2025   | 6:13:00 AM  |
| SCSD-0054 | KI                    | 2242     | Kitchen                          | PK          | 5/31/2025   | 6:10:00 AM  |
| SCSD-0055 | KI                    | 2242     | Kitchen                          | KC          | 5/31/2025   | 6:07:00 AM  |
| SCSD-0056 | KI                    | 2237     | Serving Area West                | KC          | 5/31/2025   | 6:17:00 AM  |

5/21/25  
Pb200-8878-6/12/25  
5/16/25  
Pb200-8878-6/12/25

**Building Address**  
70 South Woods Road  
Syosset, NY 11791

**Analysis Type:** ELAP 200.5


**Lab Received:** DAVID WHARTON 6/4/25 6:54 PM

**Signature:** David Wharton

**Samplers Name:** Feleki George

**Samplers Signature:** [Signature]

**JCB Project Manager:** Bryan Ezelus



# Lead in Water: Chain of Custody for

# ED52900

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: Syosset High School  
SHS

Client: Syosset Central School District

Retest/New Install [ ]  
Turn Around: Normal Wk Rush \_\_\_\_\_

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                     | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--------------------------------------|-------------|-------------|-------------|
| SCSD-0208 | HA                    | 2131     | 127 Closet                           | WF          | 5/31/2025   | 6:53:00 AM  |
| SCSD-0303 | OF                    | 2125     | Science Office                       | KC          | 5/31/2025   | 6:57:00 AM  |
| SCSD-0314 | FA                    | 3426A    | Faculty Room (Interior Wall Removed) | KC          | 5/31/2025   | 7:01:00 AM  |
| SCSD-0319 | HA                    | 3431     | Corridor E12-E15                     | WF          | 5/31/2025   | 7:04:00 AM  |
| SCSD-0376 | OF                    | 2189     | Library Office                       | KC          | 5/31/2025   | 7:18:00 AM  |
| SCSD-0377 | HA                    | 2191     | Quarter Mile Corridor South          | WF          | 5/31/2025   | 7:10:00 AM  |
| SCSD-0378 | HA                    | 2191     | Quarter Mile Corridor South          | WC          | 5/31/2025   | 7:10:00 AM  |
| SCSD-0380 | NO                    | 2274     | Nurse's Office                       | NS          | 5/31/2025   | 7:23:00 AM  |
| SCSD-0381 | NO                    | 2274     | Nurse's Office                       | NS          | 5/31/2025   | 7:24:00 AM  |
| SCSD-0383 | FA                    | 2265B    | Main Hall Copy Room                  | KC          | 5/31/2025   | 7:31:00 AM  |
| SCSD-0385 | HA                    | 2257     | Main Entrance Corridor               | WF          | 5/31/2025   | 7:53:00 AM  |
| SCSD-0386 | HA                    | 2257     | Main Entrance Corridor               | WC          | 5/31/2025   | 7:34:00 AM  |
| SCSD-0389 | HA                    | 2191     | Quarter Mile Corridor South          | WF          | 5/31/2025   | 7:40:00 AM  |
| SCSD-0390 | HA                    | 2191     | Quarter Mile Corridor South          | WC          | 5/31/2025   | 7:40:00 AM  |
| SCSD-0391 | OF                    | 2281     | Business Education Office            | KC          | 5/31/2025   | 7:43:00 AM  |
| SCSD-0393 | FA                    | 2178A    | Guidance Office Kitchen G10          | KC          | 5/31/2025   | 7:45:00 AM  |
| SCSD-0399 | HA                    | 2147     | A Wing Corridor                      | WF          | 5/31/2025   | 7:46:00 AM  |
| SCSD-0400 | HA                    | 2147     | A Wing Corridor                      | WC          | 5/31/2025   | 7:47:00 AM  |

RECEIVED  
EMSI ANALYTICAL, INC.  
Carle Place, NY  
JUN 04 25 7:45 AM

**Building Address**  
70 South Woods Road  
Syosset, NY 11791

**Analysis Type:** ELAP 200.5

**Lab Received:** DAVID WHARTON 6/14/25 6:54 PM


**Signature:** David Wharton

**Samplers Name:** Joe Van George

**Samplers Signature:** [Signature]

**JCB Project Manager:** Boyan Ereliev

5/21/25  
Pb 200-888-0 6/12/25  
5/19/25  
3008  
6/19/25



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: Syosset High School  
SHS

# ED52900

Client: Syosset Central School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk - Rush \_\_\_\_\_

| Sample ID | Functional Space Type | AHERA ID | Common Room Name  | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|---|-------------|-------------|-------------|
| SCSD-1221 | LR                    | 2331     | Girl's Locker Room  | WF          | 5/31/2025   | 8:15:00 AM  |
| SCSD-1222 | LR                    | 2331     | Girl's Locker Room  | WC          | 5/31/2025   | 8:15:00 AM  |
| SCSD-1226 | GY                    | 2332     | Auxiliary Gym   | DW          | 5/31/2025   | 8:11:00 AM  |
| SCSD-1286 | OF/LR                 | 2306A    | Trainer's Office and Part of Locker Room share a Space ID | IM          | 5/31/2025   | 7:57:00 AM  |
| SCSD-1288 | GY                    | 2293     | Main Gym  | DW          | 5/31/2025   | 7:59:00 AM  |
| SCSD-1378 | GY                    | 2332     | Auxiliary Gym   | DW          | 5/31/2025   | 8:24:00 AM  |
| SCSD-1384 | HA                    | NA       | Corridor (Fitness Center)                                 | WF          | 5/31/2025   | 8:27:00 AM  |
| SCSD-1385 | HA                    | NA       | Corridor (Fitness Center)                                 | WC          | 5/31/2025   | 8:27:00 AM  |
| SCSD-1386 | HA                    | NA       | Corridor (Fitness Center)                                 | WC          | 5/31/2025   | 8:27:00 AM  |
| SCSD-1391 | OF                    | NA       | Admin Office (Fitness Center)                             | KC          | 5/31/2025   | 8:30:00 AM  |
| SCSD-1392 | GY                    | NA       | Fitness Center  | WF          | 5/31/2025   | 8:31:00 AM  |
| SCSD-1393 | GY                    | NA       | Fitness Center  | WC          | 5/31/2025   | 8:32:00 AM  |
| SCSD-1394 | GY                    | NA       | Fitness Center  | WC          | 5/31/2025   | 8:33:00 AM  |
| SCSD-1448 | CA                    | 2234     | Cafeteria West  | WF          | 5/31/2025   | 6:18:00 AM  |
| SCSD-1449 | CA                    | 2234     | Cafeteria West  | WC          | 5/31/2025   | 6:18:00 AM  |
| SCSD-1450 | LR                    | 2045     | Corridor D Wing to Cafeteria                              | WF          | 5/31/2025   | 6:29:00 AM  |
| SCSD-1452 | HA                    | 2033     | Corridor Room D6A to D10 o/s 105B Office                  | WF          | 5/31/2025   | 6:35:00 AM  |
| SCSD-1454 | HA                    | N/A      | Corridor E30's  | WF          | 5/31/2025   | 6:50:00 AM  |

RECEIVED  
EMSL ANALYTICAL INC.  
Carle Place, NY  
JUN 04 25 - PM 06:54

5/12/25  
Pb200.887E  
5/12/25  
Pb200.887E

**Building Address**  
70 South Woods Road  
Syosset, NY 11791

**Analysis Type:** ELAP 200.5  
**Lab Received:** DAVID WHARTON 6/4/25 6:54 PM  
**Signature:** *David Wharton*

**Samplers Name:** *Kevin George*  
**Samplers Signature:** *[Signature]*  
**JCB Project Manager:** *Bryan Feehus*



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

# ED52900

**JCB #:** 23-53856  
**Building:** Syosset High School  
SHS

**Client:** Syosset Central School District

**Retest/New Install** | |  
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                    | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|-------------------------------------|-------------|-------------|-------------|
| SCSD-1455 | HA                    | N/A      | Corridor E30's                      | WC          | 5/31/2025   | 6:50:00 AM  |
| SCSD-1456 | GY                    | 2293     | Main Gym                            | DW          | 5/31/2025   | 8:00:00 AM  |
| SCSD-1513 | HA                    | NA       | Corridor (E90's)                    | WF          | 5/31/2025   | 6:46:00 AM  |
| SCSD-1514 | HA                    | NA       | Corridor (E90's)                    | WC          | 5/31/2025   | 6:46:00 AM  |
| SCSD-1515 | HA                    | 2308     | Corridor Between Gym & Locker Rooms | WF          | 5/31/2025   | 8:06:00 AM  |
| SCSD-1516 | HA                    | 2308     | Corridor Between Gym & Locker Rooms | WC          | 5/31/2025   | 8:07:00 AM  |
| SCSD-1777 | EX                    | N/A      | Exterior of Barn                    | WF          | 5/31/2025   | 8:45:00 AM  |
| SCSD-1778 | EX                    | N/A      | Exterior of Barn                    | WC          | 5/31/2025   | 8:45:00 AM  |
| SCSD-1779 | EX                    | N/A      | Exterior o/s Fitness Center         | WF          | 5/31/2025   | 8:45:00 AM  |
| SCSD-1780 | EX                    | N/A      | Exterior o/s Fitness Center         | WC          | 5/31/2025   | 8:46:00 AM  |

Samples Submitted 64

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 04 25, PM 06:54

**Building Address**  
70 South Woods Road  
Syosset, NY 11791

**Analysis Type:** ELAP 200.5

**Lab Received:** DAVID WHARTON 6/4/25 8:54 PM

**Signature:** David Wharton

**Samplers Name:** Kevin George

**Samplers Signature:** [Signature]

**JCB Project Manager:** Bryan Felius

P2018 SA 6/12/25  
P2018 SA 6/12/25



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-0011</b> Lims Reference ID: ED52900-01 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.9    |   | 1  | 1.0 | µg/L  | 06/09/25 14:58     | 06/09/25 14:58     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0012</b> Lims Reference ID: ED52900-02 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.9    |   | 1  | 1.0 | µg/L  | 06/09/25 15:00     | 06/09/25 15:00     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0013</b> Lims Reference ID: ED52900-03 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 15:01     | 06/09/25 15:01     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0014</b> Lims Reference ID: ED52900-04 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 15:02     | 06/09/25 15:02     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0015</b> Lims Reference ID: ED52900-05 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 15:26     | 06/09/25 15:26     | KT1              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0016</b> Lims Reference ID: ED52900-06 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 15:30     | 06/09/25 15:30     | KT1              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0017</b> Lims Reference ID: ED52900-07 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 15:31     | 06/09/25 15:31     | KT1              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0041</b> Lims Reference ID: ED52900-08 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 15:32     | 06/09/25 15:32     | KT1              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0042</b> Lims Reference ID: ED52900-09 Matrix: Drinking Water <b>Sampled: 05/31/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0042 (Continued) Lims Reference ID: ED52900-09 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals (Continued)**

Lead < 1.0 1 1.0 µg/L 06/09/25 15:34 06/09/25 15:34 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0043 Lims Reference ID: ED52900-10 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 15:38 06/09/25 15:38 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0045 Lims Reference ID: ED52900-11 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 9.3 1 1.0 µg/L 06/09/25 15:39 06/09/25 15:39 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0046 Lims Reference ID: ED52900-12 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 1.2 1 1.0 µg/L 06/09/25 15:40 06/09/25 15:40 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0047 Lims Reference ID: ED52900-13 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 2.7 1 1.0 µg/L 06/09/25 15:42 06/09/25 15:42 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0048 Lims Reference ID: ED52900-14 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 3.5 1 1.0 µg/L 06/09/25 15:43 06/09/25 15:43 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0049 Lims Reference ID: ED52900-15 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 3.0 1 1.0 µg/L 06/10/25 15:00 06/10/25 15:00 BP EPA 200.8 (Dig)/EPA 200.8

Sample: SCSD-0054 Lims Reference ID: ED52900-16 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 2.1 1 1.0 µg/L 06/09/25 15:44 06/09/25 15:44 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0055 Lims Reference ID: ED52900-17 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results**  
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0055 (Continued) Lims Reference ID: ED52900-17 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals (Continued)**

Lead < 1.0 1 1.0 µg/L 06/09/25 15:48 06/09/25 15:48 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0056 Lims Reference ID: ED52900-18 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 2.9 1 1.0 µg/L 06/09/25 15:50 06/09/25 15:50 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0208 Lims Reference ID: ED52900-19 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 15:54 06/09/25 15:54 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0303 Lims Reference ID: ED52900-20 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 2.1 1 1.0 µg/L 06/09/25 15:55 06/09/25 15:55 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0314 Lims Reference ID: ED52900-21 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 2.0 1 1.0 µg/L 06/09/25 15:56 06/09/25 15:56 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0319 Lims Reference ID: ED52900-22 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 15:58 06/09/25 15:58 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0376 Lims Reference ID: ED52900-23 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 2.3 1 1.0 µg/L 06/09/25 15:59 06/09/25 15:59 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0377 Lims Reference ID: ED52900-24 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:00 06/09/25 16:00 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0378 Lims Reference ID: ED52900-25 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0378 (Continued) Lims Reference ID: ED52900-25 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals (Continued)**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:02 06/09/25 16:02 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0380 Lims Reference ID: ED52900-26 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:17 06/09/25 16:17 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0381 Lims Reference ID: ED52900-27 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:21 06/09/25 16:21 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0383 Lims Reference ID: ED52900-28 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 1.6 1 1.0 µg/L 06/09/25 16:22 06/09/25 16:22 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0385 Lims Reference ID: ED52900-29 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:24 06/09/25 16:24 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0386 Lims Reference ID: ED52900-30 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:25 06/09/25 16:25 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0389 Lims Reference ID: ED52900-31 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:29 06/09/25 16:29 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0390 Lims Reference ID: ED52900-32 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:30 06/09/25 16:30 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0391 Lims Reference ID: ED52900-33 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results**  
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0391 (Continued) Lims Reference ID: ED52900-33 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals (Continued)**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:32 06/09/25 16:32 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0393 Lims Reference ID: ED52900-34 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 2.8 1 1.0 µg/L 06/09/25 16:33 06/09/25 16:33 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0399 Lims Reference ID: ED52900-35 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:34 06/09/25 16:34 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0400 Lims Reference ID: ED52900-36 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:36 06/09/25 16:36 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1221 Lims Reference ID: ED52900-37 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:40 06/09/25 16:40 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1222 Lims Reference ID: ED52900-38 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:41 06/09/25 16:41 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1226 Lims Reference ID: ED52900-39 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 3.9 1 1.0 µg/L 06/09/25 16:45 06/09/25 16:45 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1286 Lims Reference ID: ED52900-40 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:46 06/09/25 16:46 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1288 Lims Reference ID: ED52900-41 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results  
(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1288 (Continued) Lims Reference ID: ED52900-41 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals (Continued)**

Lead 2.5 1 1.0 µg/L 06/09/25 16:47 06/09/25 16:47 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1378 Lims Reference ID: ED52900-42 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 102 10 10.0 µg/L 06/10/25 15:24 06/10/25 15:24 BP EPA 200.8 (Dig)/EPA 200.8

Sample: SCSD-1384 Lims Reference ID: ED52900-43 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:49 06/09/25 16:49 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1385 Lims Reference ID: ED52900-44 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:50 06/09/25 16:50 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1386 Lims Reference ID: ED52900-45 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/09/25 16:51 06/09/25 16:51 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1391 Lims Reference ID: ED52900-46 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 1.8 1 1.0 µg/L 06/09/25 16:53 06/09/25 16:53 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1392 Lims Reference ID: ED52900-47 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:24 06/12/25 13:24 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1393 Lims Reference ID: ED52900-48 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:28 06/12/25 13:28 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1394 Lims Reference ID: ED52900-49 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1394 (Continued) Lims Reference ID: ED52900-49 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals (Continued)**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:29 06/12/25 13:29 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1448 Lims Reference ID: ED52900-50 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:30 06/12/25 13:30 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1449 Lims Reference ID: ED52900-51 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:32 06/12/25 13:32 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1450 Lims Reference ID: ED52900-52 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:36 06/12/25 13:36 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1452 Lims Reference ID: ED52900-53 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:37 06/12/25 13:37 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1454 Lims Reference ID: ED52900-54 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:38 06/12/25 13:38 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1455 Lims Reference ID: ED52900-55 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 13:40 06/12/25 13:40 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1456 Lims Reference ID: ED52900-56 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**

Lead 1.2 1 1.0 µg/L 06/12/25 13:41 06/12/25 13:41 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1513 Lims Reference ID: ED52900-57 Matrix: Drinking Water Sampled: 05/31/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Analytical Results  
(Continued)**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| Sample: SCSD-1513 (Continued) Lims Reference ID: ED52900-57 Matrix: Drinking Water Sampled: 05/31/25 00:00:00 |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals (Continued)</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:42     | 06/12/25 13:42     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| Sample: SCSD-1514 Lims Reference ID: ED52900-58 Matrix: Drinking Water Sampled: 05/31/25 00:00:00             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:46     | 06/12/25 13:46     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| Sample: SCSD-1515 Lims Reference ID: ED52900-59 Matrix: Drinking Water Sampled: 05/31/25 00:00:00             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:48     | 06/12/25 13:48     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| Sample: SCSD-1516 Lims Reference ID: ED52900-60 Matrix: Drinking Water Sampled: 05/31/25 00:00:00             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:52     | 06/12/25 13:52     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| Sample: SCSD-1777 Lims Reference ID: ED52900-61 Matrix: Drinking Water Sampled: 05/31/25 00:00:00             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:53     | 06/12/25 13:53     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| Sample: SCSD-1778 Lims Reference ID: ED52900-62 Matrix: Drinking Water Sampled: 05/31/25 00:00:00             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:54     | 06/12/25 13:54     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| Sample: SCSD-1779 Lims Reference ID: ED52900-63 Matrix: Drinking Water Sampled: 05/31/25 00:00:00             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:56     | 06/12/25 13:56     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| Sample: SCSD-1780 Lims Reference ID: ED52900-64 Matrix: Drinking Water Sampled: 05/31/25 00:00:00             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/12/25 13:57     | 06/12/25 13:57     | SEH              | EPA 200.8 (DA)/EPA 200.8 |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552900

LIMS Reference ID: ED52900

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Syosset High School SHS, 70 South Woods Road, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 18:54  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

# ED53084

**JCB #:** 23-53856  
**Building:** Berry Hill Elementary School  
BHE

**Client:** Syosset Central School District  
**Retest/New Install**   
**Turn Around:** Normal ~~1 wk~~ Rush

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                         | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--|-------------|-------------|-------------|
| SCSD-0615 | HA                    | 2063     | Multi Purpose Room Corridor              | WF          | 6/2/2025    | 5:49:00 AM  |
| SCSD-0616 | HA                    | 2063     | Multi Purpose Room Corridor              | WC          | 6/2/2025    | 5:49:00 AM  |
| SCSD-0617 | HA                    | 2063     | Multi Purpose Room Corridor              | HW          | 6/2/2025    | 5:49:00 AM  |
| SCSD-0620 | KI                    | 2063A    | Kitchen Room                             | KC          | 6/2/2025    | 5:46:00 AM  |
| SCSD-0626 | FA                    | 2034     | Room E/Gym Office                        | KC          | 6/2/2025    | 6:01:00 AM  |
| SCSD-1425 | HA                    | NA       | Corridor by D5                           | WF          | 6/2/2025    | 5:42:00 AM  |
| SCSD-1426 | HA                    | NA       | Corridor by D5                           | WC          | 6/2/2025    | 5:42:00 AM  |
| SCSD-1433 | HA                    | 2081     | Corridor Coach's Office to Main Entrance | WF          | 6/2/2025    | 5:57:00 AM  |
| SCSD-1434 | HA                    | 2081     | Corridor Coach's Office to Main Entrance | WC          | 6/2/2025    | 5:57:00 AM  |
| SCSD-1435 | HA                    | 2082     | Corridor                                 | WF          | 6/2/2025    | 6:05:00 AM  |
| SCSD-1436 | HA                    | 2082     | Corridor                                 | WC          | 6/2/2025    | 6:05:00 AM  |

Samples Submitted 11



RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 09 25, PM 08:43

**Building Address**  
181 Cold Spring Road  
Syosset, NY 11791

**Analysis Type:** ELAP 200.5  
**Lab Recieved:** A. Minnifield  
**Signature:** A. Minnifield

**Samplers Name:** Kevin Gage  
**Samplers Signature:** [Signature]  
**JCB Project Manager:** Fryant Zedler

Ph 200 8 8 9 9 6 1 2 1 2 5



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553084

LIMS Reference ID: ED53084

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Berry Hill Elementary School, Syosset  
Central School District, 181 Cold Spring Road,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/10/2025 08:43  
**Reported:**

**Analytical Results**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0615 Lims Reference ID: ED53084-01 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 11:38 06/12/25 11:38 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0616 Lims Reference ID: ED53084-02 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 11:42 06/12/25 11:42 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0617 Lims Reference ID: ED53084-03 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 11:43 06/12/25 11:43 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0620 Lims Reference ID: ED53084-04 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead 1.2 1 1.0 µg/L 06/12/25 11:44 06/12/25 11:44 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0626 Lims Reference ID: ED53084-05 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 11:48 06/12/25 11:48 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1425 Lims Reference ID: ED53084-06 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 11:50 06/12/25 11:50 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1426 Lims Reference ID: ED53084-07 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 11:51 06/12/25 11:51 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1433 Lims Reference ID: ED53084-08 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/12/25 11:52 06/12/25 11:52 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1434 Lims Reference ID: ED53084-09 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553084

LIMS Reference ID: ED53084

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Berry Hill Elementary School, Syosset  
Central School District, 181 Cold Spring Road,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/10/2025 08:43  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1434 (Continued) Lims Reference ID: ED53084-09 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals (Continued)**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/12/25 11:54 | 06/12/25 11:54 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|

Sample: SCSD-1435 Lims Reference ID: ED53084-10 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/12/25 11:55 | 06/12/25 11:55 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|

Sample: SCSD-1436 Lims Reference ID: ED53084-11 Matrix: Drinking Water Sampled: 06/02/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/12/25 11:56 | 06/12/25 11:56 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553084

LIMS Reference ID: ED53084

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Berry Hill Elementary School, Syosset  
Central School District, 181 Cold Spring Road,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/10/2025 08:43  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553084

LIMS Reference ID: ED53084

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , Berry Hill Elementary School, Syosset  
Central School District, 181 Cold Spring Road,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/10/2025 08:43  
**Reported:**

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: South Grove Elementary School  
SGE

# ED52878

Client: Syosset Central School District  
Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush \_\_\_\_\_



| Sample ID | Functional Space Type | AHERA ID | Common Room Name                    | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|-------------------------------------|-------------|-------------|-------------|
| SCSD-0997 | CA                    | 2092     | Multi Purpose Room                  | WF          | 6/3/2025    | 5:46:00 AM  |
| SCSD-0999 | CA                    | 2092     | Multi Purpose Room                  | KC          | 6/3/2025    | 5:48:00 AM  |
| SCSD-1000 | CA                    | 2092     | Multi Purpose Room                  | KC          | 6/3/2025    | 5:50:00 AM  |
| SCSD-1008 | FL                    | 2044     | Faculty Lounge - Room 15            | KC          | 6/3/2025    | 6:02:00 AM  |
| SCSD-1251 | HA                    | NA       | Gym Hallway                         | WF          | 6/3/2025    | 6:08:00 AM  |
| SCSD-1252 | HA                    | NA       | Gym Hallway                         | WC          | 6/3/2025    | 6:08:00 AM  |
| SCSD-1441 | HA                    | 2046     | Corridor Main Office to Boiler Room | WF          | 6/3/2025    | 6:00:00 AM  |
| SCSD-1442 | HA                    | 2046     | Corridor Main Office to Boiler Room | WC          | 6/3/2025    | 6:00:00 AM  |
| SCSD-1443 | HA                    | 2098     | Corridor Room 32 - Main Entrance    | WF          | 6/3/2025    | 5:55:00 AM  |
| SCSD-1444 | HA                    | 2098     | Corridor Room 32 - Main Entrance    | WC          | 6/3/2025    | 5:55:00 AM  |
| SCSD-1445 | CA                    | 2092     | Multi Purpose Room                  | KC          | 6/3/2025    | 5:51:00 AM  |

Samples Submitted 11

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 04 25, AM 11:55

**Building Address**  
60 Colony Lane  
Syosset, NY 11791

Analysis Type: ELAP 200.5

Lab Recieved: A. Minnifield

Signature: *A. Minnifield*  
6-4-25 11:55AM

Samplers Name: *Jessan Gorge*

Samplers Signature: *JG*

JCB Project Manager: *Bryan Erdus*



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552878

LIMS Reference ID: ED52878

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , South Grove Elementary School, SGE,  
Syosset Central School District, 60 Colony Lane,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:55  
**Reported:**

**Analytical Results**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-0997</b> Lims Reference ID: ED52878-01 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:12     | 06/06/25 20:12     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0999</b> Lims Reference ID: ED52878-02 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.5    |   | 1  | 1.0 | µg/L  | 06/06/25 20:13     | 06/06/25 20:13     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1000</b> Lims Reference ID: ED52878-03 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.6    |   | 1  | 1.0 | µg/L  | 06/06/25 20:15     | 06/06/25 20:15     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1008</b> Lims Reference ID: ED52878-04 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 4.3    |   | 1  | 1.0 | µg/L  | 06/06/25 20:16     | 06/06/25 20:16     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1251</b> Lims Reference ID: ED52878-05 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:17     | 06/06/25 20:17     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1252</b> Lims Reference ID: ED52878-06 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:19     | 06/06/25 20:19     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1441</b> Lims Reference ID: ED52878-07 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:23     | 06/06/25 20:23     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1442</b> Lims Reference ID: ED52878-08 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 20:24     | 06/06/25 20:24     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1443</b> Lims Reference ID: ED52878-09 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552878

LIMS Reference ID: ED52878

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , South Grove Elementary School, SGE,  
Syosset Central School District, 60 Colony Lane,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:55  
**Reported:**

**Analytical Results**  
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1443 (Continued) Lims Reference ID: ED52878-09 Matrix: Drinking Water Sampled: 06/03/25 00:00:00

**Metals (Continued)**

|      |       |  |   |     |      |                |                |    |                          |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/06/25 20:28 | 06/06/25 20:28 | KT | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|

Sample: SCSD-1444 Lims Reference ID: ED52878-10 Matrix: Drinking Water Sampled: 06/03/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |    |                          |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/06/25 20:29 | 06/06/25 20:29 | KT | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|----|--------------------------|

Sample: SCSD-1445 Lims Reference ID: ED52878-11 Matrix: Drinking Water Sampled: 06/03/25 00:00:00

**Metals**

|      |     |  |   |     |      |                |                |    |                          |
|------|-----|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | 7.8 |  | 1 | 1.0 | µg/L | 06/06/25 20:30 | 06/06/25 20:30 | KT | EPA 200.8 (DA)/EPA 200.8 |
|------|-----|--|---|-----|------|----------------|----------------|----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552878

LIMS Reference ID: ED52878

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , South Grove Elementary School, SGE,  
Syosset Central School District, 60 Colony Lane,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:55  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062552878

**LIMS Reference ID:** ED52878

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856 , South Grove Elementary School, SGE,  
Syosset Central School District, 60 Colony Lane,  
Syosset NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:55  
**Reported:**

**Notes and Definitions**


| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED 52898



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: South Grove Annex  
SGA

Client: Syosset Central School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk - Rush \_\_\_\_\_



Photo of SL plates

| Sample ID | Functional Space Type | AHERA ID | Common Room Name          | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|---------------------------|-------------|-------------|-------------|
| SCSD-1049 | HA                    | 2034     | Corridor near Boiler Room | WF          | 6/3/2025    | 6:30:00 AM  |
| SCSD-1050 | HA                    | 2034     | Corridor near Boiler Room | WC          | 6/3/2025    | 6:21:00 AM  |
| SCSD-1052 | CA                    | 2006     | Kitchen                   | KC          | 6/3/2025    | 6:31:00 AM  |
| SCSD-1053 | CA                    | 2006     | Kitchen                   | KC          | 6/3/2025    | 6:32:00 AM  |
| SCSD-1061 | FL                    | 2024     | Faculty Room              | CF          | 6/3/2025    | 6:20:00 AM  |
| SCSD-1065 | HA                    | 2033     | Corridor Room 5-7         | WF          | 6/3/2025    | 6:18:00 AM  |
| SCSD-1066 | HA                    | 2033     | Corridor Room 5-7         | WC          | 6/3/2025    | 6:18:00 AM  |
| SCSD-1379 | CA                    | 2031     | Multi Purpose Room        | HW          | 6/3/2025    | 6:19:00 AM  |
| SCSD-1446 | HA                    | 2032     | Corridor Rooms 1-3        | WF          | 6/3/2025    | 6:28:00 AM  |
| SCSD-1447 | HA                    | 2032     | Corridor Rooms 1-3        | WC          | 6/3/2025    | 6:28:00 AM  |

Samples Submitted 10

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 04 25, AM 11:51

**Building Address**  
60 Colony Lane  
Syosset, NY 11791

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 6/4/25 11:51 AM

Signature: David Wharton

Samplers Name: Juan George

Samplers Signature: [Signature]

JCB Project Manager: Bryan Freliv



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552898

LIMS Reference ID: ED52898

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, South  
Grove Annex SGA, 60 Colony Lane, Syosset, NY  
11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/04/2025 11:51  
**Reported:**

**Analytical Results**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-1049</b> Lims Reference ID: ED52898-01 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 22:10     | 06/06/25 22:10     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1050</b> Lims Reference ID: ED52898-02 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 22:11     | 06/06/25 22:11     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1052</b> Lims Reference ID: ED52898-03 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 22:12     | 06/06/25 22:12     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1053</b> Lims Reference ID: ED52898-04 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.4    |   | 1  | 1.0 | µg/L  | 06/06/25 22:14     | 06/06/25 22:14     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1061</b> Lims Reference ID: ED52898-05 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 17.0   |   | 1  | 1.0 | µg/L  | 06/06/25 22:15     | 06/06/25 22:15     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1065</b> Lims Reference ID: ED52898-06 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/06/25 22:16     | 06/06/25 22:16     | KT               | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1066</b> Lims Reference ID: ED52898-07 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/09/25 11:40     | 06/09/25 11:40     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1379</b> Lims Reference ID: ED52898-08 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 2.4    |   | 1  | 1.0 | µg/L  | 06/09/25 11:41     | 06/09/25 11:41     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1446</b> Lims Reference ID: ED52898-09 Matrix: Drinking Water <b>Sampled: 06/03/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062552898

LIMS Reference ID: ED52898

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, South  
Grove Annex SGA, 60 Colony Lane, Syosset, NY  
11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:51  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062552898

**LIMS Reference ID:** ED52898

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, South  
Grove Annex SGA, 60 Colony Lane, Syosset, NY  
11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/04/2025 11:51  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53856  
**Building:** Baylis Elementary School

ED53192

**Client:** Syosset Central School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush \_\_\_\_\_

BES

Photo of 8/11/06 photos

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                  | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|-----------------------------------|-------------|-------------|-------------|
| SCSD-1072 | HA                    | 2084     | Corridor Room 9 to 14             | WF          | 6/5/2025    | 6:55:00 AM  |
| SCSD-1073 | HA                    | 2084     | Corridor Room 9 to 14             | WC          | 6/5/2025    | 6:55:00 AM  |
| SCSD-1123 | HA                    | 2083     | Corridor Main Office to Cafeteria | WF          | 6/5/2025    | 6:58:00 AM  |
| SCSD-1124 | HA                    | 2083     | Corridor Main Office to Cafeteria | WC          | 6/5/2025    | 6:58:00 AM  |
| SCSD-1125 | CA                    | 2002     | Cafeteria                         | KC          | 6/5/2025    | 7:00:00 AM  |
| SCSD-1126 | CA                    | 2002     | Cafeteria                         | KC          | 6/5/2025    | 7:00:00 AM  |
| SCSD-1127 | CA                    | 2002     | Cafeteria                         | KC          | 6/5/2025    | 7:00:00 AM  |
| SCSD-1437 | HA                    | 2079     | Corridor Fish Bowl to Stage       | WF          | 6/5/2025    | 6:53:00 AM  |
| SCSD-1438 | HA                    | 2079     | Corridor Fish Bowl to Stage       | WC          | 6/5/2025    | 6:53:00 AM  |

Samples Submitted 9



RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 12 25, PM 06:06

**Building Address**  
580 Woodbury Road  
Plainview, NY 11803

**Analysis Type:** ELAP 200.5

**Lab Received:** 6/12/25 18:04

**Signature:** *[Signature]*

**Samplers Name:** *[Signature]*

**Samplers Signature:** *[Signature]*

**JCB Project Manager:** *[Signature]*



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553192

LIMS Reference ID: ED53192

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** Baylis Elementary School: 580 Woodbury Road,  
Plainview, NY 11803: Syosset Central School  
District: Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**

**Analytical Results**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-1072</b> Lims Reference ID: ED53192-01 Matrix: Drinking Water <b>Sampled: 06/05/25 06:55:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 09:50     | 06/16/25 09:50     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1073</b> Lims Reference ID: ED53192-02 Matrix: Drinking Water <b>Sampled: 06/05/25 06:55:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 09:51     | 06/16/25 09:51     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1123</b> Lims Reference ID: ED53192-03 Matrix: Drinking Water <b>Sampled: 06/05/25 06:58:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 09:52     | 06/16/25 09:52     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1124</b> Lims Reference ID: ED53192-04 Matrix: Drinking Water <b>Sampled: 06/05/25 06:58:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 09:53     | 06/16/25 09:53     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1125</b> Lims Reference ID: ED53192-05 Matrix: Drinking Water <b>Sampled: 06/05/25 07:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 09:55     | 06/16/25 09:55     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1126</b> Lims Reference ID: ED53192-06 Matrix: Drinking Water <b>Sampled: 06/05/25 07:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 09:56     | 06/16/25 09:56     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1127</b> Lims Reference ID: ED53192-07 Matrix: Drinking Water <b>Sampled: 06/05/25 07:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.7    |   | 1  | 1.0 | µg/L  | 06/16/25 09:57     | 06/16/25 09:57     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1437</b> Lims Reference ID: ED53192-08 Matrix: Drinking Water <b>Sampled: 06/05/25 06:53:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 10:01     | 06/16/25 10:01     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1438</b> Lims Reference ID: ED53192-09 Matrix: Drinking Water <b>Sampled: 06/05/25 06:53:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553192

LIMS Reference ID: ED53192

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** Baylis Elementary School: 580 Woodbury Road,  
Plainview, NY 11803: Syosset Central School  
District: Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553192

LIMS Reference ID: ED53192

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** Baylis Elementary School: 580 Woodbury Road,  
Plainview, NY 11803: Syosset Central School  
District: Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

# EDS 3193

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53856

**Building:** Maintenance Building

MB

**Client:**  
Syosset Central School District

Retest/New Install [ ]

**Turn Around:** Normal 1 wk Rush

Ph200-8 810 6/15/25

| Sample ID | Functional Space Type | AHERA ID | Common Room Name   | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--------------------|-------------|-------------|-------------|
| SCSD-1427 | OF                    | 1003     | Locker/Common Room | WF          | 6/5/2025    | 6:15:00 AM  |
| SCSD-1428 | OF                    | 1003     | Locker/Common Room | WC          | 6/5/2025    | 6:15:00 AM  |

Samples Submitted 2



RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 12 25, PM06:06

**Building Address**  
482 Woodbury Road  
Woodbury, NY 11797

**Analysis Type:** ELAP 200.5

**Lab Recieved:** 6/12/25 18:00

**Signature:** *[Handwritten Signature]*

**Samplers Name:** *Jillian Garg*

**Samplers Signature:** *[Handwritten Signature]*

**JCB Project Manager:** *[Handwritten Signature]*





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553193

LIMS Reference ID: ED53193

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** Maintenance Building: MB: 482 Woodbury Road,  
Woodbury, NY 11797: Syosset Central School  
District Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553193

**LIMS Reference ID:** ED53193

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** Maintenance Building: MB: 482 Woodbury Road,  
Woodbury, NY 11797: Syosset Central School  
District Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**

**Notes and Definitions**


| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED53194



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856

Building: Maintenance Garage

MG

Client: Syosset Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush \_\_\_\_\_

*Pb 200 & M 2016/25*

| Sample ID | Functional Space Type | AHERA ID | Common Room Name    | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|---------------------|-------------|-------------|-------------|
| SCSD-1415 | ST                    | NA       | Wood Storage (Barn) | BW          | 6/5/2025    | 6:18:00 AM  |
| SCSD-1416 | ST                    | NA       | Wood Storage (Barn) | WC          | 6/5/2025    | 6:18:00 AM  |

Samples Submitted 2



RECEIVED  
 EMSL ANALYTICAL, INC.  
 Carle Place, NY  
 JUN 12 25, PM 06:05

**Building Address**  
 482 Woodbury Road  
 Woodbury, NY 11797

Analysis Type: ELAP 200.5

Lab Received: A Stanley 6/12/25

Signature: [Signature] 6:05pm

Samplers Name: [Signature]

Samplers Signature: [Signature]

JCB Project Manager: [Signature]



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553194

LIMS Reference ID: ED53194

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Maintenance Garage, MG, Syosset  
Central School District, 482 Woodbury Road,  
Woodbury, NY 11797  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:05  
**Reported:**

**Analytical Results**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1415 Lims Reference ID: ED53194-01 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/16/25 10:14 | 06/16/25 10:14 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|

Sample: SCSD-1416 Lims Reference ID: ED53194-02 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/16/25 10:15 | 06/16/25 10:15 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553194

LIMS Reference ID: ED53194

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Maintenance Garage, MG, Syosset  
Central School District, 482 Woodbury Road,  
Woodbury, NY 11797  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:05  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553194

**LIMS Reference ID:** ED53194

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Maintenance Garage, MG, Syosset  
Central School District, 482 Woodbury Road,  
Woodbury, NY 11797  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:05  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53856  
**Building:** Walt Whitman Elementary School

WWE

ED53196

**Client:** Syosset Central School District

Retest  New Install

**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

Pb200 & 811 -> vehicles

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                        | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|---|-------------|-------------|-------------|
| SCSD-1297 | HA                    | 2068     | Corridor Room 2 to Room 6               | WF          | 6/5/2025    | 5:53:00 AM  |
| SCSD-1298 | HA                    | 2068     | Corridor Room 2 to Room 6               | WC          | 6/5/2025    | 5:53:00 AM  |
| SCSD-1317 | HA                    | 2075     | Corridor to Room A-C                    | WF          | 6/5/2025    | 6:02:00 AM  |
| SCSD-1318 | HA                    | 2075     | Corridor to Room A-C                    | WC          | 6/5/2025    | 6:02:00 AM  |
| SCSD-1333 | FA                    | 2028     | Faculty Lounge                          | KC          | 6/5/2025    | 6:07:00 AM  |
| SCSD-1336 | HA                    | 2067     | Corridor from Room 19 to Boy's Bathroom | WF          | 6/5/2025    | 5:37:00 AM  |
| SCSD-1337 | HA                    | 2067     | Corridor from Room 19 to Boy's Bathroom | WC          | 6/5/2025    | 5:37:00 AM  |
| SCSD-1361 | KI                    | 2043     | Kitchen/Serving Area                    | HW          | 6/5/2025    | 5:22:00 AM  |
| SCSD-1362 | KI                    | 2043     | Kitchen/Serving Area                    | KC          | 6/5/2025    | 5:21:00 AM  |
| SCSD-1363 | HA                    | 2069A    | Corridor Music Room to Main Office      | WF          | 6/5/2025    | 5:17:00 AM  |
| SCSD-1364 | HA                    | 2069A    | Corridor Music Room to Main Office      | WC          | 6/5/2025    | 5:17:00 AM  |

Samples Submitted 11



RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 12 25, PM06:06

**Building Address**  
482 Woodbury Road  
Woodbury, NY 11797

**Analysis Type:** ELAP 200.5

**Lab Received:** Astanley 6/12/25

**Signature:** [Signature] 6/10/25

**Samplers Name:** Jean George

**Samplers Signature:** [Signature]

**JCB Project Manager:** Bryan Frelus



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553196

LIMS Reference ID: ED53196

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Walt Whitman Elementary School, WWE,  
Syosset Central School District, 482 Woodbury  
Road, Woodbury, NY 11797  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**

**Analytical Results**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1297 Lims Reference ID: ED53196-01 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:55 06/16/25 11:55 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1298 Lims Reference ID: ED53196-02 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:57 06/16/25 11:57 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1317 Lims Reference ID: ED53196-03 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:58 06/16/25 11:58 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1318 Lims Reference ID: ED53196-04 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:59 06/16/25 11:59 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1333 Lims Reference ID: ED53196-05 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead 4.3 1 1.0 µg/L 06/16/25 12:00 06/16/25 12:00 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1336 Lims Reference ID: ED53196-06 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 12:02 06/16/25 12:02 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1337 Lims Reference ID: ED53196-07 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 12:13 06/16/25 12:13 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1361 Lims Reference ID: ED53196-08 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

Lead 2.0 1 1.0 µg/L 06/16/25 12:17 06/16/25 12:17 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1362 Lims Reference ID: ED53196-09 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553196

**LIMS Reference ID:** ED53196

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Walt Whitman Elementary School, WWE,  
Syosset Central School District, 482 Woodbury  
Road, Woodbury, NY 11797  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**

**Analytical Results**  
**(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1362 (Continued) Lims Reference ID: ED53196-09 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals (Continued)**

|      |     |  |   |     |      |                |                |     |                          |
|------|-----|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | 3.6 |  | 1 | 1.0 | µg/L | 06/16/25 12:18 | 06/16/25 12:18 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-----|--|---|-----|------|----------------|----------------|-----|--------------------------|

Sample: SCSD-1363 Lims Reference ID: ED53196-10 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/16/25 12:20 | 06/16/25 12:20 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|

Sample: SCSD-1364 Lims Reference ID: ED53196-11 Matrix: Drinking Water Sampled: 06/05/25 00:00:00

**Metals**

|      |       |  |   |     |      |                |                |     |                          |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | < 1.0 |  | 1 | 1.0 | µg/L | 06/16/25 12:21 | 06/16/25 12:21 | SEH | EPA 200.8 (DA)/EPA 200.8 |
|------|-------|--|---|-----|------|----------------|----------------|-----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553196

LIMS Reference ID: ED53196

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Walt Whitman Elementary School, WWE,  
Syosset Central School District, 482 Woodbury  
Road, Woodbury, NY 11797  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <b>EPA 200.8 in Drinking Water</b> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553196

**LIMS Reference ID:** ED53196

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Walt Whitman Elementary School, WWE,  
Syosset Central School District, 482 Woodbury  
Road, Woodbury, NY 11797  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:06  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

**James Han Laboratory Manager or other approved signatory**

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

ED53195

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: South Woods Middle School

Client: Syosset Central School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush \_\_\_\_\_

SWM

Pb200.8 SW 9/6/25

| Sample ID | Functional Space Type | AHERA ID | Common Room Name                           | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--|-------------|-------------|-------------|
| SCSD-0435 | HA                    | 2143     | Corridor North Cafeteria to Boy's Bathroom | WF          | 6/6/2025    | 6:50:00 AM  |
| SCSD-0436 | HA                    | 2143     | Corridor North Cafeteria to Boy's Bathroom | WC          | 6/6/2025    | 6:50:00 AM  |
| SCSD-0456 | HE                    | 3187     | Room 204                                   | EC          | 6/6/2025    | 5:50:00 AM  |
| SCSD-0457 | HE                    | 3187     | Room 204                                   | EC          | 6/6/2025    | 5:51:00 AM  |
| SCSD-0458 | HE                    | 3187     | Room 204                                   | EC          | 6/6/2025    | 5:51:00 AM  |
| SCSD-0459 | HE                    | 3187     | Room 204                                   | EC          | 6/6/2025    | 5:52:00 AM  |
| SCSD-0460 | HE                    | 3187     | Room 204                                   | EC          | 6/6/2025    | 5:53:00 AM  |
| SCSD-0462 | HE                    | 3186     | Room 202                                   | EC          | 6/6/2025    | 5:56:00 AM  |
| SCSD-0463 | HE                    | 3186     | Room 202                                   | EC          | 6/6/2025    | 5:56:00 AM  |
| SCSD-0464 | HE                    | 3186     | Room 202                                   | EC          | 6/6/2025    | 5:57:00 AM  |
| SCSD-0465 | HE                    | 3186     | Room 202                                   | EC          | 6/6/2025    | 5:58:00 AM  |
| SCSD-0466 | HE                    | 3186     | Room 202                                   | EC          | 6/6/2025    | 5:58:00 AM  |
| SCSD-0481 | NO                    | 2173     | Nurse's Sick Room                          | NS          | 6/6/2025    | 6:16:00 AM  |
| SCSD-0529 | HA                    | 2060     | Corridor Library to Room 102               | WF          | 6/6/2025    | 6:08:00 AM  |
| SCSD-0530 | HA                    | 2060     | Corridor Library to Room 102               | WC          | 6/6/2025    | 6:08:00 AM  |
| SCSD-0561 | KI                    | 2136     | Kitchen                                    | KC          | 6/6/2025    | 6:33:00 AM  |
| SCSD-0564 | KI                    | 2136     | Kitchen                                    | KC          | 6/6/2025    | 6:34:00 AM  |
| SCSD-0565 | KI                    | 2136     | Kitchen                                    | PK          | 6/6/2025    | 6:38:00 AM  |


RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 12 25 PM 06:07

**Building Address**  
99 Pell Lane  
Syosset, NY 11791



**Analysis Type:** ELAP 200.5  
**Lab Received:** 6/12/25 12:02  
**Signature:** [Handwritten Signature]

**Samplers Name:** [Handwritten: Peter George]  
**Samplers Signature:** [Handwritten Signature]  
**JCB Project Manager:** [Handwritten: Bryant Ezelus]



# Lead in Water: Chain of Custody for

ED53195

J. C. BRODERICK AND ASSOCIATES, INC.  
 1775 Expressway North Hauppauge, NY 11788  
 TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
 Building: South Woods Middle School  
 SWM

Client: Syosset Central School District  
 Retest/New Install [ ]  
 Turn Around: Normal 1 wk Rush \_\_\_\_\_

Pb200.8.8.11 9/6/16/25


| Sample ID | Functional Space Type | AHERA ID | Common Room Name                   | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|------------------------------------|-------------|-------------|-------------|
| SCSD-0566 | KI                    | 2136     | Kitchen                            | IM          | 6/6/2025    | 6:29:00 AM  |
| SCSD-0567 | KI                    | 2136A    | Kitchen Pantry                     | HW          | 6/6/2025    | 6:36:00 AM  |
| SCSD-0573 | FA                    | 2139     | Faculty Lounge                     | KC          | 6/6/2025    | 5:42:00 AM  |
| SCSD-0574 | FA                    | 2179B    | Superintendent's Kitchen           | KC          | 6/6/2025    | 6:24:00 AM  |
| SCSD-1419 | HA                    | 2060     | Corridor Library to Room 102       | WF          | 6/6/2025    | 7:20:00 AM  |
| SCSD-1420 | HA                    | 2060     | Corridor Library to Room 102       | WC          | 6/6/2025    | 7:20:00 AM  |
| SCSD-1421 | HA                    | 2157     | Main Entrance Corridor             | WF          | 6/6/2025    | 6:18:00 AM  |
| SCSD-1422 | HA                    | 2157     | Main Entrance Corridor             | WC          | 6/6/2025    | 6:18:00 AM  |
| SCSD-1423 | CA                    | 2132     | South Cafeteria                    | WF          | 6/6/2025    | 6:44:00 AM  |
| SCSD-1424 | CA                    | 2132     | South Cafeteria                    | WC          | 6/6/2025    | 6:45:00 AM  |
| SCSD-1429 | ST                    | 010      | Basement Open Storage/Copy Area    | WF          | 6/6/2025    | 7:12:00 AM  |
| SCSD-1439 | LI                    | 2011     | Library                            | KC          | 6/6/2025    | 6:11:00 AM  |
| SCSD-1440 | FA                    | 2165     | Main Office Kitchen                | KC          | 6/6/2025    | 6:20:00 AM  |
| SCSD-1457 | KI                    | 2136     | Kitchen                            | KC          | 6/6/2025    | 6:40:00 AM  |
| SCSD-1458 | KI                    | 2136     | Kitchen                            | KC          | 6/6/2025    | 6:40:00 AM  |
| SCSD-1459 | CC                    | 2095B    | Gym Boy's Locker Room Coach Office | IM          | 6/6/2025    | 6:57:00 AM  |
| SCSD-1517 | HA                    | 3192     | Corridor Room 200 to 210           | WF          | 6/6/2025    | 5:48:00 AM  |
| SCSD-1518 | HA                    | 3192     | Corridor Room 200 to 210           | WC          | 6/6/2025    | 5:48:00 AM  |

RECEIVED  
 EMSL ANALYTICAL, INC.  
 Carle Place, NY  
 JUN 12 25, PM 06:07

**Building Address**  
 99 Pell Lane  
 Syosset, NY 11791

**Analysis Type:** ELAP 200.5  
**Lab Received:** 6/12/25 18:07  
**Signature:** *[Signature]*

**Samplers Name:** *Jean George*  
**Samplers Signature:** *[Signature]*  
**JCB Project Manager:** *Bryan Fedors*



# Lead in Water: Chain of Custody for

ED53195

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: South Woods Middle School  
SWM

Client: Syosset Central School District  
~~Retest~~/New Install   
Turn Around: Normal Lwk Rush \_\_\_\_\_

PH 200.8 SA 6/16/25

| Sample ID | Functional Space Type | AHERA ID | Common Room Name | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|------------------|-------------|-------------|-------------|
| SCSD-1783 | CA                    | 2142     | North Cafeteria  | WF          | 6/6/2025    | 6:26:00 AM  |
| SCSD-1784 | CA                    | 2142     | North Cafeteria  | WC          | 6/6/2025    | 6:26:00 AM  |

Samples Submitted 38

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 12 25, PM 06:07

**Building Address**  
99 Pell Lane  
Syosset, NY 11791

Analysis Type: ELAP 200.5  
Lab Received: 6/16/25 18:07  
Signature: [Signature]

Samplers Name: Jordan George  
Samplers Signature: [Signature]  
JCB Project Manager: Bryan Fedler





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553195

LIMS Reference ID: ED53195

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** South Woods Middle School: SWM: 99 Pell Lane,  
Syosset, NY 11791: Syosset Central School District:  
Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:07  
**Reported:**

**Analytical Results  
(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0463 (Continued) Lims Reference ID: ED53195-09 Matrix: Drinking Water Sampled: 06/06/25 05:56:00

**Metals (Continued)**

Lead < 1.0 1 1.0 µg/L 06/16/25 10:51 06/16/25 10:51 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0464 Lims Reference ID: ED53195-10 Matrix: Drinking Water Sampled: 06/06/25 05:57:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 10:52 06/16/25 10:52 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0465 Lims Reference ID: ED53195-11 Matrix: Drinking Water Sampled: 06/06/25 05:58:00

**Metals**

Lead 1.3 1 1.0 µg/L 06/16/25 10:54 06/16/25 10:54 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0466 Lims Reference ID: ED53195-12 Matrix: Drinking Water Sampled: 06/06/25 05:58:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 10:55 06/16/25 10:55 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0481 Lims Reference ID: ED53195-13 Matrix: Drinking Water Sampled: 06/06/25 06:16:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 10:56 06/16/25 10:56 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0529 Lims Reference ID: ED53195-14 Matrix: Drinking Water Sampled: 06/06/25 06:08:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 10:58 06/16/25 10:58 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0530 Lims Reference ID: ED53195-15 Matrix: Drinking Water Sampled: 06/06/25 06:08:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:02 06/16/25 11:02 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0561 Lims Reference ID: ED53195-16 Matrix: Drinking Water Sampled: 06/06/25 06:33:00

**Metals**

Lead 1.1 1 1.0 µg/L 06/16/25 11:03 06/16/25 11:03 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0564 Lims Reference ID: ED53195-17 Matrix: Drinking Water Sampled: 06/06/25 06:34:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553195

LIMS Reference ID: ED53195

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** South Woods Middle School: SWM: 99 Pell Lane,  
Syosset, NY 11791: Syosset Central School District:  
Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:07  
**Reported:**

**Analytical Results  
(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-0564 (Continued) Lims Reference ID: ED53195-17 Matrix: Drinking Water Sampled: 06/06/25 06:34:00

**Metals (Continued)**

Lead 1.5 1 1.0 µg/L 06/16/25 11:07 06/16/25 11:07 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0565 Lims Reference ID: ED53195-18 Matrix: Drinking Water Sampled: 06/06/25 06:38:00

**Metals**

Lead 2330 25 25.0 µg/L 06/16/25 19:18 06/16/25 19:18 KT1 EPA 200.8 (Dig)/EPA 200.8

Sample: SCSD-0566 Lims Reference ID: ED53195-19 Matrix: Drinking Water Sampled: 06/06/25 06:29:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:08 06/16/25 11:08 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0567 Lims Reference ID: ED53195-20 Matrix: Drinking Water Sampled: 06/06/25 06:36:00

**Metals**

Lead 19.4 1 1.0 µg/L 06/16/25 11:09 06/16/25 11:09 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0573 Lims Reference ID: ED53195-21 Matrix: Drinking Water Sampled: 06/06/25 05:42:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:11 06/16/25 11:11 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-0574 Lims Reference ID: ED53195-22 Matrix: Drinking Water Sampled: 06/06/25 06:24:00

**Metals**

Lead 1.2 1 1.0 µg/L 06/16/25 11:12 06/16/25 11:12 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1419 Lims Reference ID: ED53195-23 Matrix: Drinking Water Sampled: 06/06/25 07:20:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:13 06/16/25 11:13 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1420 Lims Reference ID: ED53195-24 Matrix: Drinking Water Sampled: 06/06/25 07:20:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:15 06/16/25 11:15 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1421 Lims Reference ID: ED53195-25 Matrix: Drinking Water Sampled: 06/06/25 06:18:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553195

LIMS Reference ID: ED53195

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** South Woods Middle School: SWM: 99 Pell Lane,  
Syosset, NY 11791: Syosset Central School District:  
Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:07  
**Reported:**

**Analytical Results  
(Continued)**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1421 (Continued) Lims Reference ID: ED53195-25 Matrix: Drinking Water Sampled: 06/06/25 06:18:00

**Metals (Continued)**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:26 06/16/25 11:26 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1422 Lims Reference ID: ED53195-26 Matrix: Drinking Water Sampled: 06/06/25 06:18:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:30 06/16/25 11:30 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1423 Lims Reference ID: ED53195-27 Matrix: Drinking Water Sampled: 06/06/25 06:44:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:31 06/16/25 11:31 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1424 Lims Reference ID: ED53195-28 Matrix: Drinking Water Sampled: 06/06/25 06:45:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:33 06/16/25 11:33 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1429 Lims Reference ID: ED53195-29 Matrix: Drinking Water Sampled: 06/06/25 07:12:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:34 06/16/25 11:34 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1439 Lims Reference ID: ED53195-30 Matrix: Drinking Water Sampled: 06/06/25 06:11:00

**Metals**

Lead 4.9 1 1.0 µg/L 06/16/25 11:38 06/16/25 11:38 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1440 Lims Reference ID: ED53195-31 Matrix: Drinking Water Sampled: 06/06/25 06:20:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:39 06/16/25 11:39 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1457 Lims Reference ID: ED53195-32 Matrix: Drinking Water Sampled: 06/06/25 06:40:00

**Metals**

Lead < 1.0 1 1.0 µg/L 06/16/25 11:41 06/16/25 11:41 SEH EPA 200.8 (DA)/EPA 200.8

Sample: SCSD-1458 Lims Reference ID: ED53195-33 Matrix: Drinking Water Sampled: 06/06/25 06:40:00

**Metals**



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553195

LIMS Reference ID: ED53195

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** South Woods Middle School: SWM: 99 Pell Lane,  
Syosset, NY 11791: Syosset Central School District:  
Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 06/12/2025 18:07  
**Reported:**

**Analytical Results**  
(Continued)

| Analyte  | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|--|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-1458 (Continued) Lims Reference ID: ED53195-33 Matrix: Drinking Water Sampled: 06/06/25 06:40:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals (Continued)</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 11:42     | 06/16/25 11:42     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1459 Lims Reference ID: ED53195-34 Matrix: Drinking Water Sampled: 06/06/25 06:57:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 11:43     | 06/16/25 11:43     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1517 Lims Reference ID: ED53195-35 Matrix: Drinking Water Sampled: 06/06/25 05:48:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 11:45     | 06/16/25 11:45     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1518 Lims Reference ID: ED53195-36 Matrix: Drinking Water Sampled: 06/06/25 05:48:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 11:49     | 06/16/25 11:49     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1783 Lims Reference ID: ED53195-37 Matrix: Drinking Water Sampled: 06/06/25 06:26:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 11:50     | 06/16/25 11:50     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1784 Lims Reference ID: ED53195-38 Matrix: Drinking Water Sampled: 06/06/25 06:26:00</b>             |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/16/25 11:54     | 06/16/25 11:54     | SEH              | EPA 200.8 (DA)/EPA 200.8 |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553195

LIMS Reference ID: ED53195

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** South Woods Middle School: SWM: 99 Pell Lane,  
Syosset, NY 11791: Syosset Central School District:  
Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:07  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553195

**LIMS Reference ID:** ED53195

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** South Woods Middle School: SWM: 99 Pell Lane,  
Syosset, NY 11791: Syosset Central School District:  
Project# 23-53856  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/12/2025 18:07  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

# ED53747

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: Baylis Elementary School  
BES

Client: Syosset Central School District  
Retest New Install   
Turn Around: Normal Lwk Rush



| Sample ID | Functional Space Type | AHERA ID | Common Room Name                     | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|--------------------------------------|-------------|-------------|-------------|
| SCSD-1486 | HA                    | 2079     | Corridor Fish Bowl to Stage o/s 2046 | WF          | 6/27/2025   | 7:26:00 AM  |
| SCSD-1487 | HA                    | 2079     | Corridor Fish Bowl to Stage o/s 2046 | WC          | 6/27/2025   | 7:27:00 AM  |

Samples Submitted 2

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JUN 27 25. PM 03:52

**Building Address**  
580 Woodbury Road  
Plainview, NY 11803

Analysis Type: ELAP 200.5

Lab Received: S. Cherofsky 6/27/25

Signature: S. Clumny 3:52 PM

Samplers Name: Jarrett Bonface

Samplers Signature: [Signature]

JCB Project Manager: Bryan Ezelius



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553747

**LIMS Reference ID:** ED53747

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Baylis Elementary School, 580 Woodbury Road, Plainview, NY 11803  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/27/2025 15:52  
**Reported:**

**Analytical Results**

| Analyte  | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|--|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-1486</b> <span style="float:right"><b>Lims Reference ID: ED53747-01</b></span> <span style="float:right"><b>Matrix: Drinking Water</b></span> <span style="float:right"><b>Sampled: 06/26/25 00:00:00</b></span> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/30/25 09:37     | 06/30/25 09:37     | SEH              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-1487</b> <span style="float:right"><b>Lims Reference ID: ED53747-02</b></span> <span style="float:right"><b>Matrix: Drinking Water</b></span> <span style="float:right"><b>Sampled: 06/26/25 00:00:00</b></span> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>  |        |   |    |     |       |                    |                    |                  |                          |
| Lead   | < 1.0  |   | 1  | 1.0 | µg/L  | 06/30/25 09:38     | 06/30/25 09:38     | SEH              | EPA 200.8 (DA)/EPA 200.8 |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062553747

LIMS Reference ID: ED53747

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Baylis Elementary School, 580 Woodbury Road, Plainview, NY 11803  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/27/2025 15:52  
**Reported:**

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062553747

**LIMS Reference ID:** ED53747

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Baylis Elementary School, 580 Woodbury Road, Plainview, NY 11803  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 06/27/2025 15:52  
**Reported:**


**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53856  
Building: Syosset High School  
SHS

EE54448

Client: Syosset Central School District  
Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

| Sample ID | Functional Space Type | AHERA ID | Common Room Name | Outlet Type | Sample Date | Sample Time |
|-----------|-----------------------|----------|------------------|-------------|-------------|-------------|
| SCSD-1777 | EX                    | N/A      | Exterior of Barn | WF          | 7/3/2024    | 6:45        |
| SCSD-1778 | EX                    | N/A      | Exterior of Barn | WC          | 7/3/2024    | 6:31        |

Samples Submitted 2

RECEIVED  
EHS LABORATORY, INC.  
CARLE PLACE, NY  
2024 JUN -3 P 4: 20



af

**Building Address**  
70 South Woods Road  
Syosset, NY 11791

Analysis Type: ELAP 200.5

Lab Received: Cfaelo

Signature: [Signature]

Samplers Name: Matthew Martin

Samplers Signature: Matthew Martin

JCB Project Manager: Bryan Ezelius



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454448  
**LIMS Reference ID:** EC54448  
**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** JCB#: 23-53856, Syosset High School,  
Syosset Central School District, 70 South  
Woods Road, Syosset, NY 11791  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/03/2024 16:20  
**Reported:** 07/11/2024 15:26

**Analytical Results**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: SCSD-1777 Lims Reference ID: EC54448-01 Matrix: Drinking Water Sampled: 07/03/24 00:00:00

**Metals**

|      |      |  |   |     |      |                |                |    |                          |
|------|------|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | <1.0 |  | 1 | 1.0 | µg/L | 07/11/24 14:37 | 07/11/24 14:37 | BP | EPA 200.8 (DA)/EPA 200.8 |
|------|------|--|---|-----|------|----------------|----------------|----|--------------------------|

Sample: SCSD-1778 Lims Reference ID: EC54448-02 Matrix: Drinking Water Sampled: 07/03/24 00:00:00

**Metals**

|      |     |  |   |     |      |                |                |    |                          |
|------|-----|--|---|-----|------|----------------|----------------|----|--------------------------|
| Lead | 1.2 |  | 1 | 1.0 | µg/L | 07/11/24 14:38 | 07/11/24 14:38 | BP | EPA 200.8 (DA)/EPA 200.8 |
|------|-----|--|---|-----|------|----------------|----------------|----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454448  
**LIMS Reference ID:** EC54448  
**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** JCB#: 23-53856, Syosset High School,  
Syosset Central School District, 70 South  
Woods Road, Syosset, NY 11791

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/03/2024 16:20  
**Reported:** 07/11/2024 15:26

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <b>EPA 200.8 in Drinking Water</b> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description  | Number  | Expires    |
|--------------------|--|---------|------------|
| 06-NYSELAP         | NY NYS ELAP  | 11469   | 04/01/2025 |
| 06-NYSDOH          | New York State Department of Health                                  | 11469   | 04/01/2025 |
| 06-CTDPH           | Connecticut Department of Public Health                              | PH-0249 | 03/31/2025 |
| 06-California ELAP | California Water Boards  | 2339    | 04/01/2025 |
| 06-AIHA LAP        | EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited | 102344  | 09/01/2024 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454448  
**LIMS Reference ID:** EC54448  
**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** JCB#: 23-53856, Syosset High School,  
Syosset Central School District, 70 South  
Woods Road, Syosset, NY 11791  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/03/2024 16:20  
**Reported:** 07/11/2024 15:26

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| Q           | Qualifier   |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.







**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062555120

LIMS Reference ID: ED55120

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Robbins Lane Elementary School,  
Syosset Central School District, 157 Robbins Lane,  
Syosset, New York, 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 19:00  
**Reported:** 08/16/2025 10:56

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062555120

**LIMS Reference ID:** ED55120

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Robbins Lane Elementary School,  
Syosset Central School District, 157 Robbins Lane,  
Syosset, New York, 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 19:00  
**Reported:** 08/16/2025 10:56

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062555109

**LIMS Reference ID:** ED55109

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, South Grove Annex, SGA, Syosset Central School District, 60 Colony Lane, Syosset, New York, 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 19:00  
**Reported:** 08/16/2025 10:51

**Analytical Results**

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

**Sample:** SCSD-1061      **Lims Reference ID:** ED55109-01 **Matrix:** Drinking Water      **Sampled:** 08/13/25 00:00:00

**Metals**

|      |     |  |   |     |      |                |                |     |                          |
|------|-----|--|---|-----|------|----------------|----------------|-----|--------------------------|
| Lead | 7.1 |  | 1 | 1.0 | µg/L | 08/15/25 16:02 | 08/15/25 16:02 | KT1 | EPA 200.8 (DA)/EPA 200.8 |
|------|-----|--|---|-----|------|----------------|----------------|-----|--------------------------|



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062555109

**LIMS Reference ID:** ED55109

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, South Grove Annex, SGA, Syosset Central School District, 60 Colony Lane, Syosset, New York, 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 19:00  
**Reported:** 08/16/2025 10:51

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062555109

**LIMS Reference ID:** ED55109

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, South Grove Annex, SGA, Syosset Central School District, 60 Colony Lane, Syosset, New York, 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 19:00  
**Reported:** 08/16/2025 10:51

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062555116

**LIMS Reference ID:** ED55116

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Willits Elementary School WES, 99 Nana Place, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeremy Bish  
**Received:** 08/13/2025 18:58  
**Reported:** 08/16/2025 10:54

**Analytical Results**

| Analyte   | Result | Q | DF | RL  | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method  |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| <b>Sample: SCSD-0947</b> Lims Reference ID: ED55116-01 Matrix: Drinking Water <b>Sampled: 08/13/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 8.5    |   | 1  | 1.0 | µg/L  | 08/15/25 16:10     | 08/15/25 16:10     | KT1              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0930</b> Lims Reference ID: ED55116-02 Matrix: Drinking Water <b>Sampled: 08/13/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.9    |   | 1  | 1.0 | µg/L  | 08/15/25 16:11     | 08/15/25 16:11     | KT1              | EPA 200.8 (DA)/EPA 200.8 |
| <b>Sample: SCSD-0931</b> Lims Reference ID: ED55116-03 Matrix: Drinking Water <b>Sampled: 08/13/25 00:00:00</b> |        |   |    |     |       |                    |                    |                  |                          |
| <b>Metals</b>   |        |   |    |     |       |                    |                    |                  |                          |
| Lead  | 1.4    |   | 1  | 1.0 | µg/L  | 08/15/25 16:12     | 08/15/25 16:12     | KT1              | EPA 200.8 (DA)/EPA 200.8 |



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062555116

LIMS Reference ID: ED55116

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Willits Elementary School WES, 99 Nana Place, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 18:58  
**Reported:** 08/16/2025 10:54

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062555116

**LIMS Reference ID:** ED55116

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, Willits Elementary School WES, 99 Nana Place, Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 18:58  
**Reported:** 08/16/2025 10:54

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.







**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062555117

LIMS Reference ID: ED55117

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, South  
Grove Elementary School SGE, 60 Colony Lane,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 18:59  
**Reported:** 08/16/2025 10:55

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <b>EPA 200.8 in Drinking Water</b> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062555117

**LIMS Reference ID:** ED55117

**EMSL Customer ID:** JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** 23-53856, Syosset Central School District, South  
Grove Elementary School SGE, 60 Colony Lane,  
Syosset, NY 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 18:59  
**Reported:** 08/16/2025 10:55

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.







**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062555121

LIMS Reference ID: ED55121

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** JCB #23-53856; Syosset High School; 70 South Woods Road Syosset, New York, 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 18:58  
**Reported:** 08/16/2025 10:57

**Certified Analyses included in this Report**

| Analyte                            | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> |                |
| Lead                               | 06-NYSELAP     |

**List of Certifications**

| Code               | Description   | Number  | Expires    |
|--------------------|---|---------|------------|
| 06-NYSELAP         | NY NYS ELAP   | 11469   | 04/01/2026 |
| 06-NYSDOH          | New York State Department of Health                             | 11469   | 04/01/2026 |
| 06-CTDPH           | Connecticut Department of Public Health                         | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards   | 2339    | 04/01/2026 |
| 06-AIHA LAP        | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344  | 08/01/2026 |

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

EMSL Order ID: 062555121

LIMS Reference ID: ED55121

EMSL Customer ID: JCBR50

**Attention:** Bryan Ezelius  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
bezelius@jcbroderick.com

**Project Name:** JCB #23-53856; Syosset High School; 70 South Woods Road Syosset, New York, 11791  
**Project ID:** \_06 - Carle Place Lead Analyses  
**Customer PO:**  
**Sales Rep:** Jeromy Bish  
**Received:** 08/13/2025 18:58  
**Reported:** 08/16/2025 10:57

**Notes and Definitions**

| <b>Item</b> | <b>Definition</b>   |
|-------------|---|
| (Dig)       | For metals analysis, sample was digested.                 |
| [2C]        | Reported from the second channel in dual column analysis. |
| DA          | Direct Analysis   |
| DF          | Dilution Factor   |
| MDL         | Method Detection Limit.                                   |
| ND          | Analyte was NOT DETECTED at or above the detection limit. |
| NR          | Spike/Surrogate showed no recovery.                       |
| Q           | Qualifier   |
| RCS         | Respirable Crystalline Silica                             |
| RL          | Reporting Limit   |
| Wet         | Sample is not dry weight corrected.                       |


Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

# Attachment 4:

# Laboratory Certifications



**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026  
Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. DANIEL CLARKE  
EMSL ANALYTICAL, INC.  
528 MINEOLA AVE.  
CARLE PLACE, NY 11514

NY Lab Id No: 11469

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Bacteriology**

|   |  |
|---|--|
| Coliform, Total / E. coli (Qualitative) | SM 21, 23 9222A,B,C<br>SM 20, 21-23 9223B (-04) (Colilert) |
| E. coli (Enumeration)                   | SM 21, 23 9222A,B,C  |
| Heterotrophic Plate Count               | SM 20, 21-23 9215B (-04)                                   |

**Metals I**

|               |                    |
|---------------|--------------------|
| Copper, Total | EPA 200.8 Rev. 5.4 |
| Lead, Total   | EPA 200.8 Rev. 5.4 |
| Silver, Total | EPA 200.8 Rev. 5.4 |

**Miscellaneous**

|          |           |
|----------|-----------|
| Asbestos | EPA 100.2 |
|----------|-----------|



Serial No.: 70480

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

