

Water Testing Informtaion, Fixtures Above 5ppb

Site	Location	Fixture	PPB Ecology	PPB Tetra Tech - 1st Draw, 2nd Draw	Action Taken	Future Plan
Brookside	Kitchen - Sink to right of dish washer	Sink - Sprayer	37	4.27, .624	Replaced sprayer	Retest in 2025
Brookside	Kitchen - largest 3 tier sink	Sink Multi compartment - Tap	12	5.58, >2	Replaced tap	Retest in 2025
Brookside	Room K-1	Sink - Water fountain	10	2.4, .416	Turned off water fountain	Replace fixture
Brookside	Room 204	Sink - Water fountain	8	8.9, .825	Turned off water fountain, room used as storage	Replace fixture
Ridgecrest	PT Room - 320	Sink Tap	17	13, 1.170	Turned off tap	Placed "hand wash only" sign
Ridgecrest	Kitchen Tap	2 of 3 largest 3 tier sink	9	.659, 1.470 Left; .990, 1.460 Right	Placed sign reading run water for 30 seconds	Replaced fixture
Meridian Park	Room 239	Sink Tap	103	4.010, .537	Turned off tap	Placed "hand wash only" sign
Meridian Park	Kitchen	3 of 3 largest 3 tier sink	28	.966, .244	Turned off tap	Replaced fixture
Meridian Park	Room 237	Sink Tap	16	47.5, .622	Turned off tap	Placed "hand wash only" sign
Meridian Park	Office - Next to Room 403.1	Sink - multi compartment - Sprayer	12	1.980, .934	Turned off tap	Placed "hand wash only" sign
Meridian Park	Room 602	Sink - Tap	9	299, .471	Turned off tap	Placed "hand wash only" sign
Meridian Park	Room 405.2	Sink - Tap	7	197, 3.480	Turned off tap	Placed "hand wash only" sign
Meridian Park	Kitchen	3 of 3 largest 3 tier sink	6	16.00, .560	Placed sign reading run water for 30 seconds	Replaced fixture
Echo Lake	Kitchen	Sink 1 of 3 largest 3 tier sink - Tap	65	15.800, .495	Replaced fixture	Replaced fixture
Echo Lake	Kitchen	Sink 3 of 3 - Dish washing sink - Sprayer	21	3.380, .612	Replaced sprayer	Replaced fixture
Echo Lake	Kitchen	Sink 1 of 3 largest 3 tier sink - Sprayer	17	7.94, .664	Replaced sprayer	Replaced fixture
Echo Lake	Room 20	Sink - 1 of 2 - Water Fountain	10	22.600, 1.100	Turned off water fountain	Cap water fountain, utilize bottle filling station
Echo Lake	Room 20	Sink - 2 of 2 - Tap	10	23.100, .586	Turned off tap	Placed "hand wash only" sign
Echo Lake	Room 20	Sink - 1 of 2 - Tap	9	6.750, .553	Turned off tap	Placed "hand wash only" sign
Echo Lake	Room 1	Sink - Tap	8	5.760, .512	Placed "hand wash only" sign	
Echo Lake	Room 20	Sink 2 of 2 - Water Fountain	7	4.1, .781	Turned off water fountain	Cap water fountain, utilize bottle filling station
Echo Lake	Room 8	Sink 2 of 2 - Tap	6	10.100, .657	Placed "hand wash only" sign	
Echo Lake	Room 14	Sink 2 of 2 - Tap	6	6.390, .585	Placed "hand wash only" sign	
Echo Lake	Room 15	Sink 1 of 2 - Tap	6	6.890, .657	Placed "hand wash only" sign	
Echo Lake	Room 16	Sink 1 of 2 - Tap	6	9.330, .796	Placed "hand wash only" sign	
Echo Lake	Room 16	Sink 1 of 1 - Water Fountain	6	3.140, 1.010	Turned off water fountain	Cap water fountain, utilize bottle filling station
Echo Lake	Room 17	Sink 1 of 2 - Water Fountain	6	58.1, 4.370	Turned off water fountain	Cap water fountain, utilize bottle filling station
Echo Lake	Room 9	Sink 1 of 2 - Water Fountain	6	1.260, .509	Turned off water fountain	Cap water fountain, utilize bottle filling station
Highland Terrace	Kitchen	Sink - Tap (small sink on island)	66	41.00, 1.560	Turned off tap	Replaced fixture
Highland Terrace	OT / PT	Sink - Water Fountain (carpeted side)	9	1.780, 0.462	Turned off water fountain	Capped water fountain
Highland Terrace	OT / PT	Sink - Tap (Hardwood floor side)	8	4.840, >0.2	Turned off tap	Placed "hand wash only" sign
Highland Terrace	Kitchen	Largest 3 Tier Sink	7	>.02, >.02	Placed sign reading run water for 30 seconds	Replaced fixture
Highland Terrace	Computer Room	Sink - Tap	7	120, .599	Turned off tap	Placed "hand wash only" sign
North City	Library office - Room 53	Sink - Tap	43	39.600, 1.280	Turned off tap	Placed "hand wash only" sign
North City	Kitchen	2 of 3 largest 3 tier sink	23	8.090, .493 Left Tap, 6.190, .279 Right Tap	Placed sign reading run water for 30 seconds	Replaced fixture
North City	Room 2	Sink - Tap	18	11.600, 0.817	Placed "hand wash only" sign	
North City	Room 11	Sink - Tap	18	16.300, 1.140	Placed "hand wash only" sign	
North City	Room 3	Sink - Tap	17	10.700, 0.824	Placed "hand wash only" sign	
North City	Room 5	Sink - Tap	14	2.250, 0.966	Placed "hand wash only" sign	
North City	Room 16	Sink - Tap	14	11.400, 0.833	Placed "hand wash only" sign	
North City	Room 15	Sink - Tap	13	8.110, 0.857	Placed "hand wash only" sign	
North City	Room 14	Sink - Tap	13	8.080, 0.597	Placed "hand wash only" sign	
North City	Room 10	Sink - Tap	12	5.460, 0.696	Placed "hand wash only" sign	
North City	Room 12	Sink - Tap	11	9.970, 0.970	Placed "hand wash only" sign	
North City	Room 21	Sink - Tap	10	7.300, 1.030	Placed "hand wash only" sign	
North City	Room 13	Sink - Tap	10	5.880, 1.390	Placed "hand wash only" sign	
North City	Room 4	Sink - Tap	9	8.210, 0.574	Placed "hand wash only" sign	
North City	Room 8	Sink - Tap	8	4.430, 0.886	Placed "hand wash only" sign	
North City	Room 9	Sink - Tap	8	0.548, 0.738	Placed "hand wash only" sign	
North City	Room 6	Sink - Tap	7	7.510, .0570	Placed "hand wash only" sign	
Syre	Music Room	Sink - Tap	11	8.960, 2.010	Turned off tap	Placed "hand wash only" sign
Syre	Kitchen	Left of Dish Washer 1 of 3 - Sink	9	7.290, 2.670	Placed sign reading run water for 30 seconds	Replaced fixture
Syre	Kitchen	Sink Multi compartment - 2 of 3 largest 3 tier sink	7	7.040, 2.110	Placed sign reading run water for 30 seconds	Replaced fixture
Shorewood	Main Building Room 1110	Sink - multi compartment - Station 1, 2 of 8, Tap	36	.496, <0.2 Station 1; <0.2, <.231 Station 2	Turned off tap	Turned on water after second test
Shorewood	Main Building Room 1020	Sink - Tap	10	4.070, .9388	Turned off tap	Placed "hand wash only" sign
Lake Forest Park	Kitchen - Sink - Multi Compartment	Largest 3 Tier Sink Tap	29	17.900, 0.740	Placed sign reading run water for 30 seconds	Replaced fixture
Lake Forest Park	Room 415	Only Sink - Tap	26	53.200, 3.00	Placed "hand wash only" sign	
Lake Forest Park	Room 415	Only Sink - Water Fountain	23	1.440, 3.920	Turned off water fountain	
Lake Forest Park	Sink - Multi Compartment Kitchen	Largest 3 Tier Sink	19	15, 0.460	Placed sign reading run water for 30 seconds	Replaced fixture
Lake Forest Park	Stage Orchestra	Only Sink - Tap	19	43.100, 75.600	Shut off fixture	Removed fixture
Lake Forest Park	Room 119	Only Sink - Tap	13	7.800, 0.547	Placed "hand wash only" sign	
Lake Forest Park	Room 304 Music	Only Sink - Tap	11	6.410, 0.818	Placed "hand wash only" sign	
Lake Forest Park	Room 112	Only Sink - Tap	11	11.900, 1.140	Placed "hand wash only" sign	
Lake Forest Park	Room 414	Only Sink - Tap	11	6.720, 1.320	Placed "hand wash only" sign	
Lake Forest Park	Room 423	Only Sink - Tap	11	7.880, 0.467	Placed "hand wash only" sign	
Lake Forest Park	Room M1	Only Sink - Tap	10	4.800, 1.120	Placed "hand wash only" sign	
Lake Forest Park	Room 106	Only Sink - Tap	10	8.680, 0.802	Placed "hand wash only" sign	
Lake Forest Park	Room 413	Only Sink - Tap	10	4.160, 0.769	Placed "hand wash only" sign	
Lake Forest Park	Room 421	Only Sink - Tap	10	6.780, 0.962	Placed "hand wash only" sign	
Lake Forest Park	Room 416	Only Sink - Tap	10	23.600, 2.670	Placed "hand wash only" sign	
Lake Forest Park	Room 110	Only Sink - Tap	9	4.240, 1.390	Placed "hand wash only" sign	
Lake Forest Park	Room 109	Only Sink - Tap	9	2.980, 1.130	Placed "hand wash only" sign	
Lake Forest Park	Room M2	Only Sink - Sprayer	8	1.160, 0.591	Placed "hand wash only" sign	
Lake Forest Park	Room 418	Only Sink - Tap	8	2.740, 1.070	Placed "hand wash only" sign	
Lake Forest Park	Room 416	Only Sink - Water Fountain	8	3.780, 1.390	Turned off water fountain	Cap water fountain, utilize bottle filling station
Lake Forest Park	Room 104	Only Sink - Tap	7	4.120, .595	Placed "hand wash only" sign	
Lake Forest Park	Room 102	Only Sink - Tap	7	2.990, 0.541	Placed "hand wash only" sign	

Lake Forest Park	Room 421	Only Sink - Water Fountain	7	5.320, 1.290	Turned off water fountain	Cap water fountain, utilize bottle filling station	
Lake Forest Park	Room 105	Only Sink - Water Fountain	6	1.580, 1.050	Turned off water fountain	Cap water fountain, utilize bottle filling station	
Lake Forest Park	Room 101	Sink with Fountain - Tap	6	3.550, 0.634	Placed "hand wash only" sign		
Lake Forest Park	Primary Hallway - Across from 116	Water Fountain	6	3.100, 1.120	Turned off water fountain	Removed water fountain and covered area	Will likely install bottle filling station in late 2025
Lake Forest Park	Room 414	Only Sink - Water Fountain	6	1.550, 1.240	Turned off water fountain	Cap water fountain, utilize bottle filling station	
Lake Forest Park	Room 423	Only Sink - Water Fountain	6	1.180, 0.740	Turned off water fountain	Cap water fountain, utilize bottle filling station	
Lake Forest Park	Room 419	Only Sink - Tap	6	7.060, 0.846	Placed "hand wash only" sign		
Lake Forest Park	Room 417	Only Sink - Tap	6	13.800, 1.230	Placed "hand wash only" sign		
Lake Forest Park	Room 417	Only Sink - Water Fountain	6	1.660, 1.080	Turned off water fountain	Cap water fountain, utilize bottle filling station	
Shorecrest	Concessions	Sink multi compartment - Tap	6	Not retested		Replaced both taps since the 1st test was unclear	Retest in 2025