



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 13, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: North High Lead Testing

Order No.: 25050669

Dear Andy Chasteen:

Neilson Research Corporation received 51 sample(s) on 5/14/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050669
Date: 6/13/2025

CLIENT: Medford School District

Project: North High Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-01 Client Sample ID: DW Area-E Wall-PR Sink
Collection Date: 5/14/2025 5:40:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: DW Area-E Wall-PR Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.99		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-02 Client Sample ID: DW-E Wall-PR Spray Nozzle (L)
Collection Date: 5/14/2025 5:41:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: DW-E Wall-PR Spray Nozzle (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.14		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-03 Client Sample ID: DW-E Wall-PR Spray Nozzle (R)
Collection Date: 5/14/2025 5:42:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: DW-E Wall-PR Spray Nozzle (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.68		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-04 **Client Sample ID:** DW-W Wall-HW Sink SW Corner
Collection Date: 5/14/2025 5:43:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** DW-W Wall-HW Sink SW Corner

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-05 **Client Sample ID:** DW-W Wall-PR Sink(L)
Collection Date: 5/14/2025 5:44:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** DW-W Wall-PR Sink(L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-06 **Client Sample ID:** DW W Wall Spray Nozzle(L)
Collection Date: 5/14/2025 5:45:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** DW W Wall Spray Nozzle(L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.16		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669
Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-07 **Client Sample ID:** DW-W Wall-PR Sink(R)
Collection Date: 5/14/2025 5:46:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** DW-W Wall-PR Sink(R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.57		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-08 **Client Sample ID:** Kitchen-Men's RR-Sink
Collection Date: 5/14/2025 5:47:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-Men's RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-09 **Client Sample ID:** Kitchen-Women's RR-Sink
Collection Date: 5/14/2025 5:47:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-Women's RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-10 Client Sample ID: Kitchen-E Wall-HW Sink (L)
Collection Date: 5/14/2025 5:48:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-E Wall-HW Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.39		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-11 Client Sample ID: Kitchen-E Wall-HW Sink (R)
Collection Date: 5/14/2025 5:48:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-E Wall-HW Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.71		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-12 Client Sample ID: Kitchen-E Wall-Food Prep Sink
Collection Date: 5/14/2025 5:49:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-E Wall-Food Prep Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669
Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-13 **Client Sample ID:** Kitchen-E Island-HW Sink Eye Wash
Collection Date: 5/14/2025 5:50:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-E Island-HW Sink Eye Wash

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-14 **Client Sample ID:** Kitchen-E Island-Food Prep Sink (L)
Collection Date: 5/14/2025 5:51:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-E Island-Food Prep Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.582		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-15 **Client Sample ID:** Kitchen-NW Wall-Food Prep Sink
Collection Date: 5/14/2025 5:52:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-NW Wall-Food Prep Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-16 **Client Sample ID:** Kitchen-NW HW Sink by Hall
Collection Date: 5/14/2025 5:53:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-NW HW Sink by Hall

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-17 **Client Sample ID:** Kitchen-NE Wall-Food Prep Sink (L)
Collection Date: 5/14/2025 5:54:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-NE Wall-Food Prep Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.905		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-18 **Client Sample ID:** Kitchen-NE Wall-Food Prep Sink (R)
Collection Date: 5/14/2025 5:55:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-NE Wall-Food Prep Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.10		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-19 **Client Sample ID:** Kitchen-Small Kettle-Faucet
Collection Date: 5/14/2025 5:56:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-Small Kettle-Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.29		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-20 **Client Sample ID:** Kitchen-Large Kettle-Faucet
Collection Date: 5/14/2025 5:57:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-Large Kettle-Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-21 **Client Sample ID:** Kitchen-Spray Nozzle (R) of Lg Kettle
Collection Date: 5/14/2025 5:57:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Kitchen-Spray Nozzle (R) of Lg Kettle

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.47		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-22 Client Sample ID: Kitchen-W Wall-HW Sink
Collection Date: 5/14/2025 6:00:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-W Wall-HW Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-23 Client Sample ID: Kitchen-Coffee Mach-NW Corner
Collection Date: 5/14/2025 6:01:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Coffee Mach-NW Corner

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.81		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-24 Client Sample ID: Kitchen-Wok Faucet
Collection Date: 5/14/2025 6:03:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Wok Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.562		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-25 Client Sample ID: Kitchen-Pizza-WS Ice Machine
Collection Date: 5/14/2025 6:03:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Pizza-WS Ice Machine

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-26 Client Sample ID: Kitchen-Pizza-WS Food Prep Sink
Collection Date: 5/14/2025 6:04:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Pizza-WS Food Prep Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-27 Client Sample ID: Kitchen-Pizza-WS Hand Wash Sink
Collection Date: 5/14/2025 6:04:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Kitchen-Pizza-WS Hand Wash Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.17		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669
Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-28 **Client Sample ID:** Cafeteria-Men's RR Sink (L)
Collection Date: 5/14/2025 6:15:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Men's RR Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-29 **Client Sample ID:** Cafeteria-Men's RR Sink (C)
Collection Date: 5/14/2025 6:15:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Men's RR Sink (C)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.70		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-30 **Client Sample ID:** Cafeteria-Men's RR Sink (R)
Collection Date: 5/14/2025 6:15:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Men's RR Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.81		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669
Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-31 **Client Sample ID:** Cafeteria-Women's RR Sink (L)(1)
Collection Date: 5/14/2025 6:18:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Women's RR Sink (L)(1)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.789		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-32 **Client Sample ID:** Cafeteria-Women's RR Sink (2)
Collection Date: 5/14/2025 6:18:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Women's RR Sink (2)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.25		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-33 **Client Sample ID:** Cafeteria-Women's RR Sink (3)
Collection Date: 5/14/2025 6:18:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Women's RR Sink (3)

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.681		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669
Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-34 **Client Sample ID:** Cafeteria-Women's RR Sink (R)(4)
Collection Date: 5/14/2025 6:19:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Women's RR Sink (R)(4)

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-35 **Client Sample ID:** Rm C1-Sink
Collection Date: 5/14/2025 6:20:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Rm C1-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-36 **Client Sample ID:** Rm C1-Staff Unisex RR
Collection Date: 5/14/2025 6:21:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Rm C1-Staff Unisex RR

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.65		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-37 Client Sample ID: Tennis Court-DF
Collection Date: 5/14/2025 6:50:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Tennis Court-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.873		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-38 Client Sample ID: JV Softball Fld-DF Behind Backstop
Collection Date: 5/14/2025 6:52:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: JV Softball Fld-DF Behind Backstop

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.15		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-39 Client Sample ID: Baseball Fld-DF Visitors Dugout
Collection Date: 5/14/2025 7:29:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Baseball Fld-DF Visitors Dugout

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.16		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-40 **Client Sample ID:** Baseball Fld-Concession-Ice Mach
Collection Date: 5/14/2025 7:26:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Baseball Fld-Concession-Ice Mach

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-41 **Client Sample ID:** Baseball Field-Men's RR-Sink
Collection Date: 5/14/2025 7:25:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Baseball Field-Men's RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.06		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-42 **Client Sample ID:** Baseball Field-Women's RR-Sink
Collection Date: 5/14/2025 7:21:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Baseball Field-Women's RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.43		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669
Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-43 **Client Sample ID:** Baseball Field-O/S RR-DF
Collection Date: 5/14/2025 7:20:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Baseball Field-O/S RR-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.847		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-44 **Client Sample ID:** Bowerman Track-Concession-Ice Mach
Collection Date: 5/14/2025 7:28:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Bowerman Track-Concession-Ice Mach

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	12.9		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-45 **Client Sample ID:** Bowerman Track-Concession-Sink
Collection Date: 5/14/2025 7:28:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Bowerman Track-Concession-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-46 **Client Sample ID:** Water Horse #1-West
Collection Date: 5/14/2025 7:15:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Water Horse #1-West

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-47 **Client Sample ID:** Baseball Con Sink
Collection Date: 5/14/2025 7:30:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Baseball Con Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.900		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-48 **Client Sample ID:** Cafeteria-Bottle Filler
Collection Date: 5/14/2025 6:29:00 AM **Collected By:** Mike Medel
Matrix: Drinking Water **Sample Location:** Cafeteria-Bottle Filler

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050669

Date Reported: 6/13/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25050669
Received Date: 5/14/2025 9:51:00 AM
Reported Date: 6/13/2025 9:46:43 AM

Sample Information:

Lab ID: 25050669-49 Client Sample ID: Cafeteria-DF
Collection Date: 5/14/2025 6:28:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Cafeteria-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/10/2025	15.0	

Lab ID: 25050669-50 Client Sample ID: Cafeteria-Bar Sink SW Corner
Collection Date: 5/14/2025 6:29:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Cafeteria-Bar Sink SW Corner

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/11/2025	15.0	

Lab ID: 25050669-51 Client Sample ID: Outside Bowerman Conc-DF
Collection Date: 5/14/2025 7:29:00 AM Collected By: Mike Medel
Matrix: Drinking Water Sample Location: Outside Bowerman Conc-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.604		0.515	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050669

13-Jun-25

Client: Medford School District

Project: North High Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31563	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: PBW	Batch ID: 31563	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985295						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31563	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: LCSW	Batch ID: 31563	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985296						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.520	100	0	102	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050669-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: Kitchen-Spray Nozzl	Batch ID: 31563	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985298						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.0	0.520	100	1.47	97.6	70	130				
------	------	-------	-----	------	------	----	-----	--	--	--	--

Sample ID: 25050669-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: Kitchen-Spray Nozzl	Batch ID: 31563	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985299						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.520	100	1.47	99.0	70	130	99.0	1.47	20	
------	-----	-------	-----	------	------	----	-----	------	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050669

13-Jun-25

Client: Medford School District

Project: North High Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31627	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: PBW	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985351						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31627	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: LCSW	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985352						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.500	100	0	101	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050620-22AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: BatchQC	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985354						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.8	0.500	100	0.439	95.4	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25050620-22AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: BatchQC	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985355						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	98.6	0.500	100	0.439	98.1	70	130	95.8	2.85	20	
------	------	-------	-----	-------	------	----	-----	------	------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050669
13-Jun-25

Client: Medford School District
Project: North High Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050669-42AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: Baseball Field-Wom	Batch ID: 31564	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985380						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.2	0.520	100	1.43	95.8	70	130				
------	------	-------	-----	------	------	----	-----	--	--	--	--

Sample ID: 25050669-42AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: Baseball Field-Wom	Batch ID: 31564	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985381						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.0	0.520	100	1.43	95.6	70	130	97.2	0.195	20	
------	------	-------	-----	------	------	----	-----	------	-------	----	--

Sample ID: MB-31564	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: PBW	Batch ID: 31564	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985392						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31564	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162						
Client ID: LCSW	Batch ID: 31564	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985393						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.6	0.520	100	0	95.6	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050669

13-Jun-25

Client: Medford School District

Project: North High Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31535	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/4/2025	RunNo: 60162						
Client ID: PBW	Batch ID: 31535	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985406						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31535	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/4/2025	RunNo: 60162						
Client ID: LCSW	Batch ID: 31535	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985407						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	93.0	0.520	100	0	93.0	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 25050669-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/4/2025	RunNo: 60162						
Client ID: DW Area-E Wall-PR	Batch ID: 31535	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985409						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.520	100	6.99	97.1	70	130				
------	-----	-------	-----	------	------	----	-----	--	--	--	--

Sample ID: 25050669-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/4/2025	RunNo: 60162						
Client ID: DW Area-E Wall-PR	Batch ID: 31535	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985410						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	105	0.520	100	6.99	98.2	70	130	104	1.01	20	
------	-----	-------	-----	------	------	----	-----	-----	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050669

13-Jun-25

Client: Medford School District

Project: North High Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31650	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207						
Client ID: PBW	Batch ID: 31650	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986421						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31650	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207						
Client ID: LCSW	Batch ID: 31650	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986422						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	110	0.500	100	0	110	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25060448-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207						
Client ID: BatchQC	Batch ID: 31650	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986425						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	108	0.500	100	0.199	107	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 25060448-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/11/2025	RunNo: 60207						
Client ID: BatchQC	Batch ID: 31650	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 986426						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	109	0.500	100	0.199	109	70	130	108	0.977	20	
------	-----	-------	-----	-------	-----	----	-----	-----	-------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: MedfordSchoolDist

Work Order Number: 25050669

RcptNo: 1

Logged by: Dorie Evans 5/14/2025 9:51:00 AM

Completed By: Coni Boyko 5/16/2025 1:02:42 PM

Reviewed By: Dorie Evans 6/13/2025 9:27:08 AM

Dorie Evans
Coni Boyko
Dorie Evans

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO₃ pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 1 of 3

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: MSD 549C	Project Name: North High	Attention: Accounting	☐ Standard 10-14 Days
Address: 900 Kenyon	Project Number:	Company Name: Medford School District	☐ 5 Business Days (50% surcharge)
Medford, OR 97501	Report To: andy.chasteen@medford.k12.or.us	Address: 900 Kenyon	☐ 3 Business Days (75% surcharge)
Email: andy.chasteen@medford.k12.or.us	Copy To: seth.barry@medford.k12.or.us	Medford, OR 97501	☐ 24 - 48 hours (100% surcharge)
Phone: 541-840-4315 Fax:		P.O. #	☐ Other
Collected By (Print): Mike Medford			Authorized ☐ Yes ☐ No
Collected By (Sign):			
Email Report ☐ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information				Analysis Requested										NRC Workorder # 25050669 (Lab Use Only)		
Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers											Remarks/Field Data	NRC Sample # (Lab Use Only)
Dish Washer (DW) Area - East Wall - Pre-rinse Sink	DW	5/14/2025	5:40	1												01
DW Area - East Wall - Pre-rinse Spray Nozzle (Left)	DW	5/14/2025	5:41	1												02
DW Area - East Wall - Pre-rinse Spray Nozzle (Right)	DW	5/14/2025	5:42	1												03
DW Area - West Wall - Hand Wash Sink (South West Corner)	DW	5/14/2025	5:43	1												04
DW Area - West Wall - Pre-rinse Sink (Left)	DW	5/14/2025	5:44	1												05
DW Area - West Wall - Spray Nozzle (Left)	DW	5/14/2025	5:45	1												06
DW Area - West Wall - Pre-rinse Sink (Right)	DW	5/14/2025	5:46	1												07
Kitchen - Men's Restroom - Sink	DW	5/14/2025	5:47	1												08
Kitchen - Women's Restroom - Sink	DW	5/14/2025	5:47	1												09
Kitchen - East Wall - Hand Wash Sink (Left)	DW	5/14/2025	5:48	1												10
Kitchen - East Wall - Hand Wash Sink (Right)	DW	5/14/2025	5:48	1												11
Kitchen - East Wall - Food Prep Sink	DW	5/14/2025	5:49	1												12
Kitchen - East Island - Hand Wash Sink (Eye Wash)	DW	5/14/2025	5:50	1												13
Kitchen - East Island - Food Prep - Sink	DW	5/14/2025	5:51	1												14
Kitchen - North West Wall - Food Prep - Sink	DW	5/14/2025	5:52	1												15
Kitchen - NW Hand Wash Sink By Hall	DW	5/14/2025	5:53	1												16
Kitchen - North East Wall - Food Prep - Sink (Left)	DW	5/14/2025	5:54	1												17
Kitchen - North East Wall - Food Prep - Sink (Right)	DW	5/14/2025	5:55	1												18
Kitchen - Small Kettle - Faucet	DW	5/14/2025	5:56	1												19
Kitchen - Large Kettle - Faucet	DW	5/14/2025	5:57	1												20
Kitchen - Spray Nozzle To Right of Large Kettle	DW	5/14/2025	5:57	1												21
Kitchen - Steam Oven (Upper - Filtered)	DW	5/14/2025	N/A	1												
Kitchen - Steam Oven (Lower)	DW	5/14/2025	N/A	1												

Section G
Lab Use Only

Temp: 4.5
4°C +/- 2°C: Yes ☒ No ☐
Received on Ice: Yes ☒ No ☐
Number of Bottles Received: 1
pH Checked: Not
COC Seals Intact: Yes ☒ No ☐ (NA) ☐

Section F Relinquish/Receive	Sign	Print	Date	Time
Relinquished By		Mark M. DeL	5/14/25	7:44
Received By		SETH SMITH	5/14/25	7:45
Relinquished By		SETH SMITH	5/14/25	7:45
Received By				
Relinquished By		Tessa	5/14/25	9:51
Received By Laboratory				