



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

July 22, 2025

Andy Chasteen
Medford School District
900 Kenyon St
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: North High Lead Testing-AMENDED

Order No.: 25051004

Dear Andy Chasteen:

Neilson Research Corporation received 31 sample(s) on 5/21/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25051004
Date: 7/22/2025

CLIENT: Medford School District

Project: North High Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-01 **Client Sample ID:** Outside H-9 Womens RR Sink
Collection Date: 5/21/2025 6:38:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Outside H-9 Womens RR Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.536		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-02 **Client Sample ID:** Outside H-4 Mens RR Sink
Collection Date: 5/21/2025 6:39:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Outside H-4 Mens RR Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-03 **Client Sample ID:** Across H-38 Mens RR L N Sink 1
Collection Date: 5/21/2025 6:30:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Mens RR L N Sink 1

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004
Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-04 Client Sample ID: Across H-38 Mens RR Sink 2
Collection Date: 5/21/2025 6:30:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Across H-38 Mens RR Sink 2

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-05 Client Sample ID: Across H-38 Mens RR Sink 3
Collection Date: 5/21/2025 6:30:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Across H-38 Mens RR Sink 3

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-06 Client Sample ID: Across H-38 Mens RR R N Sink 4
Collection Date: 5/21/2025 6:30:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Across H-38 Mens RR R N Sink 4

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-07 **Client Sample ID:** Across H-38 Mens RR L S Sink 5
Collection Date: 5/21/2025 6:30:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Mens RR L S Sink 5

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-08 **Client Sample ID:** Across H-38 Mens RR Sink 6
Collection Date: 5/21/2025 6:30:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Mens RR Sink 6

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-09 **Client Sample ID:** Across H-38 Mens RR Sink 7
Collection Date: 5/21/2025 6:30:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Mens RR Sink 7

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-10 **Client Sample ID:** Across H-38 Mens RR R S Sink 8
Collection Date: 5/21/2025 6:30:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Mens RR R S Sink 8

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-11 **Client Sample ID:** Across H-38 Womens RR R W Sink 1
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR R W Sink 1

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.640		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-12 **Client Sample ID:** Across H-38 Womens RR Sink 2
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR Sink 2

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-13 **Client Sample ID:** Across H-38 Womens RR Sink 3
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR Sink 3

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-14 **Client Sample ID:** Across H-38 Womens RR L W Sink 4
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR L W Sink 4

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.86		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-15 **Client Sample ID:** Across H-38 Womens RR R E Sink 5
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR R E Sink 5

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.560		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-16 **Client Sample ID:** Across H-38 Womens RR Sink 6
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR Sink 6

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-17 **Client Sample ID:** Across H-38 Womens RR Sink 7
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR Sink 7

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-18 **Client Sample ID:** Across H-38 Womens RR L E Sink 8
Collection Date: 5/21/2025 6:35:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Across H-38 Womens RR L E Sink 8

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.639		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004
Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-19 Client Sample ID: Commons Mens RR Sink L
Collection Date: 5/21/2025 6:40:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Commons Mens RR Sink L

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.50		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-20 Client Sample ID: Commons Mens RR Sink C
Collection Date: 5/21/2025 6:40:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Commons Mens RR Sink C

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-21 Client Sample ID: Commons Mens RR Sink R
Collection Date: 5/21/2025 6:40:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Commons Mens RR Sink R

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-22 Client Sample ID: Commons Womens RR Sink L
Collection Date: 5/21/2025 6:42:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Commons Womens RR Sink L

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-23 Client Sample ID: Commons Womens RR Sink C
Collection Date: 5/21/2025 6:42:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Commons Womens RR Sink C

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.776		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-24 Client Sample ID: Commons Womens RR Sink R
Collection Date: 5/21/2025 6:42:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Commons Womens RR Sink R

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004
Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-25 Client Sample ID: Media Center Staff Unisex RR Sink
Collection Date: 5/21/2025 6:44:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: Media Center Staff Unisex RR Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.610		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-26 Client Sample ID: BB Field Mens RR Sink
Collection Date: 5/21/2025 7:02:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: BB Field Mens RR Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.44		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-27 Client Sample ID: BB Field Womens RR Sink
Collection Date: 5/21/2025 7:02:00 AM Collected By: Michael
Matrix: Drinking Water Sample Location: BB Field Womens RR Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.36		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004

Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID: 25051004-28 **Client Sample ID:** Near Track Mens RR SE Sink
Collection Date: 5/21/2025 6:55:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Near Track Mens RR SE Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.18		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-29 **Client Sample ID:** Near Track Mens RR NE Sink
Collection Date: 5/21/2025 6:55:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Near Track Mens RR NE Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.96		0.515	ppb	1	6/16/2025	15.0	A

Lab ID: 25051004-30 **Client Sample ID:** Near Track Unisex RR SW Sink
Collection Date: 5/21/2025 6:58:00 AM **Collected By:** Michael
Matrix: Drinking Water **Sample Location:** Near Track Unisex RR SW Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.54		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25051004
Date Reported: 7/22/2025

Medford School District
900 Kenyon St
Medford, OR 97501

Lab Order: 25051004
Received Date: 5/21/2025 9:31:00 AM
Reported Date: 7/22/2025 8:04:45 AM

Sample Information:

Lab ID:	25051004-31	Client Sample ID:	Near Track Unisex RR NW Sink
Collection Date:	5/21/2025 6:58:00 AM	Collected By:	Michael
Matrix:	Drinking Water	Sample Location:	Near Track Unisex RR NW Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.38		0.515	ppb	1	6/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25051004
22-Jul-25

Client: Medford School District
Project: North High Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31728	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: PBW	Batch ID: 31728	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988389
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31728	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: LCSW	Batch ID: 31728	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988390
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 104 0.520 100 0 104 85 115

Sample ID: 25050996-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: BatchQC	Batch ID: 31728	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988392
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 120 0.520 100 18.0 102 70 130

Sample ID: 25050996-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: BatchQC	Batch ID: 31728	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988393
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 120 0.520 100 18.0 102 70 130 120 0.0745 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25051004
22-Jul-25

Client: Medford School District
Project: North High Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31729	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: PBW	Batch ID: 31729	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988418
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31729	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: LCSW	Batch ID: 31729	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988419
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.520 100 0 103 85 115

Sample ID: 25051004-02AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: Outside H-4 Mens R	Batch ID: 31729	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988421
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 104 0.520 100 0.450 104 70 130

Sample ID: 25051004-02AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: Outside H-4 Mens R	Batch ID: 31729	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988422
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 104 0.520 100 0.450 104 70 130 104 0.0836 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25051004
22-Jul-25

Client: Medford School District
Project: North High Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31735	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: PBW	Batch ID: 31735	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988447
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31735	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: LCSW	Batch ID: 31735	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988448
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 100 0.520 100 0 100 85 115

Sample ID: 25051004-22AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: Commons Womens	Batch ID: 31735	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988450
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 100 0.520 100 0.366 99.6 70 130

Sample ID: 25051004-22AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/16/2025	RunNo: 60304
Client ID: Commons Womens	Batch ID: 31735	TestNo: E200.8	E200.8	Analysis Date: 6/16/2025	SeqNo: 988451
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.1 0.520 100 0.366 97.8 70 130 100 1.89 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1

Sample Log-In Check List

Client Name: MedfordSchoolDist

Work Order Number: 25051004

RcptNo: 1

Logged by: Johanna Owen 5/21/2025 9:31:00 AM

Completed By: Coni Boyko 5/23/2025 11:58:10 AM

Reviewed By: Ashley Spiegelberg 6/17/2025 2:28:37 PM

[Signature]
Coni Boyko
[Signature]

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

Page 1 of 3

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information				Section B Required Project Information				Section C Invoice Information				Section D Rush Status (Subject to Scheduling)			
Company: MSD 549C				Project Name: North High				Attention: Accounting				☐ Standard 10-14 Days ☐ 5 Business Days (50% surcharge) ☐ 3 Business Days (75% surcharge) ☐ 24 - 48 hours (100% surcharge) ☐ Other _____ Authorized ☐ Yes ☐ No			
Address: 900 Kenyon				Project Number:				Company Name: Medford School District							
Medford, OR 97501				Report To: <u>andy.chasteen@medford.k12.or.us</u>				Address: 900 Kenyon							
Email: <u>andy.chasteen@medford.k12.or.us</u>				Copy To: <u>seth.barry@medford.k12.or.us</u>				Medford, OR 97501							
Phone: 541-840-4315 Fax:								P.O. #							
Collected By (Print): <u>Michael Savin</u>															
Collected By (Sign): <u>[Signature]</u>															
Email Report ☐ Yes ☐ No Mail Report ☐ Yes ☐ No															
Fax Report ☐ Yes ☐ No															

Section E Sample Information				Analysis Requested												NRC Workorder # <u>25051004</u> (Lab Use Only)		
Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers													Remarks/Field Data	NRC Sample # (Lab Use Only)
Outside H-9 Women's Restroom - Sink	DW	5-24-23	6:38	1														01
Outside H-4 Men's Restroom - Sink	DW		6:39	1														02
Across From H-38 Men's Restroom - Left North Sink (1)	DW		6:30	1														03
Across From H-38 Men's Restroom - Sink (2)	DW		6:30	1														04
Across From H-38 Men's Restroom - Sink (3)	DW		6:30	1														05
Across From H-38 Men's Restroom - Right North Sink (4)	DW		6:30	1														06
Across From H-38 Men's Restroom - Left South Sink (5)	DW			1														07
Across From H-38 Men's Restroom - Sink (6)	DW			1														08
Across From H-38 Men's Restroom - Sink (7)	DW			1														09
Across From H-38 Men's Restroom - Right South Sink (8)	DW			1														10
Across From H-38 Women's Restroom - Right West Sink (1)	DW		6:35	1														11
Across From H-38 Women's Restroom - Sink (2)	DW			1														12
Across From H-38 Women's Restroom - Sink (3)	DW			1														13
Across From H-38 Women's Restroom - Left West Sink (4)	DW			1														14
Across From H-38 Women's Restroom - Right East Sink (5)	DW			1														15
Across From H-38 Women's Restroom - Sink (6)	DW			1														16
Across From H-38 Women's Restroom - Sink (7)	DW			1														17
Across From H-38 Women's Restroom - Left East Sink (8)	DW			1														18
	DW			1														
Common's Men's Restroom - Sink (Left)	DW		6:40	1														19
Common's Men's Restroom - Sink (Center)	DW		6:40	1														20
Common's Men's Restroom - Sink (Right)	DW		6:40	1														21
Common's Women's Restroom - Sink (Left)	DW		6:42	1														22
Common's Women's Restroom - Sink (Center)	DW		6:42	1														23

