

Sample Location	Fixture Type	App or N/A	Initial 1 <sup>st</sup> Draw Results (ppb)	Initial 1st Draw Sampling Date	Status
<b>Deasy Elementary School</b>					
No exceedances					
<b>Connelly Elementary School</b>					
Kitchen Potfiller	PF	App	10.0	4/25/2025	Remediation Complete-fixture replacement and filter
Faculty Room	SK	App	13.0	4/24/2025	Remediation Complete-permanent sign posted
<b>Gribbin Elementary School</b>					
Faculty Lounge	SK	App	9.0	4/25/2025	Remediation Complete-permanent sign posted
<b>Landing Elementary School</b>					
Faculty Room	SK	App	16.0	4/24/2025	Remediation Complete-permanent sign posted
Faculty Room	SPY	App	8.0	4/24/2025	Remediation Complete-permanent sign posted
<b>RM Finley Middle School</b>					
Kitchen-Left Prep by Oven	SK	App	14.0	4/23/2025	Remediation Complete-fixture replacement and filter
Kitchen-Right Prep by Freezer	SK	App	18.0	4/23/2025	Remediation Complete-fixture replacement and filter
Kitchen-Potfiller-Left	PF	App	8.0	4/23/2025	Remediation Complete-fixture replacement and filter
Kitchen-Potfiller-Right	PF	App	10.0	4/23/2025	Remediation Complete-fixture replacement and filter
Kitchen-Potfiller on Stove	PF	App	10.0	5/1/2025	Remediation Complete-fixture replacement and filter
<b>Glen Cove High School</b>					
Kitchen 2-Bay-Food Prep	SK	App	233.0	4/23/2025	Removed From Services; Pending Remediation
Kitchen Island-Food Prep	SK	App	27.0	4/23/2025	Removed From Services; Pending Remediation
Kitchen Potfiller Right	PF/SPY	App	10.0	4/23/2025	Removed From Services; Pending Remediation
Kitchen Steamer	SPY	App	74.0	4/23/2025	Remediation Complete-flushed
Kitchen Coffee Maker Supply Line	OS	App	18.0	4/23/2025	Remediation Complete-flushed and filter replaced
Nurse's Office 100A	SK	App	107.0	4/23/2025	Signed non-potable
Faculty Room 213A	SK	App	10.0	4/23/2025	Signed non-potable
Library Office	SK	App	9.0	4/23/2025	Signed non-potable
Thayer House-Kitchen	SK	App	8.0	4/23/2025	Remediation Complete-fixture replacement and filter
<b>Key</b>					
WF-Water Fountain					
BF-Bottle Filler					
SK-Sink					
PF-Pot Filler					
SP-Spigot					
App-currently considered an applicable/potable source					