

## Lead in Drinking Water Report



Date of Sample						5/19/2023	6/18/2024	7/19/2024	8/15/2024	Final Remediation
Sampled by						WSDOH	WSDOH	Terracon	Terracon	
Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)	Lead Test Result (ppb)			
373434	Main Building	Sink	Room 7	Only sink	Water Fountain	39	168	20	64	Fountain removed
373422	Main Building	Sink	Room 1	Only sink	Water Fountain	24	12	12		Fountain turned off- handwashing only
373433	Main Building	Sink	Room 7	Only sink	Tap	22	4853	12	45	Tap removed
373431	Main Building	Sink	Room 6	Only sink	Tap	14	5	<1		
373437	Main Building	Sink	Room 9	Only sink	Tap	14	57	1		
373429	Main Building	Sink	Room 5	Only sink	Tap	13	7	<1		
373421	Main Building	Sink	Room 1	Only sink	Tap	11	4375	<1		
373447	Main Building	Sink	Room 13	Only sink	Tap	11	1			
			Bathrooms outside							
373836	Main Building	Sink	gym	right when entering	Tap	11				
373424	Main Building	Sink	Room 2	Only sink	Water Fountain	10	33	4.1		
373435	Main Building	Sink	Room 8	Only sink	Tap	10	4			
373420	Main Building	Fountain-multi level	lower commons	lower fountain	Water Fountain	9	11	8.6	2	Water bottle filling station added. Testing complete on 8/15/24
373427	Main Building	Sink	Room 4	Only sink	Tap	9	13	<1		
373449	Main Building	Sink	Room 14	Only sink	Tap	9	2			
373457	Main Building	Sink	Room 18	Only sink	Tap	9	1			
373821	Main Building	Sink	Room 20	Only sink	Tap	9	<1			
373423	Main Building	Sink	Room 2	Only sink	Tap	8	8	2.5		
373823	Main Building	Sink	Room 21	Only sink	Tap	8	2			
			Bathroom outside	outlet closet to custodian						
373831	Main Building	Sink	gym	closet	Tap	8				Handwashing only
373439	Main Building	Sink	Room 10	Only sink	Tap	7	3			
			Upper commons							
373825	Main Building	Sink	works room/kitchen	Only sink	Tap	7	4			
			Bathroom outside							
373832	Main Building	Sink	gym	closest to custodian closet	Tap	7				
373441	Main Building	Sink	Room 11	Only sink	Tap	6	1			
373451	Main Building	Sink	Room 15	Only sink	Tap	6	1			
373453	Main Building	Sink	Room 16	Only sink	Tap	6	1			
373455	Main Building	Sink	Room 17	Only sink	Tap	6	1			
373826	Main Building	Sink	Office	Only sink	Tap	6	<1			
			porcelain sink next to							
373845	Annex	Sink	Kitchen	bathroom	Tap	6				Handwashing only
373432	Main Building	Sink	Room 6	Only sink	Water Fountain	6				Handwashing only
373438	Main Building	Sink	Room 9	Only sink	Water Fountain	5				
373445	Main Building	Sink	Room 12	Only sink	Tap	5				
373459	Main Building	Sink	Room 19	Only sink	Tap	5				
373827	Main Building	Sink	Library Office	Only sink	Tap	5				
			Bathrooms outside							
373833	Main Building	Sink	gym	closest to custodian closet	Tap	5				
373425	Main Building	Sink	Room 3	Only sink	Tap	4				
373428	Main Building	Sink	Room 4	Only sink	Water Fountain	4				
373436	Main Building	Sink	Room 8	Only sink	Water Fountain	4				
			Bathrooms outside							
373834	Main Building	Sink	gym	On right side when entering	Tap	4				
			Bathrooms outside							
373835	Main Building	Sink	gym	to the right when entering	Tap	4				
373837	Main Building	Sink	Kitchen	Left of dishwasher	Sprayer	4				
373426	Main Building	Sink	Room 3	Only sink	Water Fountain	3				

373430	Main Building	Sink	Room 5	Only sink	Water Fountain	3
373442	Main Building	Sink	Room 11	Only sink	Water Fountain	3
373838	Main Building	Sink	Kitchen	left of ovens	Tap	3
373848	Main Building	Sink	Office Kitchen	Only sink	Tap	3
373829	Main Building	Sink	Staff Lounge	Only sink	Tap	2
373843	Annex	Sink	Head Start	Sink with 2 outlets	Tap	1
373846	Annex	Sink-multicompartiment	Kitchen	only multicompartiment sink	Tap	1
373443	Main Building	Fountain-multi level	Upper commons fountain	Higher fountain	Water Fountain	<1
373444	Main Building	Fountain-multi level	Upper commons fountain	lower fountain	Water Fountain	<1
373446	Main Building	Sink	Room 12	Only sink	Water Fountain	<1
373448	Main Building	Sink	Room 13	Only sink	Water Fountain	<1
373450	Main Building	Sink	Room 14	Only sink	Water Fountain	<1
373452	Main Building	Sink	Room 15	Only sink	Water Fountain	<1
373454	Main Building	Sink	Room 16	Only sink	Water Fountain	<1
373456	Main Building	Sink	Room 17	Only sink	Water Fountain	<1
373458	Main Building	Sink	Room 18	Only sink	Water Fountain	<1
373820	Main Building	Sink	Room 19	Only sink	Water Fountain	<1
373822	Main Building	Sink	Room 20	Only sink	Water Fountain	<1
373824	Main Building	Sink	Room 21	Only sink	Water Fountain	<1
373828	Main Building	Fountain-multi level	near cafeteria and elevator	Higher fountain	Water Fountain	<1
373839	Annex	Fountain-multi level w/bottle filler	Hallway	Only fountain	Water bottle filler	<1
373840	Annex	Fountain-multi level w/bottle filler	Hallway	Only fountain	water fountain	<1
373841	Annex	Sink	Lakeside	Only sink	Tap	<1
373842	Annex	Sink	Head Start	Individual sink	Tap	<1
373844	Annex	Sink	Head Start	Sink with 2 outlets	Tap	<1
373847	Annex	Sink	Kitchen	Right of dishwasher	Sprayer	<1