



Monomoy Air Quality Testing Report

Reason for Testing: Periodic precautionary air testing

Date: August 28, 2025

Description: Air sample mold tests in other district buildings

Locations: HES Library Media Center, HES Room 12, MRHS Room A183, MRHS Room A233, CES Cafeteria, CES Room 242

Conducted By: Target Inspections

Summary of Findings: Samples in Monomoy's other schools ranged from undetectable-3418 spores per cubic meter. Outdoor air quality tests in Chatham outside of the district's middle school ranged from 2734-6420 on that date

District Response: No remediation required. According to the testing company: "Remediation is only recommended when indoor air quality samples have individual spore counts both above external ambient levels and above the recommended action level of 1000 spores per cubic meter of air. If these criteria have not been met, then No Remediation is required." When the testing was conducted, there were very high levels of mold spores in the ambient environment outside of the building. None of the indoor samples taken at CES, HES, and the High School (nor at the Middle School) had mold spore concentrations higher than the average ambient outside level of 4,510 spores per cubic meter.



September 9, 2025

Client Name and Address:

Target Inspections
P.O. Box 444
West Dennis, MA 02670

Re: Microbial Analytical Results from: Monomoy Schools; Various Town Buildings; Harwich and Chatham, MA

H2O Laboratory Number: 05155

Dear Target Inspections,

We at H2O EnviroComp would like to thank you for your recent business. Samples were received on 9/29/2025 from a job located at Monomoy Schools; Various Town Buildings; Harwich and Chatham, MA. The final report is enclosed for the following samples: 1-6.

Please note that environmental conditions should be taken into account when interpreting the associated data and sampling at any other time period may produce differing results. H2O EnviroComp follows prescribed procedures for the analysis of air cassettes and direct samples to identify and quantify particulate and microbiological contamination. These results only pertain to this job and should not be used in the interpretation of any other job. This report may be reproduced only in its entirety. H2O EnviroComp is an AIHA Proficient Laboratory (AIHA Lab ID: 290178).

If you have any questions please do not hesitate to call me at the number below.

Regards,

A handwritten signature in dark ink, appearing to read 'Steven Grevelis'.

Steven Grevelis
Laboratory Director

Enclosures:

- Analytical results
- Chain of Custody
- Fungal glossary

Background Density Effects on Spore Concentrations:

Level 1: No bias.

Level 2: May be biased to the low side.

Level 3: Most likely biased to the low side.

Level 4: High likelihood the results are biased to the low side.

Level 5: Complete coverage. Sample is not able to be analyzed.



H2O EnviroComp
Indoor Air Quality Report
Air Sample Report

24 School Street
P.O. Box 444
West Dennis, MA 02670
Phone 508.737.4289

Company: Target Inspections **Inspector:** Steven Grevelis, NG, & NF **Date Sampled:** 8/28/2025

Contact: Steven Grevelis **Project Name:** Harwich Elementary School, 263 South Street, Harwich, MA **Date Received:** 9/29/2025

Address: P.O. Box 444 **Project Notes:** Client Project Number: 791M **Date Analyzed:** 9/9/2025

City, ST, Zip: West Dennis, MA 02670 **Lab No:** 05155 **Date Reported:** 9/9/2025

Phone: (888) - 280- 2108 **Report Status:** Version 1.0

Mold Identification by Samples

Sample Number: 05155-01 **Sample Medium:** Allergenco-D
Client Sample ID: 6646847 **Sampling Rate:** 15L/Min for 5 Minutes
Magnification: 600 X **Total Liters:** 75
Location: Harwich Elementary School Media Center/Library

Sample Data:

Type:	Raw Count	Count/ Cubic Meter	Type:	Raw Count	Count/ Cubic Meter
Ascospores, Non-specified	3	89	Smuts	ND	ND
Basidiospores, Non-specified	2	59	Rusts	ND	ND
Aspergillus/Penicillium-Like	ND	ND	Spegazzinia	ND	ND
Cladosporium	1	30	Stachybotrys	ND	ND
Chaetomium	ND	ND	Ulocladium	ND	ND
Ganoderma	ND	ND	Coprinus	ND	ND
Pithomyces	ND	ND	Un-ID Spore	ND	ND
Alternaria	ND	ND	Pollen	ND	ND
Cercospora-like	ND	ND	Hyphal Frags	1	30
Curvularia	ND	ND	Insect Frags	ND	ND
Epicoccum	ND	ND			
Memnoniella	ND	ND			

Sample Data Comments:

Skin Fragment Prevalence; 1 (Low) to 4 (High):	2	
Background Density; 1 (Low) to 5 (Overloaded):	1	
Total Fungal Raw Count:	6	
Analytical Sensitivity (Spore/Cubic Meter):	30	
Number of Traverses:	17	
Total Fungal Count (Spore/Cubic Meter):	178	

Reporting Notes: N/A = Not Applicable
ND = None Detected
* = Type detected observed in clumps

Analyzed by: Steven Grevelis
Analyzed Date: 9/9/2025



H2O EnviroComp
Indoor Air Quality Report
Air Sample Report

24 School Street
P.O. Box 444
West Dennis, MA 02670
Phone 508.737.4289

Company: Target Inspections **Inspector:** Steven Grevelis, NG, & NF **Date Sampled:** 8/28/2025

Contact: Steven Grevelis **Project Name:** Harwich Elementary School, 263 South Street, Harwich, MA **Date Received:** 9/29/2025

Address: P.O. Box 444 **Project Notes:** Client Project Number: 791M **Date Analyzed:** 9/9/2025

City, ST, Zip: West Dennis, MA 02670 **Lab No:** 05155 **Date Reported:** 9/9/2025

Phone: (888) - 280- 2108 **Report Status:** Version 1.0

Mold Identification by Samples

Sample Number: 05155-02 **Sample Medium:** Allergenco-D
Client Sample ID: 6625224 **Sampling Rate:** 15L/Min for 5 Minutes
Magnification: 600 X **Total Liters:** 75
Location: Harwich Elementary School Room 12 - Windows Open

Sample Data:

Type:	Raw Count	Count/ Cubic Meter	Type:	Raw Count	Count/ Cubic Meter
Ascospores, Non-specified	15	446	Smuts	1	30
Basidiospores, Non-specified	32	951	Rusts	ND	ND
Aspergillus/Penicillium-Like	5	149	Spegazzinia	ND	ND
Cladosporium	19	565	Stachybotrys	ND	ND
Chaetomium	ND	ND	Ulocladium	ND	ND
Ganoderma	5	149	Nigrospora	ND	ND
Pithomyces	1	30	Un-ID Spore	ND	ND
Alternaria	ND	ND	Pollen	ND	ND
Cercospora-like	ND	ND	Hyphal Frags	ND	ND
Curvularia	ND	ND	Insect Frags	ND	ND
Epicoccum	ND	ND			
Oidium	ND	ND			

Sample Data Comments:

Skin Fragment Prevalence; 1 (Low) to 4 (High):	1
Background Density; 1 (Low) to 5 (Overloaded):	1
Total Fungal Raw Count:	78
Analytical Sensitivity (Spore/Cubic Meter):	30
Number of Traverses:	17
Total Fungal Count (Spore/Cubic Meter):	2318

Reporting Notes: N/A = Not Applicable
ND = None Detected
* = Type detected observed in clumps

Analyzed by: Steven Grevelis
Analyzed Date: 9/9/2025



H2O EnviroComp
Indoor Air Quality Report
Air Sample Report

24 School Street
P.O. Box 444
West Dennis, MA 02670
Phone 508.737.4289

Company: Target Inspections **Inspector:** Steven Grevelis, NG, & NF **Date Sampled:** 8/28/2025

Contact: Steven Grevelis **Project Name:** Monomoy High School, 75 Oak Street, Harwich, MA **Date Received:** 9/29/2025

Address: P.O. Box 444 **Project Notes:** Client Project Number: 791M **Date Analyzed:** 9/9/2025

City, ST, Zip: West Dennis, MA 02670 **Lab No:** 05155 **Date Reported:** 9/9/2025

Phone: (888) - 280- 2108 **Report Status:** Version 1.0

Mold Identification by Samples

Sample Number: 05155-03 **Sample Medium:** Allergenco-D
Client Sample ID: 6646823 **Sampling Rate:** 15L/Min for 5 Minutes
Magnification: 600 X **Total Liters:** 75
Location: Monomoy High School A183 Media Center

Sample Data:

Type:	Raw Count	Count/ Cubic Meter	Type:	Raw Count	Count/ Cubic Meter
Ascospores, Non-specified	ND	ND	Smuts	ND	ND
Basidiospores, Non-specified	2	59	Rusts	ND	ND
Aspergillus/Penicillium-Like	ND	ND	Spegazzinia	ND	ND
Cladosporium	ND	ND	Stachybotrys	ND	ND
Chaetomium	ND	ND	Ulocladium	ND	ND
Ganoderma	ND	ND	Nigrospora	ND	ND
Pithomyces	ND	ND	Un-ID Spore	ND	ND
Alternaria	ND	ND	Pollen	ND	ND
Cercospora-like	ND	ND	Hyphal Frags	ND	ND
Curvularia	ND	ND	Insect Frags	ND	ND
Epicoccum	ND	ND			
Oidium	ND	ND			

Sample Data Comments:

Skin Fragment Prevalence; 1 (Low) to 4 (High):	1
Background Density; 1 (Low) to 5 (Overloaded):	1
Total Fungal Raw Count:	2
Analytical Sensitivity (Spore/Cubic Meter):	30
Number of Traverses:	17
Total Fungal Count (Spore/Cubic Meter):	59

Reporting Notes: N/A = Not Applicable
ND = None Detected
* = Type detected observed in clumps

Analyzed by: Steven Grevelis
Analyzed Date: 9/9/2025



H2O EnviroComp
Indoor Air Quality Report
Air Sample Report

24 School Street
P.O. Box 444
West Dennis, MA 02670
Phone 508.737.4289

Company: Target Inspections **Inspector:** Steven Grevelis, NG, & NF **Date Sampled:** 8/28/2025

Contact: Steven Grevelis **Project Name:** Monomoy High School, 75 Oak Street, Harwich, MA **Date Received:** 9/29/2025

Address: P.O. Box 444 **Project Notes:** Client Project Number: 791M **Date Analyzed:** 9/9/2025

City, ST, Zip: West Dennis, MA 02670 **Lab No:** 05155 **Date Reported:** 9/9/2025

Phone: (888) - 280- 2108 **Report Status:** Version 1.0

Mold Identification by Samples

Sample Number: 05155-04 **Sample Medium:** Allergenco-D
Client Sample ID: 6625292 **Sampling Rate:** 15L/Min for 5 Minutes
Magnification: 600 X **Total Liters:** 75
Location: Monomoy High School A233
- Windows Open

Sample Data:

Type:	Raw Count	Count/ Cubic Meter	Type:	Raw Count	Count/ Cubic Meter
Ascospores, Non-specified	26	773	Smuts	2	59
Basidiospores, Non-specified	31	921	Rusts	ND	ND
Aspergillus/Penicillium-Like	ND	ND	Spegazzinia	ND	ND
Cladosporium	46	1367	Stachybotrys	ND	ND
Chaetomium	ND	ND	Ulocladium	ND	ND
Ganoderma	5	149	Nigrospora	ND	ND
Pithomyces	4	119	Un-ID Spore	ND	ND
Alternaria	1	30	Pollen	ND	ND
Cercospora-like	ND	ND	Hyphal Frags	ND	ND
Curvularia	ND	ND	Insect Frags	ND	ND
Epicoccum	ND	ND			
Oidium	ND	ND			

Sample Data Comments:

Skin Fragment Prevalence; 1 (Low) to 4 (High):	1
Background Density; 1 (Low) to 5 (Overloaded):	2
Total Fungal Raw Count:	115
Analytical Sensitivity (Spore/Cubic Meter):	30
Number of Traverses:	17
Total Fungal Count (Spore/Cubic Meter):	3418

Reporting Notes: N/A = Not Applicable
ND = None Detected
* = Type detected observed in clumps

Analyzed by: Steven Grevelis
Analyzed Date: 9/9/2025



H2O EnviroComp
Indoor Air Quality Report
Air Sample Report

24 School Street
P.O. Box 444
West Dennis, MA 02670
Phone 508.737.4289

Company: Target Inspections **Inspector:** Steven Grevelis, NG, & NF **Date Sampled:** 8/28/2025

Contact: Steven Grevelis **Project Name:** Chatham Elementary School, 147 Depot Road, Chatham, MA **Date Received:** 9/29/2025

Address: P.O. Box 444 **Project Notes:** Client Project Number: 791M **Date Analyzed:** 9/9/2025

City, ST, Zip: West Dennis, MA 02670 **Lab No:** 05155 **Date Reported:** 9/9/2025

Phone: (888) - 280- 2108 **Report Status:** Version 1.0

Mold Identification by Samples

Sample Number: 05155-05
Client Sample ID: 6646895
Magnification: 600 X

Sample Medium: Allergenco-D
Sampling Rate: 15L/Min for 5 Minutes
Total Liters: 75
Location: Chatham Elementary School Cafeteria

Sample Data:

Type:	Raw Count	Count/ Cubic Meter	Type:	Raw Count	Count/ Cubic Meter
Ascospores, Non-specified	5	149	Smuts	ND	ND
Basidiospores, Non-specified	14	416	Rusts	ND	ND
Aspergillus/Penicillium-Like	9	267	Spegazzinia	ND	ND
Cladosporium	2	59	Stachybotrys	ND	ND
Chaetomium	ND	ND	Ulocladium	ND	ND
Ganoderma	1	30	Nigrospora	ND	ND
Pithomyces	2	59	Un-ID Spore	ND	ND
Alternaria	ND	ND	Pollen	ND	ND
Cercospora-like	ND	ND	Hyphal Frags	ND	ND
Curvularia	1	30	Insect Frags	ND	ND
Epicoccum	ND	ND			
Oidium	ND	ND			

Sample Data Comments:

Skin Fragment Prevalence; 1 (Low) to 4 (High):	1
Background Density; 1 (Low) to 5 (Overloaded):	2
Total Fungal Raw Count:	34
Analytical Sensitivity (Spore/Cubic Meter):	30
Number of Traverses:	17
Total Fungal Count (Spore/Cubic Meter):	1011

Reporting Notes: N/A = Not Applicable
ND = None Detected
* = Type detected observed in clumps

Analyzed by: Steven Grevelis
Analyzed Date: 9/9/2025



H2O EnviroComp
Indoor Air Quality Report
Air Sample Report

24 School Street
P.O. Box 444
West Dennis, MA 02670
Phone 508.737.4289

Company: Target Inspections **Inspector:** Steven Grevelis, NG, & NF **Date Sampled:** 8/28/2025

Contact: Steven Grevelis **Project Name:** Chatham Elementary School, 147 Depot Road, Chatham, MA **Date Received:** 9/29/2025

Address: P.O. Box 444 **Project Notes:** Client Project Number: 791M **Date Analyzed:** 9/9/2025

City, ST, Zip: West Dennis, MA 02670 **Lab No:** 05155 **Date Reported:** 9/9/2025

Phone: (888) - 280- 2108 **Report Status:** Version 1.0

Mold Identification by Samples

Sample Number: 05155-06 **Sample Medium:** Allergenco-D
Client Sample ID: 6646786 **Sampling Rate:** 15L/Min for 5 Minutes
Magnification: 600 X **Total Liters:** 75
Location: Chatham Elementary School
242 - Windows Open

Sample Data:

Type:	Raw Count	Count/ Cubic Meter	Type:	Raw Count	Count/ Cubic Meter
Ascospores, Non-specified	21	624	Smuts	3	89
Basidiospores, Non-specified	46	1367	Rusts	ND	ND
Aspergillus/Penicillium-Like	ND	ND	Spegazzinia	ND	ND
Cladosporium	36	1070	Stachybotrys	ND	ND
Chaetomium	ND	ND	Ulocladium	ND	ND
Ganoderma	7	208	Nigrospora	ND	ND
Pithomyces	2	59	Un-ID Spore	ND	ND
Alternaria	ND	ND	Pollen	ND	ND
Cercospora-like	ND	ND	Hyphal Frags	ND	ND
Curvularia	ND	ND	Insect Frags	ND	ND
Epicoccum	ND	ND			
Oidium	ND	ND			

Sample Data Comments:

Skin Fragment Prevalence; 1 (Low) to 4 (High):	1
Background Density; 1 (Low) to 5 (Overloaded):	2
Total Fungal Raw Count:	115
Analytical Sensitivity (Spore/Cubic Meter):	30
Number of Traverses:	17
Total Fungal Count (Spore/Cubic Meter):	3418

Reporting Notes: N/A = Not Applicable
ND = None Detected
* = Type detected observed in clumps

Analyzed by: Steven Grevelis
Analyzed Date: 9/9/2025



H2O EnviroComp
24 School Street
P.O. Box 444
West Dennis, MA 02670

Microbial Chain of Custody
Version 1.0
4/9/2012

Client: Target Inspections Phone: (888) - 280- 2108 Client Address: 24 School Street, P.O. Box 444, West Dennis, MA 02670									
Project Name: Monomoy Regional School District Project Number: 791M									
Proj. Address: Addresses on Page 2 of 2 Town: Chatham and Harwich State: MA Zip Code									
Sampled By: Steven Grevelis H2O Lab ID: 05155									
Date: 08/28/2025 Project Manager: Steven Grevelis Email Address(es) to Send Report to: Email 1: steve@targetinspections.com									
Turn Around Time: ☐ Rush ☐ 24 Hour ☐ 48 Hour ☒ 5 Day Email 2:									
SAMPLE ID	LOCATION	Sample Type (Air, Tape Lift, Bulk)	Volume Data			Sample Media (Air-O-Cell, Allergenco-D, etc)			
			Rate (l/min)	Time (min)	Volume				
6646847	Harwich Elementary School Media Center/Library	Air	15	5	75	Allergenco-D			
6625224	Harwich Elementary School Room 12 - Windows Open	Air	15	5	75	Allergenco-D			
6646823	Monomoy High School A183 Media Center	Air	15	5	75	Allergenco-D			
6625292	Monomoy High School A233 - Windows Open	Air	15	5	75	Allergenco-D			
6646895	Chatham Elementary School Cafeteria	Air	15	5	75	Allergenco-D			
6646786	Chatham Elementary School 242 - Windows Open	Air	15	5	75	Allergenco-D			
	Note - Client declined to collect outside control samples.								

Relinquished by: Steven Grevelis

Date/Time: 08/29/2025

Page 1 of 2

Received by: H2O EnviroComp

Date/Time: 08/29/2025



H2O EnviroComp
24 School Street
P.O. Box 444
West Dennis, MA 02670

Microbial Chain of Custody
Version 1.0
4/9/2012

Client: Target Inspections		Phone: (888) - 280- 2108		Client Address: 24 School Street, P.O. Box 444; West Dennis, MA 02670	
Project Name: Monomoy Regional School District		Project Number: 791M			
Proj. Address: Addresses of Sampling Locations are Listed Below		Town: Chatham and Harwich		State: MA Zip Code	
Sampled By: Steven Grevelis		Email Address(es) to Send Report to:		H2O Lab ID:	
Date: 08/28/2025		Project Manager: Steven Grevelis		05155	
Turn Around Time: ☐ Rush ☐ 24 Hour ☐ 48 Hour ☒ 5 Day		Email 1: steve@targetinspections.com			
Email 2:					
SAMPLE ID	LOCATION	Sample Type (Air, Tape Lift, Bulk)	Volume Data		Sample Media (Air-O-Cell, Allergenco-D, etc)
			Rate (l/min)	Time (min)	
	Locations of Sampled Areas from Page 1:				
	Harwich Elementary School, 263 South Street, Harwich, MA 02645				
	Monomoy High School, 75 Oak Street, Harwich, MA 02645				
	Chatham Elementary School, 147 Depot Road, Chatham, MA 02633				

Relinquished by: Steven Grevelis
Received by: H2O EnviroComp

Date/Time: 08/29/2025
Date/Time: 08/29/2025



H2O EnviroComp Fungal Glossary

Note: The following list is not inclusive of all molds and fungi.

Absidia: Found outdoors in soil and decaying vegetation. Found indoors in stored grains and other foods. Absidia is recognized as an allergen. In immunocompromised patients pulmonary invasions, the meninges (brain or spinal cord), and kidney infections can result from exposure.

Acromonium: Found outdoors in decaying or dead plant materials. Found indoors in food and wet, cellulose based building materials. Grows well indoors when there is a high water content (>0.90 Aw). Type I (hay fever, asthma) and Type III (hypersensitivity pneumonitis) allergen. Known to cause infections in immunodeficient patients and persons with wound injuries. There are 100 known species.

Alternaria: Common saprobe and pathogen of plants. Typically found on plant tissue, decaying wood, and foods, soil and air outdoors. Indoors it is found near condensation (window frames, showers), house dust (in carpets, and air). It also colonizes building supplies, computer disks, cosmetics, leather, optical instruments, paper, sewage, stone monuments, textiles, wood pulp, and jet fuel. Type I allergies (hay fever, asthma) and Type III (hypersensitivity pneumonitis). Alternaria spores are one of the most common and potent indoor and outdoor airborne allergens. Additionally, Alternaria sensitization has been determined to be one of the most important factors in the onset of childhood asthma. Synergy with Cladosporium or Ulocladium may increase the severity of symptoms.

Arthrinium: Found outdoors in decaying plant material and soil. Found indoors on cellulose containing materials. *Arthrinium sphaerospermum* is recognized as an allergen.

Ascospores: Ascospores are found everywhere in nature. Ascospores are the result of sexual reproduction and produced in a saclike structure called an ascus. All ascospores belong to members of the Phylum Ascomycota, which encompasses a plethora of genera worldwide.

Aspergillus/Penicillium: These species are common contaminants on various substances. This organism causes food spoilage and is an indicated organism for dampness indoors. Some of these species are known to produce mycotoxins. If health effects are noticed by occupants or workers, in an environment that evidences an amplification of Penicillium, identification of species is helpful. These especially opportunistic pathogens may cause respiratory infections. Some varieties produce mycotoxins and aflatoxins.

Basidiospores: Found outdoors in gardens forests and woodlands. Plant pathogen. Indoors it is the agent of “dry rot” and other fungi causing white and brown wood rot. Grow and destroy the structural wood of buildings. *Poria incrassata* causes a particularly destructive dry rot in buildings. A probably common allergen. Type I allergies (hay fever, asthma).

Bipolaris: Found outdoors in plant debris and soil. Found indoors on houseplants and indoor building materials. Type I allergies (hay fever, asthma). Most commonly reported cause of allergic and chronic invasive sinusitis.

Botrytis: Plant pathogen responsible for causing gray mold (*B. cinerea*) on grapes, strawberries, raspberries, blackberries, low bush blueberries, lettuce, cabbage and onion. Indoors it is found on houseplants fruits and vegetables. Type I (hay fever, asthma) and type III (hypersensitivity) allergies.



H2O EnviroComp Fungal Glossary

Candida: Found in leaves, flowers, soil, water and is an inhabitant of the skin, mouth and vagina. It is unknown what suitable substrates are in the indoor environment. Has been reported as an allergen. Occurs in patients taking drugs such as oral contraceptives and antibiotics.

Cercospora: Found outdoors on plants. It is a plant parasite causing leaf spot. It is unknown what substrates it prefers indoors. Thrives in moderate to high humidity its allergenic potential is unknown.

Chaetomium: Found outdoors in soil, seeds, dung, woody and straw materials. Indoors found on damp sheet rock paper. Type I allergies (hay fever, asthma).

Coprinus: Found outdoors in wood, dung, litter and soil. Industrial uses: Popular experimental organism in genetic research

Cladosporium: Found outdoors in soil of many different types. Indoors it is found on many substrates including textiles, wood, and moist windowsills. Cladosporium grows at 0degrees C, and so is associated with refrigerated foods. It is a common and important allergen. Type I allergies (hay fever, asthma).

Cladophialophora (form of Cladosporium): Phialophora: Found outdoors in wood roots, stems and leaves of plants and grasses, and soil. It is a water loving fungus. Allergenicity has not been studied.

Coprinus: Found outdoors in wood, dung, litter and soil. Industrial uses: Popular experimental organism in genetic research

Curvularia: found outdoors in plant saprobe and pathogen to cereal plants and soil. Found indoors in paper and wood products. Type I allergies (asthma and hay fever) A relatively common cause of allergic fungal sinusitis.

Dactylaria: Found outdoors in decaying soil and leaves. Dactylaria species comprise a very small proportion of the fungal biota. There have been several reports of opportunistic infections caused by these genera but a true pathogenic role has not been firmly established. No information is available regarding upper respiratory health effects, or toxicity. Allergenicity has not been studied.

Epicoccum: Found outdoors in plant debris and soil. Found indoors in paper and textiles. Type I allergies (asthma and hay fever).

Fusarium: Found outdoors in soil. Occasionally found on a variety of substrates. Fusarium requires very wet conditions. Aw=0.86-0.91 (minimum for various species). . Type I allergies (asthma and hay fever).

Ganoderma: Found outdoors on conifers and hardwoods worldwide, causing white rot, root rot, and stem rot. Ganoderma species are known to cause allergies in people on a worldwide scale.

Memnoniella: Found outdoors in plant litter soil and many types of plants and trees. Found indoors on a variety of substrates (cellulolytic). Allergens are unknown. Very closely related to Stachybotrys.

Myxomycetes: Found outdoors in decaying logs and stumps, particularly in forested areas. Only found occasionally indoors. Type I allergies (hay fever, asthma)



H2O EnviroComp Fungal Glossary

Nigrospora: Found outdoors in decaying plants and soil. Rarely found indoors. Type I allergies (asthma and hay fever).

Pithomyces: Found outdoors in bark, leaf litter and soils. Indoors it is found in paper and requires high levels of moisture for spore germination. Its allergenic potential is unknown.

Rust: Rusts are parasitic to many types of plants. Rust fungi require a living plant host for growth. Type I allergens (hay fever, asthma). There are 5000 known species of rusts belonging to at least 150 different genera. Rusts are the cause of great economic losses on many cultivated plants.

Scopulariopsis (Hyphomycetes) Teleomorph: *Microascus* (Ascomycetes) Mainly soil-borne, but also frequently isolated from wood, grain, fruit, paper, and food such as meat and dairy products. Also isolated from indoor environments. ***Most species can liberate arsenic gaseous compounds that can lead to arsenic poisoning. Has recently been associated with invasive human infections.***

Spegazzinia: Found outdoors in plants and soil. It is unknown what substrates it is found on indoors. Allergenic properties are unknown.

Stachybotrys: Stachybotrys grows on wet materials that contain cellulose and low nitrogen content. Usually but not limited to building materials such as wallboard paper (unfinished drywall) that has a high water activity over a long period of time. It produces several types of toxic metabolites and mycotoxins that can irritate skin and mucous membranes. One of the mycotoxins it produces called satratoxin is also toxic when inhaled. ***Extreme care should be taken when this organism is amplified indoors.*** Individuals with chronic exposure to the toxin produced by this fungus reported cold and flu symptoms, sore throat, diarrhea, headaches, fatigue, dermatitis, intermittent local hair loss, and generalized malaise. The toxins produced by this fungus will suppress the immune system affecting the lymphoid tissue and the bone marrow.

Stemphylium: Found outdoors in soil, wood, decaying vegetation. Some species found on leaves are plant pathogens. Indoors growth is rare. Known allergen. Shares allergens with Alternaria. Type I allergies (hay fever, asthma).

Trichoderma: Found outdoors in soil, wood, decaying vegetation. Some species found on leaves are plant pathogens. Indoors growth on paper, textiles, and wet wood. Known allergen. Type I allergies (hay fever, asthma), Type III allergies (hypersensitivity), and has occasionally been associated with disease in immunocompromised individuals.

Torula: Found outdoors in leaves, plant roots, plant litter, soil and wood. Indoors it is found in paper, wicker furniture and wood. Type I allergies (hay fever, asthma).

Ulocladium: Found outdoors in soil, dung, paint, grasses, fibers, wood, decaying plant material, paper and textiles. Indoors it is found in gypsum board, paper, paint, tapestries, jute and other straw materials. Ulocladium has a high water requirement. As an allergen it is major with type I allergies (hay fever, asthma) and it cross reacts with Alternaria, adding to the burden of Alternaria-sensitive patients.

Wallemia: Found outdoors in hay and soil. Found indoors in jams, salted fish, mattresses, textiles and wood in crawl spaces. It is a Type I (hay fever and asthma) allergen.

Zygomycetes: Found outdoors in decaying plant and animal matter. Found indoors in fruits and vegetables. It is a Type I (hay fever, asthma) and Type III (hypersensitivity) allergen. Many zygomycetes are extremely fast growing and can inhibit other fungi when competing for food and space.