
February 6, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Support Services
9501 N Seymour Ave, Kansas City, MO 64153
Project Number: 923386

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Support Services in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

METHODOLOGY

On 1/15/2024 Mr. Justin Arnold of OCCU-TEC completed testing of twenty-four (24) sources throughout Support Services. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, two (2) of the twenty-four (24) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
386-SS-15	Room A 116	Sink	7.94
386-SS-16	Room A 116	Hot Water Dispenser	6.6

LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations



Jeff Smith
Senior Project Manager (QA/QC)

ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-01	Location:	Room A 107	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink Left Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-02	Location:	Room A 107	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink Right Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-03	Location:	Room A 106	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink Left Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-04	Location:	Room A 106	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink Right Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-05	Location:	Room A 111	
Photo:		Manufacturer:	Bunn	
		Description:		
		Coffee Maker Hot Water Spout		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-06	Location:	Room A 111	
Photo:		Manufacturer:		
		Description:		
		Kitchen Sink SSC-SINK-001		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-07	Location:	Room A 111	
Photo:		Manufacturer:	Hoshizaki	
		Description:		
		Ice Maker		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-08	Location:	RR Hall Near A113	
Photo:		Manufacturer:	Halsey taylor	
		Description:		
		Drinking Fountain Bubbler Left		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-09	Location:	RR Hall Near A113	
Photo:		Manufacturer:	Halsey taylor	
		Description:		
		Drinking Fountain Bottle Filler Left		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-10	Location:	RR Hall Near A113	
Photo:		Manufacturer:	Halsey taylor	
		Description:		
		Drinking Fountain Bubbler Right		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-11	Location:	Left Restroom Near A 113	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-12	Location:	Right Restroom Near A113	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-13	Location:	Room A 116	
Photo:		Manufacturer:	T&S Brass Co.	
		Description:		
		Kitchen Sink Left Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-14	Location:	Room A 116	
Photo:		Manufacturer:	T&S Brass Co.	
		Description:		
		Kitchen Sink Right Side		
		Result:	2.36	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-15	Location:	Room A 116	
Photo:		Manufacturer:	T&S Brass Co.	
		Description:		
		Handwashing Sink in middle		
		Result:	7.94	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:		Replace Fixture/Unit and Resample		

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-16	Location:	Room A 116	
Photo:		Manufacturer:	Bunn	
		Description:		
		Hot Water Dispenser		
		Result:	6.6	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:		Replace Fixture/Unit and Resample		

ID:	386-SS-17	Location:	Room A 116	
Photo:		Manufacturer:	Bunn	
		Description:		
		Coffee Maker		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-18	Location:	C100 Back Wall	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bubbler left Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-19	Location:	C100 Back Wall	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bubbler Right Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-20	Location:	C100 Back Wall	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bottle Filler Right Side		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-21	Location:	C100 Restroom Left	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

Drinking Water Assessment
Support Services
Park Hill School District

ID:	386-SS-22	Location:	C100 Restroom Right	
Photo:		Manufacturer:	Delta	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-23	Location:	Paint Shop C115	
Photo:		Manufacturer:	Elkay	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				

ID:	386-SS-24	Location:	C116	
Photo:		Manufacturer:	Elkay	
		Description:		
		Handwashing Sink		
		Result:	1.27	ppb
		Date Sampled:	1/15/2024	By: JEA
Recommended Action:				



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

February 02, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 923386 SUPPORT SERVICES

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **24** sample(s) the laboratory received on **1/18/24 10:45 am** and logged in under work order **HA02726**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order HA02726

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HA02726-01
Name: 386-SS-01
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:12
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:20	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-02
Name: 386-SS-02
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:12
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:21	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-03
Name: 386-SS-03
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:14
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-04
Name: 386-SS-04
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:14
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:27	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02726-05
Name: 386-SS-05
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:16
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-06
Name: 386-SS-06
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:16
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-07
Name: 386-SS-07
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:17
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-08
Name: 386-SS-08
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:18
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:33	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02726-09
Name: 386-SS-09
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:19
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:37	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-10
Name: 386-SS-10
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:19
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-11
Name: 386-SS-11
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:20
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-12
Name: 386-SS-12
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:21
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:41	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02726-13
Name: 386-SS-13
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:22
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-14
Name: 386-SS-14
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:23
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.36	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:47	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-15
Name: 386-SS-15
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:23
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	7.94	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:48	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-16
Name: 386-SS-16
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:24
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	6.60	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:49	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02726-17
Name: 386-SS-17
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:24
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:54	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-18
Name: 386-SS-18
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:27
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-19
Name: 386-SS-19
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:28
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:56	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-20
Name: 386-SS-20
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:29
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02726-21
Name: 386-SS-21
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:30
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 15:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-22
Name: 386-SS-22
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:31
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 16:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-23
Name: 386-SS-23
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:32
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/31/24 10:20	1	1.00	01/31/24 16:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02726-24
Name: 386-SS-24
Alias: SUPPORT SERVICES

Sampled: 01/15/24 10:33
Received: 01/18/24 10:45
Matrix: Drinking Water - Regular Sample
PO #: PHSD2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.27	ug/L		01/31/24 10:20	1	1.00	01/31/24 16:06	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050





Certified by: Chenise Lambert-Sykes, Project Manager

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES or IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)







1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Support Services		PURCHASE ORDER # PHSD2324		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY) HA02726			
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/15/2024		DW Lead Turb Check				LOGIN # LOGGED BY: <u>7051</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:			
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Justin Arnold		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID									
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE													
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead Turb Check				REMARKS		
386-SS-01	1/15/2024	1012	X		DW	1	6	X							
386-SS-02	1/15/2024	1012	X		DW	1	6	X							
386-SS-03	1/15/2024	1014	X		DW	1	6	X							
386-SS-04	1/15/2024	1014	X		DW	1	6	X							
386-SS-05	1/15/2024	1014	X		DW	1	6	X							
386-SS-06	1/15/2024	1014	X		DW	1	6	X							
386-SS-07	1/15/2024	1017	X		DW	1	6	X							
386-SS-08	1/15/2024	1018	X		DW	1	6	X							
386-SS-09	1/15/2024	1019	X		DW	1	6	X							
386-SS-10	1/15/2024	1019	X		DW	1	6	X							
386-SS-11	1/15/2024	1020	X		Dw	1	6	X							
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER															
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____									
7 RELINQUISHED BY: (SIGNATURE) 				DATE 1/15/24		RECEIVED BY: (SIGNATURE)				DATE				8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)				DATE		RECEIVED BY: (SIGNATURE)				DATE				SAMPLE TEMPERATURE UPON RECEIPT <u>3.4</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE	
RELINQUISHED BY: (SIGNATURE)				DATE		RECEIVED BY: (SIGNATURE) 				DATE 1/18/24 TIME 1045					

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)



1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Support Services		PURCHASE ORDER # PHSD2324		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>HA02726</u> LOGGED BY: <u>7051</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 1/15/2024		DW Lead Turb Check		REMARKS	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Justin Arnold		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED				
386-SS-12		1/15/2024	1021	X	DW	1	6	X			
386-SS-13		1/15/2024	1022	X	DW	1	6	X			
386-SS-14		1/15/2024	1023	X	DW	1	6	X			
386-SS-15		1/15/2024	1023	X	DW	1	6	X			
386-SS-16		1/15/2024	1024	X	DW	1	6	X			
386-SS-17		1/15/2024	1024	X	DW	1	6	X			
386-SS-18		1/15/2024	1027	X	DW	1	6	X			
386-SS-19		1/15/2024	1028	X	DW	1	6	X			
386-SS-20		1/15/2024	1029	X	DW	1	6	X			
386-SS-21		1/15/2024	1030	X	DW	1	6	X			
386-SS-22		1/15/2024	1031	X	Dw	1	6	X			
CHEMICAL PRESERVATION CODES: 1- HCL 2- H2SO4 3- HNO3 4- NAOH 5- NA2S2O3 6- UNPRESERVED 7- OTHER											
5		TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH		DATE RESULTS NEEDED		6					
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE						I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.					
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:				PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7		RELINQUISHED BY: (SIGNATURE) 		DATE 1/15/24 TIME		RECEIVED BY: (SIGNATURE) 		DATE 1/18/24 TIME 1045		8	
RELINQUISHED BY: (SIGNATURE) 		DATE TIME		RECEIVED BY: (SIGNATURE) 		DATE TIME		COMMENTS: (FOR LAB USE ONLY)		9	
RELINQUISHED BY: (SIGNATURE) 		DATE TIME		RECEIVED BY: (SIGNATURE) 		DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT <u>3.4</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____		Y OR N Y OR N	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Support Services		PURCHASE ORDER # PHSD2324		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY) LOGIN # <u>HA0 2726</u> LOGGED BY: <u>7051</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____			
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 1/15/2024		DW Lead Turb Check				REMARKS			
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Justin Arnold		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID									
CONTACT PERSON Jeremie Kahler		DATE COLLECTED 1/15/2024		TIME COLLECTED 1032		SAMPLE TYPE GRAB COMP		MATRIX TYPE DW		BOTTLE COUNT 1		PRES CODE CLIENT PROVIDED		6	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE		MATRIX TYPE		BOTTLE COUNT		PRES CODE		6	
386-SS- 23		1/15/2024		1032		X		DW		1		6		X	
386-SS- 24		1/15/2024		1033		X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		DW		1		6		X	
386-SS-		1/15/2024				X		Dw		1		6		X	
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER														5	
TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:														6	
7 RELINQUISHED BY: (SIGNATURE) 														8	
RELINQUISHED BY: (SIGNATURE) 														8	
RELINQUISHED BY: (SIGNATURE) 														8	
RECEIVED BY: (SIGNATURE) 														8	
RECEIVED BY: (SIGNATURE) 														8	
RECEIVED BY: (SIGNATURE) 														8	
DATE 1/15/24 TIME														8	
DATE TIME														8	
DATE 1/18/24 TIME 1045														8	
COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>3.4</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE														8	