
August 25, 2025

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Angeline Washington
8804 NW 45 Highway, Parkville, MO 64152
Project Number: 925195

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Angeline Washington Elementary in Parkville, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

METHODOLOGY

On July 2nd, 2025, Mrs. Brittany Dickmeyer of OCCU-TEC completed testing of seventy-four (74) sources throughout Angeline Washington Elementary. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, six (6) of the seventy-four (74) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
195-AWE-14	Kitchen	Prep Sink	15
195-AWE-15	Kitchen	Prep Sink	11
195-AWE-16	Kitchen	Vulcan Cooker Sprayer	10.1
195-AWE-27	C200 Pod	Handwashing Sink	6.3
195-AWE-29	C200 Pod	Handwashing Sink	6.48
195-AWE-36	C100 Pod	Handwashing Sink	7.19

LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
195-AWE-28	C200 Pod	Handwashing Sink

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school

shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above-referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Brittany Dickmeyer
Safety Specialist



Jay Hurst
Vice President of Operations

ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation

Drinking Water Assessment
 Angeline Washington Elementary
 Park Hill School District

ID:	195-AWE-01	Location:	Kitchen Bathroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				


ID:	195-AWE-02	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		Southeast Kitchen Wall Handwashing Sink		
		Result:	2.14	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-03	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		Southeast Kitchen Wall Kitchen Dish Sprayer		
		Result:	1.09	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-04	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
		Description:			
		Southeast Kitchen Wall Handwashing Sink			
		Result:	3.66	ppb	
		Date Sampled:	7/2/2025	By:	BD
Recommended Action:					

ID:	195-AWE-05	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
		Description:			
		West Wall, Front of Kitchen Handwashing Sink			
		Result:	2.32	ppb	
		Date Sampled:	7/2/2025	By:	BD
Recommended Action:					

ID:	195-AWE-06	Location:	Kitchen		
Photo:		Manufacturer:	T&S		
		Description:			
		Dish Wash Area, Southeast Wall, East Corner Kitchen Dish Sprayer			
		Result:	1.31	ppb	
		Date Sampled:	7/2/2025	By:	BD
Recommended Action:					

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-07	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		Dish Wash Area, Southeast Wall Handwashing Sink		
		Result:	3.21	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-08	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		Dish Wash Area, Southeast Wall, Left Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-09	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		Dish Wash Area, Southeast Wall, Middle Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
 Angeline Washington Elementary
 Park Hill School District

ID:	195-AWE-10	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		Dish Wash Area, Southeast Wall, Right Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-11	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		Dish Wash Area, Southeast Wall, Right Sink Kitchen Dish Sprayer		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-12	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		Drop off area in West corner, Handwashing Sink		
		Result:	1.3	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-13	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		Northwest Wall, Stand alone Handwashing Sink		
		Result:	3.71	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-14	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		S side of Island Prep Sink		
		Result:	15	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:		Investigate Feed Line / Replace Fixture/Unit and Resample		

ID:	195-AWE-15	Location:	Kitchen	
Photo:		Manufacturer:	T&S	
		Description:		
		N side of island Prep Sink		
		Result:	11	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:		Investigate Feed Line / Replace Fixture/Unit and Resample		

Drinking Water Assessment
 Angeline Washington Elementary
 Park Hill School District

ID:	195-AWE-16	Location:	Kitchen	
Photo:		Manufacturer:	Vulcan	
		Description:		
		Vulcan Cooker Sprayer		
		Result:	10.1	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:		Investigate Feed Line / Install End of line Filter and Resample		

ID:	195-AWE-17	Location:	Cafeteria	
Photo:		Manufacturer:	Unknown	
		Description:		
		SW Area of Cafeteria, Left Sink		
		Result:	1.44	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-18	Location:	Cafeteria	
Photo:		Manufacturer:	Unknown	
		Description:		
		SW Area of Cafeteria, Right Sink		
		Result:	3.74	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
 Angeline Washington Elementary
 Park Hill School District

ID:	195-AWE-19	Location:	Cafeteria	
Photo:		Manufacturer:	Murdock	
		Description:		
		Left Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-20	Location:	Cafeteria	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-21	Location:	Cafeteria	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-22	Location:	Gym Bathroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Left Handwashing Sink		
		Result:	1.93	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-23	Location:	Gym Bathroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Right Handwashing Sink		
		Result:	1.48	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-24	Location:	Art Room	
Photo:		Manufacturer:	Unknown	
		Description:		
		North Wall		
		Result:	2.12	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-25	Location:	Art Room	
Photo:		Manufacturer:	Unknown	
		Description:		
		West Wall, Right Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-26	Location:	Art Room	
Photo:		Manufacturer:	Unknown	
		Description:		
		West Wall, Left Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-27	Location:	C200 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Girls Bathroom, Right Handwashing Sink		
		Result:	6.3	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:		Label as Non-Drinking Water		

Drinking Water Assessment
 Angeline Washington Elementary
 Park Hill School District

ID:	195-AWE-28	Location:	C200 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Girls Bathroom, Left Handwashing Sink		
		Not working at time of testing.		
		Result:	NA	ppb
Date Sampled:	7/2/2025	By:	BD	
Recommended Action:		Label as Non-Drinking Water		

ID:	195-AWE-29	Location:	C200 Pod		
Photo:		Manufacturer:	Sloan		
		Description:			
		Boys Bathroom, Right Handwashing Sink			
		Result:	6.48	ppb	
		Date Sampled:	7/2/2025	By:	BD
Recommended Action:		Label as Non-Drinking Water			

ID:	195-AWE-30	Location:	C200 Pod		
Photo:		Manufacturer:	Sloan		
		Description:			
		Boys Bathroom, Left Handwashing Sink			
		Result:	2.12	ppb	
		Date Sampled:	7/2/2025	By:	BD
Recommended Action:					

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-31	Location:	C200 Pod	
Photo:		Manufacturer:	Delta	
		Description:		
		STEM Room, Right Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-32	Location:	C200 Pod	
Photo:		Manufacturer:	Delta	
		Description:		
		STEM Room, Left Handwashing Sink		
		Result:	1.28	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-33	Location:	Across from C215	
Photo:		Manufacturer:	Murdock	
		Description:		
		Left Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-34	Location:	Across from C215	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-35	Location:	Across from C215	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-36	Location:	C100 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Girls Bathroom, Right Handwashing Sink		
		Result:	7.19	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:		Label as Non-Drinking Water		

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-37	Location:	C100 Pod					
Photo:		Manufacturer:	Sloan					
		Description:						
		Girls Bathroom, Right Handwashing Sink						
		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Result:</td> <td style="width: 33%;">1.64</td> <td style="width: 34%;">ppb</td> </tr> <tr> <td>Date Sampled:</td> <td>7/2/2025</td> <td>By: BD</td> </tr> </table>			Result:	1.64	ppb	Date Sampled:
Result:	1.64	ppb						
Date Sampled:	7/2/2025	By: BD						
Recommended Action:								

ID:	195-AWE-38	Location:	C100 Pod					
Photo:		Manufacturer:	Sloan					
		Description:						
		Boys Bathroom, Right Handwashing Sink						
		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Result:</td> <td style="width: 33%;">3.95</td> <td style="width: 34%;">ppb</td> </tr> <tr> <td>Date Sampled:</td> <td>7/2/2025</td> <td>By: BD</td> </tr> </table>			Result:	3.95	ppb	Date Sampled:
Result:	3.95	ppb						
Date Sampled:	7/2/2025	By: BD						
Recommended Action:								

ID:	195-AWE-39	Location:	C100 Pod					
Photo:		Manufacturer:	Sloan					
		Description:						
		Boys Bathroom, Left Handwashing Sink						
		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Result:</td> <td style="width: 33%;">1.95</td> <td style="width: 34%;">ppb</td> </tr> <tr> <td>Date Sampled:</td> <td>7/2/2025</td> <td>By: BD</td> </tr> </table>			Result:	1.95	ppb	Date Sampled:
Result:	1.95	ppb						
Date Sampled:	7/2/2025	By: BD						
Recommended Action:								

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District


ID:	195-AWE-40	Location:	C100 Pod	
Photo:		Manufacturer:	Delta	
		Description:		
		STEM Room, Right Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-41	Location:	C100 Pod	
Photo:		Manufacturer:	Delta	
		Description:		
		STEM Room, Left Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-42	Location:	C100 Pod	
Photo:		Manufacturer:	Murdock	
		Description:		
		Left Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-43	Location:	C100 Pod	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-44	Location:	C100 Pod	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-45	Location:	C100 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Staff Restroom, Handwashing Sink		
		Result:	1.65	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-46	Location:	C200 Pod			
Photo:		Manufacturer:	Sloan			
		Description:				
		Staff Restroom, Handwashing Sink				
		Result:			2.47	ppb
		Date Sampled:	7/2/2025	By:	BD	
Recommended Action:						

ID:	195-AWE-47	Location:	Commons Area			
Photo:		Manufacturer:	Sloan			
		Description:				
		Girls Bathroom, Right Handwashing Sink				
		Result:			4.34	ppb
		Date Sampled:	7/2/2025	By:	BD	
Recommended Action:						

ID:	195-AWE-48	Location:	Commons Area			
Photo:		Manufacturer:	Sloan			
		Description:				
		Girls Bathroom, Right Handwashing Sink				
		Result:			1.82	ppb
		Date Sampled:	7/2/2025	By:	BD	
Recommended Action:						

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-49	Location:	Commons Area					
Photo:		Manufacturer:	Sloan					
		Description:						
		Boys Bathroom, Right Handwashing Sink						
		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Result:</td> <td style="width: 33%;">4.23</td> <td style="width: 34%;">ppb</td> </tr> <tr> <td>Date Sampled:</td> <td>7/2/2025</td> <td>By: BD</td> </tr> </table>			Result:	4.23	ppb	Date Sampled:
Result:	4.23	ppb						
Date Sampled:	7/2/2025	By: BD						
Recommended Action:								

ID:	195-AWE-50	Location:	Commons Area					
Photo:		Manufacturer:	Sloan					
		Description:						
		Boys Bathroom, Left Handwashing Sink						
		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Result:</td> <td style="width: 33%;">2.19</td> <td style="width: 34%;">ppb</td> </tr> <tr> <td>Date Sampled:</td> <td>7/2/2025</td> <td>By: BD</td> </tr> </table>			Result:	2.19	ppb	Date Sampled:
Result:	2.19	ppb						
Date Sampled:	7/2/2025	By: BD						
Recommended Action:								

ID:	195-AWE-51	Location:	Commons Area					
Photo:		Manufacturer:	Unknown					
		Description:						
		Staff Bathroom, Handwashing Sink						
		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Result:</td> <td style="width: 33%;">1.2</td> <td style="width: 34%;">ppb</td> </tr> <tr> <td>Date Sampled:</td> <td>7/2/2025</td> <td>By: BD</td> </tr> </table>			Result:	1.2	ppb	Date Sampled:
Result:	1.2	ppb						
Date Sampled:	7/2/2025	By: BD						
Recommended Action:								

Drinking Water Assessment
 Angeline Washington Elementary
 Park Hill School District

ID:	195-AWE-52	Location:	Commons Area	
Photo:		Manufacturer:	Murdock	
		Description:		
		Left Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-53	Location:	Commons Area	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-54	Location:	Commons Area	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-55	Location:	Staff Workroom	
Photo:		Manufacturer:	Hoshizaki	
		Description:		
		Ice Machine		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-56	Location:	Staff Workroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-57	Location:	A100 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Girls Bathroom, Right Handwashing Sink		
		Result:	1.24	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-58	Location:	A100 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Girls Bathroom, Left Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-59	Location:	A100 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Boys Bathroom, Right Handwashing Sink		
		Result:	3.94	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-60	Location:	A100 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Boys Bathroom, Left Handwashing Sink		
		Result:	1.13	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
 Angeline Washington Elementary
 Park Hill School District

ID:	195-AWE-61	Location:	A100 Pod	
Photo:		Manufacturer:	Murdock	
		Description:		
		Left Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-62	Location:	A100 Pod	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-63	Location:	A100 Pod	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-64	Location:	A100 Pod	
Photo:		Manufacturer:	Delta	
		Description:		
		STEM Room, Left Handwashing Sink		
		Result:	1.91	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-65	Location:	A100 Pod	
Photo:		Manufacturer:	Delta	
		Description:		
		STEM Room, Right Handwashing Sink		
		Result:	1.09	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-66	Location:	A100 Pod	
Photo:		Manufacturer:	Sloan	
		Description:		
		Staff Restroom, Handwashing Sink		
		Result:	2.13	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-67	Location:	Main Office	
Photo:		Manufacturer:	Sloan	
		Description:		
		Staff Restroom, Handwashing Sink		
		Result:	1.05	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-68	Location:	Lactation Room	
Photo:		Manufacturer:	Unknown	
		Description:		
		Handwashing Sink		
		Result:	2.8	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-69	Location:	Nurse's Office	
Photo:		Manufacturer:	Unknown	
		Description:		
		Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-70	Location:	Nurse Bathroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Handwashing Sink		
		Result:	1.37	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-71	Location:	Library	
Photo:		Manufacturer:	Masco	
		Description:		
		Left Handwashing Sink		
		Result:	1.47	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-72	Location:	Library	
Photo:		Manufacturer:	Masco	
		Description:		
		Right Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

Drinking Water Assessment
Angeline Washington Elementary
Park Hill School District

ID:	195-AWE-73	Location:	Gym	
Photo:		Manufacturer:	Murdock	
		Description:		
		Left Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-74	Location:	Gym	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				

ID:	195-AWE-075	Location:	Gym	
Photo:		Manufacturer:	Murdock	
		Description:		
		Right Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	7/2/2025	By: BD
Recommended Action:				



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

July 23, 2025

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 925195-Angeline Washington Elementary

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **74** sample(s) the laboratory received on **7/8/25 2:35 pm** and logged in under work order **IG01191**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



ANALYTICAL RESULTS

Sample: IG01191-01
Name: 195-AWE-01
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:30
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-02
Name: 195-AWE-02
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:31
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.14	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:04	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-03
Name: 195-AWE-03
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:31
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.09	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:05	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-04
Name: 195-AWE-04
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:33
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.66	ug/L		07/17/25 12:24	1	1.00	07/22/25 07:48	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-05
Name: 195-AWE-05
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:35
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.32	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:09	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-06
Name: 195-AWE-06
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:36
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.31	ug/L		07/17/25 12:24	1	1.00	07/22/25 07:50	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-07
Name: 195-AWE-07
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:37
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.21	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:11	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-08
Name: 195-AWE-08
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:40
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-09
Name: 195-AWE-09
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:41
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-10
Name: 195-AWE-10
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:43
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-11
Name: 195-AWE-11
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:43
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:19	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-12
Name: 195-AWE-12
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:46
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.30	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:21	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-13
Name: 195-AWE-13
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:48
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.71	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:22	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-14
Name: 195-AWE-14
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:49
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	15.0	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:24	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-15
Name: 195-AWE-15
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:50
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	11.0	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:25	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-16
Name: 195-AWE-16
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:51
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	10.1	ug/L		07/17/25 12:24	1	1.00	07/22/25 07:51	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-17
Name: 195-AWE-17
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:58
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.44	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:29	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-18
Name: 195-AWE-18
Matrix: Drinking Water - Grab

Sampled: 07/02/25 06:58
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.74	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:31	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-19
Name: 195-AWE-19
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:00
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:35	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-20
Name: 195-AWE-20
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:01
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:07	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-21
Name: 195-AWE-21
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:01
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:08	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-22
Name: 195-AWE-22
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:06
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.93	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:10	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-23
Name: 195-AWE-23
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:06
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.48	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:11	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-24
Name: 195-AWE-24
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:12
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.12	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:13	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-25
Name: 195-AWE-25
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:14
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-26
Name: 195-AWE-26
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:14
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-27
Name: 195-AWE-27
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:21
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	6.30	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:37	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-28
Name: 195-AWE-29
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:23
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	6.48	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:38	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-29
Name: 195-AWE-30
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:24
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.12	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:40	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-30
Name: 195-AWE-31
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:26
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:41	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-31
Name: 195-AWE-32
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:26
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.28	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:42	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-32
Name: 195-AWE-33
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:32
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-33
Name: 195-AWE-34
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:33
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-34
Name: 195-AWE-35
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:33
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:52	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-35
Name: 195-AWE-36
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:38
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	7.19	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:54	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-36
Name: 195-AWE-37
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:39
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.64	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:55	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-37
Name: 195-AWE-38
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:40
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.95	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:57	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-38
Name: 195-AWE-39
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:41
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.95	ug/L		07/15/25 07:58	1	1.00	07/15/25 12:58	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-39
Name: 195-AWE-40
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:42
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:00	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-40
Name: 195-AWE-41
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:43
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-41
Name: 195-AWE-42
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:46
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-42
Name: 195-AWE-43
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:47
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-43
Name: 195-AWE-44
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:47
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-44
Name: 195-AWE-45
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:50
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.65	ug/L		07/17/25 12:24	1	1.00	07/22/25 07:53	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-45
Name: 195-AWE-46
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:53
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.47	ug/L		07/17/25 12:24	1	1.00	07/22/25 07:54	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-46
Name: 195-AWE-47
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:57
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.34	ug/L		07/17/25 12:24	1	1.00	07/22/25 07:58	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-47
Name: 195-AWE-48
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:58
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.82	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:13	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-48
Name: 195-AWE-49
Matrix: Drinking Water - Grab

Sampled: 07/02/25 07:59
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.23	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:14	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-49
Name: 195-AWE-50
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:00
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.19	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:15	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-50
Name: 195-AWE-51
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:02
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.20	ug/L		07/17/25 12:24	1	1.00	07/22/25 08:00	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-51
Name: 195-AWE-52
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:04
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:17	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-52
Name: 195-AWE-53
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:05
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-53
Name: 195-AWE-54
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:06
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:20	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-54
Name: 195-AWE-55
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:11
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:21	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-55
Name: 195-AWE-56
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:12
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:23	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-56
Name: 195-AWE-57
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:26
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.24	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:27	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-57
Name: 195-AWE-58
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:27
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-58
Name: 195-AWE-59
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:28
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.94	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:33	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-59
Name: 195-AWE-60
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:29
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.13	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:34	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-60
Name: 195-AWE-61
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:30
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:37	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-61
Name: 195-AWE-62
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:30
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-62
Name: 195-AWE-63
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:30
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-63
Name: 195-AWE-64
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:32
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.91	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:44	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-64
Name: 195-AWE-65
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:33
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.09	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:46	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-65
Name: 195-AWE-66
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:35
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.13	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:47	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-66
Name: 195-AWE-67
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:37
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.05	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:48	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-67
Name: 195-AWE-68
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:39
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.80	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:50	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-68
Name: 195-AWE-69
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:42
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:51	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-69
Name: 195-AWE-70
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:43
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.37	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:53	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-70
Name: 195-AWE-71
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:46
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.47	ug/L		07/15/25 07:58	1	1.00	07/15/25 13:57	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-71
Name: 195-AWE-72
Matrix: Drinking Water - Grab

Sampled: 07/02/25 08:47
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-72
Name: 195-AWE-73
Matrix: Drinking Water - Grab

Sampled: 07/02/25 15:15
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IG01191-73
Name: 195-AWE-74
Matrix: Drinking Water - Grab

Sampled: 07/02/25 15:16
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IG01191-74
Name: 195-AWE-75
Matrix: Drinking Water - Grab

Sampled: 07/02/25 15:16
Received: 07/08/25 14:35
PO #: AWE-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		07/15/25 07:58	1	1.00	07/15/25 14:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 925195		PROJECT LOCATION Angeline Washington Elementary		PURCHASE ORDER # AWE-PB083-005		3 ANALYSIS REQUESTED ☒ DW Lead ☒ Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>1G01191</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Brittany Dickmeyer		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											

2	SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check									REMARKS
				GRAB	COMP														
	195-AWE- 01	7/2/25	630	X		DW	1	6	X										
	195-AWE- 02		631	X		DW	1	6	X										
	195-AWE- 03		631	X		DW	1	6	X										
	195-AWE- 04		633	X		DW	1	6	X										
	195-AWE- 05		635	X		DW	1	6	X										
	195-AWE- 06		636	X		DW	1	6	X										
	195-AWE- 07		637	X		DW	1	6	X										
	195-AWE- 08		640	X		DW	1	6	X										
	195-AWE- 09		641	X		DW	1	6	X										
	195-AWE- 10		643	X		DW	1	6	X										
	195-AWE- 11		643	X		DW	1	6	X										

CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER									
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:					6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____				
7 RELINQUISHED BY: (SIGNATURE) <u>Brittany Dickmeyer</u> RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)					RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) <u>Camden Barnett</u>				
DATE <u>7/2/25</u> TIME <u>1600</u> DATE TIME DATE TIME					DATE TIME DATE TIME DATE <u>7-8-25</u> TIME <u>1435</u>				
8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____									

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 925195		PROJECT LOCATION Angeline Washington Elementary		PURCHASE ORDER # AWE-PB083-005		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED		☒ DW Lead ☒ Turb Check		LOGIN # <u>1601191</u> LOGGED BY: _____ CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Brittany Dickmeyer		SAMPLER'S SIGNATURE		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS		
195-AWE- 12		7/12/25	646	X		DW	1	6	X		
195-AWE- 13			648	X		DW	1	6	X		
195-AWE- 14			649	X		DW	1	6	X		
195-AWE- 15			650	X		DW	1	6	X		
195-AWE- 16			651	X		DW	1	6	X		
195-AWE- 17			658	X		DW	1	6	X		
195-AWE- 18			658	X		DW	1	6	X		
195-AWE- 19			700	X		DW	1	6	X		
195-AWE- 20			701	X		DW	1	6	X		
195-AWE- 21			701	X		DW	1	6	X		
195-AWE- 22			706	X		Dw	1	6	X		
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL ☒ RUSH ☐ RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL ☐ PHONE ☐ EMAIL IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____				DATE RESULTS NEEDED send results to <u>jhurst3@occutec.com</u>		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)				
<u>Brittany Dickmeyer</u>		<u>7/12/25</u>									
RELINQUISHED BY: (SIGNATURE)		TIME	RECEIVED BY: (SIGNATURE)		TIME						
		<u>1600</u>									
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE						
RELINQUISHED BY: (SIGNATURE)		TIME	RECEIVED BY: (SIGNATURE)		TIME						
			<u>Camden Bennett</u>		<u>7-8-25</u>						
					<u>1435</u>						
SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____											

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler	PROJECT NUMBER 925195 PHONE NUMBER 8163596731 SAMPLER (PLEASE PRINT) Brittany Dickmeyer SAMPLER'S SIGNATURE	PROJECT LOCATION Angeline Washington Elementary E-MAIL KahlerJ@parkhill.k12.mo.us	PURCHASE ORDER # AWE-PB083-005 DATE SHIPPED	3 ANALYSIS REQUESTED DW Lead Turb Check	4 (FOR LAB USE ONLY) LOGIN # 1901191 LOGGED BY: CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:
---	---	--	---	---	---

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS
195-AWE-23	7/2/25	706	X	DW	1	6	X		
195-AWE-24		712	X	DW	1	6	X		
195-AWE-25		714	X	DW	1	6	X		
195-AWE-26		714	X	DW	1	6	X		
195-AWE-27		721	X	DW	1	6	X		
195-AWE-29		723	X	DW	1	6	X		
195-AWE-30		724	X	DW	1	6	X		
195-AWE-31		726	X	DW	1	6	X		
195-AWE-32		726	X	DW	1	6	X		
195-AWE-33		732	X	DW	1	6	X		
195-AWE-34		733	X	DW	1	6	X		

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:	1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER NORMAL RUSH send results to jhurst3@occutec.com	6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)
--	--	--

7 RELINQUISHED BY: (SIGNATURE) [Signature] RELINQUISHED BY: (SIGNATURE) [Signature] RELINQUISHED BY: (SIGNATURE) [Signature]	DATE 7/2/25 TIME 1600	RECEIVED BY: (SIGNATURE) [Signature] RECEIVED BY: (SIGNATURE) [Signature] RECEIVED BY: (SIGNATURE) [Signature]	DATE TIME DATE TIME DATE 7-8-25 TIME 1435	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE
--	--	--	--	---

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 925195 PHONE NUMBER 8163596731 SAMPLER (PLEASE PRINT) Brittany Dickmeyer SAMPLER'S SIGNATURE		PROJECT LOCATION Angeline Washington Elementary E-MAIL KahlerJ@parkhill.k12.mo.us		PURCHASE ORDER # AWE-PB083-005 DATE SHIPPED		3 ANALYSIS REQUESTED <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:5%; text-align: center;">+</td> <td style="width:5%; text-align: center;">+</td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> </tr> <tr> <td style="writing-mode: vertical-rl; transform: rotate(180deg);">DW Lead</td> <td style="writing-mode: vertical-rl; transform: rotate(180deg);">Turb Check</td> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> </table>				+	+									DW Lead	Turb Check									4 (FOR LAB USE ONLY) LOGIN # 1601191 LOGGED BY: CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:	
+	+																																
DW Lead	Turb Check																																
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%; text-align: center;">GRAB</td> <td style="width:50%; text-align: center;">COMP</td> </tr> </table>	GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS																							
GRAB	COMP																																
195-AWE- 35		7/2/25	733	X	DW	1	6	X																									
195-AWE- 36			738	X	DW	1	6	X																									
195-AWE- 37			739	X	DW	1	6	X																									
195-AWE- 38			740	X	DW	1	6	X																									
195-AWE- 39			741	X	DW	1	6	X																									
195-AWE- 40			742	X	DW	1	6	X																									
195-AWE- 41			743	X	DW	1	6	X																									
195-AWE- 42			746	X	DW	1	6	X																									
195-AWE- 43			747	X	DW	1	6	X																									
195-AWE- 44			747	X	DW	1	6	X																									
195-AWE- 45			750	X	DW	1	6	X																									

CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE send results to EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE: jhurst3@occutec.com		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)	
--	--	--	--

7 RELINQUISHED BY: (SIGNATURE) Brittany Dickmeyer RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE 7/2/25 TIME 1600 DATE TIME DATE TIME DATE TIME		RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) Corrinne Bennett		DATE TIME DATE TIME 7-8-25 1435		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE	
---	--	--	--	---	--	--	--	---	--

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 925195		PROJECT LOCATION Angeline Washington Elementary		PURCHASE ORDER # AWE-PB083-005		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>1901191</u> LOGGED BY: _____ CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED		☒ DW Lead ☒ Turb Check			
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Brittany Dickmeyer		SAMPLER'S SIGNATURE		MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED			REMARKS	
195-AWE-46		7/2/25	753	X	DW	1	6	X			
195-AWE-47			757	X	DW	1	6	X			
195-AWE-48			758	X	DW	1	6	X			
195-AWE-49			759	X	DW	1	6	X			
195-AWE-50			800	X	DW	1	6	X			
195-AWE-51			802	X	DW	1	6	X			
195-AWE-52			804	X	DW	1	6	X			
195-AWE-53			805	X	DW	1	6	X			
195-AWE-54			806	X	DW	1	6	X			
195-AWE-55			811	X	DW	1	6	X			
195-AWE-56			812	X	Dw	1	6	X			
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE send results to EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE: jhurst3@occutec.com				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) Brittany Dickmeyer		DATE 7/2/25	RECEIVED BY: (SIGNATURE)				DATE		8 COMMENTS: (FOR LAB USE ONLY)		
RELINQUISHED BY: (SIGNATURE)		TIME 1600	RECEIVED BY: (SIGNATURE)				TIME		SAMPLE TEMPERATURE UPON RECEIPT °C		
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)				DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N		
RELINQUISHED BY: (SIGNATURE)		TIME	RECEIVED BY: (SIGNATURE) Cernellin Barnett				DATE 7-8-25		DATE AND TIME TAKEN FROM SAMPLE BOTTLE 1435		

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 925195		PROJECT LOCATION Angeline Washington Elementary		PURCHASE ORDER # AWE-PB083-005		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>1901191</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED		☒ DW Lead ☒ Turb Check			
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Brittany Dickmeyer		SAMPLER'S SIGNATURE		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED			REMARKS	
195-AWE- 57		7/12/25	826	X	DW	1	6	X			
195-AWE- 58			827	X	DW	1	6	X			
195-AWE- 59			828	X	DW	1	6	X			
195-AWE- 60			829	X	DW	1	6	X			
195-AWE- 61			830	X	DW	1	6	X			
195-AWE- 62			830	X	DW	1	6	X			
195-AWE- 63			830	X	DW	1	6	X			
195-AWE- 64			832	X	DW	1	6	X			
195-AWE- 65			833	X	DW	1	6	X			
195-AWE- 66			835	X	DW	1	6	X			
195-AWE- 67			837	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		NORMAL RUSH send results to jhurst3@occutec.com		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) Brittany Dickmeyer		DATE 7/12/25	RECEIVED BY: (SIGNATURE)				DATE		8 COMMENTS: (FOR LAB USE ONLY)		
RELINQUISHED BY: (SIGNATURE)		TIME 1600	RECEIVED BY: (SIGNATURE)				TIME		SAMPLE TEMPERATURE UPON RECEIPT _____ °C		
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)				DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT Y OR N REPORT IS NEEDED Y OR N		
RELINQUISHED BY: (SIGNATURE)		TIME	RECEIVED BY: (SIGNATURE) Camden Bennett				DATE 7-8-25 TIME 1435		DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____		

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 925195 PHONE NUMBER 8163596731 SAMPLER (PLEASE PRINT) Brittany Dickmeyer SAMPLER'S SIGNATURE		PROJECT LOCATION Angeline Washington Elementary E-MAIL KahlerJ@parkhill.k12.mo.us		PURCHASE ORDER # AWE-PB083-005 DATE SHIPPED MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		3 ANALYSIS REQUESTED <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:5%; text-align: center;">+</td> <td style="width:5%; text-align: center;">+</td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> <td style="width:5%;"></td> </tr> <tr> <td colspan="18" style="text-align: center;"> DW Lead Turb Check </td> </tr> </table>				+	+																	DW Lead Turb Check																		4 (FOR LAB USE ONLY) LOGIN # 1G01191 LOGGED BY: CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:	
+	+																																																
DW Lead Turb Check																																																	
2 (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) SAMPLE DESCRIPTION		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS																																						
195-AWE- 68	7/2/25	839	X		DW	1	6	X																																									
195-AWE- 69		842	X		DW	1	6	X																																									
195-AWE- 70		843	X		DW	1	6	X																																									
195-AWE- 71		846	X		DW	1	6	X																																									
195-AWE- 72		847	X		DW	1	6	X																																									
195-AWE- 73		1515	X		DW	1	6	X																																									
195-AWE- 74		1516	X		DW	1	6	X																																									
195-AWE- 75		1516	X		DW	1	6	X																																									
195-AWE-			X		DW	1	6	X																																									
195-AWE-			X		DW	1	6	X																																									
195-AWE-			X		DW	1	6	X																																									

CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE send results to EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE: jhurst3@occutec.com	6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)
--	--

7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)	DATE TIME DATE TIME DATE TIME	RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)	DATE TIME DATE TIME DATE TIME	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE
	7/2/25 1600			

ENV-FRM-PEOR-0098 v05_Sample Condition Upon Receipt

Client Name: Park Hill School dist Work Order #: 1191 Completed by / Date: CRB 7-8-25

Custody seal on cooler/box present and seal intact:	☐ Yes ☐ No ☒ N/A
Chain of Custody (CoC) Present:	☒ Yes ☐ No
CoC is Legible:	☒ Yes ☐ No
Sampler Name Present on CoC:	☒ Yes ☐ No
Sampler Signature Present on CoC:	☒ Yes ☐ No
Sample Collection Date Present on CoC:	☒ Yes ☐ No
Sample Collection Time Present on CoC:	☒ Yes ☐ No
CoC Relinquished by Client:	☐ Yes ☐ No
Unique Sample ID's Present on CoC:	☒ Yes ☐ No
CoC and Sample Container Labels Match:	☒ Yes ☐ No
Sample chilling process started prior to receipt: If yes, what type of ice:	☐ Yes ☐ No ☒ N/A ☐ Wet ☐ Blue
Samples received within temperature compliance: ($\leq 6^{\circ}\text{C}$, but above freezing or received same day collected and chill process started prior to receipt)	☐ Yes ☐ No ☒ N/A
Container(s) Received Intact:	☒ Yes ☐ No
Containers Received Labeled and Labels are Legible:	☒ Yes ☐ No
Appropriate Bottles Received for Analysis Requested:	☒ Yes ☐ No
Sufficient Sample Volume Received:	☒ Yes ☐ No
USDA Regulated Soil: Country of Origin: _____ State of Origin: _____	☐ Yes ☐ No ☒ N/A
Trip Blank(s) Received: If present, are they Listed on CoC:	☐ Yes ☐ No ☒ N/A ☐ Yes ☐ No
VOA vials are free of any headspace larger than pea sized bubble (>6mm) – Applies to methods 8260, 624, 524.2 - including THM vials If headspace is present, note sample ID and # of vials	☐ Yes ☐ No ☒ N/A
All (Non-Field) Analysis Received Within Hold Times:	☒ Yes ☐ No
Rush Turn Around Time Requested or Time Sensitive Analysis:	☐ Yes ☒ No
Short Hold Time Analysis (48 Hours or Less):	☐ Yes ☒ No

Client Notification/ Resolution:

If checked, please see attached form for additional comments ☐

Person Contacted: _____ Date/Time: _____

Comments/ Resolution: _____

PM Review is documented electronically in LIMS. By releasing the project, the PM acknowledges they have reviewed the sample.

WORK ORDER #:

1191

INITIALS:

Drinking Water Bottle Receipt Form

SOC (Synthetic Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
Chlorine Check	Chlorine Check	P, U, 150 ml	1								
M504	EDB & DBCP	C,V, 40 ml, Na2S2O3	3								
M504 Trip Blank	Trip Blank	C,V, 40 ml, Na2S2O3	2								
M505 (subcontract)	Toxaphene	C,V, 40 ml, Na2S2O3	3								
M515.3/548	Chlorinated Acids/Endothal	A, G, 500 ml, Na2S2O3	2								
M525.2	Semi-Volatiles	A, G, 1000 ml, Na2SO3 + HCl	3								
M531	Carbamates	A, V, 60 ml, Na2S2O3 + MCAA	1								
M549.2	Diquat	A, P, 1000 ml, Na2S2O3 + H2SO4	1								
M550	Benzo(a)Pyrene	A, G, 1000 ml, Na2S2O3 + HCl	3								
*M547	Glyphosate	A, V, 60 ml, Na2S2O3	1								
*M547 Trip Blank	Trip Blank	A, V, 60 ml, Na2S2O3	1								

*"SOC_W_GLPHOS" & "SOC_IDPH_GROUP A" ONLY

VOC (Volatile Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M524.2	Regulated Volatile	C,V, 40 ml, HCl	3								
M524.2 Trip Blank	Trip Blank	C,V, 40 ml, HCl	3								
Chlorine Check	Chlorine Check	P, U, 150 ml	1								

IOC (Inorganic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
*300.0 SO4 & Fluoride Probe	Sulfate by IC/Fluoride Probe	P, 500 ml, Total	1								
**Metals - As, Ba, Be, Cd, Cr, Fe, Hg, Mn, Na, Ni, Sb, Se, Ti, Zn & Turb Check	Metals	P, 250 ml, HNO3, Total	1								
CN-T Kelada DW	Cyanide Total	P, 250 ml, NaOH	1								

*Excluded from "IOC IDPH SHORT LIST"

**Excluded Fe, Mn ,Na ,Ni & Zn from "IOC IDPH SHORT LIST" Fe, Mn ,Na ,Ni & Zn

THM/HAA

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
THM M524	Trihalomethane	C,V, 40 ml, Na2S2O3	4								
HAA M552	Haloacetic Acid	A, V, 60 ML NH4CL	4								
Chlorine Check	Chlorine Check	P, U, 150 ml	1								

TOC

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
TOC	Total Organic Carbon	A, V, 40 ml, H2SO4	3								

Chlorite/Bromate

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
Bromate (Subcontract)	Bromate	P, 100 ml, EDA	1								
Chlorite (Subcontract)	Chlorite	P, 100 ml, EDA	1								

Lead/Copper

Method	Description	Bottle Type	Qty
Lead/Copper	Lead Copper	P, 1000ml LC	
School Lead	Lead	P, 250ml LC	74

PFAS

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M533	PFAS	533, P, 250mL, C2H7NO2									
M533 FRB	PFAS - FRB	533, P, 250mL, C2H7NO2									
M537.1	PFAS	537.1, P, 250 mL, TRZ									
M537.1 FRB	PFAS - FRB	537.1, P, 250 mL, TRZ									