
August 25, 2025 Addendum

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Park Hill South High School
4500 NW River Park Drive, Riverside, MO 64151
Project Number: 925195

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Park Hill High School in Riverside, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

METHODOLOGY

On August 5, 2025, Mr. Jay Hurst of OCCU-TEC completed testing of twenty-eight (28) sources throughout the new Gymnasium and Band Room additions at Park Hill South High School. Samples were collected as ‘first draw’ samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) Method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification number 00870. A copy of the laboratory analytical results and chain of custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, zero (0) of the twenty-eight (28) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
No samples collected contained results above 5 ug/L (ppb)			

LIMITATIONS

At the request of PHSD, lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.

- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations



Erin Anderson
Project Manager (QA/QC)

ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHSHS-191	Location:	NE Gym N Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHSHS-192	Location:	NE Gym N Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHSHS-193	Location:	NE Gym N Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHSHS-194	Location:	NE Gym Men's RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Left)		
		Result:	1.05	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH


ID:	195-PHSHS-195	Location:	NE Gym Men's RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Center)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

ID:	195-PHSHS-196	Location:	NE Gym Men's RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Right)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHS-197	Location:	NE Gym Center Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHS-198	Location:	NE Gym Center Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHS-199	Location:	NE Gym Center Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHSHS-200	Location:	NE Gym Unisex RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink		
		Result:	1.26	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

ID:	195-PHSHS-201	Location:	NE Gym Women's RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Left)		
		Result:	1.08	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

ID:	195-PHSHS-202	Location:	NE Gym Women's RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Center)		
		Result:	1.15	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHSHS-203	Location:	NE Gym Women's RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Right)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

ID:	195-PHSHS-204	Location:	NE Gym S Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

ID:	195-PHSHS-205	Location:	NE Gym S Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHS-206	Location:	NE Gym S Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

ID:	195-PHS-207	Location:	New Gym Concessions	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

ID:	195-PHS-208	Location:	New Gym Concessions	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Kitchen Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/5/2025	By: JH

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHS-209	Location:	New Weight Room	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH

Recommended Action:


ID:	195-PHS-210	Location:	New Weight Room	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH

Recommended Action:

ID:	195-PHS-211	Location:	New Weight Room	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH

Recommended Action:

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHSHS-212	Location:	New Band/ Drama Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHSHS-213	Location:	New Band/ Drama Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHSHS-214	Location:	New Band/ Drama Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				


Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHSHS-215	Location:	Stage Craft	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHSHS-216	Location:	Stage Craft	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink (Left)		
		Result:	1.35	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

ID:	195-PHSHS-217	Location:	Stage Craft	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink (Right)		
		Result:	1.2	ppb
		Date Sampled:	8/5/2025	By: JH
Recommended Action:				

Drinking Water Assessment
Park Hill South High School
Park Hill School District

ID:	195-PHSHS-218	Location:	Stage Craft RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	8/5/2025	By:	JH
Recommended Action:					



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

August 20, 2025

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 925195-Park Hill South High School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **28** sample(s) the laboratory received on **8/8/25 2:00 pm** and logged in under work order **IH01830**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



ANALYTICAL RESULTS

Sample: IH01830-01
Name: 195-PHSHS-191
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:21
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:35	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-02
Name: 195-PHSHS-192
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:21
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:37	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-03
Name: 195-PHSHS-193
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:21
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-04
Name: 195-PHSHS-194
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:23
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.05	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:40	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IH01830-05
Name: 195-PHS-195
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:23
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:41	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-06
Name: 195-PHS-196
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:23
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-07
Name: 195-PHS-197
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:26
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-08
Name: 195-PHS-198
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:26
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:51	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IH01830-09
Name: 195-PHSHS-199
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:26
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:52	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-10
Name: 195-PHSHS-200
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:28
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.26	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:54	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-11
Name: 195-PHSHS-201
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:31
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.08	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:55	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-12
Name: 195-PHSHS-202
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:31
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.15	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:56	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IH01830-13
Name: 195-PHSHS-203
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:31
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-14
Name: 195-PHSHS-204
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:34
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 13:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-15
Name: 195-PHSHS-205
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:34
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-16
Name: 195-PHSHS-206
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:34
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IH01830-17
Name: 195-PHSHS-207
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:36
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-18
Name: 195-PHSHS-208
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:36
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-19
Name: 195-PHSHS-209
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:38
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-20
Name: 195-PHSHS-210
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:38
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IH01830-21
Name: 195-PHSHS-211
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:38
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:15	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-22
Name: 195-PHSHS-212
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:48
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-23
Name: 195-PHSHS-213
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:48
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:20	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-24
Name: 195-PHSHS-214
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:48
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: IH01830-25
Name: 195-PHS-215
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:51
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:23	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-26
Name: 195-PHS-216
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:53
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.35	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:25	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-27
Name: 195-PHS-217
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:53
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.20	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:29	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: IH01830-28
Name: 195-PHS-218
Matrix: Drinking Water - Grab

Sampled: 08/05/25 16:55
Received: 08/08/25 14:00
PO #: PHS-PB083-005

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		08/19/25 07:55	1	1.00	08/19/25 14:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050






Certified by: Chenise Lambert-Sykes, Project Manager

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)



1 CLIENT Park Hill School District		PROJECT NUMBER 925195		PROJECT LOCATION Park Hill South High School		PURCHASE ORDER # PHS-PB083-005		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>1401830</u>	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 8/6/2025		+ +		LOGGED BY: _____	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAB- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID						CLIENT: Park Hill School District	
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE 								PROJECT: Drinking Water Lead	
										PROJ. MGR.: Chenise Lambert-Sykes	
										CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
										PRES CODE CLIENT PROVIDED	
195-PHSHS-191		8/5/2025		16:21		X		DW		1 6	
195-PHSHS-192		8/5/2025		16:21		X		DW		1 6	
195-PHSHS-193		8/5/2025		16:21		X		DW		1 6	
195-PHSHS-194		8/5/2025		16:23		X		DW		1 6	
195-PHSHS-195		8/5/2025		16:23		X		DW		1 6	
195-PHSHS-196		8/5/2025		16:23		X		DW		1 6	
195-PHSHS-197		8/5/2025		16:26		X		DW		1 6	
195-PHSHS-198		8/5/2025		16:26		X		DW		1 6	
195-PHSHS-199		8/5/2025		16:26		X		DW		1 6	
195-PHSHS-200		8/5/2025		16:28		X		DW		1 6	
195-PHSHS-201		8/5/2025		16:31		X		Dw		1 6	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3	
		6 - UNPRESERVED		7 - OTHER							
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.			
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		send results to						PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____			
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:		jhurst3@occutec.com							
7 RELINQUISHED BY: (SIGNATURE) 		DATE 8/6/2025		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
		TIME 13:20				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE					
		TIME				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE 8/8/25					
		TIME				TIME 1400					
								SAMPLE TEMPERATURE UPON RECEIPT		°C	
								CHILL PROCESS STARTED PRIOR TO RECEIPT		Y OR N	
								SAMPLE(S) RECEIVED ON ICE		Y OR N	
								SAMPLE ACCEPTANCE NONCONFORMANT		Y OR N	
								REPORT IS NEEDED		Y OR N	
								DATE AND TIME TAKEN FROM SAMPLE BOTTLE			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)



1 CLIENT Park Hill School District		PROJECT NUMBER 925195		PROJECT LOCATION Park Hill South High School		PURCHASE ORDER # PHS-PB083-005		3 ANALYSIS REQUESTED + ☒ DW Lead + ☒ Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>1H01830</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 8/6/2025					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) SAMPLE DESCRIPTION		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS	
195-PHSHS-202		8/5/2025	16:31	X	DW	1	6	X			
195-PHSHS-203		8/5/2025	16:31	X	DW	1	6	X			
195-PHSHS-204		8/5/2025	16:34	X	DW	1	6	X			
195-PHSHS-205		8/5/2025	16:34	X	DW	1	6	X			
195-PHSHS-206		8/5/2025	16:34	X	DW	1	6	X			
195-PHSHS-207		8/5/2025	16:36	X	DW	1	6	X			
195-PHSHS-208		8/5/2025	16:36	X	DW	1	6	X			
195-PHSHS-209		8/5/2025	16:38	X	DW	1	6	X			
195-PHSHS-210		8/5/2025	16:38	X	DW	1	6	X			
195-PHSHS-211		8/5/2025	16:38	X	DW	1	6	X			
195-PHSHS-212		8/5/2025	16:48	X	Dw	1	6	X			
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5		TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL ☒ RUSH		DATE RESULTS NEEDED		6		I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.			
RUSH RESULTS VIA (PLEASE CIRCLE): EMAIL PHONE		send results to		jhurst3@occutec.com		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)					
7		RELINQUISHED BY: (SIGNATURE) 		DATE 8/6/2025		TIME 13:20		RECEIVED BY: (SIGNATURE) 		DATE 8/6/2025	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME	
										8	
										COMMENTS: (FOR LAB USE ONLY)	
										SAMPLE TEMPERATURE UPON RECEIPT °C	
										CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N	
										SAMPLE(S) RECEIVED ON ICE Y OR N	
										SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N	
										DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 925195		PROJECT LOCATION Park Hill South High School		PURCHASE ORDER # PHS-PB083-005		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 8/6/2025		☒ DW Lead ☒ Turb Check		LOGIN # 1401830 LOGGED BY: CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID					
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)											
195-PHSHS-213		8/5/2025		16:48		X		DW		1 6	
195-PHSHS-214		8/5/2025		16:48		X		DW		1 6	
195-PHSHS-215		8/5/2025		16:51		X		DW		1 6	
195-PHSHS-216		8/5/2025		16:53		X		DW		1 6	
195-PHSHS-217		8/5/2025		16:53		X		DW		1 6	
195-PHSHS-218		8/5/2025		16:55		X		DW		1 6	
						X		DW		1 6	
						X		DW		1 6	
						X		DW		1 6	
						X		DW		1 6	
						X		Dw		1 6	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3	
		6 - UNPRESERVED		7 - OTHER							
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6		I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.	
RUSH RESULTS VIA (PLEASE CIRCLE)		EMAIL		PHONE		send results to				PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____	
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:		jhurst3@occutec.com							
7 RELINQUISHED BY: (SIGNATURE) 		DATE 8/6/2025		TIME 13:20		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE) 		DATE 8/25		TIME 1400	
										SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	

WORK ORDER #: 1401830 INITIALS: MS

Drinking Water Bottle Receipt Form

SOC (Synthetic Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
Chlorine Check	Chlorine Check	P, U, 150 ml	1								
M504	EDB & DBCP	C,V, 40 ml, Na2S2O3	3								
M504 Trip Blank	Trip Blank	C,V, 40 ml, Na2S2O3	2								
M505 (subcontract)	Toxaphene	C,V, 40 ml, Na2S2O3	3								
M515.3/548	Chlorinated Acids/Endothal	A, G, 500 ml, Na2S2O3	2								
M525.2	Semi-Volatiles	A, G, 1000 ml, Na2SO3 + HCl	3								
M531	Carbamates	A, V, 60 ml, Na2S2O3 + MCAA	1								
M549.2	Diquat	A, P, 1000 ml, Na2S2O3 + H2SO4	1								
M550	Benzo(a)Pyrene	A, G, 1000 ml, Na2S2O3 + HCl	3								
*M547	Glyphosate	A, V, 60 ml, Na2S2O3	1								
*M547 Trip Blank	Trip Blank	A, V, 60 ml, Na2S2O3	1								

**SOC_W_GLPPOS* & *SOC_IDPH_GROUP A* ONLY

VOC (Volatile Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M524.2	Regulated Volatile	C,V, 40 ml, HCl	3								
M524.2 Trip Blank	Trip Blank	C,V, 40 ml, HCl	3								
Chlorine Check	Chlorine Check	P, U, 150 ml	1								

IOC (Inorganic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
*300.0 SO4 & Fluoride Probe	Sulfate by IC/Fluoride Probe	P, 500 ml, Total	1								
**Metals - As, Ba, Be, Cd, Cr, Fe, Hg, Mn, Na, Ni, Sb, Se, Ti, Zn & Turb Check	Metals	P, 250 ml, HNO3, Total	1								
CN-T Kelada DW	Cyanide Total	P, 250 ml, NaOH	1								

*Excluded from "IOC IDPH SHORT LIST"

**Excluded Fe, Mn, Na, Ni & Zn from "IOC IDPH SHORT LIST" Fe, Mn, Na, Ni & Zn

THM/HAA

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
THM M524	Trihalomethane	C,V, 40 ml, Na2S2O3	4								
HAA M552	Haloacetic Acid	A, V, 60 ML NH4CL	4								
Chlorine Check	Chlorine Check	P, U, 150 ml	1								

TOC

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
TOC	Total Organic Carbon	A, V, 40 ml, H2SO4	3								

Chlorite/Bromate

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
Bromate (Subcontract)	Bromate	P, 100 ml, EDA	1								
Chlorite (Subcontract)	Chlorite	P, 100 ml, EDA	1								

Lead/Copper

Method	Description	Bottle Type	Qty
Lead/Copper	Lead Copper	P, 1000ml LC	
School Lead	Lead	P, 250ml LC	28

PFAS

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M533	PFAS	533, P, 250mL, C2H7NO2									
M533 FRB	PFAS - FRB	533, P, 250mL, C2H7NO2									
M537.1	PFAS	537.1, P, 250 mL, TRZ									
M537.1 FRB	PFAS - FRB	537.1, P, 250 mL, TRZ									

ENV-FRM-PEOR-0098 v05_Sample Condition Upon Receipt

Client Name: Park Hill Work Order #: 1401830 Completed by / Date: 10/8/25

Custody seal on cooler/box present and seal intact:	☐ Yes ☐ No ☒ N/A
Chain of Custody (CoC) Present:	☒ Yes ☐ No
CoC is Legible:	☒ Yes ☐ No
Sampler Name Present on CoC:	☒ Yes ☐ No
Sampler Signature Present on CoC:	☒ Yes ☐ No
Sample Collection Date Present on CoC:	☒ Yes ☐ No
Sample Collection Time Present on CoC:	☒ Yes ☐ No
CoC Relinquished by Client:	☒ Yes ☐ No
Unique Sample ID's Present on CoC:	☒ Yes ☐ No
CoC and Sample Container Labels Match:	☒ Yes ☐ No
Sample chilling process started prior to receipt: If yes, what type of ice:	☐ Yes ☐ No ☒ N/A ☐ Wet ☐ Blue
Samples received within temperature compliance: ($\leq 6^{\circ}\text{C}$, but above freezing or received same day collected and chill process started prior to receipt)	☐ Yes ☐ No ☒ N/A
Container(s) Received Intact:	☒ Yes ☐ No
Containers Received Labeled and Labels are Legible:	☒ Yes ☐ No
Appropriate Bottles Received for Analysis Requested:	☒ Yes ☐ No
Sufficient Sample Volume Received:	☒ Yes ☐ No
USDA Regulated Soil: Country of Origin: _____ State of Origin: _____	☐ Yes ☐ No ☒ N/A
Trip Blank(s) Received: If present, are they Listed on CoC:	☐ Yes ☐ No ☒ N/A ☐ Yes ☐ No
VOA vials are free of any headspace larger than pea sized bubble (>6mm) – Applies to methods 8260, 624, 524.2 - including THM vials If headspace is present, note sample ID and # of vials	☐ Yes ☐ No ☒ N/A
All (Non-Field) Analysis Received Within Hold Times:	☒ Yes ☐ No
Rush Turn Around Time Requested or Time Sensitive Analysis:	☐ Yes ☒ No
Short Hold Time Analysis (48 Hours or Less):	☐ Yes ☒ No

Client Notification/ Resolution:

If checked, please see attached form for additional comments ☐

Person Contacted: _____ Date/Time: _____

Comments/ Resolution: _____

PM Review is documented electronically in LIMS. By releasing the project, the PM acknowledges they have reviewed the sample.