

Building Inspected: Briggs Elementary
Address: 1 Jefferrson Drive
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

FUNCTIONAL SPACE	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
MAIN OFFICE	544	0	69.40	44
PRINCIPAL	534	0	69.80	45
ROOM 101	548	0	73.90	35
ROOM 102	541	0	74.50	37
ROOM 103	510	0	74.10	36
ROOM 104	516	0	74.20	35
ROOM 105	534	0	74.10	35
ROOM 106	529	0	74.30	34
ROOM 107	514	0	74.30	34
STORAGE AT KITCHEN	524	0	72.50	32
KITCHEN	555	0	72.30	31

Building Inspected: Briggs Elementary
Address: 1 Jefferrson Drive
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

FUNCTIONAL SPACE	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
CAFÉ	514	0	74.10	35
NURSE	565	0	75.40	36
LIBRARY	537	0	75.80	34
ROOM 109	555	0	76.50	34
ROOM 111	519	0	78.60	34
ROOM 113	540	0	77.4	31
ROOM 112	509	0	77.5	33
ROOM 114	512	0	77.4	32
ROOM 115	511	0	77.2	32
ROOM 117	504	0	77.3	33
ROOM 116	507	0	77.6	32
ROOM 118	510	0	78.1	33

Building Inspected: Briggs Elementary
Address: 1 Jefferrson Drive
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

FUNCTIONAL SPACE	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM 119	528	0	77.8	33
ROOM 110	519	0	77.9	32
ROOM 120	514	0	78.6	33
ROOM 121	520	0	78.5	31
ROOM 124	525	0	78.7	31
ROOM 123	536	0	77.3	32
ROOM 122	512	0	76.8	32
OUTSIDE SAMPLE	657	0	63	33